



444 South 16th Street Mall  
Omaha NE 68102-2247

October 6, 2004  
LIC-04-0027

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Reference: Docket No. 50-285

**SUBJECT: September 2004 Monthly Operating Report (MOR)**

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for September 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

D. J. Bannister  
Manager – Fort Calhoun Station

DJB/EPM/epm

Attachment

## OPERATING DATA REPORT

DOCKET NO. 50-285  
UNIT NAME Fort Calhoun Station  
DATE October 2, 2004  
COMPLETED BY E. P. Matzke  
TELEPHONE (402) 533-6855

REPORT PERIOD: September 2004

Design Electrical Rating (MWe-Net): 478  
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	720	6,311	221,179
Number of Hours Generator was On-line:	720	6,294	219,819
Unit Reserve Shutdown Hours:	0		
Net Electrical Energy Generated (MWh):	342,043	2,997,995	95,524,098

### UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason <sup>1</sup>	Method of Shutting Down Reactor <sup>2</sup>	Cause & Corrective Action Comments

(1) Reason:

A-Equipment Failure (Explain)  
B-Maintenance or Test  
C-Refueling  
D-Regulatory Restriction  
E-Operator Training/License Examination  
F-Administrative  
G-Operational Error (Explain)  
H-Other (Explain)

(2) Method:

1-Manual  
2-Manual Trip/Scram  
3-Automatic Trip/Scram  
4-Continuation  
5-Other (Explain)

### OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of September 2004.