

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

4.0.3 If it is discovered that a surveillance was not performed within its specified surveillance interval, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified surveillance interval, whichever is less. This delay period is permitted to allow performance of the surveillance.

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

When the surveillance is performed within the delay period and the surveillance criteria are not met, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation has been performed within the stated surveillance interval or as otherwise specified. This provision shall not prevent passage through or to OPERATIONAL MODES as required to comply with ACTION requirements.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components (including supports and attachments) and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50, Section 50.55a(f) or (g) as modified by 10 CFR 50.55a(b)(3)(v), except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50, Section 50.55a(f)(6)(i) or Section 50.55a(g)(6)(i);