

October 15, 2004

Mr. Mano K. Nazar
American Electric Power
Senior Vice President and Chief Nuclear Officer
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNIT 1 - RESPONSE TO NRC
BULLETIN 2003-02, "LEAKAGE FROM REACTOR PRESSURE VESSEL
LOWER HEAD PENETRATIONS AND REACTOR COOLANT PRESSURE
BOUNDARY INTEGRITY" (TAC NO. MC0533)

Dear Mr. Nazar:

On August 21, 2003, the U.S. Nuclear Regulatory Commission (NRC) issued NRC Bulletin 2003-02, "Leakage from Reactor Pressure Vessel Lower Head Penetrations and Reactor Coolant Pressure Boundary Integrity," to the industry. This Bulletin informed addressees that current methods of inspecting the reactor pressure vessel (RPV) lower heads may need to be supplemented with bare-metal visual inspections in order to detect reactor coolant pressure boundary leakage and requested these addressees to provide the NRC with information related to inspections that have been performed to verify the integrity of the RPV lower head penetrations.

The Bulletin requested that addressees provide a description of the RPV lower head penetration inspection program that would be implemented at their respective plants during the next and subsequent refueling outages. This description was to include the extent of the inspection, the inspection methods to be used, the qualification standards for the inspection methods, the process used to resolve the source of findings of boric acid deposits or corrosion, the inspection documentation to be generated, and the basis for concluding that their plant satisfied applicable regulatory requirements related to the structural and leakage integrity of the RPV lower head penetrations.

By letter dated September 17, 2003, Indiana Michigan Power Company (I&M) provided its response to this request. I&M stated that a bare-metal visual examination of the RPV lower head and penetrations will be conducted at every refueling outage at Donald C. Cook Nuclear Plant (CNP), Unit 1. I&M also stated that insulation will be modified or removed from the RPV lower heads in order to permit full visual examinations of the penetrations and carbon steel in the vicinity of the penetrations. American Society of Mechanical Engineers (ASME)-qualified VT-2 examiners will perform these inspections. As such, I&M is requested to notify the NRC staff in writing of any changes to this regulatory commitment prior to implementation.

The Bulletin also requested that addressees provide a summary of the RPV lower head penetration inspection that was performed at their plants, the extent of the inspection and the

M. Nazar

methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated March 25, 2004, I&M provided a summary of its inspection results at CNP, Unit 1. I&M reported it had performed a 360-degree bare-metal visual examination on all 58 RPV lower head penetrations with no evidence of penetration leakage observed.

Based on its review of I&M's responses to NRC Bulletin 2003-02, the NRC staff finds that I&M has met the reporting requirements of the Bulletin. Accordingly, TAC No. MC0533 is closed for CNP, Unit 1.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-315

cc: See next page

methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated March 25, 2004, I&M provided a summary of its inspection results at CNP, Unit 1. I&M reported it had performed a 360-degree bare-metal visual examination on all 58 RPV lower head penetrations with no evidence of penetration leakage observed.

Based on its review of I&M's responses to NRC Bulletin 2003-02, the NRC staff finds that I&M has met the reporting requirements of the Bulletin. Accordingly, TAC No. MC0533 is closed for CNP, Unit 1.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-315

cc: See next page

Distribution:

PUBLIC	SMonarque	RGramm
PDIII-1 RF	FLyon	LRaghavan
GCheruvenci	ESullivan	ACRS
LMarsh	OGC	THarris

ADAMS ACCESSION NUMBER: ML042860145

OFFICE	PDIII-1/PM	PDIII-1/LA	LPM	EMCB	PDIII-1/SC
NAME	FLyon	THarris	SMonarque	ESullivan	LRaghavan
DATE	10/14/04	10/14/04	10/14/04	10/15/04	10/15/04

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Mr. John A. Zwolinski
Director, Design Engineering and
Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group 500 Circle Drive
Buchanan, MI 49107

Michigan Department of Environmental
Quality
Waste and Hazardous Materials Div.
Hazardous Waste & Radiological
Protection Section
Nuclear Facilities Unit
Constitution Hall, Lower-Level North
525 West Allegan Street
P. O. Box 30241
Lansing, MI 48909-7741

Michael J. Finissi, Plant Manager
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mr. Joseph N. Jensen, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106