

South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

October 11, 2004 NOC-AE-04001803 10CFR50.90

U. S. Nuclear Regulatory Commission Attention: Document Control Desk One White Flint North 11555 Rockville Pike Rockville, MD 20852

> South Texas Project Units 1 and 2 Docket No. STN 50-498 and STN 50-499 License Amendment Request -

Correction to Proposed Amendment to Technical Specifications for Steam Generators

Reference:

Letter, T. J. Jordan to NRC Document Control Desk, "License Amendment Request - Revision to Proposed Amendment to Technical Specifications for Steam Generators," dated October 5, 2004 (NOC-AE-04001794)

STP Nuclear Operating Company (STPNOC) hereby submits a correction to the referenced letter. STPNOC had not deleted two tables listed in the Technical Specifications Table of Contents that are to be deleted by the proposed license amendment request. Additionally, a "deletion" page has been added to account for the Technical Specification pages that will be deleted by the approved license amendment request. The correctly marked-up Table of Contents page and "deletion" page are provided with this letter.

This is an editorial error that has no impact on the safety evaluation performed for the license amendment request.

There are no new commitments in this letter.

If there are any questions regarding this revision to the proposed license amendment request, please contact John Conly at (361) 972-7336 or me at (361) 972-7800.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on October 11, 2004

DI Parling

Vice President, Generation and Plant General Manager

cc:

(paper copy)

Bruce S. Mallett
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of State Health Services
1100 West 49th Street
Austin, TX 78756-3189

Jeffrey Cruz
U. S. Nuclear Regulatory Commission
P. O. Box 289, Mail Code: MN116
Wadsworth, TX 77483

C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

(electronic copy)

A. H. Gutterman, Esquire Morgan, Lewis & Bockius LLP

L. D. Blaylock City Public Service

David H. Jaffe U. S. Nuclear Regulatory Commission

R. L. Balcom Texas Genco, LP

C. A. Johnson AEP Texas Central Company

Jon C. Wood Matthews & Branscomb

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

SECTION		PAGE
<u>3/4.4</u>	REACTOR COOLANT SYSTEM	
3/4.4.1	REACTOR COOLANT LOOPS AND COOLANT CIRCULATION Startup and Power Operation Hot Standby Hot Shutdown Cold Shutdown - Loops Filled Cold Shutdown - Loops Not Filled	3/4 4-1 3/4 4-2 3/4 4-3 3/4 4-5 3/4 4-6
3/4.4.2	SAFETY VALVES Shutdown Operating	3/4 4-7 3/4 4-8
3/4.4.3	PRESSURIZER	3/4 4-9
3/4.4.4	RELIEF VALVES	3/4 4-10
3/4.4.5	STEAM GENERATORS TUBEINTEGRITY	3/4 4-12
ENDE-SPIE	MINIMUM NUMBER OF STEAM CENERATORS TO BE NSPECTED DURING INSERVICE INSPECTION	SVENE F
MARKETANAS	STEAM GENERATOR TUBE INSPECTION	SIVEN ES
3/4.4.6	REACTOR COOLANT SYSTEM LEAKAGE Leakage Detection Systems Operational Leakage	3/4 4-19 3/4 4-20
TABLE 3.4-1	REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES	3/4 4-22
3/4.4.7	(This specification not used)	
3/4.4.8	SPECIFIC ACTIVITY	3/4 4-26
FIGURE 3.4-1	DOSE EQUIVALENT I-131 REACTOR COOLANT SPECIFIC ACTIVITY LIMIT VERSUS PERCENT OF RATED THERMAL POWER WITH THE REACTOR COOLANT SPECIFIC ACTIVITY >1 µCi/gram DOSE EQUIVALENT I-131	3/4 4-28
TABLE 4.4-4	REACTOR COOLANT SPECIFIC ACTIVITY SAMPLE AND ANALYSIS PROGRAM	3/4 4-29
3/4.4.9	PRESSURE/TEMPERATURE LIMITS	
	Reactor Coolant System	3/4 4-31
FIGURE 3.4-2	REACTOR COOLANT SYSTEM HEATUP LIMITATIONS - APPLICABLE UP TO 32 EFPY	3/4 4-32

Ļ

PAGES 3/4 4-14 THROUGH 3/4 4-18 HAVE BEEN DELETED.