

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|----------------|--|--|
| B. (continued) | B.3.1 Determine OPERABLE DG is not inoperable due to common cause failure. | 24 hours |
| | <u>OR</u> | |
| | B.3.2 Perform SR 3.8.1.2 for OPERABLE DG. | 24 hours |
| | <u>AND</u> | |
| | B.4 Restore DG to OPERABLE status. | 7 days* <u>AND</u> 14 days from discovery of failure to meet LCO |

-----TEMPORARY NOTE-----

* A Diesel Generator which is INOPERABLE solely due to its alignment to a fuel oil storage tank drained in support of fuel oil storage tank cleaning and coating shall be restored to OPERABLE status within 14 days. This temporary note is applicable only if the fuel oil level in the associated DG day tank is maintained above the low level alarm setpoint. This temporary note expires upon completion of the fuel oil storage tank cleaning and coating maintenance activity, but no later than November 30, 2004.

| | | |
|-------------------------------------|---|---|
| C. Two offsite circuits inoperable. | C.1 Declare required feature(s) inoperable when the redundant required feature(s) are inoperable. | 12 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s) |
| | <u>AND</u> | |
| | C.2 Restore one offsite circuit to OPERABLE status. | 24 hours |

(continued)

3.8 ELECTRICAL POWER SYSTEMS

3.8.3 Diesel Fuel Oil, Lube Oil, and Starting Air

LCO 3.8.3 The stored diesel fuel oil, lube oil, and starting air subsystem shall be within limits for each required diesel generator (DG).

-----TEMPORARY NOTE-----

Fuel oil level in temporary storage tanks may be utilized to support OPERABILITY of a DG during tank cleaning and coating maintenance activities. Equipment (temporary transfer pump, hoses, and appropriate fittings) capable of supplying the fuel oil in the temporary tanks to the DG must be available. The fuel oil level in the temporary tanks, in conjunction with the fuel in the permanent tank must be within the limits of Condition A and Condition C. This note is applicable only to the DG aligned to the full permanent tank. This temporary note expires upon completion of the fuel oil storage tank cleaning and coating maintenance activities but no later than November 30, 2004.

APPLICABILITY: When associated DG is required to be OPERABLE.

ACTIONS

-----NOTE-----

Separate Condition entry is allowed for each DG, except for Conditions A, C, and D.

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|-----------------|
| A. Fuel oil level < 49,500 gal and > 42,800 gal in storage tanks. | A.1 Restore fuel oil level to within limits. | 48 hours |
| B. One or more DGs with lube oil inventory < 504 gal and > 432 gal. | B.1 Restore lube oil inventory to within limits. | 48 hours |
| C. Stored fuel oil total particulates not within limit. | C.1 Restore stored fuel oil total particulates to within limit. | 7 days |

(continued)