

**MSPI IMPLEMENTATION PLAN**

ID	Task Name	August				September				October				November				December				January			February				
		8/1	8/8	8/15	8/22	8/29	9/5	9/12	9/19	9/26	10/3	10/10	10/17	10/24	10/31	11/7	11/14	11/21	11/28	12/5	12/12	12/19	12/26	1/2	1/9	1/16	1/23	1/30	2/6
1	Draft MSPI guidance to TF	[Task 1: Draft MSPI guidance to TF - spans from 8/1 to 8/22]																											
2	Draft MSPI guidance to NRC	[Task 2: Draft MSPI guidance to NRC - spans from 8/15 to 8/29]																											
3	Review MSPI guidance	[Task 3: Review MSPI guidance - spans from 8/29 to 9/12]																											
4	Approval of draft MSPI for lead plants	[Task 4: Approval of draft MSPI for lead plants - spans from 9/12 to 9/26]																											
5	Expert Panel recommend MSPI PRA and assessment approach	[Task 5: Expert Panel recommend MSPI PRA and assessment approach - spans from 9/26 to 10/10]																											
6	Lead plants update basis document	[Task 6: Lead plants update basis document - spans from 10/10 to 10/24]																											
7	NRC review of lead plant basis docs	[Task 7: NRC review of lead plant basis docs - spans from 10/24 to 11/7]																											
8	Revise Guidance as necessary	[Task 8: Revise Guidance as necessary - spans from 11/7 to 11/21]																											
9	CDE Project Schedule Finalized	[Task 9: CDE Project Schedule Finalized - spans from 11/21 to 12/5]																											
10	Preliminary CDE Production Functional Requirements	[Task 10: Preliminary CDE Production Functional Requirements - spans from 9/26 to 10/10]																											
11	Review CDE functional reqs	[Task 11: Review CDE functional reqs - spans from 10/10 to 10/24]																											
12	Workshop guidance sent	[Task 12: Workshop guidance sent - spans from 11/21 to 12/5]																											
13	Attend Workshop 1	[Task 13: Attend Workshop 1 - spans from 12/5 to 12/19]																											
14	Define Scope	[Task 14: Define Scope - spans from 12/19 to 1/2]																											
15	Calculate Risk Information	[Task 15: Calculate Risk Information - spans from 1/2 to 1/16]																											
16	Create Basis Doc	[Task 16: Create Basis Doc - spans from 1/16 to 1/30]																											
17	Develop Administrative Controls	[Task 17: Develop Administrative Controls - spans from 1/30 to 2/6]																											
18	NRC develop MSPI assessment approach	[Task 18: NRC develop MSPI assessment approach - spans from 11/21 to 12/26]																											
19	INPO provides failure tagging for production website	[Task 19: INPO provides failure tagging for production website - spans from 12/26 to 1/9]																											
20	Basis Documents sent to NEI	[Task 20: Basis Documents sent to NEI - spans from 1/9 to 1/23]																											
21	INPO delivers Workshop 2 software	[Task 21: INPO delivers Workshop 2 software - spans from 1/23 to 1/30]																											
22	Attend Workshop 2	[Task 22: Attend Workshop 2 - spans from 1/30 to 2/6]																											
23	Revise Scope/Risk Info as needed	[Task 23: Revise Scope/Risk Info as needed - spans from 2/6 to 2/13]																											
24	Calculate Historic Data	[Task 24: Calculate Historic Data - spans from 2/13 to 2/20]																											
25	Revise basis document	[Task 25: Revise basis document - spans from 2/20 to 2/27]																											
26	Input data to ACCESS	[Task 26: Input data to ACCESS - spans from 2/27 to 3/6]																											
27	NRC assessment necessary for implementation	[Task 27: NRC assessment necessary for implementation - spans from 3/6 to 3/13]																											
28	NRC familiarization with CDE	[Task 28: NRC familiarization with CDE - spans from 3/13 to 3/20]																											
29	Issue NEI 99-02 Revision	[Task 29: Issue NEI 99-02 Revision - spans from 3/20 to 3/27]																											

Attachment 3







## APPENDIX F

**METHODOLOGIES FOR COMPUTING THE UNAVAILABILITY INDEX, THE UNRELIABILITY INDEX AND COMPONENT PERFORMANCE LIMITS**

This appendix provides the details of three calculations: the System Unavailability Index, the System Unreliability Index, and component performance limits.

**1. System Unavailability Index (UAI) Due to Train Unavailability**

Unavailability is monitored at the train level for the purpose of calculating UAI. The process for calculation of the System Unavailability Index has three major steps:

- Identification of system trains
- Collection of plant data
- Calculation of UAI

The first of these steps is performed for the initial setup of the index calculation. The second step has some parts that are performed initially and then only performed again when a revision to the plant specific PRA is made or changes are made to the normal preventive maintenance practices. Other parts of the calculation are performed periodically to obtain the data elements reported to the NRC. This section provides the detailed guidance for the calculation of UAI.

**1.1. Identification of System Trains**

The identification of system trains is accomplished in two steps:

- Determine the system boundaries
- Identify the trains within the system

The use of simplified P&IDs can be used to document the results of this step and will also facilitate the completion of the directions in section 2.1.1 later in this document.

**1.1.1. System Boundaries**

The first step in the identification of system trains is to define the system boundaries. Include all components that are required to satisfy the risk-significant functions of the system. For fluid systems the boundary should extend from the water source (e.g., tanks, sumps, etc.) to the injection point (e.g., RCS, Steam Generators). For example, high-pressure injection may have both an injection mode with suction from the refueling water storage tank and a recirculation mode with suction from the containment sump. For Emergency AC systems, the system consists of all class 1E generators at the station.

Additional system specific guidance on system boundaries can be found in section 5 titled "Additional Guidance for Specific Systems" at the end of this appendix.

Some common conditions that may occur are discussed below.

## 1 Component Interface Boundaries

2 For water connections from systems that provide cooling water to a single monitored  
3 component, only the final connecting valve is included in the boundary. For example, for  
4 service water that provides cooling to support an AFW pump, only the final valve in the  
5 service water system that supplies the cooling water to the AFW system is included in the  
6 AFW system scope. This same valve is not included in the cooling water support system  
7 scope.

## 8 Water Sources and Inventory

9 Water tanks are not considered to be monitored components. As such, they do not  
10 contribute to URI. However, periods of insufficient water inventory contribute to UAI if  
11 they result in loss of the risk-significant train function for the required mission time.  
12 ~~Water inventory can include operator recovery actions for water make-up provided the~~  
13 ~~actions can be taken in time to meet the mission times and are modeled in the PRA. If~~  
14 additional water sources are required to satisfy train mission times, only the connecting  
15 active valve from the additional water source is considered as a monitored component for  
16 calculating UAI. If there are valves in the primary water source that must change state to  
17 permit use of the additional water source, these valves are considered monitored and  
18 should be included in UAI for the system.

## 19 Common Components

20 Some components in a system may be common to more than one system, in which case  
21 the unavailability of a common component is included in all affected systems. (However,  
22 see "Additional Guidance for Specific Systems" for exceptions; for example, the PWR  
23 High Pressure Safety Injection System.)

24

### 25 **1.1.2. Identification of Trains within the System**

26 Each monitored system shall then be divided into trains to facilitate the monitoring of  
27 unavailability.

28 *A train* consists of a group of components that together provide the risk significant  
29 functions of the system as explained in the "additional guidance for specific mitigating  
30 systems". Fulfilling the risk-significant function of the system may require one or more  
31 trains of a system to operate simultaneously. The number of trains in a system is  
32 generally determined as follows:

- 33 • for systems that provide cooling of fluids, the number of trains is determined by the  
34 number of parallel heat exchangers, or the number of parallel pumps, or the minimum  
35 number of parallel flow paths, whichever is fewer.
- 36 • for emergency AC power systems the number of trains is the number of class 1E  
37 emergency (diesel, gas turbine, or hydroelectric) generators at the station that are  
38 installed to power shutdown loads in the event of a loss of off-site power. (This does  
39 not include the diesel generator dedicated to the BWR HPCS system, which is  
40 included in the scope of the HPCS system.)

41

1 Some components or flow paths may be included in the scope of more than one train. For  
2 example, one set of flow regulating valves and isolation valves in a three-pump, two-  
3 steam generator system are included in the motor-driven pump train with which they are  
4 electrically associated, but they are also included (along with the redundant set of valves)  
5 in the turbine-driven pump train. In these instances, the effects of unavailability of the  
6 valves should be reported in all affected trains. Similarly, when two trains provide flow  
7 to a common header, the effect of isolation or flow regulating valve failures in paths  
8 connected to the header should be considered in both trains.

9 Additional system specific guidance on train definition can be found in section 5 titled  
10 "Additional Guidance for Specific Systems" at the end of this appendix.

11  
12 Additional guidance is provided below for the following specific circumstances that are  
13 commonly encountered:

- 14 • Cooling Water Support System Trains
- 15 • Swing Trains and Components Shared Between Units
- 16 • Maintenance Trains and Installed Spares

#### 17 Cooling Water Support Systems and Trains

18  
19 The cooling water function is typically accomplished by multiple systems, such as  
20 service water and component cooling water. A separate value for UAI will be calculated  
21 for each of the systems in this indicator and then they will be added together to calculate  
22 an overall UAI value.

23 In addition, cooling water systems are frequently not configured in discrete trains. In this  
24 case, the system should be divided into logical segments and each segment treated as a  
25 train. This approach is also valid for other fluid systems that are not configured in  
26 obvious trains. The way these functions are modeled in the plant-specific PRA will  
27 determine a logical approach for train determination. For example, if the PRA modeled  
28 separate pump and line segments (such as suction and discharge headers), then the  
29 number of pumps and line segments would be the number of trains.

#### 30 Unit Swing trains and components shared between units

31 Swing trains/components are trains/components that can be aligned to any unit. To be  
32 credited as such, their swing capability must be modeled in the PRA to provide an  
33 appropriate Fussell-Vesely value.

#### 34 Maintenance Trains and Installed Spares

35 Some power plants have systems with extra trains to allow preventive maintenance to be  
36 carried out with the unit at power without impacting the risk-significant function of the  
37 system. That is, one of the remaining trains may fail, but the system can still perform its  
38 risk significant function. To be a maintenance train, a train must not be needed to  
39 perform the system's risk significant function.

40 An "installed spare" is a component (or set of components) that is used as a replacement  
41 for other equipment to allow for the removal of equipment from service for preventive or

1 corrective maintenance without impacting the risk-significant function of the system. To  
2 be an "installed spare," a component must not be needed for the system to perform the  
3 risk significant function.

4 Unavailability of the spare component/train is only counted in the index if the spare is  
5 substituted for a primary train/component. Unavailability is not monitored for a  
6 component/train when that component/train has been replaced by an installed spare or  
7 maintenance train.

## 8 **1.2.Collection of Plant Data**

9 Plant data for the UAI portion of the index includes:

- 10 • Actual train total unavailability data for the most recent 12 quarter period collected on  
11 a quarterly basis,
- 12 • Plant specific baseline planned unavailability, and
- 13 • Generic baseline unplanned unavailability.

14 Each of these data inputs to UAI will be discussed in the following sections.

### 15 **1.2.1. Actual Train Unavailability**

16 The Consolidated Data Entry (CDE) inputs for this parameter are Train Unavailable  
17 Hours and Critical Hours. The actual calculation of Train Unavailability is performed by  
18 CDE.

19 *Train Unavailability:* Train unavailability is the ratio of the hours the train was  
20 unavailable to perform its risk-significant functions due to planned or unplanned  
21 maintenance or test during the previous 12 quarters while critical to the number of critical  
22 hours during the previous 12 quarters.

23 *Train unavailable hours:* The hours the train was not able to perform its risk significant  
24 function due to maintenance, testing, equipment modification, electively removed from  
25 service, corrective maintenance, or the elapsed time between the discovery and the  
26 restoration to service of an equipment failure or human error that makes the train  
27 unavailable (such as a misalignment) while the reactor is critical. Fault exposure hours  
28 are not included; unavailable hours are counted only for the time required to recover the  
29 train's risk-significant functions. Unavailability must be by train; do not use average  
30 unavailability for each train because trains may have unequal risk weights.

31  
32 Additional guidance on the following topics for counting train unavailable hours is  
33 provided below.

- 34 • Short Duration Unavailability
- 35 • Credit for Operator Recovery Actions to Restore the Risk-Significant Function

1           Short Duration Unavailability

2           Trains are generally considered to be available during periodic system or equipment  
3           realignments to swap components or flow paths as part of normal operations. Evolutions  
4           or surveillance tests that result in less than 15 minutes of unavailable hours per train at a  
5           time need not be counted as unavailable hours. Licensees should compile a list of  
6           surveillances or evolutions that meet this criterion and have it available for inspector  
7           review. In addition, equipment misalignment or mispositioning which is corrected in less  
8           than 15 minutes need not be counted as unavailable hours. The intent is to minimize  
9           unnecessary burden of data collection, documentation, and verification because these  
10          short durations have insignificant risk impact. If a licensee is required to take a  
11          component out of service for evaluation and corrective actions for greater than 15  
12          minutes (for example, related to a Part 21 Notification), the unavailable hours must be  
13          included.

14          Credit for Operator Recovery Actions to Restore the Risk-Significant Functions

15          1.       *During testing or operational alignment:*

16          Unavailability of a risk-significant function during testing or operational alignment need  
17          not be included if the test configuration is automatically overridden by a valid starting  
18          signal, or the function can be promptly restored either by an operator in the control room  
19          or by a designated operator<sup>1</sup> stationed locally for that purpose. Restoration actions must  
20          be contained in a written procedure<sup>2</sup>, must be uncomplicated (*a single action or a few*  
21          *simple actions*), must be capable of being restored in time to satisfy PRA success criteria  
22          and must not require diagnosis or repair. Credit for a designated local operator can be  
23          taken only if (s)he is positioned at the proper location throughout the duration of the test  
24          for the purpose of restoration of the train should a valid demand occur. The intent of this  
25          paragraph is to allow licensees to take credit for restoration actions that are virtually  
26          certain to be successful (i.e., probability nearly equal to 1) during accident conditions.

27  
28          The individual performing the restoration function can be the person conducting the test  
29          and must be in communication with the control room. Credit can also be taken for an  
30          operator in the main control room provided (s)he is in close proximity to restore the  
31          equipment when needed. Normal staffing for the test may satisfy the requirement for a  
32          dedicated operator, depending on work assignments. In all cases, the staffing must be  
33          considered in advance and an operator identified to perform the restoration actions  
34          independent of other control room actions that may be required.

35  
36          Under stressful, chaotic conditions, otherwise simple multiple actions may not be  
37          accomplished with the virtual certainty called for by the guidance (e.g., lifting test leads

---

<sup>1</sup> Operator in this circumstance refers to any plant personnel qualified and designated to perform the restoration function.

<sup>2</sup> Including restoration steps in an approved test procedure.

1 and landing wires; or clearing tags). In addition, some manual operations of systems  
2 designed to operate automatically, such as manually controlling HPCI turbine to establish  
3 and control injection flow, are not virtually certain to be successful. These situations  
4 should be resolved on a case-by-case basis through the FAQ process.

## 5 6 2. *During Maintenance*

7 Unavailability of a risk-significant function during maintenance need not be included if  
8 the risk-significant function can be promptly restored either by an operator in the control  
9 room or by a designated operator<sup>3</sup> stationed locally for that purpose. Restoration actions  
10 must be contained in a written procedure<sup>4</sup>, must be uncomplicated (*a single action or a*  
11 *few simple actions*), must be capable of being restored in time to satisfy PRA success  
12 criteria and must not require diagnosis or repair. Credit for a designated local operator  
13 can be taken only if (s)he is positioned at a proper location throughout the duration of the  
14 maintenance activity for the purpose of restoration of the train should a valid demand  
15 occur. The intent of this paragraph is to allow licensees to take credit for restoration of  
16 risk-significant functions that are virtually certain to be successful (i.e., probability nearly  
17 equal to 1).

18 The individual performing the restoration function can be the person performing the  
19 maintenance and must be in communication with the control room. Credit can also be  
20 taken for an operator in the main control room provided (s)he is in close proximity to  
21 restore the equipment when needed. Normal staffing for the maintenance activity may  
22 satisfy the requirement for a dedicated operator, depending on work assignments. In all  
23 cases, the staffing must be considered in advance and an operator identified to perform  
24 the restoration actions independent of other control room actions that may be required.

25 Under stressful chaotic conditions otherwise simple multiple actions may not be  
26 accomplished with the virtual certainty called for by the guidance (e.g., lifting test leads  
27 and landing wires, or clearing tags). These situations should be resolved on a case-by-  
28 case basis through the FAQ process.

## 29 30 3. *During degraded conditions*

31 *No credit is allowed for operator actions during degraded conditions that render the*  
32 *train unavailable to perform its risk-significant functions.*

### 33 34 1.2.2. **Plant Specific Baseline Planned Unavailability**

35 The baseline planned unavailability is based on actual plant-specific values for the period  
36 2002~~2003~~ through 2005~~2004~~. (Plant specific values of the most recent data are used so  
37 that the indicator accurately reflects deviation from expected planned maintenance.)

---

<sup>3</sup> Operator in this circumstance refers to any plant personnel qualified and designated to perform the restoration function.

<sup>4</sup> Including restoration steps in an approved test procedure.

1 These values are expected to remain fixed unless the plant maintenance philosophy is  
2 substantially changed with respect to on-line maintenance or preventive maintenance. In  
3 these cases, the planned unavailability baseline value can be adjusted. A comment  
4 should be placed in the comment field of the quarterly report to identify a substantial  
5 change in planned unavailability. The baseline value of planned unavailability may be  
6 changed at the discretion of the licensee except that they shall be changed when changes  
7 in maintenance practices result in greater than a 25% change in planned unavailability.  
8 Revised values will be used in the calculation the quarter following their update.

9 To determine the initial value of planned unavailability:

- 10 1) Record the total train unavailable hours reported under the Reactor Oversight Process  
11 for 20023-20045.
- 12 2) Subtract any fault exposure hours still included in the 20023-20054 period.
- 13 3) Subtract unplanned unavailable hours.
- 14 4) Add any on-line overhaul hours and any other planned unavailability excluded in  
15 accordance with NEI 99-02.<sup>5</sup>
- 16 5) Add any planned unavailable hours for functions monitored under MSPI which were  
17 not monitored under SSU in NEI 99-02.
- 18 6) Subtract any unavailable hours reported when the reactor was not critical.
- 19 7) Subtract hours cascaded onto monitored systems by support systems. (However, do  
20 not subtract any hours already subtracted in the above steps.)
- 21 8) Divide the hours derived from steps 1-7 above by the total critical hours during  
22 20023-20045. This is the baseline planned unavailability.

23 Support cooling planned unavailability baseline data is based on plant specific  
24 maintenance rule unavailability for years 20023-20054. Maintenance Rule practices do  
25 not typically differentiate planned from unplanned unavailability. However, best efforts  
26 will be made to differentiate planned and unplanned unavailability during this time  
27 period.

### 28 29 **1.2.3. Generic Baseline Unplanned Unavailability**

30 The unplanned unavailability values are contained in Table 1 and remain fixed. They are  
31 based on ROP PI industry data from 1999 through 2001. (Most baseline data used in Pis  
32 come from the 1995-1997 time period. However, in this case, the 1999-2001 ROP data  
33 are preferable, because the ROP data breaks out systems separately. Some of the industry  
34 1995-1997 INPO data combine systems, such as HPCI and RCIC, and do not include  
35 PWR RHR. It is important to note that the data for the two periods is very similar.)

---

<sup>5</sup> Note: The plant-specific PRA should model significant on-line overhaul hours.

**Table 1. Historical Unplanned Unavailability Train Values**  
**(Based on ROP Industry wide Data for 1999 through 2001)**

SYSTEM	UNPLANNED UNAVAILABILITY/TRAIN
EAC	1.7 E-03
PWR HPSI	6.1 E-04
PWR AFW (TD)	9.1 E-04
PWR AFW (MD)	6.9 E-04
PWR AFW (DieselD)	7.6 E-04
PWR (except CE) RHR	4.2 E-04
CE RHR	1.1 E-03
BWR HPCI	3.3 E-03
BWR HPCS	5.4 E-04
BWR RCIC	2.9 E-03
BWR IC	Need a value for isolation condensers
BWR RHR	1.2 E-03
Support Cooling	Use plant specific Maintenance Rule data for 2002-20042003-2005

Unplanned unavailability baseline data for the support cooling systems should be developed from plant specific Maintenance Rule data from the period 2002-20042003-2005. Maintenance Rule practices do not typically differentiate planned from unplanned unavailability. However, best efforts will be made to differentiate planned and unplanned unavailability during this time period. NOTE: The sum of planned and unplanned unavailability cannot exceed the total unavailability.

### 1.3. Calculation of UAI

The specific formula for the calculation of UAI is provided in this section. Each term in the formula will be defined individually and specific guidance provided for the calculation of each term in the equation. Required inputs to the INPO Consolidated Data Entry (CDE) System will be identified.

Calculation of System UAI due to train unavailability is as follows:

$$UAI = \sum_{j=1}^n UAI_{tj} \quad \text{Eq. 1}$$

where the summation is over the number of trains ( $n$ ) and  $UAI_t$  is the unavailability index for a train.

1 Calculation of  $UAI_t$  for each train due to actual train unavailability is as follows:

$$2 \quad UAI_t = CDF_p \left[ \frac{FV_{UA_p}}{UA_p} \right]_{\max} (UA_t - UABL_t) \quad \text{Eq. 2}$$

3 where:

4  $CDF_p$  is the plant-specific Core Damage Frequency,

5  $FV_{UA_p}$  is the train-specific Fussell-Vesely value for unavailability,

6  $UA_p$  is the plant-specific PRA value of unavailability for the train,

7  $UA_t$  is the actual unavailability of train t, defined as:

$$8 \quad UA_t = \frac{\text{Unavailable hours during the previous 12 quarters while critical}}{\text{Critical hours during the previous 12 quarters}}$$

9 and, determined in section 1.21

10  $UABL_t$  is the historical baseline unavailability value for the train (sum of planned  
11 unavailability determined in section 1.2.2 and unplanned unavailability in  
12 section 1.2.3)

13 Calculation of the quantities in equation 2 are discussed in the following sections.

#### 14 1.3.1. Calculation of Core Damage Frequency (CDF<sub>p</sub>)

15 The Core Damage Frequency is a CDE input value. The required value is the internal  
16 events, average maintenance, at power value. Internal flooding and fire are not included  
17 in this calculated value. In general, all inputs to this indicator from the PRA are  
18 calculated from the internal events model only.

#### 19 1.3.2. Calculation of [FV/UA]<sub>max</sub> for each train

20 FV and UA are separate CDE input values. Equation 2 includes a term that is the ratio of  
21 a Fussell-Vesely importance value divided by the related unavailability. This ratio is  
22 calculated for each train in the system and both the FV and UA are CDE inputs. (It may  
23 be recognized that the quantity [FV/UA] multiplied by the CDF is the Birnbaum  
24 importance measure, which is used in section 2.3.3.)

25 Calculation of these quantities is generally complex, but in the specific application used  
26 here, can be greatly simplified.

27 The simplifying feature of this application is that only those components (or the  
28 associated basic events) that can make a train unavailable are considered in the  
29 performance index. Components within a train that can each make the train unavailable  
30 are logically equivalent and the ratio FV/UA is a constant value for any basic event in  
31 that train. It can also be shown that for a given component or train represented by  
32 multiple basic events, the ratio of the two values for the component or train is equal to the  
33 ratio of values for any basic event within the train. Or:

$$34 \quad \frac{FV_{be}}{UA_{be}} = \frac{FV_{UA_p}}{UA_p} = \text{Constant}$$

1 Thus, the process for determining the value of this ratio for any train is to identify a basic  
2 event that fails the train, determine the unavailability for the event, determine the  
3 associated FV value for the event and then calculate the ratio. Use the basic event in the  
4 train with the largest failure probability (hence the maximum notation on the bracket) to  
5 minimize the effects of truncation on the calculation.

6 Some systems have multiple modes of operation, such as PWR HPSI systems that operate  
7 in injection as well as recirculation modes. In these systems all monitored components  
8 are not logically equivalent; unavailability of the pump fails all operating modes while  
9 unavailability of the sump suction valves only fails the recirculation mode. In cases such  
10 as these, if unavailability events exist separately for the components within a train, the  
11 appropriate ratio to use is the maximum.

12 Note: If the basic event  $Be$  is truncated in quantification and has no FV to ratio, do not  
13 include the train in the MSPI scope. [What level of truncation is appropriate?]

## 14 15 **2. System Unreliability Index (URI) Due to Component Unreliability**

16  
17 Calculation of the URI is performed in three major steps:

- 18 • Identification of the monitored components for each system
- 19 • Collection of plant data
- 20 • Calculation of the URI

21 Only the most risk significant components in each system are monitored to minimize the burden  
22 for each utility. It is expected that most, if not all the components identified for monitoring are  
23 already being monitored for failure reporting to INPO and are also monitored in accordance with  
24 the maintenance rule.

### 25 **2.1. Identify Monitored Components**

26 *Monitored Component:* A component whose failure to change state or remain running  
27 renders the train incapable of performing its risk-significant functions. In addition, all pumps  
28 and diesels in the monitored systems are included as monitored components.

29 The identification of monitored components involves the use of the system boundaries and  
30 success criteria, identification of the components to be monitored within the system boundary  
31 and the scope definition for each component.

#### 32 **2.1.1. System Boundaries and Success Criteria**

33 The system boundaries developed in section 1.1.1 should be used to complete the steps in  
34 the following section.

35 For each system, the at power risk significant functions described in the Appendix F  
36 section "Additional Guidance for Specific Systems," that were determined to be risk-  
37 significant in accordance with NUMARC 93-01, or NRC approved equivalents (e.g., the  
38 STP exemption request) shall be identified. Success criteria shall then be identified for  
39 these functions.

1 If the licensee has chosen to use success criteria documented in the plant specific PRA,  
2 examples of plant specific performance factors that may be used to identify the required  
3 capability of the train/system to meet the risk-significant functions are provided below.

- 4 • Actuation
  - 5 ○ Time
  - 6 ○ Auto/manual
  - 7 ○ Multiple or sequential
- 8 • Success requirements
  - 9 ○ Numbers of components or trains
  - 10 ○ Flows
  - 11 ○ Pressures
  - 12 ○ Heat exchange rates
  - 13 ○ Temperatures
  - 14 ○ Tank water level
- 15 • Other mission requirements
  - 16 ○ Run time
  - 17 ○ State/configuration changes during mission
- 18 • Accident environment from internal events
  - 19 ○ Pressure, temperature, humidity
- 20 • Operational factors
  - 21 ○ Procedures
  - 22 ○ Human actions
  - 23 ○ Training
  - 24 ○ Available externalities (e.g., power supplies, special equipment, etc.)

25 If the licensee has chosen to use design basis success criteria, it is not required to  
26 separately document them other than to indicate that is what was used.

27 If success criteria for a system vary by function or initiator, the most restrictive set will  
28 be used for the MSPI.

### 29 30 **2.1.2. Selection of Components**

31 For unreliability, use the following process for determining those components that should  
32 be monitored. These steps should be applied in the order listed.

- 33 1) INCLUDE all pumps and diesels.
- 34 2) Identify all AOV's and MOV's that change state to achieve the risk significant  
35 functions for the system as potential monitored components. Check valves,  
36 solenoid valves and manual valves are not included in the index.
  - 37 a. INCLUDE those valves from the list of valves from step 2 whose failure  
38 alone can fail a train. The success criteria used to identify these valves are  
39 those identified in the previous section. (See Figure F-5)
  - 40 b. INCLUDE redundant valves from the list of valves from step 2 within a  
41 multi-train system, whether in series or parallel, where the failure of both

1 valves would prevent all trains in the system from performing a risk-  
 2 significant function. The success criteria used to identify these valves are  
 3 those identified in the previous section.(See Figure F-5)

4 c. EXCLUDE those valves from steps a) and b) above whose Birnbaum  
 5 importance, (See section 2.3.3) as calculated in this appendix, is less than  
 6 1.0e-06. This rule is applied at the discretion of the individual plant. A  
 7 balance should be considered in applying this rule between the goal to  
 8 minimize the number of components monitored and having a large enough  
 9 set of components to have an adequate data pool.

10 3) INCLUDE components that cross tie monitored systems between units (i.e.  
 11 Electrical Breakers and Valves) if they are modeled in the PRA.

12 **2.1.3. Definition of Component Boundaries**

13 Table 2 defines the boundaries of components, and Figures F-1, F-2, F-3 and F-4 provide  
 14 examples of typical component boundaries as described in Table 2.

15 **Table 2. Component Boundary Definition**

Component	Component boundary
Diesel Generators	The diesel generator boundary includes the generator body, generator actuator, lubrication system (local), fuel system (local), cooling components (local), startup air system receiver, exhaust and combustion air system, dedicated diesel battery (which is not part of the normal DC distribution system), individual diesel generator control system, circuit breaker for supply to safeguard buses and their associated local control circuit (coil, auxiliary contacts, wiring and control circuit contacts, and breaker closure interlocks) .
Motor-Driven Pumps	The pump boundary includes the pump body, motor/actuator, lubrication system cooling components of the pump seals, the voltage supply breaker, and its associated local control circuit (coil, auxiliary contacts, wiring and control circuit contacts).
Turbine-Driven Pumps	The turbine-driven pump boundary includes the pump body, turbine/actuator, lubrication system (including pump), extractions, turbo-pump seal, cooling components, and local turbine control system including the control valve (speed).
Motor-Operated Valves	The valve boundary includes the valve body, motor/actuator, the voltage supply breaker (both motive and control power) and its associated local open/close circuit (open/close switches, auxiliary and switch contacts, and wiring and switch energization contacts).
Air-Operated Valves	The valve boundary includes the valve body, the air operator, associated solenoid-operated valve, the power supply breaker or fuse for the solenoid valve, and its associated control circuit (open/close switches and local auxiliary and switch contacts).

1 For control and motive power, only the last relay, breaker or contactor necessary to  
2 power or control the component is included in the monitored component boundary. For  
3 example, if an ESFAS signal actuates a MOV, only the relay that receives the ESFAS  
4 signal in the control circuitry for the MOV is in the MOV boundary. No other portions of  
5 the ESFAS are included.

6 Each plant will determine its monitored components and support components and have them  
7 available for NRC inspection.

## 8 **2.2. Collection of Plant Data**

9 Plant data for the URI includes:

- 10 • Demands and run hours
- 11 • Failures

### 12 **2.2.1. Demands and Run Hours**

13 *Start demand:* Any demand for the component to successfully start to perform its risk-  
14 significant functions, actual or test. (Exclude post maintenance tests, unless in case of a  
15 failure the cause of failure was independent of the maintenance performed.) The number  
16 of demands is:

- 17 • the number of actual ESF demands plus
- 18 • the number of estimated test demands plus
- 19 • the number of estimated operational/alignment demands.

20 The number of estimated demands can be derived based on the number of times a  
21 procedure or maintenance activity is performed, or based on historical data over a year or  
22 more averaged to provide a quarterly average. It is also permissible to use the actual  
23 number of test and operational demands.

24 An update to the estimated demands is required if a change to the basis for the estimated  
25 demands results in a >25% change in the estimate. The new estimate will be used in the  
26 calculation the quarter following the input of the updated estimates into CDE. Some  
27 monitored valves will include a throttle function as well as open and close functions. ~~It is~~  
28 ~~not required to include every throttle movement of a valve as a counted demand~~ One  
29 should not include every throttle movement of a valve as a counted demand. Only the  
30 initial movement of the valve should be counted as a demand.

31 Some components such as valves make need to be in different states at different times to  
32 fulfill the risk significant function of the monitored system. In this case each change of  
33 state is a demand. An example would be a minimum flow valve that needs to open on the  
34 pump start (one demand) then close (second demand) to prevent a diversion path or a  
35 valve needs to open(one demand) for the initial water supply then close (second demand)  
36 while another water supply valve opens.

37 *Post maintenance tests:* Tests performed following maintenance but prior to declaring the  
38 train/component operable, consistent with Maintenance Rule implementation.

39 *Run demand:* Any demand for the component, given that it has successfully started and  
40 run for 1 hour, to run/operate for its mission time to perform its risk-significant functions.

1 (Exclude post maintenance tests, unless the cause of failure was independent of the  
2 maintenance performed.)

3 *Run Hours:* The number of run hours is:

- 4 • the number of actual ESF run hours plus
- 5 • the number of estimated test run hours plus
- 6 • the number of estimated operational/alignment run hours.

7 The number of estimated run hours can be derived based on the number of times a  
8 procedure or maintenance activity is performed, or based on historical data over a year or  
9 more averaged to provide a quarterly average. It is also permissible to use the actual  
10 number of test and operational run hours. Run hours include the first hour of operation of  
11 a component. An update to the estimated run hours is required if a change to the basis for  
12 the estimated hours results in a >25% change in the estimate. The new estimate will be  
13 used in the calculation the quarter following the input of the updated estimates into CDE.

#### 14 2.2.2. Failures

15 *EDG failure to start:* A failure to start includes those failures up to the point the EDG has  
16 achieved rated speed and voltage. (Exclude post maintenance tests, unless the cause of  
17 failure was independent of the maintenance performed.)

18 *EDG failure to load/run:* Given that it has successfully started, a failure of the EDG  
19 output breaker to close, to successfully load sequence and to run/operate for one hour to  
20 perform its risk-significant functions. This failure mode is treated as a demand failure for  
21 calculation purposes. (Exclude post maintenance tests, unless the cause of failure was  
22 independent of the maintenance performed.)

23 *EDG failure to run:* Given that it has successfully started and loaded and run for an hour,  
24 a failure of an EDG to run/operate. (Exclude post maintenance tests, unless the cause of  
25 failure was independent of the maintenance performed.)

26 *Pump failure on demand:* A failure to start and run for at least one hour is counted as  
27 failure on demand. (Exclude post maintenance tests, unless the cause of failure was  
28 independent of the maintenance performed.)

29 *Pump failure to run:* Given that it has successfully started and run for an hour, a failure of  
30 a pump to run/operate. (Exclude post maintenance tests, unless the cause of failure was  
31 independent of the maintenance performed.)

32 *Valve failure on demand:* A failure to transfer to the required risk significant positionstate  
33 (open, close, or throttle to the desired position as applicable) is counted as failure on  
34 demand. (Exclude post maintenance tests, unless the cause of failure was independent of  
35 the maintenance performed.)

36 *Breaker failure on demand:* A failure to transfer to the required risk significant  
37 positionstate (open or close as applicable) is counted as failure on demand. (Exclude post  
38 maintenance tests, unless the cause of failure was independent of the maintenance  
39 performed.)

#### 40 Treatment of Demand and Run Failures

1 Failures of monitored components on demand or failures to run, either actual or test are  
2 included in unreliability. Failures on demand or failures to run while not critical are  
3 included unless an evaluation determines the failure would not have affected the ability  
4 of the component to perform its risk-significant at power function. In no case can a  
5 postulated action to recover a failure be used as a justification to exclude a failure from  
6 the count.

7 Treatment of Degraded Conditions Capable of Being Discovered By Normal Surveillance  
8 Tests

9 Normal surveillance tests are those tests that are performed at a frequency of a refueling  
10 cycle or more frequently.

11 Degraded conditions, even if no actual demand or test existed, that render a monitored  
12 component incapable of performing its risk-significant functions are included in  
13 unreliability as a demand and a failure. The appropriate failure mode must be accounted  
14 for. For example, for valves, a demand and a demand failure would be assumed and  
15 included in URI. For pumps and diesels, if the degraded condition would have prevented  
16 a successful start, a demand and a failure is included in URI, but there would be no run  
17 time hours or run failures. If it was determined that the pump/diesel would start and load  
18 run, but would fail sometime during the 24 hour run test or its surveillance test  
19 equivalent, the evaluated failure time would be included in run hours and a run failure  
20 would be assumed. A start demand and start failure would not be included. If a running  
21 component is secured from operation due to observed degraded performance, but prior to  
22 failure, then a run failure shall be counted unless evaluation of the condition shows that  
23 the component would have continued to operate for the risk-significant mission time  
24 starting from the time the component was secured. Unavailable hours are included for the  
25 time required to recover the risk-significant function(s) and only while critical.

26 Degraded conditions, or actual unavailability due to mispositioning of non-monitored  
27 components that render a train incapable of performing its risk-significant functions are  
28 only included in unavailability for the time required to recover the risk-significant  
29 function(s) and only while critical.

30 Loss of risk significant function(s) is assumed to have occurred if the established success  
31 criteria have not been met. If subsequent analysis identifies additional margin for the  
32 success criterion, future impacts on URI or UAI for degraded conditions may be  
33 determined based on the new criterion. However, the current quarter's URI and UAI  
34 must be based on the success criteria of record at the time the degraded condition is  
35 discovered. If subsequently, new success criteria are to be used, they must be included in  
36 the PRA and the MSPI basis document.

37  
38 If the degraded condition is not addressed by any of the pre-defined success criteria, an  
39 engineering evaluation to determine the impact of the degraded condition on the risk-  
40 significant function(s) should be completed and documented. The use of component  
41 failure analysis, circuit analysis, or event investigations is acceptable. Engineering  
42 judgment may be used in conjunction with analytical techniques to determine the impact  
43 of the degraded condition on the risk-significant function. The engineering evaluation

1 should be completed as soon as practicable. If it cannot be completed in time to support  
 2 submission of the PI report for the current quarter, the comment field shall note that an  
 3 evaluation is pending. The evaluation must be completed in time to accurately account  
 4 for unavailability/unreliability in the next quarterly report. Exceptions to this guidance  
 5 are expected to be rare and will be treated on a case-by-case basis. Licensees should  
 6 identify these situations to the resident inspector.

#### 7 Treatment of Degraded Conditions Not Capable of Being Discovered by Normal 8 Surveillance Tests

9 These failures or conditions are usually of longer exposure time. Since these failure  
 10 modes have not been tested on a regular basis, it is inappropriate to include them in the  
 11 performance index statistics. These failures or conditions are subject to evaluation  
 12 through the inspection process. Examples of this type are failures due to pressure  
 13 locking/thermal binding of isolation valves, blockages in lines not regularly tested,  
 14 unforeseen sequences not incorporated into the surveillance test, or inadequate  
 15 component sizing/settings under accident conditions (not under normal test conditions).  
 16 While not included in the calculation of the index, they should be reported in the  
 17 comment field of the PI data submittal.

#### 18 Failures of Non-Monitored Components

19 Failures of SSC's that are not included in the performance index will not be counted as a  
 20 failure or a demand. Failures of SSC's that cause an SSC within the scope of the  
 21 performance index to fail will not be counted as a failure or demand. An example could  
 22 be a manual suction isolation valve left closed which causes a pump to fail. This would  
 23 not be counted as a failure of the pump. Any mispositioning of the valve that caused the  
 24 train to be unavailable would be counted as unavailability from the time of discovery.  
 25 The significance of the mispositioned valve prior to discovery would be addressed  
 26 through the inspection process.

### 28 2.3. Calculation of URI

29 Unreliability is monitored at the component level and calculated at the system level.  
 30 Calculation of system URI due to changes in component unreliability is as follows:

$$31 \quad URI = CDF_p \sum_{j=1}^m \left[ \frac{FV_{URcj}}{UR_{pcj}} \right]_{\max} (UR_{Bcj} - UR_{BLcj}) \quad \text{Eq. 3}$$

32 Where the summation is over the number of monitored components ( $m$ ) in the system, and:

33  $CDF_p$  is the plant-specific Core Damage Frequency,

34  $FV_{URc}$  is the component-specific Fussell-Vesely value for unreliability,

35  $UR_{pc}$  is the plant-specific PRA value of component unreliability,

36  $UR_{Bc}$  is the Bayesian corrected component unreliability for the previous 12 quarters,

37 and

1  $UR_{BLc}$  is the historical industry baseline calculated from unreliability mean values for  
 2 each monitored component in the system. The calculation is performed in a manner  
 3 similar to equation 6 in section 2.3.4 below using the industry average values in Table 4.

4 The following sections will discuss the calculation of each of the terms in equation 3.

### 5 2.3.1. Calculation of Core Damage Frequency (CDFp)

6 The Core Damage Frequency is a CDE input value. The required value is the internal  
 7 events average maintenance at power value. Internal flooding and fire are not included in  
 8 this calculated value. In general, all inputs to this indicator from the PRA are calculated  
 9 from the internal events model only.

### 10 2.3.2. Calculation of [FV/UR]max

11 The FV, UR and common cause adjustment values developed in this section are separate  
 12 CDE input values.

13 Equation 3 includes a term that is the ratio of a Fussell-Vesely importance value divided  
 14 by the related unreliability. The calculation of this ratio is performed in a similar manner  
 15 to the ratio calculated for UAI, except that the ratio is calculated for each monitored  
 16 component. Two additional factors need to be accounted for in the unreliability ratios that  
 17 were not needed in the unavailability ratios, the contribution to the ratio from common  
 18 cause failure events and the possible contribution from cooling water initiating events.  
 19 The discussion will start with the calculation of the initial ratio and then proceed with  
 20 options for adjusting this value to account for the additional two factors.

21 It can be shown that for a given component represented by multiple basic events, the ratio  
 22 of the two values for the component is equal to the ratio of values for any basic event  
 23 representing the component. Or:

$$24 \quad \frac{FV_{be}}{UR_{be}} = \frac{FVUR_c}{URP_c} = \text{Constant}$$

25 Note that the constant value may be different for the unreliability ratio and the  
 26 unavailability ratio because the two types of events are frequently not logically  
 27 equivalent. For example recovery actions may be modeled in the PRA for one but not the  
 28 other.

29 Thus, the process for determining the initial value of this ratio for any component is to  
 30 identify a basic event that fails the component (excluding common cause events),  
 31 determine the failure probability for the event, determine the associated FV value for the  
 32 event and then calculate the ratio,  $[FV/UR]_{ind}$ , where the subscript refers to independent  
 33 failures. Use the basic event for the component and its associated FV value that results in  
 34 the largest  $[FV/UR]$  ratio. This will typically be the event with the largest failure  
 35 probability to minimize the effects of truncation on the calculation.

36 It is typical, given the component scope definitions in Table 2, that there will be several  
 37 plant components modeled separately in the plant PRA that make up the MSPI  
 38 component definition. For example, it is common that an MOV, the actuation relay for  
 39 the MOV and the power supply breaker for the MOV are separate components in the

1 plant PRA. Ensure that the basic events related to all of these individual components are  
2 considered when choosing the appropriate  $[FV/UR]$  ratio.

3 If the basic event  $Be$  is truncated in quantification, do not include the component in the  
4 scope of the MSPI. [What level of truncation is appropriate?]

### 5 **Cooling Water and Service Water System $[FV/UR]_{ind}$ Values**

6 Component Cooling Water Systems (CCW) and Service Water Systems (SWS) at some  
7 nuclear stations contribute to risk in two ways. First, the systems provide cooling to  
8 equipment used for the mitigation of events and second, the failures in the systems may  
9 also result in the initiation of an event. The contribution to risk from failures to provide  
10 cooling to other plant equipment is modeled directly through dependencies in the PRA  
11 model. However, the contribution due to event initiation is treated in three general ways  
12 in current PRAs:

- 13 1) The use of linked initiating event fault trees for these systems
- 14 2) Fault tree solutions are generated for these systems external to the PRA and the  
15 calculated value is used in the PRA as a point estimate
- 16 3) A point estimate value is generated for the initiator using industry and plant  
17 specific event data and used in the PRA.

18 If a PRA uses the first modeling option, then the FV values calculated will reflect the  
19 total contribution to risk for a component in the system, as long the same basic event is  
20 used in the initiator and mitigation fault trees. If different basic events are used, the  
21 FV values for the initiator tree basic event and the mitigation tree basic event should be  
22 added.

23 If a linked initiating event fault tree is the modeling approach taken, then no additional  
24 corrections to the FV values is required. This section will outline a method to be used to  
25 if linked initiating event fault trees are not used.

26 The corrected  $[FV/UR]_{ind}$  for a component  $C$  is calculated from the expression:

$$27 \quad [FV/UR]_{ind} = [(FV_c + FV_{ie} * FV_{sc}) / UR]$$

28 Where:

29  $FV_c$  is the Fussell-Vesely for CDF for component  $C$  as calculated from the PRA  
30 Model. This does not include any contribution from initiating events.

31  $FV_{ie}$  is the Fussell-Vesely contribution for the initiating event in question (e.g.  
32 loss of service water).

33  $FV_{sc}$  is the Fussell-Vesely **within the system fault tree only** for component  $C$   
34 (i.e. the ratio of the sum of the cut sets in the fault tree solution in which that  
35 component appears to the overall system failure probability).

36  $[FV/UR]_{ind}$  is a CDE input value.

### 37 **Including the Effect of Common Cause in $[FV/UR]_{max}$**

38 Changes in the independent failure probability of an SSC imply a proportional change in  
39 the common cause failure probability, even though no actual common cause failures have

1 occurred. The impact of this effect on URI is considered by including a multiplicative  
 2 adjustment to the  $[FV/UR]_{ind}$  ratio developed in the section above. This multiplicative  
 3 factor is a CDE input value.

4 Two methods are provided for including this effect, a simple generic approach that uses  
 5 bounding generic adjustment and a more accurate plant specific method that uses values  
 6 derived from the plant specific PRA.

7 Generic Adjustment Values

8 Generic values have been developed for monitored components that are subject to  
 9 common cause failure. The correction factor is used as a multiplier on the  $[FV/UR]$  ratio  
 10 for each component in the common cause group. This method may be used for simplicity  
 11 and is recommended for components that are less significant contributors to the URI (e.g.  
 12  $[FV/UR]$  is small). The multipliers are provided in the table below. Single train systems  
 13 are not included.

14 **Table 3. Generic CCF Adjustment Values**

System	Component	Generic CCF Adjustment Values				
		1.25	1.50	2.00	3.00	5.00
EAC	EDG	2 EDGs (1/2) or 3 EDGs (2/3)	4 EDGs(1/4) with other diverse sources of power	3 EDGs(1/3)		4 EDGs(1/4) and no diverse sources of power
HPI	MDP Running		With SI and CVC		With only CVC	
	MDP Standby		With SI and CVC		With only SI	
HRS	MDP Standby	2 MDP (1/2)			3 MDP (1/3)	
	TDP	2 TDP and 1 MDP			3 TDP and no MDP	
RHR	MDP Standby		ALL			
SWS	MDP Running				ALL	
	MDP Standby		ALL			
	DDP	ALL				
CCW	MDP Running		ALL			
	MDP Standby			ALL		
ALL	MOV			ALL		

System	Component	Generic CCF Adjustment Values				
		1.25	1.50	2.00	3.00	5.00
ALL	AOV		ALL			

Note: Success criteria noted in parenthesis

1 NOTE THIS TABLE WILL BE DEVELOPED FOR ALL PLANTS

2 The Multiplier in the table above is used to adjust the FV value selected for use in the  
 3 preceding section. For example, at a plant with three one hundred percent capacity  
 4 EDG's, the FV selected in the preceding section would be multiplied by 2.00.

5 Plant Specific Common Cause Adjustment

6 The general form of a plant specific common cause adjustment factor is given by the  
 7 equation:

$$A = \frac{\left[ \left( \sum_{i=1}^n FV_i \right) + FV_{cc} \right]}{\sum_{i=1}^n FV_i} \quad \text{Eq. 4}$$

9 Where:

10  $n$  = is the number of components in a common cause group,

11  $FV_i$  = the FV for independent failure of component  $i$ ,

12 and

13  $FV_{cc}$  = the FV for the common cause failure of components in the group.

14 In the expression above, the  $FV_i$  are the values for the specific failure mode for the  
 15 component group that was chosen because it resulted in the maximum  $[FV/UR]$  ratio.  
 16 The  $FV_{cc}$  is the FV that corresponds to all combinations of common cause events for that  
 17 group of components for the same specific failure mode. Note that the  $FV_{cc}$  may be a sum  
 18 of individual  $FV_{cc}$  values that represent different combinations of component failures in a  
 19 common cause group.

20 For example consider again a plant with three one hundred percent capacity emergency  
 21 diesel generators. In this example, three failure modes for the EDG are modeled in the  
 22 PRA, fail to start (FTS), fail to load (FTL) and fail to run (FTR). Common cause events  
 23 exist for each of the three failure modes of the EDG in the following combinations:

- 24 1) Failure of all three EDGs,
- 25 2) Failure of EDG-A and EDG-B,
- 26 3) Failure of EDG-A and EDG-C,
- 27 4) Failure of EDG-B and EDG-C.

28 This results in a total of 12 common cause events.

29 Assume the maximum  $[FV/UR]$  resulted from the FTS failure mode, then the  $FV_{cc}$  used  
 30 in equation 4 would be the sum of the four common cause FTS events for the  
 31 combinations listed above.

1 It is recognized that there is significant variation in the methods used to model common  
 2 cause. It is common that the 12 individual common cause events described above are  
 3 combined into a fewer number of events in many PRAs. Correct application of the plant  
 4 specific method would, in this case, require the decomposition of the combined events  
 5 and their related FV values into the individual parts. This can be accomplished by  
 6 application of the following proportionality:

$$7 \quad FV_{part} = FV_{total} \times \frac{UR_{part}}{UR_{total}} \quad \text{Eq. 5}$$

8 Returning to the example above, assume that common cause was modeled in the PRA by  
 9 combining all failure modes for each specific combination of equipment modeled. Thus  
 10 there would be four common cause events corresponding to the four possible equipment  
 11 groupings listed above, but each of the common cause events would include the three  
 12 failure modes FTS, FTL and FTR. Again, assume the FTS independent failure mode is  
 13 the event that resulted in the maximum [FV/UR] ratio. The FV<sub>cc</sub> value to be used would  
 14 be determined by determining the FTS contribution for each of the four common cause  
 15 events. In the case of the event representing failure of all three EDGs this would be  
 16 determined from

$$17 \quad FV_{FTSABC} = FV_{ABC} \times \frac{UR_{FTSABC}}{UR_{ABC}}$$

18 Where,

19  $FV_{FTSABC}$  = the FV for the FTS failure mode and the failure of all three EDGs

20  $FV_{ABC}$  = the event from the PRA representing the failure of all three EDGs due to  
 21 all failure modes

22  $UR_{FTSABC}$  = the failure probability for a FTS of all three EDGs, and

23  $UR_{ABC}$  = the failure probability for all failure modes for the failure of all three  
 24 EDGs.

25  
 26 After this same calculation was performed for the remaining three common cause events,  
 27 the value for FV<sub>CC</sub> to be used in equation 4 would then be calculated from:

$$28 \quad FV_{cc} = FV_{FTSABC} + FV_{FTSAB} + FV_{FTSAC} + FV_{FTSBC}$$

29 This value is used in equation 4 to determine the value of A. The final quantity used in  
 30 equation 3 is given by:

$$31 \quad [FV/UR]_{max} = A * [FV/UR]_{ind}$$

32 In this case the individual values on the right hand side of the equation above are input to  
 33 CDE.

### 34 2.3.3. Birnbaum Importance

35 One of the rules used for determining the valves to be monitored in this performance  
 36 indicator permitted the exclusion of valves with a Birnbaum importance less than 1.0e-

1 06. To apply this screening rule the Birnbaum importance is calculated from the values  
2 derived in this section as:

$$3 \quad B = CDF * A * [FV/UR]_{ind} = CDF * [FV/UR]_{max}$$

4

#### 5 2.3.4. Calculation of $UR_{Bc}$

6 Component unreliability is calculated by:

$$7 \quad UR_{Bc} = PD + \lambda T_m \quad \text{Eq 6}$$

8 Where:

9  $P_D$  is the component failure on demand probability calculated based on data  
10 collected during the previous 12 quarters,

11  $\lambda$  is the component failure rate (per hour) for failure to run calculated based on  
12 data collected during the previous 12 quarters,

13 and

14  $T_m$  is the risk-significant mission time for the component based on plant specific  
15 PRA model assumptions. Where there is more than one mission time for different  
16 initiating events or sequences (e.g., turbine-driven AFW pump for loss of offsite  
17 power with recovery versus loss of feedwater), the longest mission time is to be  
18 used.

19 NOTE:

20 For valves only the  $P_D$  term applies

21 For pumps  $P_D + \lambda T_m$  applies

22 For diesels  $P_{D \text{ start}} + P_{D \text{ load run}} + \lambda T_m$  applies

23

24 The first term on the right side of equation 6 is calculated as follows.<sup>6</sup>

$$25 \quad PD = \frac{(Nd + a)}{(a + b + D)} \quad \text{Eq. 7}$$

26 where in this expression:

27  $N_d$  is the total number of failures on demand during the previous 12 quarters,

28  $D$  is the total number of demands during the previous 12 quarters determined in  
29 section 2.2.1

30 The values  $a$  and  $b$  are parameters of the industry prior, derived from industry  
31 experience (see Table 4).

---

<sup>6</sup> Atwood, Corwin L., Constrained noninformative priors in risk assessment, *Reliability Engineering and System Safety*, 53 (1996; 37-46)

1 In the calculation of equation 5 the numbers of demands and failures is the sum of all  
 2 demands and failures for similar components within each system. Do not sum across  
 3 units for a multi-unit plant. For example, for a plant with two trains of Emergency Diesel  
 4 Generators, the demands and failures for both trains would be added together for one  
 5 evaluation of  $P_D$  which would be used for both trains of EDGs.

6 In the second term on the right side of equation 6,  $\lambda$  is calculated as follows.

$$\lambda = \frac{(Nr + a)}{(Tr + b)} \quad \text{Eq. 8}$$

8 where:

9  $N_r$  is the total number of failures to run during the previous 12 quarters  
 10 (determined in section 2.2.2),

11  $T_r$  is the total number of run hours during the previous 12 quarters (determined in  
 12 section 2.2.1)

13 and

14  $a$  and  $b$  are parameters of the industry prior, derived from industry experience (see  
 15 Table 4).

16 In the calculation of equation 8 the numbers of demands and run hours is the sum of all  
 17 run hours and failures for similar components within each system. Do not sum across  
 18 units for a multi-unit plant. For example, a plant with two trains of Emergency Diesel  
 19 Generators, the run hours and failures for both trains would be added together for one  
 20 evaluation of  $\lambda$  which would be used for both trains of EDGs.

22 **2.3.5. Baseline Unreliability Values**

23 The baseline values for unreliability are contained in Table 4 and remain fixed.

25 **Table 4. Industry Priors and Parameters for Unreliability**

Component	Failure Mode	a <sup>a</sup>	b <sup>a</sup>	Industry Mean Value <sub>b</sub> URBLC
Circuit Breaker		4.99E-1	6.23E+2	8.00E-4
Motor-operated valve	Fail to open (or close)	4.99E-1	7.12E+2	7.00E-4
Air-operated valve	Fail to open (or close)	4.98E-1	4.98E+2	1.00E-3
Motor-driven pump,	Fail to start	4.97E-1	2.61E+2	1.90E-3

Component	Failure Mode	a <sup>a</sup>	b <sup>a</sup>	Industry Mean Value <sub>b</sub> URBLC
standby	Fail to run	5.00E-1	1.00E+4	5.00E-5
Motor-driven pump, running or alternating	Fail to start	4.98E-1	4.98E+2	1.00E-3
	Fail to run	5.00E-1	1.00E+5	5.00E-6
Turbine-driven pump, AFWS	Fail to start	4.85E-1	5.33E+1	9.00E-3
	Fail to run	5.00E-1	2.50E+3	2.00E-4
Turbine-driven pump, HPCI or RCIC	Fail to start	4.78E-1	3.63E+1	1.30E-2
	Fail to run	5.00E-1	2.50E+3	2.00E-4
Diesel-driven pump, AFWS	Fail to start	4.80E-1	3.95E+1	1.20E-2
	Fail to run	5.00E-1	2.50E+3	2.00E-4
Emergency diesel generator	Fail to start	4.92E-1	9.79E+1	5.00E-3
	Fail to load/run	4.95E-1	1.64E+2	3.00E-3
	Fail to run	5.00E-1	6.25E+2	8.00E-4

1 NOTE: THIS TABLE IS SUBJECT TO UPDATE AFTER THE FIRST DATA SUBMISSION  
 2 IN APRIL 2006

3 a. A constrained, non-informative prior is assumed. For failure to run events, a = 0.5 and  
 4 b = (a)/(mean rate). For failure upon demand events, a is a function of the mean  
 5 probability:  
 6

Mean Probability	a
0.0 to 0.0025	0.50
>0.0025 to 0.010	0.49
>0.010 to 0.016	0.48
>0.016 to 0.023	0.47
>0.023 to 0.027	0.46

7 Then b = (a)(1.0 - mean probability)/(mean probability).

b. Failure to run events occurring within the first hour of operation are included within the fail to start failure mode. Failure to run events occurring after the first hour of operation are included within the fail to run failure mode.

c. Fail to load and run for one hour was calculated from the failure to run data in the report indicated. The failure rate for 0.0 to 0.5 hour ( $3.3E-3/h$ ) multiplied by 0.5 hour, was added to the failure rate for 0.5 to 14 hours ( $2.3E-4/h$ ) multiplied by 0.5 hour.

### 3. Establishing Statistical Significance

What is desired here is a short, non-technical explanation and reference to NRC technical report and CDE.

### 4. Calculation of System Component Performance Limits

The mitigating systems chosen to be monitored are generally the most important systems in nuclear power stations. However, in some cases the system may not be as important at a specific station. This is generally due to specific features at a plant, such as diverse methods of achieving the same function as the monitored system. In these cases a significant degradation in performance could occur before the risk significance reached a point where the MSPI would cross the white boundary. In cases such as this it is not likely that the performance degradation would be limited to that one system and may well involve cross cutting issues that would potentially affect the performance of other mitigating systems.

A performance based criterion for determining degraded performance is used as an additional decision criteria for determining that performance of a mitigating system has degraded to the white band. This decision is based on deviation of system performance from expected performance. The decision criterion was developed such that a system is placed in the white performance band when there is high confidence that system performance has degraded even though  $MSPI < 1.0e-06$ .

The criterion is applied to each component type in a system. If the number of failures in a 36 month period for a component type exceeds a performance based limit, then the system is considered to be performing at a white level, regardless of the MSPI calculated value. The performance based limit is calculated in two steps:

1. Determine the expected number of failures for a component type and
2. Calculate the performance limit from this value.

The expected number of failures is calculated from the relation

$$Fe = Nd * p + \lambda * Tr$$

Where:

$N_d$  is the number of demands

$p$  is the probability of failure on demand

$\lambda$  is the failure rate

$T_r$  is the runtime of the component

1 This value is used in the following expression to determine the maximum number of failures:

$$2 \quad F_m = 4.65 * F_e + 4.2$$

3 If the actual number of failures ( $F_a$ ) of a similar group of components (components that are  
4 grouped for the purpose of pooling data) within a system in a 36 month period exceeds  $F_m$ , then  
5 the system is placed in the largest of the white performance level or the level dictated by the  
6 MSPI calculation.

7 This calculation will be performed by the CDE software, no additional input values are required.  
8

## 9 **5. Additional Guidance for Specific Systems**

10 This guidance provides typical system scopes. Individual plants should include those systems  
11 employed at their plant that are necessary to satisfy the specific risk-significant functions  
12 described below and reflected in their PRAs.

### 13 **Emergency AC Power Systems**

#### 14 **Scope**

15 The function monitored for the emergency AC power system is the ability of the emergency  
16 generators to provide AC power to the class 1E buses upon a loss of off-site power while the  
17 reactor is critical, including post-accident conditions. The emergency AC power system is  
18 typically comprised of two or more independent emergency generators that provide AC power to  
19 class 1E buses following a loss of off-site power. The emergency generator dedicated to  
20 providing AC power to the high pressure core spray system in BWRs is not within the scope of  
21 emergency AC power.

22 The electrical circuit breaker(s) that connect(s) an emergency generator to the class 1E buses that  
23 are normally served by that emergency generator are considered to be part of the emergency  
24 generator train.

25 Emergency generators that are not safety grade, or that serve a backup role only (e.g., an  
26 alternate AC power source), are not included in the performance reporting.

#### 27 **Train Determination**

28 The number of emergency AC power system trains for a unit is equal to the number of class 1E  
29 emergency generators that are available to power safe-shutdown loads in the event of a loss of  
30 off-site power for that unit. There are three typical configurations for EDGs at a multi-unit  
31 station:

- 32 1. EDGs dedicated to only one unit.
- 33 2. One or more EDGs are available to "swing" to either unit
- 34 3. All EDGs can supply all units

35 For configuration 1, the number of trains for a unit is equal to the number of EDGs dedicated to  
36 the unit. For configuration 2, the number of trains for a unit is equal to the number of dedicated  
37 EDGs for that unit plus the number of "swing" EDGs available to that unit (i.e., The "swing"  
38 EDGs are included in the train count for each unit). For configuration 3, the number of trains is  
39 equal to the number of EDGs.

## 1 Clarifying Notes

2 The emergency diesel generators are not considered to be available during the following portions  
3 of periodic surveillance tests unless recovery from the test configuration during accident  
4 conditions is virtually certain, as described in "Credit for operator recovery actions during  
5 testing," can be satisfied; or the duration of the condition is less than fifteen minutes per train at  
6 one time:

7 • Load-run testing

8 • Barring

9 An EDG is not considered to have failed due to any of the following events:

- 10 • spurious operation of a trip that would be bypassed in a loss of offsite power event
- 11 • malfunction of equipment that is not required to operate during a loss of offsite power event  
12 (e.g., circuitry used to synchronize the EDG with off-site power sources)
- 13 • failure to start because a redundant portion of the starting system was intentionally disabled  
14 for test purposes, if followed by a successful start with the starting system in its normal  
15 alignment

16 Air compressors are not part of the EDG boundary. However, air receivers that provide starting  
17 air for the diesel are included in the EDG boundary.

18 If an EDG has a dedicated battery independent of the station's normal DC distribution system,  
19 the dedicated battery is included in the EDG system boundary.

20 The fuel transfer pumps are not considered to be a monitored component in the EDG system.  
21 They are considered to be a support system.

22

## 23 **BWR High Pressure Injection Systems**

24 **(High Pressure Coolant Injection, High Pressure Core Spray, and Feedwater Coolant**  
25 **Injection)**

### 26 Scope

27 These systems function at high pressure to maintain reactor coolant inventory and to remove  
28 decay heat following a small-break Loss of Coolant Accident (LOCA) event or a loss of main  
29 feedwater event.

30 The function monitored for the indicator is the ability of the monitored system to take suction  
31 from the suppression pool (and from the condensate storage tank, if credited in the plant's  
32 accident analysis) and inject into the reactor vessel.

33 Plants should monitor either the high-pressure coolant injection (HPCI), the high-pressure core  
34 spray (HPCS), or the feedwater coolant injection (FWCI) system, whichever is installed. The  
35 turbine and governor (or motor-driven FWCI pumps), and associated piping and valves for  
36 turbine steam supply and exhaust are within the scope of these systems. Valves in the feedwater  
37 line are not considered within the scope of these systems.

1 The emergency generator dedicated to providing AC power to the high-pressure core spray  
2 system is included in the scope of the HPCS. The HPCS system typically includes a "water leg"  
3 pump to prevent water hammer in the HPCS piping to the reactor vessel. The "water leg" pump  
4 and valves in the "water leg" pump flow path are ancillary components and are not included in  
5 the scope of the HPCS system. Unavailability is not included while critical if the system is below  
6 steam pressure specified in technical specifications at which the system can be operated.

#### 7 Train Determination

8 The HPCI and HPCS systems are considered single-train systems. The booster pump and other  
9 small pumps are ancillary components not used in determining the number of trains. The effect  
10 of these pumps on system performance is included in the system indicator to the extent their  
11 failure detracts from the ability of the system to perform its risk-significant function. For the  
12 FWCI system, the number of trains is determined by the number of feedwater pumps. The  
13 number of condensate and feedwater booster pumps are not used to determine the number of  
14 trains.

15

### 16 **Reactor Core Isolation Cooling**

17 (or Isolation Condenser)

#### 18 Scope

19 This system functions at high pressure to remove decay heat following a loss of main feedwater  
20 event. The RCIC system also functions to maintain reactor coolant inventory following a very  
21 small LOCA event.

22 The function monitored for the indicator is the ability of the RCIC system to cool the reactor  
23 vessel core and provide makeup water by taking a suction from either the condensate storage  
24 tank or the suppression pool and injecting at rated pressure and flow into the reactor vessel.

25 The Reactor Core Isolation Cooling (RCIC) system turbine, governor, and associated piping and  
26 valves for steam supply and exhaust are within the scope of the RCIC system. Valves in the  
27 feedwater line are not considered within the scope of the RCIC system.

28 The Isolation Condenser and inlet valves are within the scope of Isolation Condenser system.  
29 Unavailability is not included while critical if the system is below steam pressure specified in  
30 technical specifications at which the system can be operated.

#### 31 Train Determination

32 The RCIC system is considered a single-train system. The condensate and vacuum pumps are  
33 ancillary components not used in determining the number of trains. The effect of these pumps on  
34 RCIC performance is included in the system indicator to the extent that a component failure  
35 results in an inability of the system to perform its risk-significant function.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39

## **BWR Residual Heat Removal Systems**

### **Scope**

The functions monitored for the BWR residual heat removal (RHR) system are the ability of the RHR system to remove heat from the suppression pool, provide low pressure coolant injection, and provide post-accident decay heat removal. The pumps, heat exchangers, and associated piping and valves for those functions are included in the scope of the RHR system.

### **Train Determination**

The number of trains in the RHR system is determined by the number of parallel RHR heat exchangers.

## **PWR High Pressure Safety Injection Systems**

### **Scope**

These systems are used primarily to maintain reactor coolant inventory at high pressures following a loss of reactor coolant. HPSI system operation following a small-break LOCA involves transferring an initial supply of water from the refueling water storage tank (RWST) to cold leg piping of the reactor coolant system. Once the RWST inventory is depleted, recirculation of water from the reactor building emergency sump is required. The function monitored for HPSI is the ability of a HPSI train to take a suction from the primary water source (typically, a borated water tank), or from the containment emergency sump, and inject into the reactor coolant system at rated flow and pressure.

The scope includes the pumps and associated piping and valves from both the refueling water storage tank and from the containment sump to the pumps, and from the pumps into the reactor coolant system piping. For plants where the high-pressure injection pump takes suction from the residual heat removal pumps, the residual heat removal pump discharge header isolation valve to the HPSI pump suction is included in the scope of HPSI system. Some components may be included in the scope of more than one train. For example, cold-leg injection lines may be fed from a common header that is supplied by both HPSI trains. In these cases, the effects of testing or component failures in an injection line should be reported in both trains.

### **Train Determination**

In general, the number of HPSI system trains is defined by the number of high head injection paths that provide cold-leg and/or hot-leg injection capability, as applicable.

For Babcock and Wilcox (B&W) reactors, the design features centrifugal pumps used for high pressure injection (about 2,500 psig) and no hot-leg injection path. Recirculation from the containment sump requires operation of pumps in the residual heat removal system. They are typically a two-train system, with an installed spare pump (depending on plant-specific design) that can be aligned to either train.

For two-loop Westinghouse plants, the pumps operate at a lower pressure (about 1600 psig) and there may be a hot-leg injection path in addition to a cold-leg injection path (both are included as a part of the train).

1 For Westinghouse three-loop plants, the design features three centrifugal pumps that operate at  
2 high pressure (about 2500 psig), a cold-leg injection path through the BIT (with two trains of  
3 redundant valves), an alternate cold-leg injection path, and two hot-leg injection paths. One of  
4 the pumps is considered an installed spare. Recirculation is provided by taking suction from the  
5 RHR pump discharges. A train consists of a pump, the pump suction valves and boron injection  
6 tank (BIT) injection line valves electrically associated with the pump, and the associated hot-leg  
7 injection path. The alternate cold-leg injection path is required for recirculation, and should be  
8 included in the train with which its isolation valve is electrically associated. This represents a  
9 two-train HPSI system.

10 For Four-loop Westinghouse plants, the design features two centrifugal pumps that operate at  
11 high pressure (about 2500 psig), two centrifugal pumps that operate at an intermediate pressure  
12 (about 1600 psig), a BIT injection path (with two trains of injection valves), a cold-leg safety  
13 injection path, and two hot-leg injection paths. Recirculation is provided by taking suction from  
14 the RHR pump discharges. Each of two high pressure trains is comprised of a high pressure  
15 centrifugal pump, the pump suction valves and BIT valves that are electrically associated with  
16 the pump. Each of two intermediate pressure trains is comprised of the safety injection pump, the  
17 suction valves and the hot-leg injection valves electrically associated with the pump. The cold-  
18 leg safety injection path can be fed with either safety injection pump, thus it should be associated  
19 with both intermediate pressure trains. This HPSI system is considered a four-train system for  
20 monitoring purposes.

21 For Combustion Engineering (CE) plants, the design features two or three centrifugal pumps that  
22 operate at intermediate pressure (about 1300 psig) and provide flow to two or four cold-leg  
23 injection paths or two hot-leg injection paths. In most designs, the HPSI pumps take suction  
24 directly from the containment sump for recirculation. In these cases, the sump suction valves are  
25 included within the scope of the HPSI system. This is a two-train system (two trains of combined  
26 cold-leg and hot-leg injection capability). One of the three pumps is typically an installed spare  
27 that can be aligned to either train or only to one of the trains (depending on plant-specific  
28 design).

29

## 30 **PWR Auxiliary Feedwater Systems**

### 31 Scope

32 The AFW system provides decay heat removal via the steam generators to cool down and  
33 depressurize the reactor coolant system following a reactor trip. The AFW system is assumed to  
34 be required for an extended period of operation during which the initial supply of water from the  
35 condensate storage tank is depleted and water from an alternative water source (e.g., the service  
36 water system) is required. Therefore components in the flow paths from both of these water  
37 sources are included; however, the alternative water source (e.g., service water system) is not  
38 included.

39 The function monitored for the indicator is the ability of the AFW system to take a suction from  
40 the primary water source (typically, the condensate storage tank) or, if required, from an  
41 emergency source (typically, a lake or river via the service water system) and inject into at least  
42 one steam generator at rated flow and pressure.

1 The scope of the auxiliary feedwater (AFW) or emergency feedwater (EFW) systems includes  
2 the pumps and the components in the flow paths from the condensate storage tank and, if  
3 required, the valve(s) that connect the alternative water source to the auxiliary feedwater system.  
4 Pumps included in the Technical Specifications are included in the scope of this indicator.  
5 Startup feedwater pumps are not included in the scope of this indicator.

#### 6 **Train Determination**

7 The number of trains is determined primarily by the number of parallel pumps. For example, a  
8 system with three pumps is defined as a three-train system, whether it feeds two, three, or four  
9 injection lines, and regardless of the flow capacity of the pumps. Some components may be  
10 included in the scope of more than one train. For example, one set of flow regulating valves and  
11 isolation valves in a three-pump, two-steam generator system are included in the motor-driven  
12 pump train with which they are electrically associated, but they are also included (along with the  
13 redundant set of valves) in the turbine-driven pump train. In these instances, the effects of testing  
14 or failure of the valves should be reported in both affected trains. Similarly, when two trains  
15 provide flow to a common header, the effect of isolation or flow regulating valve failures in  
16 paths connected to the header should be considered in both trains.

#### 17 **PWR Residual Heat Removal System (Check for any needed change wrt CE plants 18 and Surry, N. Anna and Beaver Valley)**

##### 19 **Scope**

20 The functions monitored for the PWR residual heat removal (RHR) system are those that are  
21 required to be available when the reactor is critical. These typically include the low-pressure  
22 injection function and the post-accident recirculation mode used to cool and recirculate water  
23 from the containment sump following depletion of RWST inventory to provide post-accident  
24 decay heat removal. The pumps, heat exchangers, and associated piping and valves for those  
25 functions are included in the scope of the RHR system. Containment spray function should be  
26 included if it is identified as a risk-significant post accident decay heat removal function.  
27 Containment spray systems that only provide containment pressure control are not included.

##### 28 **Train Determination**

29 The number of trains in the RHR system is determined by the number of parallel RHR heat  
30 exchangers. Some components are used to provide more than one function of RHR. If a  
31 component cannot perform as designed, rendering its associated train incapable of meeting one  
32 of the risk-significant functions, then the train is considered to be failed. Unavailable hours  
33 would be reported as a result of the component failure.

#### 34 **Cooling Water Support System**

##### 35 **Scope**

36 The function of the cooling water support system is to provide for direct cooling of the  
37 components in the other monitored systems. It does not include indirect cooling provided by  
38 room coolers or other HVAC features.

39 Systems that provide this function typically include service water and component cooling water  
40 or their cooling water equivalents. Pumps, valves, heat exchangers and line segments that are  
41 necessary to provide cooling to the other monitored systems are included in the system scope up

1 to, but not including, the last valve that connects the cooling water support system to a single  
2 component in another monitored system. This last valve is included in the other monitored  
3 system boundary. Service water systems are typically open "raw water" systems that use natural  
4 sources of water such as rivers, lakes or oceans. Component Cooling Water systems are typically  
5 closed "clean water" systems.

6 Valves in the cooling water support system that must close to ensure sufficient cooling to the  
7 other monitored system components to meet risk significant functions are included in the system  
8 boundary.

9 If a cooling water system provides cooling to only one monitored system, then it should be  
10 included in the scope of that monitored system.

### 11 **Train Determination**

12 The number of trains in the Cooling Water Support System will vary considerably from plant to  
13 plant. The way these functions are modeled in the plant-specific PRA will determine a logical  
14 approach for train determination. For example, if the PRA modeled separate pump and line  
15 segments, then the number of pumps and line segments would be the number of trains.

### 16 **Clarifying Notes**


17 Service water pump strainers and traveling screens are not considered to be monitored  
18 components and are therefore not part of URI. However, clogging of strainers and screens that  
19 render the train unavailable to perform its risk significant cooling function (which includes the  
20 risk-significant mission times) are included in UAI.

21 .

22


1  
2

Figure F-1



3

1




2

3

4

Figure F-2

1



2


3

4

5

Figure F-3

1




2

3

4

Figure F-4

1



2  
3  
4

Figure F-5

## NEI 99-02 Appendix G, MSPI Basis Document Development

To implement the Mitigating Systems Performance Index (MSPI), Licensees will ~~shall~~ develop a plant specific basis document that documents the information and assumptions used to calculate the Reactor Oversight Program (ROP) MSPI. This basis document is necessary to support the NRC inspection process, and to record the assumptions and data used in developing the MSPI on each site.

The Basis document will have two major sections. The first described below will document the information used in developing the MSPI. The second section will document the conformance of the plant specific PRA to the requirements that are outlined in this appendix.

### I. MSPI Data

The basis document ~~should be written to~~ provides a separate section for each monitored system as defined in Section 2.2 of NEI 99-02. The section for each monitored system ~~should~~ contains the following subsections:

#### A. System Boundaries

This section ~~shall~~ contains a description of the boundaries for each train of the monitored system. A plant drawing or figure (training type figure) should be included and marked adequately (i.e., highlighted trains) to show the boundaries. The guidance for determining the boundaries is provided in Appendix F, Section 1.1 of NEI 99-02.

#### B. Risk Significant Functions

This section ~~shall~~ lists the risk significant functions for each train of the monitored system. Risk Significant Functions are defined in section 2.2 of NEI 99-02. Additional detail is given in Appendix F, Section 2.1.1 and Section 5 "Additional Guidance for Specific Systems". A single list for the system may be used as long as any differences between trains are clearly identified. This section may also be combined with the section on Success Criteria if a combination of information into a table format is desired.

#### C. Success Criteria

This section ~~shall~~ documents the success criteria as defined in Section 2.2 of NEI 99-02 for each of the identified risk significant functions identified for the system. Additional detail is given in Appendix F, Section 2.1.1. The criteria used should be the documented PRA success criteria. Otherwise plant design basis values are used, and identified in this section. Where there are different success criteria for different functions or initiators, all should be recorded and the most restrictive shown as the one used.

#### D. Mission Time

This section ~~shall~~ documents the risk significant mission time as defined in Section 2.2 of NEI 99-02 for each of the identified risk significant functions identified for the system.

The default value of 24 hours should be used unless other values are used in the plant PRA, documented by the plant, and identified in this section.

#### **E. Monitored Components**

This section shall documents the selection of monitored components as defined in Appendix F, Section 2.1.2 of NEI 99-02 in each train of the monitored system. A listing of all monitored pumps, breakers and EDG's should be included in this section. A listing of AOV's and MOV's that change state to achieve the risk significant functions should be provided as potential monitored components. The basis for excluding valves in this list from monitoring should be provided. Component boundaries as described in Appendix F, Section 2.1.3 of NEI 99-02 should be included where appropriate.

#### **F. Basis for Demands/Run Times (estimate or actual)**

The determination of reliability largely relies on the values of demands, run times and failures of components to develop a failure rate. This section shall documents how the licensee will determine the demands on a component. Several methods may be used.

- Actual counting of demands/run times during the reporting period
- An estimate of demands/run times based on the number of times a procedure or maintenance activity is performed
- An estimate based on historical data over a year or more averaged for a quarterly average

The method used should be described and the basis information used documented.

#### **G. PRA Information used in the MSPI**

##### **1. Unavailability FV and UA**

This section shall includes a table or spreadsheet that lists the basic events for unavailability for each train of the monitored systems. This listing should include the probability, FV, and FV/probability ratio and text description of the basic event or component ID.

##### **a) Unavailability Baseline Data**

This section shall includes the baseline unavailability data by train for each monitored system. The discussion should include the basis for the baseline values used.

##### **2. Unreliability FV and UR**

This section shall includes a table or spreadsheet that lists the basic events for component failures for each monitored component. This listing should include the probability, FV, the common cause adjustment factor and FV/probability ratio and text description of the basic event or component ID.

##### **a) Treatment of Support System Initiator**

This section shall documents whether the cooling water systems are an initiator or not. This section shall contain the provides a description of how the plant will include the support system initiator as described in Appendix F of NEI 99-02. If an analysis is performed for a plant specific value, the

calculation must be documented in accordance with plant processes and referred to here. The results should also be included in this section.

**b) Calculation of Common Cause Factor**

This section shall contain the description of how the plant will determine the common cause factor as described in Appendix F of NEI 99-02. If an analysis is performed for a plant specific value, the calculation must be documented in accordance with plant processes and referred to here. The results should also be included in this section.

**H. Assumptions**

This section shall document any specific assumptions made in determination of the MSPI information that may need to be documented. Causes for documentation in this section could be special methods of counting hours or runtimes based on plant specific designs or processes, or other instances not clearly covered by the guidance in NEI 99-02.

**II. PRA REQUIREMENTS**

- A. INSERT THE PRA TECHNICAL ADEQUACY REQUIREMENTS DEVELOPED BY THE EXPERT PANEL HERE**
- B. DOCUMENT HOW THE PLANT PRA MEETS THE PRA TECHNICAL ADEQUACY REQUIREMENTS HERE**

TempNo.	PI	Question/Response	Status	Plant/ Co.
27.3	IE02	<p>Question: Should a reactor scram due to high reactor water level, where the feedwater pumps tripped due to the high reactor water level, count as a scram with a loss of normal heat removal</p> <p>Background Information: On April 6, 2001 LaSalle Unit 2 (BWR), during maintenance on a motor driven feedwater pump regulating valve, experienced a reactor automatic reactor scram on high reactor water level. During the recovery, both turbine driven reactor feedwater pumps (TDRFPs) tripped due to high reactor water level. The motor driven reactor feedwater pump was not available due to the maintenance being performed. The reactor operators choose to restore reactor water level through the use of the Reactor Core Isolation Cooling (RCIC) System, due to the fine flow control capability of this system, rather than restore the TDRFPs. Feedwater could have been restored by resetting a TDRFP as soon as the control board high reactor water level alarm cleared. Procedure LGA-001 "RPV Control" (Reactor Pressure Vessel control) requires the unit operator to "Control RPV water level between 11 in. and 59.5 in. using any of the systems listed below: Condensate/feedwater, RCIC, HPCS, LPCS, LPCI, RHR."</p> <p>The following control room response actions, from standard operating procedure LOP-FW-04, "Startup of the TDRFP" are required to reset a TDRFP. No actions are required outside of the control room (and no diagnostic steps are required).</p> <p>Verify the following: TDRFP M/A XFER (Manual/Automatic Controller) station is reset to Minimum No TDRFP trip signals are present Depress TDRFP Turbine RESET pushbutton and observe the following Turbine RESET light Illuminates TDRFP High Pressure and Low Pressure Stop Valves OPEN PUSH M/A increase pushbutton on the Manual/Automatic Controller station Should this be considered a scram with the loss of normal heat removal?</p> <p>Proposed Answer: The ROP working group is currently working to prepare a response.</p>	<p>1/25 Introduced 2/28 NRC to discuss with resident 4/25 Discussed 5/22 On hold 6/12 Discussed. Related FAQ 30.8 9/26 Discussed 10/31 Discussed</p>	LaSalle
28.3	IE02	<p>Question: This event was initiated because a feedwater summer card failed low. The failure caused the feedwater circuitry to sense a lower level than actual. This invalid low level signal caused the Reactor Recirculation pumps to shift to slow speed while also causing the feedwater system to feed the Reactor Pressure Vessel (RPV) until a high level scram (Reactor Vessel Water Level – High, Level 8) was initiated.</p> <p>Within the first three minutes of the transient, the plant had gone from Level 8, which initiated the scram, to Level 2 (Reactor Vessel Water Level – Low Low, Level 2), initiating High Pressure Core Spray (HPCS) and Reactor Core Isolation Cooling (RCIC) injection, and again back to Level 8. The operators had observed the downshift of the Recirculation pumps nearly coincident with the scram, and it was not immediately apparent what had caused the trip due to the rapid sequence of events.</p> <p>As designed, when the reactor water level reached Level 8, the operating turbine driven feed pumps tripped. The pump control logic prohibits restart of the feed pumps (both the turbine driven pumps and motor driven feed pump</p>	<p>3/21 Discussed 4/25 Discussed 5/22 Modified to reflect discussion of 4/25, On Hold 6/12 Discussed. Related FAQ 30.8</p>	Perry

Attachments

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>(MFP)) until the Level 8 signal is reset. (On a trip of one or both turbine feed pumps, the MFP would automatically start, except when the trip is due to Level 8.) All three feedwater pumps (both turbine driven pumps and the MFP) were physically available to be started from the control room, once the Level 8 trip was reset. Procedures are in place for the operators to start the MFP or the turbine driven feedwater pumps in this situation.</p> <p>Because the cause of the scram was not immediately apparent to the operators, there was initially some misunderstanding regarding the status of the MFP. (Because the card failure resulted in a sensed low level, the combination of the recirculation pump downshift, the reactor scram, and the initiation of HPCS and RCIC at Level 2 provided several indications to suspect low water level caused the scram.) As a result of the initial indications of a plant problem (the downshift of the recirculation pumps), some operators believed the MFP should have started on the trip of the turbine driven pumps. This was documented in several personnel statements and a narrative log entry. Contributing to this initial misunderstanding was a MFP control power available light bulb that did not illuminate until it was touched. In fact, the MFP had functioned as it was supposed to, and aside from the indication on the control panel, there were no impediments to restarting any of the feedwater pumps from the control room. No attempt was made to manually start the MFP prior to resetting the Level 8 feedwater trip signal.</p> <p>Regardless of the issue with the MFP, however, both turbine driven feed pumps were available once the high reactor water level cleared, and could have been started from the control room without diagnosis or repair. Procedures are in place to accomplish this restart, and operators are trained in the evolution. Since RCIC was already in operation, operators elected to use it as the source of inventory, as provided for in the plant emergency instructions, until plant conditions stabilized. Should this event be counted as a Scram with a Loss of Normal Heat Removal?</p> <p>Response: The ROP working group is currently working to prepare a response.</p>		
30.8	IE02	<p>Question: Many plant designs trip the main feedwater pumps on high reactor water level (BWRs), and high steam generator water level or certain other automatic trips (PWRs). Under what conditions would a trip of the main feedwater pumps be considered/not considered a scram with loss of normal heat removal?</p> <p>Response: The ROP working group is currently working to prepare a response.</p>	5/22 Introduced 6/12 Discussed 9/26 Discussed. 10/31 Discussed	Generic
32.3a	IE02	<p>Question: An unplanned scram occurred October 7, 2001, during startup following an extended forced outage. The unit was in Mode 1 at approximately 8% reactor power with a main feed pump and low-flow feedwater preheating in service. The operators were preparing to roll the main turbine when a reactor tripped occurred. The cause of the trip was a loss of voltage to the control rod drive mechanisms and was not related to the heat removal path. Main feedwater isolated on the trip, as designed, with the steam generators being supplied by the auxiliary feedwater (AFW) pumps. At 5 minutes after the trip, the reactor coolant system (RCS) temperature was 540 degrees and trending down. The operators verified that the steam dumps, steam generator power operated relief valves, start-up steam supplies and blowdown were isolated. Additionally, AFW flow was isolated to all Steam Generators as allowed by the trip response procedure. At 9 minutes after the trip, with RCS temperature still trending down, the main steam isolation valves (MSIV) were closed in accordance with the reactor trip response procedure curtailing the cooldown.</p> <p>The RCS cooldown was attributed to steam that was still being supplied to low-flow feedwater preheating and #4 steam generator AFW flow control valve not automatically moving to its flow retention position as expected with high AFW flow. The low-flow feedwater preheating is a known steam load during low power operations and the AFW flow control issue was identified by the control room balance of plant operator. The trip response procedure directs the operators to check for and take actions to control AFW flow and eliminate the feedwater heater steam supply.</p>	1/23 Revised. Split into two FAQs 3/20 Discussed 5/1 Discussed 5/22 Tentative Approval 6/18 Discussion deferred to July 7/24 Discussed	DC Cook

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>When this trip occurred the unit was just starting up following a 40 day forced outage. The reactor was at approximately 8% power and there was very little decay heat present following the trip. With very little decay heat available, the primary contribution to RCS heating is from Reactor Coolant Pumps (RCPs). Evaluation of these heat loads, when compared to the cooling provided by AFW, shows that there is approximately 3.5 times as much cooling flow provided than is required to remove decay heat under these conditions plus pump heat. This resulted in rapid cooling of the RCS and ultimately required closure of the MSIVs. Other conditions such as low flow feedwater preheating and the additional AFW flow due to the AFW flow control valve failing to move to its flow retention setting contributed to this cooldown, but were not the primary cause. Even without these contributors to the cooldown, closure of MSIVs would have been required due to the low decay heat present following the trip.</p> <p>It should also be noted that the conditions that are identified as contributing to the cooldown are not conditions which prevent the secondary plant from being available for use as a cooldown path. The AFW flow control valve not going to the flow retention setting increases the AFW flow to the S/G, and in turn causes an increase in cooldown. This condition is corrected by the trip response procedure since the procedure directs the operator to control AFW flow as a method to stabilize the RCS temperature. With low-flow feedwater preheating in service, main steam is aligned to feedwater heaters 5 and 6 and is remotely regulated from the control room. Low-flow feedwater preheating is used until turbine bleed steam is sufficient to provide the steam supply then the system is isolated. There are no automatic controls or responses associated with the regulating valves, so when a trip occurs, operators must close the regulating valves to secure the steam source. Until the steam regulating valves are closed, this is a steam load contributing to a cooldown. The low-flow preheating steam supplies are identified in the trip response procedure since they are a CNP specific design issue.</p> <p>The actions taken to control RCS cooldown were in accordance with the plant procedure in response to the trip. The primary reason that the MSIVs were required to be closed was due to the low level of decay heat present following a 40 day forced outage. The closure of the MSIVs was to control the cooldown as directed by plant procedure and not to mitigate an off-normal condition or for the safety of personnel or equipment. With the low decay heat present following the 40 day forced outage, there would not have been a need to reopen the MSIVs prior to recommencing the startup.</p> <p>Should the reactor trip described above be counted in the Unplanned Scrams with Loss of Normal Heat Removal Performance Indicator?</p> <p>Response:  Yes. The licensee's reactor trip response procedure has an "action/expected response" that reactor coolant system temperature following a trip would be stable at or trending to the no-load Tavg value. If that expected response is not obtained, operators are directed to stop dumping steam and verify that steam generator blowdown is isolated. If cooldown continues, operators are directed to control total feedwater flow. If cooldown continues, operators are directed to close all steam generator stop valves (MSIVs) and other steam valves.</p> <p>During the unit trip described, the #4 steam generator auxiliary feedwater flow control valve did not reposition to the flow retention setting as expected (an off normal condition). In addition, although control room operators manually closed the low-flow feedwater preheat control valves that were in service, leakage past these valves (a pre-existing degraded condition identified in the Operator Workaround database) also contributed to the cooldown. Operator logs attributed the reactor system cooldown to the #4 AFW flow control valve failure as well as to steam being supplied to low-flow feedwater preheating. As stated above, the trip response procedure directs operators to control feedwater flow in order to control the cooldown. Operator inability to control the cooldown through control of feedwater flow as directed is considered an off normal condition. Since the cooldown continued due to an off normal condition, operators closed the MSIVs, and therefore this trip is considered a scram with loss of normal heat removal.</p>		
34.6	IE02	<p>Question: Should the following event be counted as a scram with loss of normal heat removal?</p>	3/20 Introduced 3/20 Discussed	STP

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>STP Unit Two was manually tripped on Dec. 15, 2002 as required by the off normal procedure for high vibration of the main turbine. Approximately 17 minutes after the Unit was manually tripped main condenser vacuum was broken at the discretion of the Shift Supervisor to assist in slowing the turbine. Plant conditions were stabilized using Auxiliary Feedwater and Steam Generator Power Operated Relief Valves. Main Feedwater remained available via the electric motor driven Startup Feedwater pump. Main steam headers remained available to provide cooling via the steam dump valves. At any time vacuum could have been reestablished without diagnoses or repair using established operating procedures until after completion of the scram response procedures.</p> <p>Scrams with a Loss of Normal Heat Removal performance indicator is defined as <i>"The number of unplanned scrams while critical, both manual and automatic, during the previous 12 quarters that were either caused by or involved a loss of the normal heat removal path prior to establishing reactor conditions that allow use of the plant's normal long term heat removal systems."</i> This indicator states that a loss of normal heat removal has occurred whenever any of the following conditions occur: loss of main feedwater, loss of main condenser vacuum, closure of the main steam isolation valves or loss of turbine bypass capability. The determining factor for this indicator is whether or not the normal heat removal path is available, not whether the operators choose to use that path or some other path.</p> <p>The STP plant is designed to isolate main feedwater after a trip by closing the main feedwater control valves. The auxiliary feedwater pumps are then designed to start on low steam generator levels. This is expected following normal operation above low power levels and in turn provides the normal heat removal.</p> <p>This design functioned as expected on December 15, 2002 when the reactor was manually tripped due to high turbine vibration. Normal plant operating procedures OPOP03-ZG-0006 (Plant Shutdown from 100% to Hot Standby) and OPOP03-ZG-0001 (Plant Heatup) state if Auxiliary Feedwater is being used to feed the steam generators than the preferred method of steaming is through the steam generator power operated relief valves. This can be found in steps 7.4 and 7.5 of OPOP03-ZG-0001 and steps 6.6.5 and 6.6.10 of OPOP03-ZG-0006. The note prior to 6.6.10 states <i>"the preferred method for controlling SG steaming rates while feeding with AFW is with the SG PORVs"</i>.</p> <p>The normal heat removal path as defined in NEI 99-02 Revision 2 was in service and functioning properly for seventeen minutes after the manual reactor trip and would have continued to function had not the shift supervisor voluntarily broke condenser vacuum and closed the MSIV's. Interviews with the shift supervisor showed that the decision to break vacuum was two part. 1) Based on experience and reports from the field it was known that vacuum would need to be broken to support the maintenance state required for the main turbine and at a minimum to support timely inspection. 2) This would assist in slowing the turbine. The decision to break vacuum was not based solely on mitigating an off-normal condition or for the safety of personnel or equipment. Because Auxiliary Feedwater system had actuated and was in service as expected, the decision was made to use Auxiliary Feedwater and steam through the SG PORVs. As stated earlier, this is the preferred method of heat removal if the decision to use Auxiliary Feedwater is employed as supported by the normal operating procedures while the plant is in Mode 3. Main feedwater remained available via the electric motor driven Startup Feedwater pump and the main steam headers remained available to provide cooling via the steam dump valves if required. Discussion with the shift supervisor showed he was confident that at any time vacuum could have been readily recovered from the control room without the need for diagnoses or repair using established operating procedures if the need arose. An outside action would be required in drawing vacuum in that a Condenser Air Removal pump would require starting locally in the TGB. This is a simplistic, proceduralized and commonly performed evolution. Personnel are fully confident this would have been performed without incident if required.</p> <p>Closing the MSIVs and breaking vacuum as quickly as possible is not uncommon at STP. For a normal planned shutdown MSIVs are closed and vacuum broken within four to six hours typically to support required maintenance in the secondary. If maintenance in the secondary is known to be critical path than vacuum has been broken as early as three hours and fifteen minutes following opening of the main generator breaker. The only reason that vacuum is not broken sooner is because in most cases it is needed to support chemistry testing.</p>	<p>6/18 Discussed; Question to be revised to reflect discussion 7/24 Discussed</p>	

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>By limiting the flow path as described in NEI 99-02 for normal heat removal there is undue burden being placed on the utility. Only recognizing this one specific flow path reduces operational flexibility and penalizes utilities for imparting conservative decision making. Conditions are established immediately following a reactor trip (100% to Mode 3) that can be sustained indefinitely using Auxiliary Feedwater and steaming through the steam generator PORVs. This fact is again supported in the stations Plant Shutdown from 100% to Hot standby and Plant Heatup normal operating procedures. The cause of a trip, the intended forced outage work scope, or outage duration varies and inevitably will factor into which method of normal long term heat removal is best for the station to employ shortly following a trip.</p> <p>Response: The ROP working group is currently working to prepare a response. Licensee Proposed Response: NO. Since vacuum was secured at the discretion of the Shift Supervisor and could have been restored using existing normally performed operating procedures, the function meets the intention of being available but not used.</p>		
36.1	IE02	<p>Question: With the unit in RUN mode at 100% power, the control room received indication that a Reactor Pressure Vessel relief valve was open. After taking the steps directed by procedure to attempt to reseal the valve without success, operators scrammed the reactor in response to increasing suppression pool temperature. Following the scram, and in response to procedural direction to limit the reactor cooldown rate to less than 100 degrees per hour, the operators closed the Main Steam Isolation Valves (MSIVs). The operators are trained that closure of the MSIV's to limit cool down rate is expected in order to minimize steam loss through normal downstream balance-of-plant loads (steam jet air ejectors, offgas preheaters, gland seal steam). At the time that the MSIVs were closed, the reactor was at approximately 500 psig. One half hour later, condenser vacuum was too low to open the turbine bypass valves and reactor pressure was approximately 325 psig. Approximately eight hours after the RPV relief valve opened, the RPV relief valve closed with reactor pressure at approximately 50 psig. This information is provided to illustrate the time frame during which the reactor was pressurized and condenser vacuum was low. Although the MSIVs were not reopened during this event, they could have been opened at any time. Procedural guidance is provided for reopening the MSIVs. Had the MSIVs been reopened within approximately 30 minutes of their closure, condenser vacuum was sufficient to allow opening of the turbine bypass valves. If it had been desired to reopen the MSIVs later than that, the condenser would have been brought back on line by following the normal startup procedure for the condenser. As part of the normal startup procedure for the condenser, the control room operator draws vacuum in the condenser by dispatching an operator to the mechanical vacuum pump. The operator starts the mechanical vacuum pump by opening a couple of manual valves and operating a local switch. All other actions, including opening the MSIVs and the turbine bypass valves, are taken by the control room operator in the control room. It normally takes between 45 minutes and one hour to establish vacuum using the mechanical vacuum pump. The reactor feed pumps and feedwater system remained in operation or available for operation throughout the event. The condenser remained intact and available and the MSIVs were available to be opened from the control room throughout the event. The normal heat removal path was always and readily available (i.e., use of the normal heat removal path required only a decision to use it and the following of normal station procedures) during this event. Does this scram constitute a scram with a loss of normal heat removal?</p> <p>Response: No. The normal heat removal path was not lost even though the MSIVs were manually closed to control cooldown rate. There was no leak downstream of the MSIVs, and reopening the MSIVs would not have introduced further</p>	9/25 Introduced and discussed	Quad Cities

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>complications to the event. The normal heat removal path was purposefully and temporarily isolated to address the cooldown rate, only. Reopening the normal heat removal path was always available at the discretion of the control room operator and would not have involved any diagnosis or repair.</p> <p>Further supporting information:  The clarifying notes for this indicator state: "<i>Loss of normal heat removal path</i> means the loss of the normal heat removal path as defined above. The determining factor for this indicator is whether or not the normal heat removal path is <i>available</i>, not whether the operators choose to use that path or some other path." In this case, the operator did not choose to use the path through the MSIVs, even though the normal heat removal path was available.  The clarifying notes for this indicator also state: "<i>Operator actions or design features to control the reactor cooldown rate or water level</i>, such as closing the main feedwater valves or closing all MSIVs, are not reported in this indicator as long as the normal heat removal path can be readily recovered from the control room without the need for diagnosis or repair." In this case, the closing of the MSIVs was performed solely to control reactor cooldown rate. It was not performed to isolate a steam leak. There was no diagnosis or repair involved in this event. The MSIVs could have been reopened following normal plant procedures</p>		
36.2	IE02	<p>Question:  Should an "Unplanned Scram with a Loss of Normal Heat Removal" be reported for the Peach Bottom Unit 2 (July 22, 2003) reactor scram followed by a high area temperature Group I isolation?</p> <p><u>Description of Event:</u>  At approximately 1345 on 07/22/03, a Main Generator 386B and 386F relay trip resulted in a load reject signal to the main turbine and the main turbine control valves went closed. The Unit 2 reactor received an automatic Reactor Protection System (RPS) scram signal as a result of the main turbine control valves closing. Following the scram signal, all control rods fully inserted and, as expected, Primary Containment Isolation System (PCIS) Group II and III isolations occurred due to low Reactor Pressure Vessel (RPV) level. The Group III isolation includes automatic shutdown of Reactor Building Ventilation. RPV level control was re-established with the Reactor Feed System and the scram signal was reset at approximately 1355 hours.  At approximately 1356 hours, the crew received a High Area Temperature alarm for the Main Steam Line area. The elevated temperature was a result of the previously described trip of the Reactor Building ventilation system. At approximately 1358, a PCIS Group I isolation signal occurred due to Steam Tunnel High Temperature resulting in the automatic closure of all Main Steam Isolation Valves (MSIV). Following the MSIV closure, the crew transitioned RPV pressure and level control to the High Pressure Coolant Injection (HPCI) and Reactor Core Isolation Cooling (RCIC) systems. Following the reset of the PCIS Group II and III isolations at approximately 1408, Reactor Building ventilation was restored.  At approximately 1525, the PCIS Group I isolation was reset and the MSIVs were opened. Normal cooldown of the reactor was commenced and both reactor recirculation pumps were restarted. Even though the Group I isolation could have been reset following the Group II/III reset at 1408, the crew decided to pursue other priorities before reopening the MSIVs including: stabilizing RPV level and pressure using HPCI and RCIC; maximizing torus cooling; evaluating RCIC controller oscillations; evaluating a failure of MO-2-02A-53A "A" Recirculation Pump Discharge Valve; and, minimizing CRD flow to facilitate restarting the Reactor Recirculation pumps.</p> <p><u>Problem Assessment:</u>  It is recognized that loss of Reactor Building ventilation results in rising temperatures in the Outboard MSIV Room. The rate of this temperature rise and the maximum temperature attained are exacerbated by summertime temperature conditions. When the high temperature isolation occurred, the crew immediately recognized and understood the cause to be the loss of Reactor Building ventilation. The crew then prioritized their activities and utilized existing General Plant (GP) and System Operating (SO) procedures to re-open the MSIVs.  Reopening of the MSIVs was:</p>	9/25 Introduced and discussed	Peach Bottom

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<ul style="list-style-type: none"> <li>• easily facilitated by restarting Reactor Building ventilation,</li> <li>• completed from the control room using normal operating procedures</li> <li>• without the need of diagnosis or repair</li> </ul> <p>Therefore, the MSIV closure does not meet the definition of "Loss of normal heat removal path" provided in NEI 99-02, Rev. 2, page 15, line 37, and it is appropriate not to include this event in the associated performance indicator – Unplanned Scrams with Loss of Normal Heat Removal.</p> <p><u>Discussion of specific aspects of the event:</u></p> <p>Was the recognition of the condition from the Control Room?</p> <ul style="list-style-type: none"> <li>▪ Yes. Rising temperature in the Outboard MSIV Room is indicated by annunciator in the main control room. Local radiation levels are also available in the control room. During the July 22, 2003 scram, control room operators also recognized that the increase in temperature was not due to a steam leak in the Outboard MSIV Room because the local radiation monitor did not indicate an increase in radiation levels. Initiation of the Group I isolation on a Steam Tunnel High Temperature is indicated by two annunciators in the control room.</li> </ul> <p>Does it require diagnosis or was it an alarm?</p> <ul style="list-style-type: none"> <li>▪ The event is annunciated in the control room as described previously.</li> </ul> <p>Is it a design issue?</p> <ul style="list-style-type: none"> <li>▪ Yes. The current Unit 2 design has the Group I isolation temperature elements closer to the Outboard MSIV Room ventilation exhaust as compared to Unit 3. As a result, the baseline temperatures, which input into the Group I isolation signal, are higher on Unit 2 than Unit 3.</li> </ul> <p>Are actions virtually certain to be successful?</p> <ul style="list-style-type: none"> <li>▪ The actions to reset a Group I isolation are straight forward and the procedural guidance is provided to operate the associated equipment. No diagnosis or troubleshooting is required.</li> </ul> <p>Are operator actions proceduralized?</p> <ul style="list-style-type: none"> <li>▪ The actions to reset the Group I isolation are delineated in General Plant procedure GP-8.A "PCIS Isolation-Group I." The actions to reopen the MSIVs are contained in System Operating procedures SO 1A.7.A-2 "Main Steam System Recovery Following a Group I Isolation" and Check Off List SO 1A.7.A-2 "Main Steam Lineup After a Group I Isolation." These procedures are performed from the control room.</li> </ul> <p>How does Training address operator actions?</p> <ul style="list-style-type: none"> <li>▪ The actions necessary for responding to a Group I isolation and subsequent recovery of the Main Steam system are covered in licensed operator training.</li> </ul> <p>Are stressful or chaotic conditions during or following an accident expected to be present?</p> <ul style="list-style-type: none"> <li>• As was demonstrated in the event of July 22, 2003, sufficient time existed to stabilize RPV level and pressure control and methodically progress through the associated procedures to reopen the MSIVs without stressful or chaotic conditions</li> </ul> <p>Response: The Peach Bottom Unit 2 July 22, 2003 reactor scram followed by a high area temperature Group I isolation should not be included in the Performance Indicator - "Unplanned Scram with a Loss of Normal Heat Removal." This specific MSIV closure does not meet the definition of "Loss of normal heat removal path" provided in NEI 99-02, Rev. 2, page 15, line 37, in that the main steam system was "easily recovered from the control room without the need for diagnosis or repair. Therefore, it would not be appropriate to include this event in the associated performance indicator – Unplanned Scrams with Loss of Normal Heat Removal.</p>		
36.8	IE02	<p>Question: On August 14, 2003 Ginna Station scrambled due to the wide spread grid disturbance in the Northeast United States.</p>	1/22 Introduced 3/25 Discussed	Ginna

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>Subsequent to the scram, Main Feedwater Isolation occurred as designed on low Tavg coincident with a reactor trip. However, due to voltage swings from the grid disturbance, instrument variations caused the Advanced Digital Feedwater Control System (ADFCS) to transfer to manual control. This transfer overrode the isolation signal causing the Main Feedwater Regulation Valves (MFRVs) to go to, and remain at, the normal or nominal automatic demand position at the time of the transfer, resulting in an unnecessary feedwater addition. The feedwater addition was terminated when the MFRVs closed on the high-high steam generator level (85%) signal. Operators conservatively closed the MSIVs in accordance with the procedure to mitigate a high water level condition in the Steam Generators. Decay heat was subsequently removed using the Atmospheric Relief Valves (ARVs). Should the scram be counted under the PI "Unplanned Scrams with Loss of Normal Heat Removal?"</p> <p>Response:            No. Under clarifying notes, page 16, lines 18 - 22, NEI 99-02 states: "Actions or design features to control the reactor cool down rate or water level, such as closing the main feedwater valves or closing all MSIVs, are not reported in this indicator as long as the normal heat removal path can be readily recovered from the control room without the need for diagnosis or repair. However, operator actions to mitigate an off-normal condition or for the safety of personnel or equipment (e.g., closing MSIVs to isolate a steam leak) are reported." In this case, a feedwater isolation signal had automatically closed the main feed regulating valves, effectively mitigating the high level condition. Manually closing the MSIVs was a conservative procedure driven action, which in this case was not by itself necessary to protect personnel or equipment. The main feed regulating valves were capable of being easily opened from the control room, and the MSIVs were capable of being opened from the control room (after local action to bypass and equalize pressure, see FAQ 303).</p> <p>In addition, the cause of the high steam generator level was due to voltage fluctuations on the offsite power grid which resulted in the operators closing the MSIVs. Clarifying notes for this performance indicator exempt scrams resulting in loss of all main feedwater flow, condenser vacuum, or turbine bypass capability caused by loss of offsite power. In this case, offsite power was not lost. However, the disturbances in grid voltage affected the ADFCS system which started a chain of events which ultimately resulted in the closure of the MSIVs.</p>	6/16 Discussed	
36.9	IE02	<p>Question:            During startup activities following a refueling outage in which new monoblock turbine rotors were installed in the LP turbines, reactor power was approximately 10% of rated thermal power, and the main turbine was being started up. Feedwater was being supplied to the steam generators by the turbine driven main feedwater pumps, and the main condensers were in service. During main turbine startup, the turbine began to experience high bearing vibrations before reaching its normal operating speed of 1800 rpm, and was manually tripped. The bearing vibrations increased as the turbine slowed down following the trip. To protect the main turbine, the alarm response procedure for high-high turbine vibration required the operators to manually SCRAM the reactor, isolate steam to the main condensers by closing the main steam isolation valves and to open the condenser vacuum breaker thereby isolating the normal heat removal path to the main condensers. This caused the turbine driven main feedwater pumps to trip. Following the reactor SCRAM, the operators manually started the auxiliary feedwater pumps to supply feedwater to the steam generators.</p> <p>Based on industry operating experience, operators expected main turbine vibrations during this initial startup. Nuclear Engineering provided Operations with recommendations on how to deal with the expected turbine vibration issues that included actions up to and including breaking condenser vacuum. Operations prepared the crews for this turbine startup with several primary actions. First, training on the new rotors, including industry operating experience and technical actions being taken to minimize the possibility of turbine rubs was conducted in the pre-outage Licensed Operator Requalification Training. Second, the Alarm Response Procedures (A-34 and B-34) for turbine vibrations were modified to include procedures to rapidly slow the main turbine to protect it from damage. Under the worst</p>	1/22 Introduced 3/25 Discussed. Question to be rewritten and response provided 4/22 Question and response provided 6/16 Discussed 7/22 Discussed 8/18 Discussed	Millstone 2

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>turbine vibration conditions, the procedure required operators to trip the reactor, close MSIVs and break main condenser vacuum. Third, operating crews were provided training in the form of a PowerPoint presentation for required reading which included a description of the turbine modifications, a discussion of the revised Alarm Response Procedures and industry operating experience.</p> <p>Does this SCRAM count against the performance indicator for scrams with loss of normal heat removal?</p> <p>Response: No, this scram does not count against the performance indicator for scrams with loss of normal heat removal. The conditions that resulted in the closure of the MSIVs after the reactor trip were expected for the main turbine startup following rotor replacement. Operator actions for this situation had been incorporated into normal plant procedures.</p>		
37.3	ORI	<p>Question: The definition of the Occupational Exposure Control Effectiveness performance indicator refers to "measures that provide assurance that inadvertent entry into the technical specification high radiation areas by unauthorized personnel will be prevented" (page 98, NEI 99-02, Revision 2). In the context of applying the performance indicator definition in evaluating physical barriers to control access to technical specification high radiation areas, what is meant by "inadvertent entry"?</p> <p>Response: In reference to application of the performance indicator definition in evaluating physical barriers, the term "inadvertent entry" means that the physical barrier can not be easily circumvented (i.e., an individual who incorrectly assumes, for whatever reason, that he or she is authorized to enter the area, is unlikely to disregard, and circumvent, the barrier). The barriers used to control access to technical specification high radiation areas should provide reasonable assurance that they secure the area against unauthorized access.</p>	<p>3/25 Introduced 4/22 Directed to HP counterparts for review 5/27 To be revised by HP counterparts 7/22 Revised 8/18 Tentative Approval 9/16 Final</p>	NRC
37.5	ORI	<p>Question: A worker entered a Technical Specification High Radiation Area (&gt; 1R/hr) with all requirements of the job (training, briefings, dosimetry, ALARA Plan and RWP requirements, electronic dosimetry, etc.). The worker did not perform the RWP process auto-sign-in on the RWP, which would have electronically checked the worker's 700 mrem administrative RWP buffer. Not performing this auto-sign-in process did not violate the primary means of controlling access and did not invalidate the RWP for the job. The RWP stated that 700 mrem dose availability was required prior to entry. This administrative dose buffer is an additional defense-in-depth, licensee-initiated control to protect against exceeding the licensee's system of dose control and is not utilized to control dose. The worker's actual dose did not exceed the electronic dosimeter set point and the minimum administrative control guideline. The dose availability of the worker is defined as the difference between the site-specific administrative control level of 2000 mrem (significantly below Federal Limits) and the worker's current accumulated dose for the year.</p> <p>An ALARA Plan and RWP controlled the work activity. The individual used teledosimetry with predetermined alarm setpoints for the job, which transmitted dose and dose rate information during the entry. Video surveillance was utilized by radiation protection technicians and in compliance with 10CFR20.1601(b) during the entry into the &gt;1R/hr area. Specific authorization was given by the remote monitoring station technician to enter into the area. The worker had the training and respiratory protection qualifications required by the RWP, multiple TLDs had been issued, the required RWP was obtained and signed, and briefings were attended. The RWP entry was accomplished within predetermined stay-time limitations, as discussed in the worker briefing. The electronic entry time was entered after the worker had exited the area. There was no over exposure or unintended dose for this worker. The work was completed within the maximum projected dose for the activity. Technical Specification requirements for control of entry into the high radiation area were met and worker dose was controlled since the worker was authorized and had obtained the RWP for the job.</p>	<p>3/25 Introduced 4/22 Being revised by licensee 5/27 Revised To be reviewed by HP counterparts 8/18 Tentative Approval 9/16 Final</p>	TMI

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>The primary means of control of occupational dose exposure include pre-determined stay-time limitations and alarming dosimetry set below expected job levels. The administrative control level is an additional exposure control mechanism. The licensee's administrative control level is conservatively established at 2 rem, or 40% of the Federal dose limit, to provide a substantial margin to prevent personnel from exceeding the Federal dose limit of 5 rem and to help ensure equitable distribution of dose among workers with similar jobs. The individual's annual dose was well below 2 rem and the administrative control level had not been raised above 2 rem prior to the worker obtaining a TLD. If needed, additional and higher levels of managerial review and authorization are required for higher dose control levels. Increasing levels of management review and approvals are required to exceed the administrative control level of 2000 mrem (i.e., to 3000 mrem requires written approval by the Radiation Protection Manager and the work group supervisor, to 4000 mrem requires written approval by the Radiation Protection Manager, work group supervisor, and Plant Manager, to 5000 mrem requires written approval by the Site Vice President). The administrative dose buffer is in addition to the Technical Specification requirements for an RWP and therefore not material to the Technical Specification requirements for control of occupational dose.</p> <p>As it is stated in NEI 99-02, "this PI does not include nonconformance with licensee-initiated controls that are beyond what is required by technical specifications and the comparable provisions in 10CFR Part 20." The check of dose availability is a licensee-initiated administrative control that is beyond what is required by technical specifications, comparable provisions in 10CFR20, or Regulatory Guide 8.38. Does failure of the worker to meet the internal administrative control guideline for dose available as specified by the RWP for the job activity count as a PI occurrence?</p> <p>Response: Yes this event would be a reportable PI occurrence. The above clearly describes a nonconformance with an RWP procedural requirement that resulted in a loss of control of access to the Tech. Spec. High Radiation Area. Had the RWP procedure been adhered to, this individual would not have been allowed to enter without further approval.</p>		
37.6	BI02	<p>Question: River Bend Station (RBS) seeks clarification of BI-02 information contained in NEI 99-02 guidance, specifically page 80, lines 36 and 37 <i>"Only calculations of RCS leakage that are computed in accordance with the calculational methodology requirements of the Technical Specifications are counted in this indicator."</i></p> <p>NEI 99-02, Revision 2 states that the purpose for the Reactor Coolant System (RCS) Leakage Indicator is to monitor the integrity of the reactor coolant system pressure boundary. To do this, the indicator uses the identified leakage as a percentage of the technical specification allowable identified leakage. Moreover, the definition provided is "the maximum RCS identified leakage in gallons per minute each month per technical specifications and expressed as a percentage of the technical specification limit."</p> <p>The RBS Technical Specification (TS) states "Verify RCS unidentified LEAKAGE, total LEAKAGE, and unidentified LEAKAGE increase are within limits (12 hour frequency)." RBS accomplishes this surveillance requirement using an approved station procedure that requires the leakage values from the 0100 and 1300 calculation be used as the leakage "of record" for the purpose of satisfying the TS surveillance requirement. These two data points are then used in the population of data subject to selection for performance indicator calculation each quarter (highest monthly value is used).</p> <p>The RBS approved TS method for determining RCS leakage uses programmable controller generated points for total RCS leakage. The RBS' programmable controller calculates the average total leakage for the previous 24 hours and</p>	<p>3/25 Introduced 4/22 Discussed 5/27 Discussed 8/18 Tentative Approval 9/16 Final</p>	River Bend

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>prints a report giving the leakage rate into each sump it monitors, showing the last four calculations to indicate a trend and printing the total unidentified LEAKAGE, total identified LEAKAGE, their sum, and the 24 hour average. The programmable controller will print this report any time an alarm value is exceeded. The printout can be ordered manually or can be automatic on a 1 or 8 hour basis. While the equipment is capable of generating leakage values at any frequency, the equipment generates hourly values that are summarized in a daily report.</p> <p>The RBS' TS Bases states "In conjunction with alarms and other administrative controls, a 12 hour Frequency for this Surveillance is appropriate for identifying changes in LEAKAGE and for tracking required trends."</p> <p>The Licensee provides that NEI 99-02 requires only the calculations performed to accomplish the approved TS surveillance using the station procedure be counted in the RCS leakage indicator. In this case, the surveillance procedure captures and records the 0100 and 1300 RCS leakage values to satisfy the TS surveillance requirements. The NRC Resident has taken the position that <u>all</u> hourly values from the daily report should be used for the RCS leakage performance indicator determination, even though they are not required by the station surveillance procedure. The Resident maintains that all hourly values use the same method as the 0100 and 1300 values and should be included in the leakage determination.</p> <p>Is the Licensee interpretation of NEI 99-02 correct?</p> <p>Response: Appendix D All calculations of RCS leakage that are computed in accordance with the calculational methodology requirements of the Technical Specifications are counted in this indicator. Since the River Bend Station leakage calculation is an average of the previous 24 hourly leakage rates which are calculated in accordance with the technical specification methodology, it is acceptable for River Bend Station to include only those calculations that are performed to meet the technical specifications surveillance requirement when determining the highest monthly values for reporting. The ROP Working Group is forming a task force to review this performance indicator based on industry practices.</p>		
37.9	EP02	<p>Question: NEI 99-02 Rev 2 ERO Participation PI defines the numerator and denominator of the calculation as based on Key ERO Members. The key position list (on page 89 and 90) was originally created from NUREG 0696 key functions that involved actions associated with the risk significant planning standards (classification, notification, PARs, and assessment), with the addition of the Key OSC Operations Manager included from a mitigation perspective.</p> <p>When a single individual is assigned in more than one 'key position' that individual must be counted for each key position (page 91 lines 4-7 of NEI 99-02).</p> <p>Guidance is not provided in the case where more than one key position is performed by a single member of the ERO in a single drill/exercise. For example, the communicator is defined in NEI 99-02 as the key position that fills out the notification form, seeks approval and usually communicates the information to off site agencies (these duties may vary from site to site based on site procedures).</p> <p>Assigning a single member to multiple Key Positions and then only counting the performance for one Key Position could mask the ability or proficiency of the remaining Key Positions. The concern is that an ERO member having multiple Key Positions may never have a performance enhancing experience for all of them, yet credit for participation will be given when any one of the multiple Key Positions is performed.</p> <p>When the communicator key position is performed by an ERO member who is also assigned another key position (e.g.,</p>	<p>4/22 Introduced 5/27 Discussed. To be revised to reflect discussion. 7/22 EP peer experts to review this issue 8/18 To be discussed at 9/1 EP public meeting 9/16 Tentative Approval</p>	generic

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>the Shift Manager (Emergency Director)), should participation be counted for two key positions or for one key position?</p> <p>Response: Participation by a single member of the ERO performing multiple key positions should be counted for each key position performed. For the situation described, two key positions should be counted.</p> <p>ERO participation should be counted for each key position, even when multiple key positions are assigned to the same ERO member. In the case where a utility has assigned two or more key positions to a single ERO member, each key position must be counted in the denominator for each ERO member and credit given in the numerator when the ERO member performs each key position</p> <p>“Assigned” as used in this FAQ applies to those ERO personnel filling key positions listed on the licensee duty roster on the last day of the reporting period (quarter). Note, however, the exception on page 92 line 1-2 of NEI 99-02, that states, “All individuals qualified to fill the Control Room Shift Manager/Emergency Director position that actually might fill the position should be included in this indicator.”</p> <p>This FAQ will become effective 1/1/05 and applies to data submitted for the first quarter 2005 and going forward.</p>		
38.2	MS01, MS04	<p>Question: If the emergency AC power system or the residual heat removal system is not required to be available for service (e.g., the plant is in "no mode" or Technical Specifications do not require the system to be operable), is it appropriate to include this time in the "hours train required" portion of the safety system performance indicator calculation?</p> <p>NEI 99-02, Revision 2, starting on line 25 of page 33, discusses the term "hours train required" as used in safety system unavailability performance indicators. For the emergency AC power system and residual heat removal system, the guidance allows the "hours train required" to be estimated by the number of hours in the reporting period because the emergency generators are normally expected to be available for service during both plant operations and shutdown, and because the residual heat removal system is required to be available for decay heat removal at all times. The response to FAQ 183 states: "During periods and conditions where Technical Specifications allow both shutdown cooling trains to be removed from service the shutdown cooling system is, in effect, not required and required hours and unavailable hours would not be counted."</p> <p>Response: Being revised</p>	5/27 Introduced 7/22 Discussed 8/18 Discussed 9/16 Discussed	
38.3	MS01	<p>Appendix D FAQ: Mitigating Systems – Safety System Unavailability, Emergency AC Power</p> <p>During a monthly surveillance test of Emergency Diesel Generator 3 (EDG3), an alarm was received in the control room for an abnormal condition. The jacket water cooling supply to EDG3 had experienced a small leak (i.e., less than 1 gpm) at a coupling connection that resulted in a low level condition and subsequent control room alarm. The Low Jacket Water Pressure Alarm, which annunciates locally and in the control room, indicated low pump suction pressure. This was due to low level in the diesel generator jacket water expansion tank. An Auxiliary Operator (AO) stationed at EDG3 responded to the alarm by opening the manual supply valve to provide makeup water to the expansion tank. EDG3 continued to function normally and the surveillance test was completed satisfactorily. Review of data determined that improper tightening of the coupling was performed after the monthly EDG run on December 8, which led to an unacceptable leak if the EDG was required to run. The coupling was properly repaired and tested, and declared to be available and operable on January 6. The condition existed for approximately 28 days. Although the recovery action was conducted outside of the main control room, it was a simple evolution directed by a procedure step, with a high probability of success. This operator response is similar to the response described in</p>	6/16 Introduced 7/22 Discussed 8/18 Discussed	Brunswick

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>Appendix D FAQ 301. In addition, this operator action would be successful during a postulated loss of offsite power event, except for a 23 hour period when the demineralized water supply level was too low to support gravity feed. The engineering analysis determined that a level of 21' 5" of demineralized water supply level was necessary to support gravity feed to the expansion tank. Another 9" (4,740 gallons) was added to this level to allow for the leak and nominal usage and makeup over the 24 hour mission time. Using this analysis, any time the demineralized water level fell below 22" 2", the EDG was considered to be unavailable. A human reliability analysis calculated the probability of an AO failing to add water to the expansion tank from receipt of the low pressure alarm to be 4.7 E-3. In other words, there would be a greater than 99.5% probability of successful task completion within twenty minutes of receiving the annunciator. Vendor analysis determined that, with the existing leak rate, the EDG would remain undamaged for twenty minutes.</p> <p>The human reliability analysis considered that the low jacket water pressure would be annunciated in the control room, the annunciator procedure provided specific direction for filling the expansion tank, the action is reinforced through operator training, and sufficient time would be available to perform the simple action. In its calculation of the probability of operator recovery, the analysis also considered that another indicator, a low-level expansion tank alarm was out-of-service during this time period. However, although the low expansion tank alarm was out of service, it results in low pump suction pressure which did annunciate.</p> <p>NEI 99-02 Appendix D lists several issues that may be addressed for exceptions to allow credit for operator compensatory actions to mitigate the effects of unavailability of monitored systems.</p> <ol style="list-style-type: none"> <li>1. The capability to recognize the need for compensatory actions – Low pump suction pressure annunciates in the control room.</li> <li>2. The availability of trained personnel to perform the compensatory action – This is an uncomplicated action, but operators are trained on it. An auxiliary operator simply has to open one manual valve as directed by the annunciator procedure.</li> <li>3. The means of communications between the control room and the local operator – Communications can be accomplished either via the plant PA system or a portable radio.</li> <li>4. The availability of compensatory equipment – No compensatory equipment is necessary.</li> <li>5. The availability of a procedure for compensatory actions – There is an annunciator procedure in the diesel generator room that would direct the auxiliary operator to open the manual valve.</li> <li>6. The frequency with which the compensatory actions are performed – This action is performed infrequently, but it was demonstrated to be successful during the surveillance test.</li> <li>7. The probability of successful completion of compensatory actions within the required time – The human reliability analysis determined that there was a 99.5% probability of successful completion of compensatory action within the required time.</li> </ol> <p>In summary, over a 28-day period, jacket water cooling for EDG3 was degraded, but functional for approximately 27 days, and was totally unavailable for 23 hours. This is based on a review of Operator logs, plant trending computer points, and flow calculations. During the 27-day degraded period, a simple manual action directed by procedure and performed by an operator would have been used to ensure that jacket water was available.</p> <p>Should fault exposure hours be reported for the 27 days when the Emergency Diesel Generator 3 jacket water was considered to be degraded but functional?</p>		

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>Response: No. Unavailable hours need not be reported for this situation. The actions are proceduralized, operators are trained on the procedure, no troubleshooting or diagnosis is necessary, there is a control room alarm to alert the operators to the need for action, and the actions have been demonstrated to be able to be accomplished within the necessary time constraints. Therefore, operator recovery actions are considered to be virtually certain of success.</p>		
38.4	EP03	<p>Question: Pilgrim has 112 sirens which are normally scheduled to be tested for performance indicator purposes once each calendar month (e.g., once during the month of September). This was reflected in procedure as a requirement to test all of the sirens "monthly". The person scheduling the testing of the sirens incorrectly interpreted the procedure's "monthly" frequency consistent with other "monthly" tests as allowing a 25% grace period for scheduling flexibility. As a result, 29 of the siren tests normally scheduled to be performed in September were scheduled to be performed during the beginning of October. On October 1 the status of the siren testing was discussed with other members of the plant staff who understood that the intent of the "monthly" requirement was once per calendar month and that no grace period applied. Immediate actions were taken including performing the remaining 29 tests on an accelerated basis (all satisfactory tested by October 3) and entering the item in the corrective action program. All of the 29 sirens passed the testing performed during the first 3 days of October. The testing was not delayed due to the unavailability or suspected unavailability of the sirens. The reason for the late testing of the equipment was purely an administrative error and not siren functionality related. For plants where siren tests are initiated by the utility, if a scheduled test(s) was not performed due to an administrative issue but the untested siren(s) was not out-of-service for maintenance or repair and was believed to be capable of operation if activated, should the missed tests be considered non-opportunities or failures for performance indicator reporting purposes?</p> <p>Response: Regularly scheduled tests missed for reasons other than siren unavailability (e.g., out of service for planned maintenance or repair) should be considered non-opportunities. The failure to perform a regularly scheduled test should be entered in the plant's corrective action program and annotated in the comment field on the quarterly data submittal. The failure to perform regularly scheduled tests may be reviewed as part of the baseline inspection process.</p>	6/16 Introduced 8/18 To be discussed at 9/1 EP public meeting 9/16 Tentative Approval	Pilgrim
38.9	OR01	<p>Question: On March 4, 2004, workers initiated a series of diving activities related to the inspection and repair of the Steam Dryer in the Dryer Separator Pit. On March 5, 2004, a contract diver proceeded to the Unit 1 Reactor Building 117' Elevation in preparation for the next diving evolution on the Steam Dryer. Based on underwater dose gradients from the steam dryer, 5 Electronic Dosimeters (EDs), 10 thermoluminescent dosimeters (TLDs) and a telemetry transmitter were placed on the diver by a Radiation Protection Technician (RPT) to monitor personnel exposure. ED/TLD combinations were placed on the chest, right arm, left arm, right leg, and left leg. TLDs were used to monitor the extremities. Communication between the EDs and the telemetry system was verified after placement on the diver. The RPT conducted the pre-dive radiological briefing and the diver entered the Contaminated Area. Telemetry problems were experienced prior to the diver entering the Dryer Separator Pit. The underwater antenna was changed out and telemetry problems appeared to be corrected. The diver was in the Dryer Separator Pit approximately 40 minutes when additional telemetry problems occurred. The diver was instructed to exit the water and the transmitter replaced. The telemetry problems were corrected and the diver re-entered the Dryer Separator Pit. After entering the water, the left arm ED stopped communicating with the telemetry system. The telemetry computer was rebooted while the diver was in the Dryer Separator Pit, but the left arm ED failed to transmit. The RP Supervisor evaluated the situation and decided to allow the dive to continue since four of the five EDs were transmitting properly. The left arm ED did not transmit for the remainder of the dive. However, it did remain functional and continued to</p>	7/22 Introduced 8/18 Additional information required Referred to HP group	Brunswick

TempNo.	PI	Question/Response	Status	Plant/ Co.																										
		<p>accumulate dose. Upon completion of the work, the diver exited the Dryer Separator Pit and it was discovered that his left arm ED was in alarm. Specific ED results for the diver are given below:</p> <table border="1" data-bbox="573 206 1358 403"> <thead> <tr> <th>ED Location</th> <th>ED Result (mrem)</th> </tr> </thead> <tbody> <tr> <td>Chest</td> <td>147</td> </tr> <tr> <td>Right Arm</td> <td>319</td> </tr> <tr> <td>Left Arm</td> <td>588</td> </tr> <tr> <td>Right Leg</td> <td>30</td> </tr> <tr> <td>Left Leg</td> <td>31</td> </tr> </tbody> </table> <p>Per the RWP, the Administrative Dose Limit for the dive was 500 mrem. The diver's TLDs were processed and the results are given below</p> <table border="1" data-bbox="573 464 1358 695"> <thead> <tr> <th>TLD Location</th> <th>TLD Result (mrem)</th> </tr> </thead> <tbody> <tr> <td>Chest</td> <td>135</td> </tr> <tr> <td>Right Arm</td> <td>403</td> </tr> <tr> <td>Left Arm</td> <td>673</td> </tr> <tr> <td>Right Leg</td> <td>30</td> </tr> <tr> <td>Left Leg</td> <td>34</td> </tr> <tr> <td>Head</td> <td>216</td> </tr> </tbody> </table> <p>Does the situation described above constitute an unintended exposure occurrence in the Occupational Radiation Safety Cornerstone as described in NEI 99-02?</p> <p>Response: NEI 99-02 identifies the dose value used as a screening criterion to identify an unintended exposure occurrence as 100 mrem. The administrative dose guideline was established in the RWP as 500 mrem. Since the ED was functional and read 588 mrem, the screening criterion in 99-02 was not exceeded.</p>	ED Location	ED Result (mrem)	Chest	147	Right Arm	319	Left Arm	588	Right Leg	30	Left Leg	31	TLD Location	TLD Result (mrem)	Chest	135	Right Arm	403	Left Arm	673	Right Leg	30	Left Leg	34	Head	216		
ED Location	ED Result (mrem)																													
Chest	147																													
Right Arm	319																													
Left Arm	588																													
Right Leg	30																													
Left Leg	31																													
TLD Location	TLD Result (mrem)																													
Chest	135																													
Right Arm	403																													
Left Arm	673																													
Right Leg	30																													
Left Leg	34																													
Head	216																													
39.1	IE03	<p>Question: On June 23, 2004, condenser waterbox level and temperature readings on the Unit 1 and 2 main condensers indicated partial blockage of the waterbox intake debris filters. The cause was an influx of gracilaria, which is a marine grass found in the river water that is the circulating water intake supply to the plant. Subsequent backwashes of the debris filters were successful at restoring waterbox level and temperature readings to the normal band, except for the 2B-South waterbox, which is one of four waterboxes of the Unit 2 main condenser. An extended backwash was unsuccessful in restoring its readings back to normal.</p> <p>Debris is removed prior to entering the circulating water intake bay by traveling screens with spray nozzles. The 2B-South debris filter is directly downstream from the 2D traveling screen. Investigation of this event found that the spray nozzles for the 2D traveling screen had more fouling than the other spray nozzles. The 2D traveling screen was able to adequately remove normal debris loading, but was not as effective as the other spray nozzles in removing the debris during the large influx of gracilaria.</p> <p>A decision was made on June 24, 2004 to reduce power to about 53% and isolate the 2B-South waterbox to clean its debris filter. The decision to reduce power within 24 hours was based on several factors, such as reduced condenser efficiency, the potential for additional debris filter clogging, and a reduction in reactor water chemistry due to elevated condensate demineralizer resin temperatures. It was also based on input from work management, operations, and the load dispatcher. The 2B-South waterbox was successfully cleaned during the downpower and reactor power was restored to normal operating conditions.</p> <p><u>This was an anticipated power change in response to expected conditions.</u> Operating experience has shown that the plant is susceptible to large influxes of gracilaria when the salinity level in the river water is elevated. For example,</p>	8/18 Introduced 9/16 On hold for more information	Brunswick																										

TempNo.	PI	Question/Response	Status	Plant/ Co.
		<p>gracilaria problems were correlated with high salinity levels in 2002, which led to high vulnerability conditions. In addition, during another influx of gracilaria, a downpower was required in August, 2001 to clean the 1A-South debris filter. In response to experience over the past 5 years with gracilaria and other intake canal debris, modifications are being implemented at the river water intake diversion structure, which is the first barrier for intake debris, to improve the debris removal capability.</p> <p>In response to the influx of gracilaria, the plant implemented compensatory actions for a "High Vulnerability" condition in the intake canal. These actions include manning the diversion structure round-the-clock for manual debris removal, increasing screen wash pressure, and staging fire hoses at the traveling screens, if needed, to assist in removing debris. During the June 23 event, all four waterboxes on Unit 1 and three of four waterboxes on Unit 2 were managed within normal operating levels.</p> <p><u>The power change was proceduralized.</u> The plant operating procedure for circulating water directs a power reduction to isolate a waterbox and clean the debris filter if an abnormally high differential pressure exists after debris filter flushing has been completed.</p> <p><u>The influx of gracilaria was not predictable greater than 72 hours in advance.</u> Although the biology staff has found that high salinity levels in the river water make the conditions for a gracilaria release favorable, it is not possible to predict when an excessive influx will occur. The compensatory actions taken for a high vulnerability condition have usually been effective in preventing debris filter clogging.</p> <p>Should this event be counted as an unplanned power change?</p> <p>Response: No, the event should not be counted as an unplanned power change. The increased accumulation of gracilaria in the river water was anticipated due to operating experience with high salinity levels in the river water, but the timing of the gracilaria release into the intake canal could not be predicted with certainty. In addition, the response to the condenser level and temperature conditions is proceduralized.</p>		
39.2	EP03	<p>Question: If a licensee makes a change in ANS testing methodology, when can that change be used in the ANS PI calculation?</p> <p>Response: The change in test methodology shall be reported as part of the ANS Reliability Performance Indicator effective the start of the next quarterly reporting period.</p> <p>A licensee may change ANS test methodology at any time consistent with regulatory guidance. For the purposes of the Performance Indicator, only the testing methodology in effect on the first day of the quarter shall be used for that reporting period. Neither successes nor failures beyond the testing methodology at the beginning of the quarter will be counted in the PI.</p> <p>NEI 99-02 requires that the periodic tests be used in developing the Performance Indicator. Pg 94, lines 12-13, states that: "Periodic tests are the regularly scheduled tests..." Therefore, a reporting period (quarter) starts with a sequence of regularly scheduled tests for that quarter. If a licensee determines that testing methodology should be changed, the plan/procedure directing the periodic tests should be revised and screened in accordance with the licensee's change. If the change in ANS test methodology is considered to be a significant change per FEMA requirements, the change is required to have FEMA approval prior to implementation.</p>	8/18 Introduced. To be discussed at 9/1 EP public meeting 9/16 Tentative Approval	NRC

TempNo.	PI	Question/Response	Status	Plant/ Co.
40.1	EP03	<p><u>Question:</u>            Catawba Nuclear Station has 89 sirens in their 10-mile EPZ; 68 of these are located in York County. Duke Power's siren testing program includes a full cycle test for performance indicator purposes once each calendar quarter. On Tuesday, September 7, 2004, York County sounded the sirens in their county's portion of the EPZ to alert the public of the need to take protective actions for a Tornado Warning. Catawba is uncertain whether to include the results of the actual activation in their ANS PI statistics. The definition in NEI 99-02 does not address actual siren activations. In contrast, the Drill/Exercise Performance (DEP) Indicator requires that actual events be included in the PI. Should the performance during the actual siren activation be included in the Alert and Notification System (ANS) Performance Indicator Data?</p> <p><u>Response:</u>            Yes. Performance during actual siren activations should be included in the PI data. The purpose of the ANS Performance Indicator is to monitor the reliability of the offsite Alert and Notification System (ANS), a critical link for alerting and notifying the public of the need to take protective actions. In this case, the system was performing its intended function of alerting the public of the need to take protective actions. While actual activations are included in the performance indicator data, the NRC may choose to inspect system response to actual events.</p>	10/13 Introduced	Catawba
40.2	MS02	<p><u>Question:</u>            As discussed in NEI 99-02 (Revision 2), licensees reduce the likelihood of reactor accidents by maintaining the availability and reliability of mitigating systems – systems that mitigate the effects of initiating events to prevent core damage. The Harris Nuclear Plant (HNP) is actively pursuing measures to reduce mitigating system unavailability, such as those discussed below pertaining to High Head Safety Injection (HHSI) unavailability.            At the Harris plant, the Essential Services Chilled Water (ESCW) system is a support system (room cooling) for the HHSI system. The HHSI system consists of three centrifugal, high-head pumps, each housed in its own room. HNP Engineering recently analyzed the effect of a loss of ESCW on HHSI availability by performing a room heatup calculation. This analysis showed that a train of HHSI can be maintained available even without the normal room cooling support system (ESCW) for a period greater than the PRA model success criteria (24 hours) through the use of a substitute cooling source powered by a non class 1E electric power source as allowed for in NEI 99-02, Page 37, Lines 27-35.            It is important to note that: 1) a HHSI train utilizing the substitute cooling source will be considered Inoperable, 2) only one HHSI train at a time will utilize a substitute cooling source, and 3) the length of time that HHSI is required following a design basis accident is not specified in the FSAR.            Since HHSI will remain available throughout the 24 hour period specified in the PRA model success criteria with a substitute cooling source, the Harris plant considers it available when calculating the NRC's Safety System Unavailability performance indicator.            HNP and the resident inspector are not in agreement with respect to how to interpret the definition of unavailability (Page 23, Line 29). Specifically, in this instance, can a safety system train be considered available if it successfully meets its PRA model success criteria or must it satisfy its design basis requirements (long term cooling) to be considered available?</p> <p><u>Response:</u>            A safety system train may be considered available if it successfully meets its PRA model success criteria. Since HHSI will remain available throughout the 24 hour period specified in the PRA model success criteria with a substitute cooling source, it can be considered available when calculating the NRC's Safety System Unavailability performance indicator.</p>	10/13 Introduced	Harris

TempNo.	PI	Question/Response	Status	Plant/ Co.
40.3	MS04	<p><u>Question:</u></p> <p><u>The Safety System Unavailability Performance Indicator for BWR Residual Heat Removal (RHR) Systems monitors:</u></p> <ul style="list-style-type: none"> <li>• <u>the ability of the RHR system to remove heat from the suppression pool so that pool temperatures do not exceed plant design limits, and,</u></li> <li>• <u>the ability of the RHR system to remove decay heat from the reactor core during a normal unit shutdown (e.g., for refueling or servicing).</u></li> </ul> <p><u>Perry Technical Specifications require an alternate means of decay heat removal (DHR) to be available when removing an RHR system from service. Technical Specifications do not restrict the options for an alternate decay heat removal system to specific systems or methods. The Bases of Technical Specifications for LCO 3.4.10, RHR Shutdown Cooling System - Shutdown, Required Action A.1 state, "The required cooling capacity of the alternate method should be ensured by verifying (by calculation or demonstration) its capability to maintain or reduce temperature. Alternate methods that can be used include (but are not limited to) the Reactor Water Cleanup System." During the repair of Emergency Service Water (ESW) Pump B, an Off-Normal Instruction with an attachment for "RPV Feed And Bleed With ESW Not Available" was credited as an alternate decay heat removal method for the inoperable RHR system. The referenced procedure takes reactor water from the RHR system shutdown cooling flowpath and directs it to the main generator condenser which acts as the heat sink. The condensate and feedwater systems return the cooled water to the reactor. Reactor temperature is limited to 150°F for this alternate DHR method. The heat removal capability of this method was demonstrated by calculation before being credited. Does the Perry reactor feed and bleed methodology described above constitute an "NRC approved alternate method of decay heat removal" as referenced in NEI 99-02 above?</u></p> <p><u>Response:</u></p> <p><u>NEI 99-02, "Systems Required to be in Service at All Times" states, "For RHR systems, when the reactor is shutdown with fuel in the vessel, those systems or portions of systems that provide shutdown cooling can be removed from service without incurring planned or unplanned unavailable hours under the following conditions:</u></p> <ul style="list-style-type: none"> <li>• <u>RHR trains may be removed from service provided an <i>NRC approved alternate method</i> of decay heat removal is verified to be available for each RHR train removed from service. The intent is that at all times there will be two methods of decay heat removal available, at least one of which is a forced means of heat removal". (<i>Emphasis added.</i>)</u></li> </ul> <p><u>The response to FAQ ID-145 for PI MS04 Residual Heat Removal System Unavailability (Posted 04/01/2000) parenthetically defines an NRC approved method as "an alternate method allowed by Technical Specifications." Since the Bases of Technical Specification only require that the system be capable of maintaining or reducing temperature and since they do not limit the options to the Reactor Water Cleanup System, the feed and bleed methodology is acceptable as an alternate method of decay heat removal. Thus, the reactor feed and bleed alternate decay heat removal method described above is an NRC approved alternate method.</u></p>	10/13 Introduced	Perry

**FAQ 38.3**

NRC Response:

For this case, fault exposure hours should be reported. The main body of NEI 99-02 (Revision 2, page 31, line 8), describes when operator actions can be credited to recover from equipment malfunctions in the monitored system. Operator actions to recover from the failure of the monitored system, in this case, do not meet these requirements since the actions can not be promptly accomplished from the control room.

Appendix D of NEI 99-02, recognizes that unique circumstances may exist that warrant an exception to the guidance as written. A previous exception has been granted to another plant to allow compensatory actions to mitigate the effects of unavailability of a monitored system. However, unlike the previous exception, the compensatory actions taken in this case were not preplanned and specifically identified as compensatory actions, and were not NRC approved prior to crediting them to mitigate the effects of the monitored system unavailability.

## SCRAMS WITH LOSS OF NORMAL HEAT REMOVAL TASK GROUP

### Meeting Summary

Date: October 5, 2004

Time: 8:45 a.m. to 12:30 p.m.

Location: Region IV conference room

Attendees: Charles Bottemiller, Grand Gulf  
Russell Bywater, NRC  
Donald Hickman, NRC  
Thomas Houghton, NEI  
William Mookhoek, STP  
James Trapp, NRC

Discussion: The discussion began with the need for a performance indicator (PI) to monitor more complicated scrams. Some attendees expressed the view that such a PI is not necessary but, if required, it should be more risk-informed. The group then continued along this line by proposing to count events that include more risk-significant conditions. Proposed events included losses of off-site power and safety injection actuations. Some members proposed that losses of the power conversion system (PCS) be counted only if they were non-recoverable, that is, there had been a failure in the PCS that prevented it from removing heat from the core. Additional events to be counted in the PI were proposed, including the use of high-pressure core spray (or high-pressure coolant injection) to maintain level, and a single train of safety equipment out of service for other than scheduled maintenance or test. The suggestion was made that a good way to clearly define such a PI might be through the use of a flow chart. The action items described below were then assigned.

Action items: 1. Each participant to develop a list of events that should be counted in the PI.  
2. Each participant to develop a flow chart to identify the events that count.  
3. Each participant to also develop a proposed written definition of the PI.

Due dates: October 26 - all provide their proposed list of events, flow chart and written definition of the PI to the other members of the group.

November 15, 1:00 p.m. in One White Flint North - second meeting

**REACTOR OVRSIGHT PROCESS  
WORKING GROUP ACTION LIST – Status October 2, 2004**

The following is the current listing of action items:

<b>OPEN Action Items</b>	<b>Description</b>	<b>Due Date</b>
04-05	<p><b>Safety System Functional Failure (MS05) Reconciliation Project</b>  <u>Task:</u> NRC provided the docket number and corresponding Licensee Event Reports (LER) for which the NRC's contractor assessed the LER as being a Safety System Functional Failure (SSFF: MS05). Industry is reviewing this data against ROP reported data and will provide an analysis of differences.  <u>Status:</u> <i>Initial review of all contractor LER-evaluations complete; results provided to individual licensees for reconciliation/additional-information. Licensee feedback being evaluated. Industry results presented at September 16 meeting. Draft report undergoing review.</i></p>	11/18/04
04-09	<p><b>Maintenance Rule Workshop</b>  <u>Task:</u> NRC is considering holding a workshop on the new Maintenance Rule SDP. Doug Coe will go over the issues raised by industry, and determine whether a meeting is appropriate. Decision whether a workshop would be appropriate will be made in several months.  <u>Status:</u> <i>Open- Doug Coe to determine if workshop is necessary.</i></p>	OPEN
04-13	<p><b>Fire Protection SDP Review</b>  <u>Task:</u> NRC Review process for fire protection SDPs has no apparent feedback (to licensees) provided from the NRC panel meetings.  <u>Status:</u> <i>Review process on the Fire Protection SDP panel and determine (and report back) how will have feedback provided from the panel meetings.</i></p>	OPEN
04-16	<p><b>NEI 99-02 Revision 3</b>  <u>Task:</u> NEI (Tom Houghton) to provide a consolidated "for comment draft" (for further review/comment) by the November meeting. The overall goal will be to develop a final Rev3 by December 2004.  <u>Status:</u> NRC comments received; work proceeding on incorporation of FAQs and Appendix E on FAQ process</p>	12/31/04
04-18	<p><b>Licensee Identified versus Self-Revealing Events</b>  <u>Task:</u> NRC to evaluate the MC 0612 criteria on "self identified" versus "self-revealing"</p>	09/30/04
04-19	<p><b>Resolution of old IE02 FAQs</b>  <u>Task:</u> Discussed the eight FAQs which involve SCRAMS with loss of normal heat removal. Industry proposed in the April meeting that NRC consider dropping these FAQs since (1) they involve specific conflicting guidance in NEI 99-02; (2) NRC has already assessed each scram, sometimes with a special inspection. NRC agreed to review the NEI data and determine next steps.  <u>Status:</u> <i>NRC to consider NEI proposal to delete these FAQs</i></p>	Open
04-21	<p><b>MSPI Lessons Learned Evaluation</b>  <u>Task:</u> Industry has requested NRC support a joint "lessons learned" team to examine the MSPI Pilot Program for lessons learned – to improve future management and administration of future PI Pilot Programs and development of future indicators.  <u>Status:</u> Under consideration</p>	Open

<u>OPEN</u> <u>Action Items</u>	<u>Description</u>	<u>Due Date</u>
------------------------------------	--------------------	-----------------

04-22	<b>SECURITY IN THE ROP</b> <u>Task:</u> NSIR will be asked to come to present information on the status of including Security issues in security (Action Matrix, Pls, etc.) and the status of the Security SDP.	Open
04-23	<b>ISFSI</b> <u>Task:</u> Industry inquired as to the status of ISFSI facilities within the ROP inspection program.	Open
04-24	<b>SSU – Examples of Problems with Applying 15-minute Exemption on Unreliability</b> <u>Task:</u> Jim Anderson committed to come back to the October meeting with a specific list of “problems” in applying the 15-minute exemptions.	10/04
04-25	<b>SSU – Examples of Problems with Applying No mode</b> <u>Task:</u> Jim Anderson committed to come back to the October meeting with a specific list of “problem plants” in applying the no mode FAQ.	10/04

<b>CLOSED</b> <b>Action Items</b>	<b>Description</b>	<b>Due Date</b>
04-01	<b>RCS Leakage PI (B02)</b> <b>Task:</b> INDUSTRY/NRC to establish task force to explore feasibility of new replacement metric. Closed. <b>Status:</b> August 19 meeting formed a subgroup.	Closed
04-02	<b>Steam Generator SDP</b> <b>Task:</b> INDUSTRY– Provide examples of “minor” steam generator issues/results/findings by the March meeting  <b>Status:</b> Examples provided and NRC to include appropriate examples in MC 0612 Appendix E.	Closed
04-03	<b>Maintenance Rule SDP</b> <b>Task:</b> Provide written comments on the Maintenance Rule SDP by the March meeting. <b>Status:</b> Example/comments provided and NRC to include in final SDP.	Closed
04-04	<b>SDP Lessons Learned</b> <b>Task:</b> NRC and Industry brought SDP timeliness examples to the meeting. Industry to evaluate these examples for inclusion as case studies in an SDP workshop devoted to improving SDP timeliness. Industry to review schedule to support a summer workshop.  <b>Status:</b> Workshop targeted for for mid-July. NRC to confirm dates and NEI to send out letter to APCs announcing workshop. Rescheduled for September.	Closed
04-06	<b>Graded Reset of Action Matrix Inspection Findings</b> <b>Task:</b> NRC to provide the resolution (answer) to the graded reset question raised by Industry by the March meeting and in FRN comments on the ROP. <b>Status:</b> NRC provided response. While closed, Industry intends to continue to pursue via other channels.	Closed
04-07	<b>NRC Comments on Generic Changes in NEI 99-02 (Revision 3)</b> <b>Task:</b> NRC to provide a listing of sections within NEI 99-02 Rev 2 that contain ambiguous or unclear guidance that the NRC has identified as needing modification when drafting Rev 3 by March meeting. This is to be subsumed within 04-16 when NRC comments received.  <b>Status:</b> NRC provided comments to NEI for consideration. The approved FAQs, and a new Appendix E FAQ process.	Closed
04-08	<b>Industry Trends Report</b> <b>Task:</b> NRC will provide the Industry Trends Report when available. <b>Status:</b> Received	Closed
04-10	<b>Ginna FAQ</b> <b>Task:</b> Licensee to review their previous FAQ and determine if their closing of the MSIVs (early on in the post trip recovery) is still applicable, or if their process has changed and the FAQ is no longer appropriate to apply [Licensee responded that the process has not changed – Open for discussion in May meeting].  <b>Status:</b> Licensee has provided input To be discussed at June ROP meeting	Closed
04-11	<b>Revised FAQ Process</b> <b>Task:</b> Provided NRC with current draft of FAQ process. <b>Status:</b> NEI is incorporating comments into Appendix E of NEI 99-02	Closed

<b>CLOSED</b> <b>Action Items</b>	<b>Description</b>	<b>Due Date</b>
04-01	<b>RCS Leakage PI (B02)</b> <u>Task:</u> INDUSTRY/NRC to establish task force to explore feasibility of new replacement metric. Closed. <u>Status:</u> August 19 meeting formed a subgroup.	Closed
04-12	<b>Replacement Metric for SCRAMS wlonhr (IE02)</b> <u>Task:</u> NRC and Industry to develop a proposed replacement indicator for existing IE02 metric. <u>Status:</u> . August 19 meeting formed a subgroup.	Closed
04-14	<b>NRC FAQ Feedback Process</b> <u>Task:</u> NRC to examine their internal feedback form process and how it should be included in the FAQ process. <u>Status:</u> NRC has agreed to initiate FAQs for all NRC feedback forms related to NEI 99-02 interpretation issues. This item will be folded into Action 04-11 upon completion of draft FAQ process.	Closed
04-15	<b>Mitigating Systems PIs – No Mode</b> <u>Task:</u> NRC to prepare an FAQ on how to account for “No Mode” hours in MS04 PI. <u>Status:</u> This would be a going forward FAQ.	Closed
04-17	<u>Mitigating Systems Performance Index</u> <u>Task:</u> NRC Commission has directed the NRC staff to work together with industry to resolve the issues associated with the MSPI. <u>Status:</u> NRC to provide a letter to NEI confirming intention of proceeding with MSPI with targeted implementation date of 1/1/06	Closed
04-20	<u>Maintenance Rule and MSPI</u> <u>Task:</u> a white paper from NEI/Industry explaining why it is acceptable to change NUMARC 93-01 to stop monitoring unavailability when subcritical. NRC contact: Steve Alexander  <u>Status:</u> NEI provided white paper	Closed