03-1 NRC Exam (as submitted 6/30/04)

Questions 1-75 make up the RO portion of the exam. Questions 76-100 make up the SRO portion of the exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5874

Points: 1.00

Given the following conditions:

1

•Unit 2 is operating at 55% power.

While <u>single notching</u> a control rod from notch position 18 to 20, the RMCS timer PLC freezes with the "rod out" logic made up.

Annunciator 902-5 D-3, TIMER MALFUNCTION ROD SELECT BLOCK, would be expected upon timer failure ______ after directional control valves are energized.

- A. immediately
- B. 2 3 seconds
- C. 5 6 seconds
- D. 8 9 seconds

Answer: B

Question 1 Details

Question Type:	Multiple Choice
System ID:	5874
User ID:	03-1 NRC-5874
Status:	Active
Must Appear:	No
Difficulty:	3.00
Time to Complete:	2
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE201LN002.06
	Reference: LP DRE201LN002 and DAN 902-5 D-3
	K/A: 201002 A3.04 2.8 / 2.8
	Level: Recall
	Explanation: As described in the LP. Once the RMCS
	timer begins its sequence, all "normal" rod blocks are
	essentially bypassed. The logic assumes the timer will
	complete its sequence. The 115 (rod out) contacts are
	monitored by the 130 relay. If they remain closed for
	more than 2 seconds (and a continuous withdraw signal
	is not present) the 130 relay will energize. The 130 relay
	de-energizes the rod out bus causing rod motion to stop
	and annunciator 902-5 D-3 to alarm.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: Modified from Dresden Bank (123296)

ID: 03-1 NRC-5820

Points: 1.00

The following conditions exist on Unit 3:

- •Reactor pressure is 360 psig and steady.
- •The CRD pumps have tripped and cannot be started.
- •The accumulators nitrogen side pressures range from 550 to 600 psig.

A scram has been inserted by the Unit 3 NSO.

What will be the response of the control rods?

The controls rods will..

2

- A. insert FASTER than when at 1000 psig reactor pressure.
- B. insert SLOWER than when at 1000 psig reactor pressure.
- C. insert at the same rate as when at 1000 psig reactor pressure.
- D. NOT insert.

Answer: D

Question 2 Details

Question Type:	Multiple Choice
Topic:	2 DILTS.201LN003.12 CRD: Rx pressure only scram
System ID:	5820
User ID:	03-1 NRC-5820
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective:201LN003.12
	Reference: LP DRE 201LN003
	K/A: 201003 K6.02 3.0/ 3.0
	Level: Recall
	Explanation: per LP, during a reactor pressure only scram, the drive cannot be scrammed below 400 psig. The pressure in the accumulators will be of no use to the
	CRD since they are already discharged with the piston

03-1 NRC Exam (as submitted 6/30/04)

all of the way at the top. (Rx pressure is given as 360 psig) Pedigree: New for ILT 03-1 NRC exam.

ID: 03-1 NRC-5822Points: 1.00Following the Control Rod Sequence Package, rod H-4 is the next rod to be moved. Rod H-4 is at position 48.

Which of the following would an Operator expect to see on the Rod Worth Minimizer screen when rod H-4 is selected for movement?

- A. "++" in white inverse video.
- B. "++" in green inverse video.
- C. "48" in white inverse video.
- D. "48" in green inverse video.

Answer: B

Question 3 Details

Question Type: Topic:	Multiple Choice 3 DILTS.201LN006.11 RWM: Indications of a selected rod at 48
System ID:	5822
User ID:	03-1 NRC-5822
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE201LN006.11
	Reference: DOP 0400-02 Rod Worth Minimizer
	K/A: 201006 A4.06 3.2 / 3.2 4.0 / 4.0
	Level: High
	Explanation: Per the procedure, "The control rods in the
	current latched step are green", "Rods at position 48 will
	show two (++) symbols", and "The selected rod will be shown in inverse video".
	Pedigree: new for 03-1 NRC exam.

3

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5802

Points: 1.00

Given the following conditions:

4

At time =0, Unit 2 is at full power.
At time +10 seconds, Drywell pressure increased to +2.1 psig.
At time +12 seconds, annunciator "4 KV Bus 23-1 OVERCURRENT" alarms.

•At time +15 seconds, 345kv BT 2-3 CB and 345kv BT 3-4 CB opened.

What is the expected status of LPCI pumps 2A and 2D at time +30 seconds?

	A	D
Α.	Running	Running
В.	Stopped	Stopped
C.	Running	Stopped
D.	Stopped	Running

Answer: D

^

Question 4 Details

Question Type: **Multiple Choice** 4 DILTS.203LN001.12 LPCI: ECCS Pumps available Topic: with LOOP & Loss of 23-1 System ID: 5802 User ID: 03-1 NRC-5802 Status: Active Must Appear: No Difficulty: 0.00 Time to Complete: 0 Point Value: 1.00 Cross Reference: User Text: User Number 1: 0.00 User Number 2: 0.00 Comment: Objective: 203LN001-12 Reference: LP DRE203LN001 K/A: 203000 K2.01 3.5/3.5 Level: High After a loss of offsite power with a LOCA signal all pumps will attempt to start. The loss of Bus 23-1, due to the overcurrent condition, prevents 2A and 2B from starting. 2C and 2D are powered from 24-1 approximately 8 seconds after bus 24-1 goes undervoltage and the EDG picks up the bus.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: Dresden Bank

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5862

Points: 1.00

The following conditions exist:

5

•Unit 2 was operating at 912 MWe for 412 days.

•Unit 2 has been shutdown for 48 hours.

•2A SDC is lined up for cooling.

•2B SDC is lined up for mixing.

•2C SDC is out of service for heat exchanger tube plugging.

- •SDC is taking a suction on the A Recirc Loop and discharging into the B Recirc Loop.
- •B Recirc Loop temperature is currently 320°F.

Which of the following describes the effect on Reactor pressure if the B Recirc Loop temperature sensor fails high?

Reactor pressure will (1) because (2).

- A. increase, **ONLY** 2A SDC has tripped.
- B. increase, the SDC system has isolated.
- C. remain the same, **ONLY** 2B SDC has tripped.
- D. remain the same, the SDC system is unaffected.

Answer: B

Question 5 Details

Question Type:	Multiple Choice
Topic:	5 DILTS.205LN001.12 SDC: Recirc loop temp sensor
	failing high effect on SDC and Rx pressure
System ID:	5862
User ID:	03-1 NRC-5862
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE205LN001.12
	Reference: DOA 1000-01
	K/A: 205000 K3.01 3.3 / 3.3
	Level: High
	Explanation: All SDC is lost in this event due to the recirc
	loop temp sensor exceeding 350°F. The SDC system

03-1 NRC Exam (as submitted 6/30/04)

will isolate when EITHER recirc loop exceeds the setpoint. Due to the short time after shutdown and the loss of SDC, reactor water temp will go up and since the vessel is a saturated system at this point, reactor vessel pressure will in turn go up.

Pedigree: New for 03-1 NRC Exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5803

Points: 1.00

Given the following plant conditions exist on Unit 3:

- •A LOCA has occurred and HPCI has initiated.
- •The HPCI system was aligned for injection.
- •Drywell pressure is 6.5 psig and rising 0.25 psig per minute.
- •Reactor water level reached +47".

6

- •Reactor water level is currently +40" and dropping one inch per minute.
- •The SRO has directed you to maintain RPV water level +8" to +48" using the HPCI system.

What must be done to the HPCI system in order to maintain the specified water level?

- A. Depress the HPCI AUTO INITIATE pushbutton and control level with the HPCI FLOW CONTROLLER.
- B. Depress the TURB TRIP RESET pushbutton and control level with the HPCI FLOW CONTROLLER.
- C. Nothing, HPCI will automatically re-initiate to maintain RPV water level within the specified band.
- D. Nothing, HPCI is already maintaining RPV water level within the specified band.

Answer: B

Question 6 Details

Question Type:	Multiple Choice
Topic:	6 DILTS.206LN001.06 HPCI: High RPV/L turb trip - How
	to reset to maintain RPV/L
System ID:	5803
User ID:	03-1 NRC-5803
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE206LN001.06
	Reference: LP DRE206LN001 and DAN 902-3 A-9
	K/A: 206000 K4.03 4.2/4.1
	Level: High - Analysis & Application
	Explanation: The HPCI turbine trip will reset itself at
	-59" following a high level trip and will trip again on a
	high level. In order to maintain the specified water level

03-1 NRC Exam (as submitted 6/30/04)

+8 to +48, the Operator will have to depress the TURB TRIP RESET pushbutton and manually control HPCI turbine speed to control the injection flowrate. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5901

Points: 1.00

With Unit-2 at 100% power, the following sequence of events occur:

•A small steam leak causes HPCI area temperature to peak at 240°F and has now stabilized at 160° F.

•Subsequently, a loss of feedwater causes RPV water level to drop to -85 inches.

HPCI Injection valve (2-2301-8) will ...

7

- A. NOT open automatically until the high temperature condition clears; then HPCI will auto initiate.
- B. NOT open automatically until HPCI is manually initiated in accordance with DOA 2300-02, HPCI Fast Startup.
- C. NOT open automatically until the isolation signal is reset in accordance with DAN 902-3 C-7, HPCI AUTO ISOL INITIATED.
- D. open automatically and level can be controlled in accordance with DOP 2300-03, High Pressure Coolant Injection System Manual Startup and Operation.

Answer: C

Question 7 Details

Question Type: Topic:	Multiple Choice 7 DILTS.206LN001.12 HPCI: High Area Temperature Isolation Seal-In
System ID:	5901
User ID:	03-1 NRC-5901
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE206LN001.06
	Reference: LP Fig 20600-01, DAN 902(3)-3 C-7 K/A: 206000 A2.11 4.1 / 4.2
	Level: High
	Explanation: The HPCI high area temperature isolation signal is SEAL-IN. The RESET pushbutton must be depressed before the 4 and 5 valves will re-open. The HPCI area high temperature is 173°F so the signal is clear. The signal automatically resets, the valve closure

03-1 NRC Exam (as submitted 6/30/04)

interlock does NOT. Manually initiating HPCI will not work, the 4 and 5 valves are still interlocked closed. Injection valve will NOT automatically open until discharge pressure is above the minimum for injection. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5888

Points: 1.00

While performing panel walkdowns with the Unit at rated power, the NSO noticed that the 2-1301-17, Iso Cond Vent VIv, was closed.

What is the concern with this valve being closed for an extended period of time?

Upon Isolation Condenser initiation...

8

- A. a water hammer event will occur due to partially drained condensate return lines.
- B. steam flow will be reduced due to non-condensed steam having nowhere to vent.
- C. air and non-condensible gases will have built up in the shell side reducing the heat removal capacity.
- D. air and non-condensible gases will be forced into the tube side reducing the heat removal capacity.

Answer: D

Question 8 Details

Question Type: Topic:	Multiple Choice 8 DILTS.207LN001.12 Iso Cond: Implication of vent valve shut during stby ops
System ID:	5888
User ID:	03-1 NRC-5888
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 207LN001.12
	Reference: DRE LP207LN001
	K/A: 207000 K5.10 3.0 / 3.2
	Level: Recall
	Explanation: The lesson plan states: "The Steamline Vent Valves provide a path to vent non-condensable
	gases to the "A" main steamline. The driving force for
	flow is the pressure drop across the Main Steam line flow
	restrictors and the MSIVs" and "If non-condensable
	gases were allowed to accumulate in the isolation
	condenser steam lines, they would be forced into the
	tube bundles upon initiation of the system. This would

03-1 NRC Exam (as submitted 6/30/04)

limit or prevent steam condensation and hence natural circulation. As a result, Isolation Condenser heat removal rate would be reduced". Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5827

Points: 1.00

A loss of off-site power has occurred with the following events on Unit 2:

The U2/3 Diesel Generator jacket water temperature is 205°F and going up 1°F every 5 minutes.
NO Operator actions have been taken yet.
All equipment responded as expected.

At this time, which Core Spray pumps are available?

- A. BOTH Core Spray pumps are available.
- B. 2A Core Spray ONLY.
- C. 2B Core Spray ONLY.
- D. NEITHER Core Spray pump is available.

Answer: A

Question 9 Details

Question Type: Topic:	Multiple Choice 9 DILTS.209LN001.03 CS: Power Supplies - Analyze Transient/Givens - Determine Pumps Available
System ID:	5827
User ID:	03-1 NRC-5827
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE203LN001.03 and DRE209LN001.03 Reference: LP DRE209LN001, 264LN001, DWG 262LN001-02, DAN 902-8 A-7 and DAN DG2A B-4 K/A: 209001 K6.02 3.8 / 3.9
	Explanation: Since the 2/3 EDG received an autostart signal from the undervoltage on the 4kv-1 buses due to
	the station blackout, the high engine temperature trip has
	been bypassed therefor the 2/3 EDG is still loaded onto
	bus 23-1. Both CS pumps are available.
	Pedigree: New for 03-1 NRC exam.

9

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5804

Points: 1.00

Besides the FLOW light, which of the following would also be indications of Standby Liquid Control Injection flow into the reactor?

- 1. SBLC SQUIB A and SQUIB B continuity lights lit.
- 2. SBLC PUMP 1 AND PUMP 2 lights lit.
- 3. SBLC Pump Discharge Pressure slightly ABOVE Reactor Pressure.
- 4. Annunciator 902-5 H-6, SBLC SQUIB VLV CKT FAILURE is clear.
 - A. BOTH 1 AND 2
 - B. BOTH 1 AND 3
 - C. BOTH 2 AND 3
 - D. BOTH 2 AND 4

Answer: C

Question 10 Details

Question Type: Topic:	Multiple Choice 10 DILTS.211LN001.11 SBLC True indications of flow to reactor
Svstem ID:	5804
User ID:	03-1 NRC-5804
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference: User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE211LN001.11
	Reference: LP DRE211LN001
	K/A: 211000 A1.04 3.8/3.9
	Level: High - Analysis & Application
	Explanation: A and B not correct - if squib valve continuity lights are still lit, no path exists to the reactor for SBLC flow. D not correct - if both pump lights lit and annunciator 902-5 H-6 is clear, the squib valves have NOT fired. C is correct - the pump discharge pressure slightly above reactor pressure and both pumps running would be the best indication that there is flow to the reactor vessel.
	Pedigree: New for 03-1 NRC exam.

10

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5805

Points: 1.00

While at power, the actual water level in the Unit 2 West Scram Instrument Volume (SIV) exceeds the high level setpoint resulting in the following annunciator, 902-5 A-14, CHANNEL A/B INST VOL LVL HI.

In addition to alarms, which of the following will result, AND what action(s) by the Unit NSO will be necessary to mitigate the consequences of the condition?

- A. Only a ROD OUT BLOCK; manually open all Scram Instrument Volume vent and drain valves per DAN 902-5 C-1, SCRAM INST VOL HI LVL ROD BLOCK.
- B. Only a half scram; manually open the WEST side Scram Instrument Volume vent and drain valves and reset the half scram per DOP 500-7, INSERTION/RESET OF MANUAL HALF SCRAM.
- C. A full reactor scram; press scram buttons, place the mode switch to SHUTDOWN, per DGP-2-3, REACTOR SCRAM.
- D. The SDV vent and drain valves open automatically; re-close the valves when the high level condition clears per DAN 902-5 D-1, WEST SCRAM INST VOL NOT DRAINED.

Answer: C

Question 11 Details

Question Type: Topic:	Multiple Choice 11 DILTS.212LN001.10 Scram Inst Vol High level - result
System ID:	5805
User ID:	03-1 NRC-5805
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE212LN001.10 Reference: LP DRE212LN001 p. 16 and DAN 902-5 A- 14, CHANNEL A/B INST VOL LVL HI K/A: 212000 A2.12 3.9/4.0 Level: Recall Explanation: DAN 902-5 A-14, a full reactor scram will occur when this alarm comes in. Pedigree: Modified from 1996 Nine Mile Point question:

11

03-1 NRC Exam (as submitted 6/30/04)

While at power, the actual water level in ONE Scram Discharge Volume (SDV) exceeds the high-high level setpoint (49 inches). In addition to alarms, which of the following will result?

A full reactor scram.

Only a half reactor scram.

The SDV vent and drain valves open

Only a control rod block

03-1 NRC Exam (as submitted 6/30/04)

12

ID: 03-1 NRC-5825

Points: 1.00

Unit 3 has just been declared critical. ALL Full In position indications for rod J-8 have been lost.

Which of the following Tech Spec LCOs is applicable for the above situation?

- A. 3.9.3, Control Rod Position AND 3.9.4, Control Rod Position Indication.
- B. 3.9.3, Control Rod Position ONLY.
- C. 3.1.3, Control Rod Operability AND 3.9.4, Control Rod Position Indication.
- D. 3.1.3, Control Rod Operability ONLY.

Answer: D

Question 12 Details

Question Type: Topic:	Multiple Choice 12 DILTS.201LN002.08 RPIS: Loss of position indication
	for 1 rod, which LCO is applicable
System ID:	5825
User ID:	03-1 NRC-5825
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 201LN002.08
	Reference: TS 3.1.3
	K/A: 214000 2.1.33 3.4 / 4.0
	Level: High
	Explanation: The examinee must know that Tech Spec
	3.9.3 and 3.9.4 are for Mode 5 only and do not apply
	since the stem stated the reactor was in Mode 2 (just
	critical) Tech Spec 313 SP 3131 requires
	determining the position of each control rod every 24 hrs
	This cannot be done with the conditions given. Tech
	Spec LCO not being mot for 313 Control Pod
	Operability
	Operability.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5875 Points: 1.00

Unit 3 is at 270 MWe with a power ascension in progress.

•APRM 3 is reading 31.5%.

13

•APRM 4 is reading 29.5%.

•3 LPRM inputs to RBM 7 are operable for rod J-6.

•4 LPRM inputs to RBM 8 are operable for rod J-6.

•A Limiting Control Rod Pattern exists.

Predict the effects that will occur when the Operator selects rod J-6 and the actions required for those effects.

A Rod Out Block will occur due to (1). Refer to appropriate procedures and (2).

	1	2
A.	too few inputs on RBM 7	bypass RBM 7 and continue rod withdrawal
В.	too few inputs on RBM 7	do NOT bypass RBM 7 and halt rod withdrawal
C.	low APRM reference signal on RBM 8	bypass RBM 8 and continue rod withdrawal
D.	low APRM reference signal on RBM 8	do NOT bypass RBM 8 and stop rod withdrawal

Answer: B

Question 13 Details

Question Type: Topic:	Multiple Choice 13 DILTS.215LN002.10 RBM: Results of <50% inputs and actions.
System ID:	5875
User ID:	03-1 NRC-5875
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE215LN002.10
	Reference: DAN 902-5 A-7, C-3, and A-7, DOA 700-03

03-1 NRC Exam (as submitted 6/30/04)

K/A: 215002 A2.05 3.2 / 3.3 Level: High

Explanation: <50% inputs to the RBM will cause a RBM HI/INOP alarm and also cause a ROD OUT BLOCK. The DAN says to stop control rod withdrawals until the block clears. DOA 700-03 directs the operators to contact the Instrument Maintenance department for assistance. It does NOT give guidance to bypass the reference APRM based on too few inputs. The RBM downscale alarm is generated from RBM 7.10% or Reference APRM 28%. Neither condition exists.

Pedigree: New for 03-1 NRC Exam

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5823

Points: 1.00

Given the following conditions:

•The mode switch is in RUN

14

•IRM 14 and 18 have failed up-scale and are bypassed.

•APRM Channel 5 has failed downscale and is bypassed.

•APRM Channel 3 is downscale.

Which of the following would subsequently cause a half scram?

- A. Bypassing APRM Channel 3.
- B. Taking APRM Channel 5 out of bypass.
- C. Taking IRM 14 out of bypass.
- D. Taking IRM 18 out of bypass.

Answer: C

Question 14 Details

Question Type: Topic:	Multiple Choice 14 DILTS.215LN003.06 IRM: Moving IRM 14 out of bypass with APRM 3 downscale
System ID:	5823
User ID:	03-1 NRC-5823
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE215LN003.06
	Reference: DOP 0700-02, LP DRE215LN003, and
	DRE215LN005
	K/A: 215003 A1.03 3.7 / 3.7
	Level: High - Comprehension & Application
	Explanation: APRM 3 is the companion APRM to IRM
	"14". With IRM "14" failed up-scale and taken out of
	bypass, and it's companion APRM downscale a half-
	scram will be generated. One APRM failed downscale
	per channel will NOT cause a half scram nor will a single
	IRM failed up-scale with the Mode Switch in RUN.
	Bypassing APRM 3 will clear the APRM Ch 3 DWNSCL

03-1 NRC Exam (as submitted 6/30/04)

OR INOP light. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

15

ID: 03-1 NRC-5896

Points: 1.00

Unit 3 is in a startup with power increase in progress.

IRMs indicate 30 on range 6.

Positioning IRM CH 11 RANGE SWITCH from range 6 to 7 will automatically change the scale on IRM-APRM recorder, RR 2-750-10A to (1) and the recorder will now read (2).

	1	2
Α.	0 - 40	3.0
В.	0 - 40	30
C.	0 - 125	3.0
D.	0 - 125	30

Answer: A

Question 15 Details

Question Type: Topic:	Multiple Choice 15 DILTS.215LN003.11 IRM: Changes to IRM recorder scale and IRM reading change from 6 to 7
System ID:	5896
User ID:	03-1 NRC-5896
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 215LN003.11
	Reference: DRE LP215LN003
	K/A: 215003 A3.01 3.3 / 3.3
	Level: High
	Explanation: Odd number ranges have a scale of 0-40,
	even ranges have a scale of 0 -125. Ranges 5 and 6 are
	paired and would both read 30. Ranges 6 and 7 vary by
	a factor of 10, so ranging the IRM up would change the
	indication on the recorder top 3.0.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5890

Points: 1.00

Currently SRM 22 and 23 are being trended on recorder RR 2-750-2, Source Range Monitor Level.

To trend SRM 21 on the recorder, the Operator would...

- A. move the toggle switch above the recorder to position "21".
- B. place the SRM recorder channel selector switch below the recorder to "21".
- C. depress the SRM 21 "Channel Select" pushbutton on the horizontal portion of the 902-5 panel.
- D. press the MENU button on the recorder until SRM 21 was displayed and then press ENTER to trend.

Answer: B

Question 16 Details

21
ər
1
in
le
er
v
'n

16

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5806

Points: 1.00

Which one of the following design features is utilized to offset the effects of LPRM detector aging?

- A. The LPRM flux amplifier gain can be increased.
- B. The LPRM detector chamber is filled with a high pressure argon gas.
- C. The LPRM ion chamber high voltage power supply can be decreased.
- D. The LPRM detector chamber is coated with enriched U-235.

Answer: A

17

Question 17 Details

Question Type: Topic:

System ID: User ID: Status: Must Appear: Difficulty: Time to Complete: Point Value: Cross Reference: User Text: User Number 1: User Number 2: Comment: **Multiple Choice** 17 DILTS.215LN006.03 Effects of detector aging on **APRM** readings 5806 03-1 NRC-5806 Active No 0.00 0 1.00 0.00 0.00 Objective: DRE215LN006.03 Reference: LP DRE215LN006 p. 8 K/A: 215005 K4.06 2.6/2.8 Level: Recall Explanation: per the lesson plan. Pedigree: Perry 2002 Exam question.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5824

Points: 1.00

Unit 2 is operating at 912 MWe.

18

APRM 5 is currently bypassed due to maintenance.

Which of the following conditions will result in the LCO requirements for Tech Spec 3.3.1.1, Reactor Protection System (RPS) Instrumentation NOT being met?

- A. 3 of 6 LPRMs are currently bypassed which input into the "A" core level of APRM 4.
 Another LPRM input to the "A" core level of APRM 4 fails and cannot be restored.
- B. 4 of 6 LPRMs are currently bypassed which input into the "A" core level of APRM 3.
 Another LPRM input to the "A" core level of APRM 3 fails and cannot be restored.
- C. 9 LPRMs are currently bypassed which input into APRM 3. Two additional LPRM inputs to APRM 3 fails and cannot be restored.
- D. 9 LPRMs are currently bypassed which input into APRM 4. Two additional LPRM inputs to APRM 4 fails and cannot be restored.

Answer: D

Question 18 Details

Question Type: Topic:	Multiple Choice 18 DILTS.215LN005.08 APRM: 1 bypassed and 9 LPRM inputs to another bypassed
System ID:	5824
User ID:	03-1 NRC-5824
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 215LN005.08
	Reference: DOP 700-08 and TS 3.3.1.1
	K/A: 215005 2.1.33 3.4 / 4.0
	Level: High
	Explanation: Per TS 3.3.1.1 in mode 1, 2 of the 3 APRM
	channels per trip system need to be available to meet
	the LCO. With 9 inputs to APRM channel 4 bypassed, it
	is no longer operable. With APRM channel 5 bypassed
	there are not enough APRM channels available to meet
	the LCO. Per DOP 0/00-08 at least 2 LPRMs per core

03-1 NRC Exam (as submitted 6/30/04)

level must be available. Since APRM 3 and 5 are in different channels, <2 operable in APRM 3 still meets the requirements of the LCO. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5807

Points: 1.00

The Reactor is operating at 70% power when a LOCA condition develops in the Drywell.

The following is a timeline of ADS associated events:

- 17:15:00, Division I, 2 psig High Drywell Pressure
- 17:15:30, Division II, -59" Low Low Reactor Water Level
- 17:15:35, Division I, -59" Low Low Reactor Water Level
- 17:16:00, Division I, ECCS >100 psig Discharge Permissive

Without operator action, at what time will ADS initiate?

A. 17:17:00

19

- B. 17:17:30
- C. 17:17:35
- D. 17:18:00

Answer: C

Question 19 Details

Question Type: Topic: System ID: User ID:	Multiple Choice 19 DILTS.218LN001.06 ADS: Initiation Logic 5807 03-1 NRC-5807
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE218LN001.06
	Reference: LP DRE218LN001
	K/A: 218000 K1.04 3.9/4.2
	Level: High
	Objective: 218L-S1-05
	Explanation: Unit 2 ADS Initiation Logic requires the following conditions for initiation:
	High Drywell Pressure and Low-Low Level signals in the same division for 120 seconds + any division's ECCS

pump >100# - These conditions are met at 17:17:35

03-1 NRC Exam (as submitted 6/30/04)

17:17:00 is wrong because the 120 second timer doesn't start until both signals are received in the same division. 17:17:30 is wrong because the 120 second timer doesn't start until both signals are received in the same division. 17:18:00 is wrong because the ECCS pump doesn't affect the timer Pedigree: Dresden Bank

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5808

Points: 1.00

Of the four actions listed below, which action would <u>prevent</u> a Unit 2 Div II ADS logic actuation to occur as designed?

- A. Placing ALL Div II ECCS pump control switches in PTL.
- B. Depressing and holding the ADS Timer Reset Pushbutton.
- C. Placing ALL five ADS valve keylock switches to OFF.
- D. Loss of 125 Vdc Dist. Pnl. 2B-1.

Answer: B

Question 20 Details

Question Type:	Multiple Choice
Topic:	20 DILTS.218LN001.11 ADS: Preventing/Inhibiting Initiation/Logic
System ID:	5808
User ID:	03-1 NRC-5808
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 218LN001-11
	Reference: LP DRE218LN001
	K/A: 218000 K5.01 3.8/3.8
	Level: High
	Explanation: Placing all of the Div II ECCS pumps in PTL
	will not prevent an ADS actuation due to the system still
	seeing 100 psig from the Div I pumps. Continually
	holding the ADS Timer Reset Pushbutton DOES prevent
	the ADS function. ADS is an 'energize to actuate' system
	-both initiation relays in one or both divisions must
	energize to cause an ADS blowdown. Losing 2B-1
	removes Normal power to Div II ADS logic circuitry
	however 2A-1 is the backup supply. The OFF position of
	the individual switches for each valve removes the
	RELIEF function, NOT the ADS function. This is a
	commonly confused point.
	Pedigree: Modified from Dresden Bank DILT-252982

20
03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5826

Points: 1.00

The following plant conditions exist:

21

•RPV level is -240" and trending up slowly.
•RPV pressure is 560 psig and trending down slowly.
•Drywell pressure is 10.5 psig and trending up slowly.
•316 in "MANUAL"

The Unit Supervisor then orders initiation of drywell sprays.

Considering only electrical interlocks, under these conditions, the drywell spray valves can be opened with which of the following switch alignments?

Note: "316" is the Containment Spray Permissive Keylock Switch "317" is the 2/3 Core Coverage Override Keylock Switch "318" is the CCSW Pump Start Permissive Keylock

- A. 317 in "MANUAL OVERRIDE"
- B. 318 in "MANUAL OVERRIDE"
- C. 318 in "AUTO" AND 30 second timer timed out
- D. 317 in "AUTO" **AND** Torus pressure greater than 1 psig

Answer: A

Question 21 Details

Question Type:	Multiple Choice
Topic:	21 DILTS.203LN001.06 LPCI: Conditions required to allow Drywell Spray
System ID:	5826
User ID:	03-1 NRC-5826
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 203LN001-06
	Reference: LP DRE203LN001
	K/A: 219000 K4.03 3.8 / 3.8
	Level: High - Comprehension
	Without proper control switch position, water is

03-1 NRC Exam (as submitted 6/30/04)

prevented from being diverted from the vessel. Drywell pressure must be above 1 psig in order to open drywell spray valves with a LPCI initiation signal present - that condition is met in the givens. With an initiation signal present, the 316 must be placed in MANUAL in order to spray the drywell, and with RPV level below 2/3 core height (i.e. less than minus 191), the 317 must ALSO be placed in MANUAL OVERRIDE (correct answer - 316 and 317 operated to Manual & Manual Override respectively). The 318 is only used if it is desired to start CCSW pumps, therefore, distractors including 318 are incorrect. Distractor with 317 in AUTO and Torus Pressure is wrong because 317 must be in Manual and the logic does not monitor Torus pressure. Pedigree: Dresden Bank

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5809

Points: 1.00

Unit 3 HPCI is being run for Post Maintenance Test (PMT). The Unit 3 HPCI steam flow instrument fails high causing a SPURIOUS Group IV isolation.

Which of the following valves are DIRECTLY affected by the Group IV signal?

- A. MO 3-2301-4, STM ISOL VLV, and MO 3-2301-35, TORUS SUCT VLV
- B. MO 3-2301-3, TURB STM SUPPLY, and MO 3-2301-8, PP DISCH VLV
- C. MO 3-2301-3, TURB STM SUPPLY, and MO 3-2301-4, STEAM ISOL VLV
- D. MO 3-2301-8, PP DISCH VLV, and MO 3-2301-9, PP DISCH VLV

Answer: A

Question 22 Details

Question Type:	Multiple Choice
Topic:	22 DOPSS.223LN005.02 PCIS: Group IV Isol Results
System ID:	5809
User ID:	03-1 NRC-5809
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE223LN005.02
	Reference: LP 223LN005 and DAN 902-3 C-7
	K/A: 223002 K1.04 3.5/3.8
	Level: Recall
	Explanation: As described in training material/LP.
	Pedigree: Dresden Bank

22

23			ID: 03-1 NRC-5811 Points: 1.00
	The contents	from the Fuel Poo	I Cooling Demineralizer vessel are transferred directly to the
	A.	Resin Cleaner Slu	idge Tank
	В.	Main Concentrate	d Waste Tank
	C.	Spent Resin Tank	
	D.	Unit 3 Mix and Ho	ld Tank
	Answe	er: C	
	Ques	tion 23 Details	
	Ques Topic Syste User Statu Must Diffic Time Point Cross	tion Type: :: em ID: ID: s: Appear: ulty: to Complete: Value: s Reference: Tout:	Multiple Choice 23 DILTS.233LN001.02 FPC: spent resins destination 5811 03-1 NRC-5811 Active No 0.00 0 1.00
	User User Com	Number 1: Number 2: ment:	0.00 0.00 Objective: 233LN001.01 References: LP DRE233LN001, 268LN001, and DOP 1900-08 K/A: 233000 K1.12 2.5/2.6 Level: Recall per the lesson plan and DOP 1900-08 the exhausted resins may be sent directly to the Spent Resin Tank. The resins may be sent to the mix and hold but must be sent to the catex tank first. The Resin Cleaner Sludge tank is where the SRT gets decanted to. There is no direct path for the FPC resins to get to the main concentrated waste tank. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

24

ID: 03-1 NRC-5893

Points: 1.00

How will a complete loss of nitrogen system pressure in the drywell affect the ability of the ADS valves to depressurize the Reactor Vessel on a valid initiation signal?

Automatic depressurization will...

- A. NOT occur.
- B. occur at approximately 20% design capacity.
- C. occur at approximately 80% design capacity.
- D. occur at design capacity.

Answer: C

Question 24 Details

Question Type:	Multiple Choice
Topic:	24 DILTS.239LN001.03 MS: loss of all N2 pressue in the drywell, effect on ability to ED
System ID:	5893
User ID:	03-1 NRC-5893
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 239LN001.03
	Reference: DRE LP239LN001
	K/A: 239002 K3.03 4.3 / 4.4
	Level: High
	Explanation: A complete loss of nitrogen pressure in the
	drywell will only affect the target rock valve, making it
	inoperable. The remaining 4 electromatic relief valves
	will NOT be affected as they are solenoid actuated.
	Pedigree: New for ILT 03-1 NRC exam.

25		ID:	03-1 NRC-5828	Points: 1.00
	Unit 3 was ope	erating at 912 MWe with	the following conditions:	
	•The Auxiliary •Due to a prot	Power system was in a plem with the Turbine Oi	normal configuration. il system, the Main Turbine tripped.	
	What is the ex	spected status of Bus 35	5 10 seconds after the above transient?	
	Α.	De-energized.		
	В.	Powered from Bus 33		
	C.	Powered from Bus 36		
	D.	Powered from Bus 37		
	Answe Ques	er: B tion 25 Details		
	Ques Topic Syste User Statu Must Diffic Time Point Cross User User Comr	tion Type: :: em ID: ID: ID: s: Appear: ulty: to Complete: Value: s Reference: Text: Number 1: Number 2: ment:	Multiple Choice 25 DILTS.262LN001.12 Aux Pwr: Tripower to Bus 35 5828 03-1 NRC-5828 Active No 0.00 0 1.00 0 0.00 0.	ip of Main Gen, ast transfer to TR erefore Bus 35 will k power from Bus

03-1 NRC Exam (as submitted 6/30/04)

26

ID: 03-1 NRC-5810

Points: 1.00

While operating at 95% power with both main feedwater regulating valves (FWRVs) in service controlling reactor vessel water level, the air line supplying FWRV 2B pulse positioner ruptures (air pressure to the four way solenoid valve in local cabinet goes to zero psig).

Which one of the following statements identifies the response of the 2B FWRV?

- A. The valve fails full open.
- B. The valve will continue to operate normally for up to 30 minutes.
- C. The valve "locks up" in its present position.
- D. The valve transfers to 'Manual Bypass' mode.

Answer: C

Question 26 Details

Question Type: Topic:	Multiple Choice 26 DILTS.25902LN002.06 FWLC: FRV Lock Up on Loss of Air at Pulse Positioner
System ID:	5810
User ID:	03-1 NRC-5810
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 259LN002.06
	References: LP DRE259LN002, DWG 259LN001-001.
	DAN 902-6 E-10
	K/A: K/A 259002 K4.13 3.5/3.6
	Level: High - Application & Analysis
	The valve locks up due to loss of air pressure (< 65 psig), i.e., the pulse positioner will not move and the
	pressure at the actuator will not change - so the valve
	locks up 'as is'. The 30 minute nitrogen backup can't be
	supplied with a line break as describe in the question.
	Since the valve locks up, it will not fail open or closed.
	Auto transfer to 'Manual Bypass' happens on loss of
	communication between M/A station and Bailey OR M/A
	station output failure - neither is true.
	Pedigree: Dresden Bank.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5832

Points: 1.00

The following conditions exist on unit 3:

- •A small steam leak has developed in the Drywell.
- •The operating team has entered DEOP 200-1.
- •As directed by DEOP 200-1, Primary Containment Control, Drywell is being vented through "B" SBGT using DOP 1600-01 NORMAL PRESSURE CONTROL OF THE DRYWELL OR TORUS.
- •"A" SBGT fan control switch is in "A STBY", and "B" SBGT fan control switch is in "START B"
- •Drywell pressure is steady at 1.6 psig.
- •NO Group II OR Secondary Containment isolation signals are present.

What is the effect on Drywell pressure if the "B" SBGT heater's feed breaker trips on overload?

Drywell pressure will...

27

- A. rise due to loss of all vent flow.
- B. rise slightly until "A" SBGT train auto starts.
- C. remain steady but vented gases will be untreated.
- D. rise due to an increased differential pressure across the charcoal.

Answer: A

Question 27 Details

Question Type:	Multiple Choice
Topic:	27 DILTS.261LN001.06 SBGT: Effects on drywell
	pressure when venting and lose power to heater
System ID:	5832
User ID:	03-1 NRC-5832
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 261LN001.06
	Reference: LP261LN001, DOP 1600-01, and DOP 7500-
	01
	K/A: 261000 K3.03 3.2 / 3.4
	Level: High
	Explanation: The heater de-energizing will trip the
	running train. Since it was the STBY train started, per

03-1 NRC Exam (as submitted 6/30/04)

DOP 7500-01 and since there is no auto initiation signal, the Primary train will not start, therfore there will be no flow through the system. Also the inlet and outlet dampers will go closed automatically when the fan trips. Pedigree: New for ILT 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

28

ID: 03-1 NRC-5835

Points: 1.00

125 Vdc Reserve Bus 2B is being fed from its Alternate feed. A loss of 125 Vdc Main Bus 2A-1 occurs.

If Bus 24 voltage drops 5 volts per minute, the BUS 24 TO BUS 24-1 TIE ACB at Bus 24 will ...

- A. open when bus voltage reaches 2930 volts with NO time delay.
- B. open when bus voltage reaches 3870 volts with NO time delay.
- C. open 5 minutes after bus voltage reaches 3870 volts.
- D. NOT open.

Answer: D

Question 28 Details

Question Type:	Multiple Choice
Topic:	28 DOPSS.262LN001.03 Aux Power: 125 Vdc Reserve
	Bus 3B-1 on alt feed, effect on bus 34
System ID:	5835
User ID:	03-1 NRC-5835
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE262LN001.03
	Reference: LP DRE263LN001, 262LN004, DWG -
	263LN002-001, DAN 902-8 E-3 and H-10.
	K/A: 262001 K6.01 3.1 / 3.4
	Level: High
	Explanation: 125 Vdc Reserve Bus 2B's reserve power
	supply is Main Bus 2A-1. The control power supply to
	Bus 24 feed breaker to bus 24-1 is 2B-1. Since 2B-1 has
	been lost due to the loss of power to its' reserve power
	supply, the breaker will not open on any protective
	signal.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5829

Points: 1.00

The Bus 29 feed breaker has opened on a fault.

Which of the following indications in the Main Control Room would alert the Operator to this fault?

- A. 902-8 E-8, ESS UPS ON DC OR ALTERNATE AC, annunciator in alarm ONLY.
- B. 902-8 E-10, 120/240V AC ESS BUS ON EMERG SPLY, annunciator in alarm ONLY.
- C. 902-8 E-8, ESS UPS ON DC OR ALTERNATE AC, annunciator in alarm AND a momentary loss of power to the ESS loads.
- D. 902-8 E-10, 120/240V AC ESS BUS ON EMERG SPLY, annunciator in alarm AND a momentary loss of power to the ESS loads.

Answer: A

Question 29 Details

Question Type: Topic:	Multiple Choice 29 DILTS.262LN005.02 Vow Volt AC: ESS UPS feed breaker from 29 opens, indications
System ID:	5829
User ID:	03-1 NRC-5829
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE262LN005.02
	Reference: DAN 902-8 E-8 and LP262LN005
	K/A: 262002 A3.01 2.8 / 3.1
	Level: Recall
	Explanation: DAN 902-8 E-8, ESS UPS ON DC OR ALTERNATE AC, warns the operator that the ESS UPS is no longer being powered from Bus 29. As stated in the lesson plan,the static switch "automatically transfers between its two feeds without missing a cycle, thus making a bumpless transfer." DAN 902-8 E-10, 120/240V AC ESS BUS ON EMERG SPLY, indicates that the ABT has transferred and the ESS Bus is being supplied from MCC 28(38)-2. Pedigree: New for ILT 03-1 NRC Exam

29

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5837

Points: 1.00

Unit 2 is operating with the 125 Vdc batteries on an equalizing charge.

A loss of ventilation to the Unit 2 125 Vdc Battery Room has occured and repairs will take a minimum of 8 hours to complete.

Radiation Protection has reported there is currently NO buildup of hydrogen in the battery room.

According to DOA 5750-01, Ventilation System Failure, what is the danger with the loss of the battery room ventilation AND what actions need to be taken?

	DANGER	ACTIONS
Α.	Buildup of heat and pressure in the battery cells.	Place portable blowers in the battery room to provide temporary ventilation.
В.	Buildup of heat and pressure in the battery cells.	Place the battery on a normal charge.
C.	Buildup of hydrogen in the battery room.	Place portable blowers in the battery room to provide temporary ventilation.
D.	Buildup of hydrogen in the battery room.	Place the battery on a normal charge.

Answer: D

Question 30 Details

Question Type:	Multiple Choice
Topic:	30 DILTS.288LN002.12 DC Systems: Loss of Battery room vent while performing an equalizing charge
System ID:	5837
User ID:	03-1 NRC-5837
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE288LN002.12
	Reference: DOA 5750-01
	K/A: 263000 A2.02 2.6 / 2.9
	Level: High
	Explanation: Per DOA 5750-01 "IF ventilation to a battery

30

03-1 NRC Exam (as submitted 6/30/04)

room will be lost for an extended period of time AND an affected battery is undergoing an Equalizing Battery Charge, Service Test OR Performance Test THEN place the battery on a normal charge." and in the discussion section, "During an Equalizing Battery Charge, Service Test or Performance Test significant amounts of hydrogen are generated. A loss of battery room ventilation during one of these evolutions can result in the build up of a hazardous concentration of hydrogen in the battery room in a short period of time." Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5813

Points: 1.00

The following conditions exist:

31

- •The 2/3 Emergency Diesel Generator Cooling Water Pump Power Source Selector Switch is in the 'U2 AUTO' position.
- •The 2/3 EDG has been started for a surveillance on Unit 3 but has NOT been closed in on Bus 33-1.

The 2/3 Emergency Diesel Generator Cooling Water Pump is currently receiving power from...

- A. MCC 28-3.
- B. MCC 38-3.
- C. MCC 29-2.
- D. MCC 39-2.

Answer: A

Question 31 Details

Question Type: Topic:	Multiple Choice 31 DILTS.264LN004.06 EDG Aux: power supply to 2/3 DGCWP
System ID:	5813
User ID:	03-1 NRC-5813
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE264LN004.06
	Reference: LP DRE 264LN004
	K/A· 264000 A3 06 3 1 / 3 2
	Level: High - Comprehension
	Explanation: Since the 2/3 diesel generator cooling water
	nump was started for a surveillance and has NOT been
	leaded onto the Unit 2 bus 22.1 the DCCWD will not
	loaded onto the onto 5 bus 55-1, the DGCWP will not
	swap power supplies to unit 5. It will remain powered
	Trom unit 2 (MCC 28-3)
	Pedigree: Dresden Bank.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5878

Points: 1.00

The following conditions exist:

•Unit 3 is at 750 MWe.

32

•Unit 3 Hydrogen addition flow rate is 14 scfm.

•Unit 3 Oxygen Injection FCV has reduced oxygen flowrate from 7 scfm to 5.25 scfm.

Which of the following indications would alert the NSO to this situation?

- A. Off Gas flow increasing.
- B. Hydrogen gas concentration decreasing.
- C. Preheater outlet temperature decreasing.
- D. Annunciator 903-65, O2 INJ FLOW LO, in alarm.

Answer: A

Question 32 Details

Multiple Choice 32 DILTS.271LN001.03 Off Gas: O2 FCV going closed 5878 03-1 NRC-5878 Active No 0.00 0
1.00
0.00
0.00
Objective: DRE271LN001.03 Reference: LP DRE271LN001and Dan 903-65 B-4 K/A: 271001 A1.14 2.7 / 2.8 Level: High Explanation: Oxygen injection rate will not effect preheater temperature. Off gas flow will go up due to more free hydrogen exiting the recombiner, this would also increase hydrogen gas concentration. The hydrogen addition system will NOT try and compensate for the lower oxygen flow, it positions according to feedwater flow rate. 903-65 D-3 will not alarm because oxygen flowrate has not dropped to less than 2 scfm below 1/2

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: Modified from 03-1 Cert exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5858

Points: 1.00

Which one of the following describes how the Reactor Building Ventilation System maintains the required 0.25 inches of negative water pressure in the Reactor Building during normal operation of the system?

- A. A d/p controller regulates a recirculation damper position.
- B. At least one (1) more exhaust fan than supply fan is operated.
- C. A variable vane controller positions movable vanes on the operating exhaust fans based on Building D/P.
- D. A variable vane controller positions movable vanes on the operating supply fans based on Building D/P.

Answer: C

Question 33 Details

Question Type:	Multiple Choice
Topic:	33 DILTS.288LN001.03 RBV: Proper dp maintained by
System ID:	5858
User ID:	03-1 NRC-5858
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE288LN001
	Reference: DRE LP 288LN001 and DOP 5750-02
	K/A: 288000 K5.02 3.2 / 3.4
	Level: Recall
	Explanation: The reactor building is maintained at a
	negative pressure by controlling the variable vanes on
	the exhaust fans NOT the supply fans. DOP 5750-02 has
	the operator start 2 supply and 2 exhaust fans for a
	normal system startup. The reactor building ventilation
	system does NOT use a recirc damper, the reactor feed
	pump ventilation system has a recirc damper for
	temperature control.
	Pedigree: Cooper 1999 NRC exam

33

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5876

Points: 1.00

The following conditions exist:

34

•Unit 2 and 3 are operating at 912MWe.

•The NSO reports that Reactor Building differential pressure is at 0 inches of water AND going up.

As a result, during a design basis loss of coolant accident...

- A. the torus could be overpressurized.
- B. an unmonitored release could occur.
- C. reactor water level instrumentation may read lower.
- D. the secondary containment interlock doors may NOT function.

Answer: B

Question 34 Details

Question Type: Topic:	Multiple Choice 34 DILTS.288LN001.10 keeping at a vacuum.	Containment:	Reason f	for
System ID:	5876			
User ID:	03-1 NRC-5876			
Status:	Active			
Must Appear:	No			
Difficulty:	0.00			
Time to Complete:	0			
Point Value:	1.00			
Cross Reference:				
User Text:				
User Number 1:	0.00			
User Number 2:	0.00			
Comment:	Objective: DRE288LN001.	10		
	Reference: DAN 923-5 C	-1, DOA 5750	-01, DRE I	LP
	295LS03			
	K/A: 290001 2.1.32 3.4 /	3.8		
	Level: Recall			
	Explanation: Per the DAM	N, DOA and Le	sson Plan,	, a
	building DP that is not neg	ative will result	in a potent	ial
	unmonitored release, espe	ecially during a	LOCA who	en
	primary containment ma	y be breache	d. If react	tor
	building pressure was hi	gher, the pres	sure on t	he
	outside of the torus would	be higher, lowe	ring DP. Th	nis
	will have a minimal positiv	ve effect on ov	erpressure	of
	torus during a LOCA. Th	e only level in	strument th	nat
	would be affected by a cha	inge in RB press	sure would	be

03-1 NRC Exam (as submitted 6/30/04)

Refueling level indication and it has such a large level band, the change would NOT be noticeable on any level instrument. A 0.25 inch of water difference across the access doors will NOT significantly limit access to the reactor building.

Pedigree: Modified from Duane Arnold 2002 Exam

During movement of a large component on the Refuel floor the component contacted the outside wall and opened a large hole in the wall to atmosphere.

The Reactor Building Supply fans are all OFF.

The Reactor Building to Atmosphere DP has stabilized at 0.1 inches of water with the Reactor Building Exhaust Fans EF 1, 2, and 3 running.

HPs report there are NO abnormal radiation level readings.

Which ONE of the following states the adverse consequences that has/will occur in this situation and what procedure directs the actions for this event?

In the event of a design basis Loss of Coolant Accident (LOCA) an unmonitored release could occur. T.S. directs actions (Shutdown using IPOI 4 "Shutdown" or IPOI 5 "Reactor Scram") if secondary containment operability can not be restored.

The Drywell pressure instrumentation is inoperable. ARP 1C23C A-6 "Main Plant Exhaust Plenum HI Pressure" directs re-calibration of the Drywell pressure instruments.

Refuel Floor integrity has been lost to atmosphere with spent fuel in the Fuel Pool. EOP 4 is entered to prevent Radioactive release to the environment.

The differential pressure across the Reactor Building doors will prevent access to the Secondary Containment. EOP 3 is entered on loss of Secondary Containment access.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5921

Points: 1.00

Unit 3 is at 500 MWe.

35

The 3C ERV pressure controller PC 3-203-3C begins momentarily spiking high every 2 seconds.

For the first ten seconds of this transient, steam dryer differential pressure will...

- A. increase one time and return to normal.
- B. decrease one time and return to normal.
- C. increase every two seconds and return to normal.
- D. decrease every two seconds and return to normal.

Answer: A

Question 35 Details

Question Type:	Multiple Choice
Topic:	35 DILTS.216LN001.12 NBI: Press controller effect on
	stm dryer dp
System ID:	5921
User ID:	03-1 NRC-5921
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE216LN001.12
	Reference: DRE LP 239LN001
	K/A: 290002 K6.08 2.9 / 3.2
	Level: High
	Explanation: When the pressure controller spikes high
	the 3C ERV will open. The opening of the valve will
	initially increase steam flow from the Reactor and raise
	steam dryer dp. The ERV will not cycle on a 2 second
	frequency because the 3C ERV has a ten second time
	delay, once open, before it will open again.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

36

ID: 03-1 NRC-5834

Points: 1.00

According to DOA 4700-01, Instrument Air System Failure, where does the Operator monitor Instrument Air system pressure for the manual scram initiation setpoint?

Panel...

A.	901-2
В.	902(3)-4
C.	923-1
D.	923-5
Answer	C
Questio	on 36 Details
Questic Topic:	on Type:
System User IE Status: Must A Difficul Time to Point V Cross I User T User N User N Comm	n ID:): ppear: ty: o Complete: /alue: Reference: ext: umber 1: umber 1: umber 2: ent:

Multiple Choice 36 DILTS.278LN001.11 IA: Location of header pressure gages used for scram criteria 5834 03-1 NRC-5834 Active No 0.00 0 1.00 0.00 0.00 Objective: DRE278LN001.11 Reference: DOA 4700-01 K/A: 300000 A4.01 2.6 / 2.7 Level: Recall Explanation: DOA 4700-01 states "IF at panel 923-1, U2(3) IA HDR PRESS, drops to 55 psig, THEN manually scram U2(3) reactor (DGP 02-03)." The 923-5 panel is next to the 923-1 panel and contains ventilation system pressures. The 901-2 panel has U1 instrument air header pressure gage. 902(3)-4 panel has pumpback system air receiver pressure. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

37

ID: 03-1 NRC-5836

Points: 1.00

The following conditions exist:

The Switchyards were in a normal lineup with both Unit 2 and 3 on-line. 345 KV LN 1221 developed a fault. 345 KV BT 2-3 CB failed to open. The rest of the electrical system operated as designed.

Which of the following is a result of the above transient?

Loss of power to...

- A. Transformer 21
- B. Transformer 22
- C. 138 KV Bus 2
- D. 138 KV Bus 4

Answer: B

Question 37 Details

Question Type: Topic:	Multiple Choice 37 DILTS 262LN001.12 Aux Pwr: Fault on line in 345 vd.
	1 breaker fails to open
System ID:	5836
User ID:	03-1 NRC-5836
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE262LN001.12
	Reference: LP DRE 262LN001, 262LN003, and DWG
	262LN003-001
	K/A: 262001 K2.01 3.3 / 3.6
	Level: High
	Explanation: If a fault on Line 1221 occurs and CB 2-3
	doesn't open, the next breaker downstream will open to
	try and protect the system. This will cause CB 3-4 to
	open causing the loss of the feed to TR-22, our normal
	supply of offsite power to Bus 22 and 24.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

38

ID: 03-1 NRC-5816

Points: 1.00

Unit 2 is operating at 750 MWe.

Annunciator 923-1 D-1, U2 OR U3 RBCCW PRESS LO, is received. In accordance with DOA 3700-1, "LOSS OF COOLING BY REACTOR BUILDING CLOSED COOLING WATER (RBCCW) SYSTEM", if RBCCW pressure CANNOT be restored within one minute you should secure the:

- A. Drywell Coolers
- B. Fuel Pool Cooling System
- C. Reactor Water Cleanup System
- D. Reactor Recirculation Pumps

Answer: D

Question 38 Details

Question Type: Topic:	Multiple Choice 38 DILTS.208LN001.12 RBCCW: Loss of pressure for > 1 min. trip regire numps
Svstem ID:	5816
User ID:	03-1 NRC-5816
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE208LN001.12
	Reference: LP DRE 208LN001 and DOA 3700-01
	K/A: 400000 2.1.2 3.0 / 4.0
	Level: Recall
	Explanation: Per the DOA and lesson plan, IF RBCCW flow is lost and CANNOT be restored within one minute, THEN perform the following: If the Mode switch is in RUN, THEN manually scram the reactor AND enter DGP 2-3, Reactor Scram and perform concurrently with this procedure. Trip the Recirculation Pumps AND enter DOA 202-01, Recirculation (Recirc) Pump Trip - One or Both Pumps and perform concurrently with this procedure.

Modified from Quad 1996 Exam:

03-1 NRC Exam (as submitted 6/30/04)

Annunciator 912-1 D-1, "REACTOR BLDG COOLING WATER LOW PRESSURE", is received. In accordance with QCOA 3700-1, "RBCCW LOW PRESSURE", within one minute you should shutdown the:

Reactor recirculation pumps.

Drywell Coolers

Fuel Pool Cooling System.

Reactor Water Cleanup System

03-1 NRC Exam (as submitted 6/30/04)

39

ID: 03-1 NRC-5809

Points: 1.00

A malfunction in the EHC system has caused Reactor pressure to increase.

A and C Reactor pressure transmitters from Division 1 sense 1192 psig. B Reactor pressure transmitter from Division 2 senses 1250 psig.

D Reactor pressure transmitter from Division 2 senses 1193 psig.

Which of the following describes the response of the Recic pumps?

- A. Both Recirc Pumps will continue to operate.
- B. Both Recirc pumps will trip immediately.
- C. Only the B Recirc pump will trip immediately.
- D. Both Recirc pumps will trip after a 9 second time delay.

Answer: A

Question 39 Details

Question Type: Topic:	Multiple Choice 39 DILTS.212LN002.06 ATWS: Response to ATWS Initiation from high reactor pressure.
System ID:	5908
User ID:	03-1 NRC-5809
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE212LN002.07
	Reference: 12E6582F, LP DRE212LN002
	K/A: 295001 K2.04 3.3/ 3.3
	Level: Recall
	Explanation: The high reactor pressure setpoint in Division 1 has not been exceeded, so no signal to trip the Recirc pumps has been received. In Division 2, only one transmitter in each channel has been energized so the circuit is not made up to trip the recirc pumps. While a single channel can cause a trip, it takes two transmitters in a channel to trip the recirc pumps. A mod was installed to allow either division to trip both Recirc pumps. The nine second time delay is only applicable to

03-1 NRC Exam (as submitted 6/30/04)

the low low level trip, not the high reactor pressure trip. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5920

Points: 1.00

A loss of ALL AC power has occured on Unit 2 from rated conditions.

Which of the following describes the response of the Isolation Condenser to this event AND the reason for that response?

The Isolation Condenser will initiate...

40

- A. immediately due to de-energization of its initiation logic.
- B. after a short time delay due to the closure of the MSIVs.
- C. immediately due to the closure of the turbine stop valves.
- D. after a short time delay due to the EDGs re-energizing its initiation logic.

Answer: B

Question 40 Details

Question Type: Topic:	Multiple Choice 40 DILTS.207LN001.06 Iso Cond: reason the Iso initiates on Loss of all AC
Svstem ID:	5920
User ID:	03-1 NRC-5920
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE207LN001.06
	Reference: DOP 1300-02, DAN 902(3)-5 F-1, DAN
	902(3)-5 H-4, DAN 902(3)-7 G-5, DRE LP207LN001
	K/A: 295003 AK3.07 3.8 / 4.0
	Level: Recall
	Explanation: Following a loss of all offsite power, the
	MSIVs will close and pressure will rapidly rise in the RPV
	due to the loss of the normal heat sink and after a time
	delay of 15 seconds, the isolation condenser will
	automaticaly initiate. The isolation condenser will not
	initiate on a turbine stop valve closure because there is
	a 15 second time delay on Iso initiation and the MSIVs
	will close in 3-5 seconds, additionally the bypass valves
	will open to control Rx pressure with just turbine stop

03-1 NRC Exam (as submitted 6/30/04)

valve closure. The initiation logic is de-energize to actuate but since it is DC, it will not lose power during this event. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5872

Points: 1.00

The following conditions exist:

41

•Unit 2 and Unit 3 were at 912 MWe.

•Unit 3 experienced a loss of 250 Vdc Turbine Building Bus 3.

•Five minutes later a spurious Unit 2 Group I isolation occurs.

The Unit 2 Isolation Condenser MO 2-1301-3, Rx Inlet Isol valve...

- A. Can be opened by using control switch located in plant.
- B. Will operate as designed upon auto initiation signal.
- C. Will open when swapped to it's alternate power supply.
- D. Can only be opened through local manual operation.

Answer: D

Question 41 Details

Question Type: Topic:	Multiple Choice 41 DILTS.207LN001.12 ISO: How to operate Iso with a loss of 250 VDC Bus 2A
System ID:	5872
User ID:	03-1 NRC-5872
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 207LN001.12
	Reference: DRE207LN001
	K/A: 295004 A1.02 3.8 / 4.1
	Level: Recall
	Explanation: With a loss of U3 250 VDC TB Bus 3, the U2 250 VDC RB Bus 2A and 2B have lost power. U2 RB Bus 2A is the power supply to the U2 Iso 3 vlv so the valve has to be locally opened manually since it has no power. Swapping of power supplies capability and local control switches are provided in the U 2/3 EDG for the Iso 1 and 4 valves. Pedigree: Dresden Bank (276629)

42	ID: 03-1 NRC-5852 Points: 1.0			Points: 1.00
	Unit 3 was at 912 MWe when Annunciator 903-7, TURB TRIPPED MOIST SEP TK LY came in and would not clear for 15 seconds. Which of the following describes the expected status of the Main Turbine Stop V Combined Intermediate Stop Valves?			SEP TK LVL HI-HI, alarm
				ne Stop Valves and The
	Main Turbine Stop Valves Combined Intermediate Stop		Stop Valves	
	Α.	Closed	Open	
	В.	Closed	Closed	
	C.	Open	Open	
	D.	Open	Closed	
	Answer:	В		
	Question	42 Details		
	Question Type: Topic: System ID: User ID: Status: Must Appear: Difficulty: Time to Complete: Point Value: Cross Reference: User Text:		Multiple Choice 42 DILTS.245LN001.04 Main Ge stop and CIVs when conditions of 5852 03-1 NRC-5852 Active No 0.00 0 1.00	en: Positions of Turbine exist
User Number 1: User Number 2: Comment:		0.00 0.00 Objective: DRE245LN001.09 Reference: DAN 902-7 G-4 K/A: 295005 A2.03 3.1 / 3.1 Level: High Explanation: Per the DAN, the MSDT level reaches 24 inches tank with a 10 second time dela causes a generator trip. The sto closed on a turbine trip. Pedigree: New for ILT 03-1 NRC	e turbine will trip when from the bottom of the y. A turbine trip always op valves and CIVs go C Exam	
03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5853

Points: 1.00

Which of the following is NOT a purpose of a reactor scram?

- A. Preserve the integrity of the fuel cladding.
- B. Preserve the integrity of the primary system.
- C. Bring the reactor to a shutdown condition from full power at any time during core life independent of the Control Rod Drive Hydraulic System.
- D. Minimize the energy that must be absorbed, and prevent criticality following a Loss Of Coolant Accident (LOCA).

Answer: C

Question 43 Details

Question Type:	Multiple Choice
Topic:	43 DILTS.212LN001.01 SCRAM: function of a reactor
	scram
Svstem ID:	5853
User ID:	03-1 NRC-5853
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 212LN001.01
	Reference: DRE LP212LN001
	K/A: 295006 2.1.27 2.8 / 2.9
	Level: Recall
	Explanation: Per the lesson plan, a reactor scram is
	designed to: "Preserve the integrity of the fuel cladding.
	Preserve the integrity of the primary system, and
	Minimize the energy that must be absorbed, and prevent
	criticality following a Loss Of Coolant Accident (LOCA)."
	The purpose of SBLC is to "bring the reactor to a
	shutdown condition from full power at any time during
	core life independent of the Control Rod Drive Hydraulic
	System."
	Pedigree: New for 03-1 NRC exam.

43

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5831

Points: 1.00

Given the following information:

•Unit 2 was operating at 700MWe.

•The 2A and 2B RFPs were operating with B RFP being the last RFP started.

•The 2C RFP was selected for standby.

•A transient caused Reactor water level to increase to 54 inches.

•Reactor water level is now 45 inches and lowering at 1 inch per minute.

What will be 2C RFP's response to this transient?

2C RFP will...

44

- A. auto start as soon as level is below the trip setpoint.
- B. remain in STBY until the high level trip seal-in signal is reset and then auto start.
- C. start and immediately trip and will auto start after the high level trip seal in signal is reset.
- D. start and immediately trip and must be manually restarted after level is below the trip setpoint.

Answer: D

Question 44 Details

Question Type:	Multiple Choice
Topic:	44 DOPSS.259LN001.06 FW: Actions to restore RFP
	after high RPV water level
System ID:	5831
User ID:	03-1 NRC-5831
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE259LN001.06
	Reference: DOA 0600-01, DAN 902(3)-6 H-6
	K/A: 259008 AA1.08 3.5/3.5
	Level: High
	Explanation: The RPV water level has exceeded ther trip
	setpoint. As described in training material/LP. Standby

03-1 NRC Exam (as submitted 6/30/04)

pump will receive a start signal when one or both of the running pumps trip - its breaker will auto-close. Due to high level, as soon as the breaker closes, it will receive a auto-trip signal. There is no auto restart on a RFP when the high level condition clears. 2B RFP being the last pump started, only comes into play on selective tripping on low suction pressure, NOT on RFP auto start. Pedigree: New for ILT 03-1 NRC Exam

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5830

Points: 1.00

Unit 2 is at 210 MWe with the following conditions:

•Power ascension in progress.

45

- •FWLC system is maintaining RPV water level at +30 inches.
- •EHC system is maintaining RPV pressure is 980 psig.
- •Annunciator 902-4 D-18, DIV 2 TORUS WTR LOCAL TEMP HI, has alarmed due to 2B ERV opening.

The expected Operator actions would be to first verify the alarm is valid by checking local Torus temperatures on the Torus Temperature Recorder on panel (1) and then placing the 2B ERV control switch in (2).

	1	2
A.	902-4	"MAN"
В.	902-4	"OFF"
C.	902-36	"MAN"
D.	902-36	"OFF"

Answer: D

Question 45 Details

Question Type:	Multiple Choice
Topic:	45 DILTS.223LN001.10 Cont: Torus local temp hi, where
	to verify and actions to take
System ID:	5830
User ID:	03-1 NRC-5830
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE223LN001.10
	Reference: DAN 902-4 D-18
	K/A: 295013 2.4.50 3.3 / 3.3
	Level: Recall
	Explanation: DAN 902(3)-4 D-18, DIV 2 TORUS WTR
	LOCAL TEMP HI, states "Check TIRS 2-1640-200B,
	Torus Water Temperature Recorder, on Panel 902-36 to

03-1 NRC Exam (as submitted 6/30/04)

determine which alarm sensor(s) generated the alarm." and "IF a high temperature condition exists, THEN verify bulk torus water temperature using the following recorders: TIRS 2-1640-200B on Panel 902-36 and TR 2(3)-1641-9 on Panel 902-4." The Temp Recorder TR 2-1641-9 on the 902-4 panel will only give BULK temp, not local temp. For Operator Actions the DAN states "IF a relief valve is open, THEN close the valve." Taking the control switch to MAN will OPEN the valve. Taking the control switch to OFF will CLOSE the valve. Pedigree: New for ILT 03-1 NRC Exam

03-1 NRC Exam (as submitted 6/30/04)

46		ID:	03-1 NR	C-5841 Points: 1.00
	DSSP 0100-C	R, Control Room Evacua	ation, is	in progress.
	Due to damage in the control room wirin OUTLET ISOL VLV, has gone closed.			the 2-1301-1, U2 ISOLATION CONDENSER RX
	How would the	e Unit 2 Aux NSO re-ope	n the 2-	1301-1 valve?
	Proceed to	(1) and open the value	ve at the	e <u>(2)</u> .
		1		2
	Α.	Reactor Building 3rd flo	oor	2202-76, UNIT 2 ISOLATION CONDENSER VALVES CONTROL panel
	В.	Reactor Building 3rd flo	oor	MO 2-1301-1, U2 ISOL COND RX OUTLET ISOL VLV pushbutton control station
	C.	2/3 EDG Room		2202-76, UNIT 2 ISOLATION CONDENSER VALVES CONTROL panel
	D.	2/3 EDG Room		MO 2-1301-1, U2 ISOL COND RX OUTLET ISOL VLV pushbutton control station
	Answe	er: C		
	Ques	tion 46 Details		
	Ques Topic	stion Type: c:	Multiµ 46 D opera	ble Choice ILTS.207LN001.05 Iso Cond: Where to locally ite Iso 4 valve
	Syste User	em ID: ID:	5841 03-1	NRC-5841
	Statu Must	is: Appear:	Activo No	e
	Diffic	culty:	0.00	
	Point	: Value:	1.00	
	User	s Reference: Text:		
	User User	Number 1: Number 2:	0.00 0.00	
	Com	ment:	Objeo Refer	ctive: DRE07LN001.05
			K/A: 2	295016 AK2.02 4.0 / 4.1
			Ever Expla 2202	Ination: Per DOA 5750-01 "Perform the following at 76 UNIT 2 ISOLATION CONDENSER VALVES

03-1 NRC Exam (as submitted 6/30/04)

CONTROL panel (2/3 D/G room top of stairs) to verify U2 Isolation Condenser Valves are open..." The 2-1301-3 valve would be operated from the 3rd floor of the reactor building. Only the 2-1301-10 valve has a MOV local pushbutton control station. Pedigree: New for 03-1 NRC exam.

ILT EXAM

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5817

Points: 1.00

The following conditions exist:

47

- •3A Pumpback compressor is operating normally.
- •2A RBCCW pump is running.
- •2/3 RBCCW pump is lined up to Unit 2 and is being powered by Unit 3 due to maintenance being performed on the Unit 2 breaker that supplies the RBCCW pump.
- •3A and 3B RBCCW pumps are running.

•Bus 33-1 trips on overcurrent.

How does this affect the cooling water supply to the 3A Pumpback compressor?

- A. NO cooling water has been lost.
- B. Limited cooling water is being supplied from 2/3 RBCCW pump.
- C. Limited cooling water is being supplied from 3B RBCCW pump.
- D. ALL cooling water has been lost.

Answer: A

Question 47 Details

Question Type:	Multiple Choice
Topic:	47 DILTS.208LN001.12 RBCCW: Loss of 34-1 on U3
	Pumpback compressor cooling
System ID:	5817
User ID:	03-1 NRC-5817
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE208LN001.12
	Reference: LP DRE 208LN001
	K/A: 295018 AK2.01 3.3 / 3.4
	Level: High
	Explanation: Cooling water for the Unit 3 pumpback
	compressors is supplied from UNIT 2, NOT Unit 3, and
	2/3 RBCCW pump is supplied from 34-1 in this case.
	Therefore NO cooling water is lost.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5814

Points: 1.00

The following conditions exist on Unit 2:

• Operating at 912 MWe.

48

- 2A Instrument Air compressor is running.
- 3C Instrument Air compressor is secured and lined up to Unit 2.
- The Instrument Air system is in a normal lineup and all systems operate as designed.

What is the FIRST automatic response when Instrument Air pressure drops to the actuation setpoint of Annunciator 923-1 F-4, U2 INST AIR PRESS LO **AND** what is the reason for the automatic action?

- A. The Nitrogen Backup Supply Isolation valve will automatically open to keep the MSIVs open.
- B. The 3C Instrument Air Compressor will automatically start in an attempt to restore Instrument Air pressure.
- C. The Service Air to Instrument Air crosstie valve will automatically open in an attempt to restore Instrument Air pressure.
- D. The Instrument Air dryer bypass valve will automatically open to minimize the loads on the Instrument Air system.

Answer: C

Question 48 Details

Question Type:	Multiple Choice
Topic:	48 DILTS.278LN001.06 Inst Air: Response to sys lo
System ID:	5814
User ID:	03-1 NRC-5814
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE278LN001.06
	Reference: LP DRE 278LN001 and DANs 923-1 F-4 and
	E-4
	K/A: 295019 AK3.01 3.3 / 3.4
	Level: Recall
	Explanation: Per the DAN 923-1 F-4, when the alarm is

03-1 NRC Exam (as submitted 6/30/04)

received, the SA-IA xtie valve will open (<85# IA header press). The IA dryer bypass valve will open at ~ 60 psig downstream of the dryer, well below the setpoint of the SA-IA xtie actuation. The 3C IA compressor can be manually started but will NOT auto start. The N2 backup supply valve will open when a low pressure condition is sensed in the drywell pneumatic system (~70 psig) Pedigree: Modified from Quad 2001 Exam

What is the automatic response, if any, when instrument air pressure drops low enough to energize Annunciator 912-1 A-11, U1A INST AIR LOW PRESSURE?

The Service air back-up valve will automatically open in an attempt to restore instrument air pressure.

The Drywell Pneumatic Compressor will automatically start to maintain control air for the MSIVs and the Target Rock Valve.

The 1 / 2 Instrument Air Compressor will automatically start in an attempt to restore instrument air pressure.

The air supply to non-critical systems will automatically isolate to conserve instrument air pressure.

03-1 NRC Exam (as submitted 6/30/04)

49	ID: 03	3-1 NRC-5877 Points: 1.00
	The following conditions exist on Unit 3:	
	 A spurious Group I isolation has occure RPV level is 10 inches and lowering 1 i RPV pressure is 1070 and increasing 1 All rods are in. EHC pressure is 0 psig. 	d. nch per minute. psig per minute.
	The Operators FIRST concern is (1)	by(2)
	1	2
	A. lowering RPV pressure	opening the bypass valves
	B. lowering RPV pressure	initiating the Isolation Condenser
	C. raising RPV water level	injecting with HPCI
	D. raising RPV water level	injecting with feedwater
	Answer: B Question 49 Details Question Type: Topic:	Multiple Choice 49 DILTE.29501LK019 EHC Failure: actions to take to control containment pressure
	System ID: User ID: Status: Must Appear: Difficulty: Time to Complete: Point Value: Cross Reference: User Text:	5877 03-1 NRC-5877 Active No 0.00 0 1.00
	User Number 1: User Number 2: Comment:	0.00 0.00 Objective: 29501LK019 Reference: LP 295L-S1 and DEOP 100 K/A: 295020 K1.01 3.7 / 3.9 Level: High - Application Explanation: Entry for DEOP 100 is 1060 psig and 8 inches. For the conditions given, the action that need to be taken first are restoring pressure in accordance with DEOP 100-1. Since EHC is NOT available, the bypass valves are unable to be opened.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5927

Points: 1.00

2C SDC pump motor developed a short circuit direct to ground but the motor supply breaker did NOT trip.

All other AC distribution components worked as designed.

Where AND how would the Operator be expected to obtain Drywell Temperature?

- A. Process computer ONLY since the 902-3 panel indication would be lost.
- B. Directly off Temperature Recorder TR 2-1340-1, ISOL COND/DW ATMOS TEMPS on the 902-3 panel.
- C. Installation of a fluke at the 902-3 panel to read the RTD's for TR 2-1340-1, ISOL COND/DW ATMOS TEMPS.
- D. Operator reports from the local drywell temperature monitoring panel since ALL Main Control Room indication would be lost.

Answer: B

Question 50 Details

Question Type: Topic:	Multiple Choice 50 DILTS.223LN001.12 SDC pump fault effect on ability to monitor torus temp.
System ID:	5927
User ID:	03-1 NRC-5927
Status:	Active
Must Appear	No
Difficulty:	0.00
Time to Complete	0
Point Value	1 00
Cross Reference:	1.00
User Text:	
User Number 1	0.00
User Number 2:	0.00
Comment:	Objective: DRE223I N001 12
eennient.	Reference: Fig 2621 N005-001 and 2621 N001-002 LP
	221 N001and 2051 N001
	K/A· 295021 A1 06 2 8 / 3 0
	Level: High
	Evolution: When the faulted SDC nump breaker fails
	to trip, it will trip the Bus 23.1 feed breaker and lockout
	Bus 23-1 on over-current When Bus 23-1 deenergizes
	Bus 28 loses nower which causes MCC 28.2 to lose
	nower When MCC 28.2 loses nower the Instrument
	Bus ART will swap to MCC 25-2, which is still powered
	Therefore NO drawell temperature recorder will less
	mererore, NO drywen temperature recorder will lose

50

03-1 NRC Exam (as submitted 6/30/04)

power, though the drywell temperature recorders will temporarily lose power while the Inst. Bus ABT swaps. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

51

ID: 03-1 NRC-5926

Points: 1.00

During a fuel move from the core to the spent fuel pool, a fuel bundle is dropped rupturing the Drywell to RPV bellows.

As a result fuel pool level will...

- A. remain constant.
- B. drop to the level of the skimmer surge tank weirs.
- C. drop to approximately 3 feet above the top of the spent fuel.
- D. drop to approximately 19 feet above the top of the spent fuel.

Answer: C

Question 51 Details

Multiple Choice
51 DILTS.233LN001.03 FPC: RPV to Drywell bellows
broke, resultant fuel pool level
03-1 NRC-5926
Active
No
0.00
0
1.00
0.00
0.00
Objective: DRE233LN001.03
Reference: Fig 233LN001.001, LP 233LN001
K/A: 295023 AA2.02 3.4 / 3.7
Level: High
Explanation: Since a fuel bundle is being moved from
the Reactor vessel to the fuel pool, the shielding blocks
and fuel pool gates are removed. If a RPV to Drywell
bellows is ruptured there would be nothing stopping the
level from dropping to the level of the bottom of the cattle
shoot. This would have the same effect as draining the
RPV with the fuel pool gates removed, so level will drop
to approximately 3 feet above the top of the spent fuel in
the racks. If the puncture was in the fuel pool skimmer
surge tank, level would drop to the level of the skimmer
surge tank weirs. 19 feet above the top of the spent fuel
is the Tech Spec required minimum water level above

03-1 NRC Exam (as submitted 6/30/04)

irradiated fuel. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5819

Points: 1.00

The following conditions exist on Unit 3:

- •A loss of RBCCW has occured.
- •The reactor mode switch has been placed in shutdown.
- •All APRMs are downscale.

52

- •During the transient, reactor water level dropped to 15 inches and is currently 24 inches and going up 0.5 inches per minute.
- •Drywell pressure is 2.2 psig and going up 0.2 psig per minute.
- •All ECCS pumps have automatically started.

The NSO should notify the Unit Supervisor that entry conditions have been met for which of the following?

- A. DGP 2-3, Reactor Scram ONLY.
- B. DEOP 100, RPV Control and DGP 2-3, Reactor Scram ONLY.
- C. DEOP 200-1, Primary Containment Control and DGP 2-3, Reactor Scram ONLY.
- D. DEOP 100, RPV Control, DEOP 200-1, Primary Containment Control, and DGP 2-3, Reactor Scram.

Answer: D

Question 52 Details

Question Type:	Multiple Choice
Topic:	52 DILTS.295L034 Drywell Press: Determine procedures
	to enter given conditions 100,200-1,DGP 2-3
System ID:	5819
User ID:	03-1 NRC-5819
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 295L034
	Reference: DEOP 100, 200-1, and DGP 2-3
	K/A: 295024 2.4.4 4.0/4.3
	Level: Recall
	Explanation: Given the following conditions, DEOP 100
	and 200-1 must be entered based on drywell pressure

03-1 NRC Exam (as submitted 6/30/04)

>2#. DGP 2-3 is entered any time a scram is initiated. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

53

ID: 03-1 NRC-5928

Points: 1.00

A concern during the performance of DEOP 100 is the occurrence of swell and shrink causing RPV level fluctuations. These level fluctuations can then complicate level control actions.

Which of the following is performed to minimize RPV shrink and swell?

- A. Verify FWLCS in automatic.
- B. Inhibit ADS and initiate IC.
- C. Initiate IC and open ADSVs to lower RPV pressure to 945 psig.
- D. Maximize injection using Condensate/Feedwater or other preferred injection system.

Answer: C

Question 53 Details

Question Type:	Multiple Choice
Topic:	53 DILTS.29501LK025 Pressure effects on RPV water level
System ID:	5928
User ID:	03-1 NRC-5928
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LK025
	Reference: DRE LP295L-S1
	K/A: 295025 EK1.06 3.5 / 3.6
	Level: Recall
	Explanation: SRV cycling at high reactor pressure will
	result in swell and shrink from pressure fluctuations. The
	swell and shrink will then result in RPV level fluctuations.
	The SRV cycling is stopped by initiating the IC and
	opening ADSVs to lower reactor pressure below the
	opening setpoint of the SRVs.
	Pedigree: Dresden 2001 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

E A				Deinter 4.00
54			ID: 03-1 NRC-5905	Points: 1.00
	Torus tempera depressurizatio	ture is maintai n.	ned below 206°F in order to avoid	an emergency
	Α.	over-pressuriz	ring the Torus during	
	В.	loss of all RP	/ level instruments after	
	 C. damaging SRV downstream piping during D. excessive hydrodynamic loading on downcomer piping during Answer: A 			
				uring
	Questi	on 54 Details		
	Questi Topic: Syster User II Status Must A Difficu Time t Point V Cross User T	on Type: n ID: D: : Appear: lty: to Complete: Value: Reference:	Multiple Choice 54 DILTS.29501LK007 HCL c torus temp. 5905 03-1 NRC-5905 Active No 0.00 0 1.00	urve: Basis for limiting
	User N User N Comm	Jumber 1: Jumber 2: hent:	0.00 0.00 Objective: DRE29501LK007 Reference: DRE LP295LC01 K/A: 295026 EK2.03 3.2 / 3.6 Level: Recall Explanation: The bases for the to described in the lesson overpressurization of the toru Emergency Depressurization. T SRV tailpipes. The level instrue drywell temperature. Hydro downcomers is not relevant to H Pedigree: Vermont Yankee 200 <i>If torus temperature or RPV maintained below the Heat Cap EOP-3, Primary Containment C</i> <i>This action is performed to avoil</i>	orus temperature limit as plan is to prevent us in the event of an This limit is unrelated to mentation is affected by odynamic loading on HCL. 2 NRC exam. / pressure cannot be acity Temperature Limit, ontrol, requires RPVED. d:

03-1 NRC Exam (as submitted 6/30/04)

overpressurizing the Primary Containment during RPV Emergency Depressurization.

damaging SRV downstream piping during RPV Emergency Depressurization.

loss of all RPV level instruments after RPV Emergency Depressurization.

excessive hydrodynamic loading on downcomer piping during RPV Emergency Depressurization.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5898

Points: 1.00

What is the reason the RPV may have to be flooded when Drywell temperatures become excessive?

- A. The ADS valves may be unreliable.
- B. RPV water level instruments may be unreliable.
- C. Increase NPSH to Recirc pumps to prevent cavitation.
- D. Provide additional cooling by establishing a flow path to the main condenser.

Answer: B

Question 55 Details

Question Type:	Multiple Choice
Topic:	55 DILTS.29501LK001 RPV water level inst relationship
	to drywell temp
System ID:	5898
User ID:	03-1 NRC-5898
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LK001
	Reference: DRE LP295LC-01 and Fig A on DEOP
	charts.
	K/A: 295028 K3.02
	Level: Recall
	Explanation: Per the DEOP chart fig A, with elevated
	drywell temperatures, boiling may occur in the instrument
	runs rendering them unreliable. The recirc pumps will be
	tripped when drywell temperatures are high enough to
	affect RPV level instruments so cavitation of the recirc
	pumps is NOT a concern. The ADS valves become a
	concern when the conditions for a blowdown exist. The
	main steam lines are isolated during RPV flooding so
	there would be no way to use the main condenser for
	additional cooling.
	Pedigree: New for 03-1 NRC exam.

55

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

56

ID: 03-1 NRC-5917

Points: 1.00

A Reactor startup was in progress on Unit 2 when a fire broke out in the Drywell.

- •Drywell temperature is 281°F and increasing 5°F per minute.
- •The Unit has been successfully scrammed.
- •The Unit Supervisor has entered DEOP 200-1, Primary Containment Control, and has ordered an emergency depressurization based on Drywell temperature.

What is the reason the Unit Supervisor ordered an emergency depressurization?

The design temperature limit of the _____ has been exceeded.

- A. Drywell
- B. ERV solenoids
- C. Target Rock solenoid
- D. Target Rock nitrogen supply piping

А

Answer:

Question 56 Details

Question Type: Topic:	Multiple Choice 56 DILTS.239LN001.09 ADS: Indications available to determine if ERV open.
System ID:	5917
User ID:	03-1 NRC-5917
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE239LN001.09
	Reference: BWROG EPG/SAG and PSTG
	K/A: 295028 EK3.06 3.4 / 3.7
	Level: Recall
	Explanation: The BWROG EPG/SAG says an
	emergency depressurization is performed when the
	maximum temperature the ADS system is qualified for or
	drywell design temperature is exceeded. The PSTG says
	the Drywell design temp is 281°F and the ADS
	qualification temperature is 334°F. The drwell design
	temp is the reason for the emergency depressurization.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

57 ID: 03-1 NRC-5925 Pc

Points: 1.00

Torus water level is 18.5 feet and going up 1 inch every 10 minutes.

What is the reason the Unit Supervisor orders a scram?

Torus water level has reached the point where...

- A. the Torus to Drywell vacuum breakers have become flooded preventing them from opening at the correct pressure.
- B. pressure will drop below the design Drywell scram setpoint if torus sprays are initiated.
- C. the Torus design load will be exceeded if SRVs are opened.
- D. equipment necessary for safe shutdown will fail.

Answer: C

Question 57 Details

Question Type: Topic:	Multiple Choice 57 DILTS.29501LK009 Torus Water Level: reason to scram
System ID:	5925
User ID:	03-1 NRC-5925
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LK009
	Reference: BWROG EPGs/SAG, DRE LP295LC-01
	K/A: 295029 EK3.03 3.4 / 3.5
	Level: Recall
	Explanation: BWROG EPGs/SAG describes one of the
	inputs to developing the Pressure Suppression Pressure
	curve as being the Maximum Pressure Suppression
	Primary Containment Water Level. The design of the
	PSP curve is to ensure if SRVs are opened Torus design
	load is not exceeded. The concern with the evaporative
	cooling pressure drop is associated with the Drywell
	Spray Initiation Limit (EPG/SAG 17.4). The concern with
	level reaching safe shutdown equipment is the Max Safe

03-1 NRC Exam (as submitted 6/30/04)

Operating Water Level for the secondary containment, NOT the torus. Dresden's Torus to Drywell vacuum breakers are outside the Torus, not inside so flooding of the vacuum breakers will not occur until the Torus is completely flooded.

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5889

Points: 1.00

The following plant conditions exist following a LOCA with a leak in the Torus:

- •Torus Water Temperature is 150°F and stable.
- •Torus Water level is 9.5 feet and stable after the Torus leak was isolated.
- •Torus Bottom Pressure is 10 psig and stable.
- •Reactor Pressure is 300 psig and slowly going down.
- •CST levels are 8 feet.

58

Under which of the following conditions should the Operator be MOST concerned with cavitation in the ECCS pumps?

- A. 2 LPCI pumps injecting at 5000 gpm each.
- B. 2 LPCI AND 2 CS pumps injecting at 4000 gpm each.
- C. 2 LPCI pumps **AND** 1 CS pump injecting at 4250 gpm each.
- D. Total ECCS injection flow is 14,000 gpm.

Answer: D

Question 58 Details

Question Type: Topic:	Multiple Choice 58 DILTS.29501LK003 ECCS vortex limit on low torus water level.
System ID:	5889
User ID:	03-1 NRC-5889
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 29501LK003
	Reference: DEOP 200-1 Provide the students with a
	copy of the DEOP charts with the entry conditions
	blanked out.
	K/A: 295030 EA1.01 3.6 / 3.8
	Level: High
	Explanation: With the given conditions, torus level and total flow will be the closest to the ECCS Vortex Limit with total ECCS flow at 14,000 gpm. With 2 LPCI pumps at 5000 gpm, fig W is used. With 2 LPCI and 2 CS at

03-1 NRC Exam (as submitted 6/30/04)

3000 gpm each, fig. X is used. With HPCI at 4000 gpm, fig. Y is used. All are below the NPSH curves. HPCI has swapped to the Torus (CST level 8 feet).

Pedigree: Modified from Fermi 2001 exam.

The following plant conditions exist following a LOCA event:

- Torus Water Temperature	180F and stable
- Torus Water level	-70 inches and
stable	

- Torus Pressure 0 psig and stable - Reactor Pressure 0 psig and stable Which one of the following describes the effect that these conditions has on the operation of ECCS pump for RPV level control?

Single pump LPCI flow is limited to 10,000 gpm to ensure vortex limits are not exceeded.

Continued operation of HPCI is allowed if the suction is aligned to the CST to provide adequate suction pressure.

Total core spray loop flow must be limited to 7000 to ensure adequate NPSH.

RCIC operation is allowed up to 650 gpm as long as torus level remains above -105 inches.

03-1 NRC Exam (as submitted 6/30/04)

59

ID: 03-1 NRC-5884

Points: 1.00

A DBA LOCA accompanied by a partial ATWS has occured resulting in only 2/3 of the core being covered.

Which of the following LPRMs would provide the LEAST accurate indication of power?

- A. 1C-32-57
- B. 3B-08-33
- C. 4D-56-33
- D. 5A-48-25

Answer: C

Question 59 Details

Question Type: Topic:	Multiple Choice 59 DILTS.215LN006.09 LPRM: 2/3 core coverage, which LPRMs would be most accurate
System ID:	5884
User ID:	03-1 NRC-5884
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 215LN006.09
	Reference: DRE LP 215LN006
	K/A: 295031 EA2.02 4.0 / 4.2
	Level: High
	Explanation: LPRMs with a level designation of "D" are
	closest to the top of the core. Since this is the portion of
	the core that has no/little moderator to slow down
	neutrons, the LPRM will be less accurate. 2/3 core
	coverage would be near notch position 16. "C" level
	LPRMs monitor notch position 18. "B" level - notch
	position 30 and "A" - notch position 42.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5916

Points: 1.00

The HPCI room radiation level has increased to 180 mRem/hr following an automatic HPCI initiation.

As a result of the above condition, the ARM system will...

- A. alarm the 902-11 panel indicator and trip unit AND annunciator 902-3 A-1, RX BLDG RAD HI.
- B. alarm annunciator 902-3 A-1, RX BLDG RAD HI, **ONLY**.
- C. alarm the 902-11 panel indicator and trip unit **ONLY**.
- D. **NOT** alarm.

Answer: A

Question 60 Details

Question Type: Topic:	Multiple Choice 60 DILTS.272LN001.10 ARM: Indications of a high rad
	condition in the HPCI room.
System ID:	5916
User ID:	03-1 NRC-5916
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE272LN001.10
	Reference: DAN 902(3) A-1, 12E-2480, Main Control
	Room ARM placard
	K/A: 295033 EK2.01 3.8 / 4.0
	Level: Recall
	Explanation: The radiation level present in the HPCI
	Cubicle is above the setpoint for ARM alarm (150
	mRem/hr). This will send a signal to BOTH the MCR
	indicator and trip unit on the 902-11 panel and alarm the
	902-3 A-1 annunciator.
	Pedigree: New for ILT 03-1 NRC exam.

60

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5915

Points: 1.00

The following actions automatically occurred as the result of high radiation condition:

•Reactor Building ventilation has tripped and isolated on BOTH units. •SBGT started.

Based on the information provided above, choose the parameter and radiation level that caused the automatic actions.

- A. RX BLDG VENT CH B RAD at 4 mRem/hr.
- B. REFUEL FLOOR RAD at 8 mRem/hr.
- C. U2/3 RX VENT CH A/B RAD at 5,000 cpm.
- D. U2/3 CHIMNEY NOBLE GAS at 12,000 cpm.

Answer: A

Question 61 Details

Question Type: Topic:	Multiple Choice 61 DILTS.288LN001.06 What caused RB vent to isolate and SBGT
System ID:	5915
User ID:	03-1 NRC-5915
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE288LN001.06
	Reference: DAN 902(3)-3 A-3
	K/A: 295034 A2.01 3.8 / 4.2
	Level: Recall
	Explanation: The RX BLDG VENT CH B RAD HI HI alarm at 4 mRem/hr is the only one of the alarms that would correspond to a trip and isolation of Rx Bldg ventilation. The other alarms have no automatic effect on Px Bldg ventilation
	Pedigree: Modified from Fermi 2001 NRC exam. The following actions automatically occurred as the result of high radiation:

61

03-1 NRC Exam (as submitted 6/30/04)

- Reactor Building HVAC tripped
- SGTS started
- Control Center HVAC aligned to recirculation mode

Based on the information provided above, CHOOSE the radiation monitor and indicated radiation level that caused the automatic actions.

Fuel Pool Vent Exhaust = 7.3 mRem.

Reactor Building Vent Exhaust = 14,500 cpm.

Turbine Building Vent Exhaust = 11,500 cpm.

Radwaste Building Vent Exhaust = 14.5 mRem.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5907

Points: 1.00

Unit 3 is in Mode 2, withdrawing control rods for a Unit startup with the following conditions:

•APRM 1, 3, 4, 5 indicate 11.2% power. •APRM 2 and 6 indicate 17.5% power.

Based on the above conditions the NSO's next action should be to...

- A. place the Mode switch in RUN.
- B. manually drive in the last control rod withdrawn.
- C. scram the Reactor and place the Mode switch in S/D.
- D. stop the withdrawal of control rods and check APRM GAFs.

Answer: C

Question 62 Details

Question Type: Topic:	Multiple Choice 62 DILTS.215LN005.06 SCRAM: 2 channels of APRMs high in S/U and no scram
System ID:	5907
User ID:	03-1 NRC-5907
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE215LN005.06 Reference: DRE LP215LN005, DAN 902-5 C-12, OP- AA-101-111, TS 3.3.1.1295037 K/A: 295037 2.1.33 3.4/ 4.0 Level: High
	Explanation: The Tech Spec setpoint for an APRM Hi flux scram in mode other than run has been exceeded. A scram should have occured and did not. OP-AA-101- 111, states that an RO will shutdown the reactor "when operating parameters exceed any of the reactor protection circuit setpoints and automatic shutdown does <u>not</u> occur". NO procedure guidance for placing the mode switch to RUN or driving in the last control rod withdrawn.
03-1 NRC Exam (as submitted 6/30/04)

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5815

Points: 1.00

The following conditions exist at Dresden.

63

- •A Tornado Warning is in effect for the area that includes Dresden.
- •Reactor Building crane lifts are in progress to move material from the 517 foot elevation of the reactor building to the refuel floor.
- •Dresden Security personnel have sighted a tornado.

Which of the following must be performed as a result of these conditions per DOA 10-2?

- A. Verify blowout panels are in place on both Unit 2 and 3 Reactor Buildings.
- B. Start EDG's in anticipation of a loss of off-site power.
- C. Open ALL Unit 2 and 3 Turbine Building doors to equalize building pressure.
- D. Stop crane lifts ONLY if a local assessment determines the tornado will hit on site.

Answer: A

Question 63 Details

Question Type:	Multiple Choice
Topic:	63 DILTS.29501LK063 Off Site Release: Met effects on
System ID:	5815
User ID:	03-1 NRC-5815
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LK063
	Reference: DOA 0010-02 Tornado Warning / Severe Winds
	K/A ⁺ 295038 EK1 03 2 8 / 3 8
	Level: Recall
	Explanation: Verifying the blowout panels is the required action per DOA 10-2. Answers b and c are items the procedure directs NOT to do and all crane lifts are stopped whether or not the tornado will impact on site. This would affect the off-site release rate due to a loss of secondary containment. Pedigree: Dresden 2001 Exam

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

64

ID: 03-1 NRC-5902

Points: 1.00

Containment venting is being established on Unit 2 to reduce hydrogen concentration in the Drywell following a LOCA per DEOP 500-04, Containment Venting.

Placing the AUGMENTED PRI CNMT VENT MODE SWITCH to the APCV position will allow the Operator to open...

- A. AO 2-1601-63, VENT TO SBGT.
- B. AO 2-1601-92, VENT TO MAIN CHIMNEY.
- C. AO 2-1601-23, DW VENT VALVE, with a Group 2 isolation signal present.
- D. AO 2-1601-60, TORUS VENT VLV, with a Group 2 isolation signal present.

Answer: B

Question 64 Details

Question Type:	Multiple Choice
Topic:	64 DILTS.223LN003.11 CAC: APCV mode control switch operation.
System ID:	5902
User ID:	03-1 NRC-5902
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE223LN003.11
	Reference: DOA 6800-01, LP DRE223LN003
	K/A: 500000 EA1.03 3.4 / 3.2
	Level: Recall
	operation of the 1601-63, 91 and 92 valves. In the APCV position, the 63 and 91 cannot be opened. In the NORMAL position, the 92 cannot be opened. The CNMT ISOLATION GROUP 2 OVER RIDE switches
	allow the 23 and 60 valves to be opened with a GROUP 2 isolation signal present.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

65 ID: 03-1 NRC-5880 Points: 1.00

A mechanic has reported a fire with a 10 foot radius surrounding TR-28 due to an oil leak.

The Unit supervisor has ordered Bus 28 be de-energized.

Attempts to de-energize Bus 28 from the Main Control Room have been unsuccessful.

The NSO would direct the NLO to go to...

- A. RB 570 foot elevation (3rd floor) and open the Bus 28 main feed breaker at Bus 23-1.
- B. RB 545 foot elevation (2nd floor) and open the Bus 28 main feed breaker at Bus 23-1.
- C. RB 570 foot elevation (3rd floor) and open the Bus 28 feed breaker at Bus 28.
- D. RB 545 foot elevation (2nd floor) and open the Bus 28 feed breaker at Bus 28.

Answer: B

Question 65 Details

Question Type: Topic:	Multiple Choice 65 DILTO.LOJIP00.26205LP005 DOP 6700-01: Fire at TR-28 where to go to deenergize Bus 28.
System ID:	5880
User ID:	03-1 NRC-5880
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 26205LP005
	Reference: DSSP 0100-CR
	K/A 600000 AK2.04 2.5 / 2.6
	Level: High
	Explanation: Since there is a fire in TR-28, and Bus 28
	is right next to TR-28, the NSO will dispatch the operator
	to Bus 23-1 to deenergize the the Bus. Bus 23-1 is
	located on the 2nd floor of the RB elevation 545.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5895

		Floor Drain Leakage (FDL)	Equipment Drain Leakage (EDL
Day	Time	Integrator Reading Gallons Pumped	Integrator Reading Gallons Pumped
	2000	1195	401
THU			
	1600	1162	398
	1200	1038	395
	0800	963	400
	0400	847	415
	0000	688	408

Unit 3 is 912 MWe.

Which of the following statements is correct concerning the above readings taken from this weeks Appendix A, Unit NSO Daily Surveillance Log for Unit 3?

- A. NO leakage limits have been exceeded.
- B. The unidentified leakage limit has been exceeded.
- C. The increase in unidentified leakage limit has been exceeded.
- D. The total leakage over a 24 hour period limit has been exceeded.

Answer: C

Question 66 Details

Multiple Choice 66 DILTS.298L050 Determine if Reactor Coolant leakage is within TS limits.
5895
03-1 NRC-5895
Active
No
0.00
0
1.00
0.00

Points: 1.00

03-1 NRC Exam (as submitted 6/30/04)

User Number 2: Comment: 0.00 Objective: 298L0509 Reference: Appendix A, TS 3.4.4 K/A: Generic 2.1.12 2.9 / 4.0 Level: High Explanation: The change from Thurs 0000 (2.86 gpm) until 2000 (4.97 gpm) is 2.11 gpm. The TS limit for increase in unidentified leakage (from the Floor Drains) is 2 gpm. 25 gpm is the total leakage limit (FDL + EDL). FDL limit is 5 gpm. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

67

ID: 03-1 NRC-5845

Points: 1.00

Unit 2 was at 912 MWe when Main Steam line pressure dropped to 810 psig due to a rupture. The reactor scrammed prior to any Operator action.

Reactor water level dropped to -20 inches and is currently at +5 inches and going up 0.5 inches per minute.

Which of the following conditions would be indicated by a RED Primary Containment Isolation Status box on SPDS?

- A. 2-2301-5, HPCI Steam Isol VIv is OPEN.
- B. 2-2301-5, HPCI Steam Isol VIv is CLOSED.
- C. 2-0203-2B, 2B Outboard MSIV is OPEN.
- D. 2-0203-2B, 2B Outboard MSIV is CLOSED.

Answer: C

Question 67 Details

Question Type: Topic:	Multiple Choice 67 DILTS.283LN001.10 SPDS: Meaning of Red PCIS box
System ID:	5845
User ID:	03-1 NRC-5845
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE283LN001.10
	Reference: DOP 9900-205
	K/A: Generic 2 1 19 3 0 / 3 0
	Level: High
	Explanation: Per DOP 9900-205 "The PCIS box will be
	red if a Group L or II isolation demand signal is present
	and the valve positions do not indicate a completion of
	the isolation "The given conditions will cause Group L 2
	and 3 legistions. Only Group Land 2 have an input to the
	Primary Containment Isolation boy on SPDS. The HPCL
	valvo is a Group 4 valvo
	Valve is a Gloup 4 valve. Dediaree: New for 02.1 NDC even
	reuigiee. New 101 05-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

68

ID: 03-1 NRC-5859

Points: 1.00

During a core off-load, which one of the following Spent Fuel Pool water levels is the LOWEST level which would allow irradiated fuel handling activities per DGP 4-1, Fuel Moves and Refueling?

- A. 10' 4"
- B. 19'
- C. 23'
- D. 37' 7"

Answer: D

Question 68 Details

Question Type: **Multiple Choice** 68 DILTS.299L042 Refueling: Minimium FP level to Topic: allow irradiated fuel movements System ID: 5859 User ID: 03-1 NRC-5859 Status: Active Must Appear: No Difficulty: 0.00 Time to Complete: 0 Point Value: 1.00 Cross Reference: User Text: User Number 1: 0.00 User Number 2: 0.00 Comment: Objective: DRE299L042 Reference: DGP 4-1 K/A: Generic 2.2.27 2.6 / 3.5 Level: Recall Explanation: Per DGP 4-1 the minimum level for moving irradiated fuel inside secondary containment is 37' 7". 10' 4" is the minimum allowed suppression pool level. 19' is the minimum water level permitted in the Spent Fuel pool by Tech Spec 3.7.8. 23' is the minimum reactor water level above the top of the RPV flange when in

> refueling. Pedigree: Palisades 2003 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5860

Points: 1.00

Which one of the following is a responsibility of the Reactor Operator during core alterations?

- A. Perform verification of in-core coordinates.
- B. Observe Source Range Monitors for rising counts.
- C. Observe and directly supervise Core Alterations.
- D. Maintain the official copy of the Special Nuclear Material Move Sheets.

Answer: B

69

Question 69 Details

Question Type: **Multiple Choice** Topic: 69 DILTS.215L016 Generic: RO responsibilities during refeuling operations System ID: 5860 User ID: 03-1 NRC-5860 Status: Active Must Appear: No Difficulty: 0.00 Time to Complete: 0 Point Value: 1.00 Cross Reference: User Text: User Number 1: 0.00 User Number 2: 0.00 Comment: Objective: 215L016 Reference: DFP 800-01 K/A: Generic 2.2.30 3.5 / 3.3 Level: Recall Explanation: Per DFP 800-01, the NSO shall: "IF the component move will affect core reactivity, THEN check SRM response." A is the responsibility of SNM Custodian / Nuclear Engineer. C is the responsibility of Bridge

> Refuel SRO. Pedigree: Clinton 2002 NRC exam.

Operator, Spotter, Refuel SRO. D is the responsibility of

03-1 NRC Exam (as submitted 6/30/04)

70

ID: 03-1 NRC-5850

Points: 1.00

You have received no dose for the current calendar year. Your Administrative Dose Control Level has been raised to the MAXIMUM allowed by the Radiation Protection Manager and your Work Group Supervisor per RP-AA-203 Exposure Control and Authorization.

The dose field you will be working in is 500 mRem/hr.

What is your MAXIMUM stay time in the area?

- A. 4 hours.
- B. 6 hours.
- C. 8 hours.
- D. 10 hours.

Answer: B

Question 70 Details

Question Type:	Multiple Choice
Topic:	70 DILTS. Generic Administrative exposure limits and extensions
System ID:	5850
User ID:	03-1 NRC-5850
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: NGET
	Reference: Nuclear General Employee Training, Rev 28 and RP-AA-203
	K/A: Generic 2.3.4 2.5 / 3.1
	Level: High
	Explanation: Per NGET material and RP-AA-203, the
	administrative limit for exposure is 2000 mRem/yr TEDE.
	Exposure levels may be authorized by the Radiation
	Protection Manager up to 3000 mRem/yr. To raise the
	level to 4000 mrem/yr requires the Station/Plant
	Manager's permission as well. 3000 mRem/500mRem

03-1 NRC Exam (as submitted 6/30/04)

per hr = 6 mins. 2000 mRem is the current authorized ADCL. 4000 mRem is an allowed extension by takes Plant Manager permission as well. Pedigree: New for 03-1 NRC Exam

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5818

Points: 1.00

In order to purge the containment to the Reactor Building Ventilation system, sample results for which of the following must be below the prescribed limits?

- A. Iodine 131 and Alpha (total particulate).
- B. Iodine 131 and Beta/Gamma (total particulate)
- C. Nitrogen 16 and Alpha (total particulate).
- D. Nitrogen 16 and Beta/Gamma (total particulate).

Answer: B

Question 71 Details

Question Type:	Multiple Choice
Topic:	71 Generic.2.3.9: Containment purge through Rx Bldg
System ID:	5818
User ID:	03-1 NRC-5818
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 223LN001.02
	Reference: DOP 1600-07
	K/A: Generic 2.3.9 2.5 / 3.4
	Level: Recall
	Explanation: Per DOP 1600-07, "Purge Containment to
	the Reactor Building Ventilation System ONLY if sample
	results indicate that release rates are LESS THAN the
	following limits: Iodine 131: 7.2 X 10 E-9 uCi/cubic
	centimeter (uCi/cc). Beta/Gamma (total particulate): 1.8 X 10 E-7 uCi/cc."

Pedigree: Dresden 00-1 NRC Exam.

03-1 NRC Exam (as submitted 6/30/04)

72

ID: 03-1 NRC-5861

Points: 1.00

Unit 2 Drywell venting through Reactor Building Ventilation is in progress per DOP 1600-01, NORMAL PRESSURE CONTROL OF THE DRYWELL OR TORUS due to Drywell pressure approaching 1.3 psig.

Annunciator 902-4 B-17, DRYWELL EQUIP SUMP LVL HI, alarms. 15 seconds later annunciator 902-4 A-17, DRYWELL EQUIP SUMP LVL HI-HI, alarms.

Based on the above conditions, the Operator should...

- A. re-align the vent path through SBGT.
- B. stop the venting until the drywell atmosphere is resampled.
- C. continue venting but have the drywell atmosphere resampled.
- D. continue venting but closely monitor Rx Bldg Vent Rad levels for changes.

Answer: B

Question 72 Details

Question Type:	Multiple Choice
Topic:	72 DILTS.223L001 Rad Release: Actions to control radiation release.
System ID:	5861
User ID:	03-1 NRC-5861
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE223L001
	Reference: DOP 1600-01, DAN 902-4 A-17, and DOA 40-1
	K/A: Generic 2.3.11 2.7 / 3.2
	Level: High
	Explanation: The Operator will realize that a leak has
	occured in the drywell somewhere. DAN 902-4 A-17
	directs the operator to enter DOA 40-1. DOP 1600-01
	states, "IF drywell/torus conditions change while venting,
	THEN: Terminate the venting process. Resample to
	verify conditions prior to reinitiating the venting process."

03-1 NRC Exam (as submitted 6/30/04)

If the containment pressure limit was approaching, the operator could vent regardless of release rate. Pedigree: New for ILT 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5864

Points: 1.00

Unit 2 is being refueled with 2A loop of SDC in use and NO Recirculation Pumps running.

2B SDC loop is in the Fuel Pool Cooling mode of operation.

Which of the following describes Operator's actions if Reactor Vessel Level decreased from +50 inches to +3 inches?

- A. Enter DOA 1000-01, RESIDUAL HEAT REMOVAL ALTERNATIVES, verify the running Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate and verify the 2A **AND** 2B SDC Pumps trip.
- B. Enter DOA 600-01 TRANSIENT LEVEL CONTROL, verify the Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate and verify the 2A AND 2B SDC pumps trip.
- C. Verify DAN for 902-5 F-8 RPV LVL LO, and verify Shutdown Cooling continues unaffected.
- D. Enter DEOP 100 RPV Control, and verify the Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate and verify **ONLY** the 2A SDC Pump trips.

Answer: D

Question 73 Details

Question Type: Topic:	Multiple Choice 73 DILTS.295LK019 Generic: Actions if SDC on and level drops to +4"
System ID:	5864
User ID:	03-1 NRC-5864
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 295LK019
	Reference: DEOP 100, DOA 600-01, DAN 902-5 D-5
	K/A: Generic 2.4.9 3.3 / 3.9
	Level: High
	Explanation: The Operators will enter DEOP 100 on RPV
	level \leq +8 inches. The SDC system will isolate due to a Group 3 isolation (PPV level +6). The 24 SDC nump will
	trip due to low suction pressure sensed when the system

03-1 NRC Exam (as submitted 6/30/04)

isolation occurs. The 2B pump will NOT trip due to it being lined up to FPC (takes it's suction from FPC). Pedigree: Modified from Susquehanna 2003 NRC exam question.

The reactor is shut down with one loop of shutdown cooling in use and NO Recirculation Pumps running.

How would the Control Room operators respond if Reactor Vessel Level decreased from +50 inches to +4 inches?

Enter EO-100-102 RPV Control, maximize CRD and check the Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate, the operating RHR Pump will trip.

Enter ON-149-001, Loss of Shutdown Cooling, maximize RHR keepfill, check the Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate, the operating RHR Pump remain running.

Verify alarm response for RX WATER HI-LO LEVEL AR-101-B17, verify Shutdown Cooling continues unaffected.

Verify alarm response for HV-151-F006A/C AND HV-151-F007A OPEN DRAINS RX VESSEL AR-109-C09, verify the Shutdown Cooling Suction Inboard and Outboard Isolation Valves isolate, the operating RHR Pump will trip, HV-151-F015A will open, remaining RHR Pumps auto start.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5863

Points: 1.00

A reactor scram has occurred and not all rods have inserted.

Which of the following conditions would allow the SRO to make the determination that the "Reactor will remain shutdown under all conditions?"

- A. Power is in the source range and decreasing on ALL channels.
- B. One control rod remains withdrawn at 48. ALL other control rods are at 00.
- C. The only control rods which remain withdrawn are at position 06 or less.
- D. No more than one control rod remains withdrawn in any 5 x 5 array.

Answer: B

Question 74 Details

Question Type:	Multiple Choice
Topic:	74 DILTS.29501LK020 Generic: Meaning of Reactor will
System ID:	5863
User ID:	03-1 NRC-5863
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LK020
	Reference: LP DRE 295L-S1
	K/A: Generic 2.4.17 3.1 / 3.8
	Level: Recall
	Explanation: Reference: all rods at 02 or 00; "Shutdown
	margin check"- one rod can be fully withdrawn form the
	core provided all others are at 00. Answer a and c don't
	meet this check, answer d would allow multiple rods to
	be withdrawn.
	Pedigree: LaSalle 2000 NRC exam

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5821

Points: 1.00

According to HU-AA-104-101, Procedure Use and Adherence, which of the following may be performed from memory?

- A. Procedures that have less than or equal to 5 steps.
- B. Actions that are instinctive and simple to remember.
- C. Actions to manually duplicate an automatic action that has failed to occur.
- D. Evolutions that an Operator has performed before and has been briefed by his Supervisor.

Answer: C

Question 75 Details

Question Type:	Multiple Choice
Topic:	75 DILTS.Generic: Actions that can be taken from
	memory
System ID:	5821
User ID:	03-1 NRC-5821
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE299L081
	Reference: HU-AA-104-101
	K/A: 2.4.49 4.0 / 4.0
	Level: Recall
	Explanation: per HU-AA-104-101"Actions required to
	manually duplicate an automatic action that has failed to
	automatically occur may be performed from memory".

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

76

ID: 03-1 NRC-5919

Points: 1.00

MO 2-1501-32A and 32B LPCI XTIE VLVs allow the 'A' LPCI loop to use the 'B' LPCI loop's <u>(1)</u>. If MO 2-1501-32A cannot be returned to full open following DOS 1500-01, LPCI System Valve Operability and Timing, the Unit Supervisor will declare <u>(2)</u>.

2

A.	heat exchanger	BOTH LPCI subsystems inoperable
В.	heat exchanger	ONLY 'A' LPCI subsystem inoperable
C.	injection piping	BOTH LPCI subsystems inoperable
D.	injection piping	ONLY 'A' LPCI subsystem inoperable

Answer: C

Question 76 Details

Question Type:	Multiple Choice
Topic:	76 DILTS.203LN001.02 LPCI: 32 valve purpose and operability.
System ID:	5919
User ID:	03-1 NRC-5919
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE203LN001.02
	Reference: M-29, TS 3.5.1 and Bases
	K/A: 203000 K4.12 3.6
	Level: Recall
	Explanation: The LPCI 32A and 32B valves allow each
	loop to use the other loops injection path if necessary.
	The flow coming from the opposite unit uses its own HX
	and does not flow through the redundant loops HX. TS
	3.5.1 Bases state that if the LPCi cross-tie valves are not
	both full open, BOTH LPCI subsystems must be
	declared inoperable due to needing 3 pumps for
	adequate core cooling
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5911

Points: 1.00

Unit 3 is shutting down per DGP 2-1, Unit Shutdown.

Shutdown cooling is being placed in service per DOP 1000-03, Shutdown Cooling Mode of Operation as directed by DGP 2-1.

•Both Recirc pumps are secured.

•Two SDC loop operation is desired.

•3A SDC loop is operating.

77

•3C SDC heat exchanger is OOS for tube repair.

- •While attempting to throttle open MO 3-1001-4B, 3B SDC PP DISCH VLV, the NSO reported the valve did NOT open and position indication was lost.
- •An NLO sent to investigate reports that the cable powering the MOV has burned up and EMD estimates repairs to take at least 8 hours.
- •MMD reports there is no damage to the valve.

Based on the above information, the Unit Supervisor should...

- A. direct the NLO to manually throttle open the 3B pump discharge valve to lineup the system for cooling and consider the 3B SDC loop OPERABLE.
- B. lineup FPC to the 3B SDC loop and consider the 3B SDC loop OPERABLE.
- C. direct the NLO to manually throttle open the 3B pump discharge valve to lineup the system for mixing and declare the 3B SDC loop INOPERABLE.
- D. isolate the 3B SDC loop and declare the 3B SDC loop INOPERABLE.

Answer: A

Question 77 Details

Multiple Choice 77 DILTS.205LN001.07 SDC: actions and operability call if SDC pp suct vlv won't open electrically
5911
03-1 NRC-5911
Active
No
0.00
0
1.00
0.00
0.00

03-1 NRC Exam (as submitted 6/30/04)

Comment:

Objective: DRE205LN001.07 Reference: TS 3.4.7 K/A: 205000 2.1.23 4.0 Level: High

Explanation: With Recirc pumps running, 2 SDC subsystems are required to be operable. The repairs will take more than 2 hours to complete, which exceeds the 2 hours allowed by a note in the LCO. The Bases state that a SDC subsystem is considered operable if it can be aligned remotely or locally in the SDC mode for the removal of decay heat. The operator can still locally open the SDC pump discharge valve. There is NO procedure guidance to line up FPC to SDC. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5914 Points: 1.00

Unit 2 is at rated conditions.

78

An NLO reported to the control room that he heard an abnormal noise near the 2A RPS MG. The NLO subsequently reported 2A RPS MG and associated RPS Bus voltage are both 105v and stable.

APRM channels (1) are impacted by the NLO's report and (2).		
	1	2
A.	1, 2, and 3	the affected RPS bus must be transferred to its reserve power supply in accordance with DOP 500-03, Reactor Protection System Operation within 1 hour
B.	1, 2, and 3	a manual half scram must be inserted on the affected RPS channel within 1 hour in accordance with DOA 500-02, Partial 1/2 or Full Scram Actuation, until the affected EPA can be repaired
C.	4, 5, and 6	the affected RPS bus must be transferred to its reserve power supply in accordance with DOP 500-03, Reactor Protection System Operation within 1 hour
D.	4, 5, and 6	a manual half scram must be inserted on the affected RPS channel within 1 hour in accordance with DOA 500-02, Partial 1/2 or Full Scram Actuation, until the affected EPA can be repaired
Answe	er: C	

Question 78 Details

Question Type: Topic:	Multiple Choice 78 DILTS.262LN005.08 RPS EPA: failure to trip, actions to take.
System ID:	5914
User ID:	03-1 NRC-5914
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE262LN005.08

03-1 NRC Exam (as submitted 6/30/04)

Reference: TS 3.3.8.2 and Bases and DOA 0500-05 K/A: 215005 A2.01 3.1 Level: High

Explanation: The A RPS MG powers the B RPS Bus which is the power supply to APRM channels 4, 5, and 6. Common confusion is that RPS MG A powers RPS Bus A. Since EPAs 2A-1 and 2A-2 did NOT trip on low voltage as required (greater than or equal to 106.3v) the in service power supply must be removed from service within 1 hour. The bases allow the RPS Bus to be powered from the alternate power supply to regain operability to the affected RPS bus. A half scram does NOT need to be inserted while the EPA is being repaired.

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5910

During the Unit 2 NLOs round, he notices breaker C-4 on MCC 29-3 which feeds the Unit 2 Refueling Platform receptacle is damaged. Unit 3 Refueling Platform is OOS. Because of the failure described above (1) . Fuel moves may be performed by (2) in accordance with DFP 0800-21, Refueling Platform and Fuel Handling Grapple Operation. 2 1 Α. only the frame mounted and connecting to the Unit 3 refueling monorail hoists lose power platform receptacle only the frame mounted and connecting to a welding receptacle Β. monorail hoists lose power C. all power to the refueling platform connecting to the Unit 3 refueling is lost platform receptacle D. all power to the refueling platform connecting to a welding receptacle is lost D Answer:

Question 79 Details

Question Type:	Multiple Choice
Topic:	79 DILTS.23400LK014 Loss of power to the refueling platform.
System ID:	5910
User ID:	03-1 NRC-5910
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE23400LK014
	Reference: DFP 0800-21
	K/A: 234000 A2.03 3.1
	Level: Recall
	Explanation: There is only one breaker that supplies the
	refueling platform, that is from 29-3 Cub C-4, so all power will be lost to the refueling platform. DFP 0800-21

79

Points: 1.00

03-1 NRC Exam (as submitted 6/30/04)

provides guidance to provide temporary power to the refueling platform from a welding receptacle. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

80 ID: 03-1 NRC-5873 Points: 1.00

The following conditions exist on Unit 3:

- •The drywell is being vented to control H₂ and O₂.
- •Torus level is 31 feet.
- •The following values were noted prior to initiating venting:

	Drywell	Torus
Hydrogen	7%	6%
Oxygen	5%	7%

•The NSO reports that A SBGT train has tripped and the B SBGT train will **NOT** start.

•The NSO then reports Nitrogen purge is **NOT** controlling hydrogen and oxygen concentrations.

Given the above conditions, how will the Oxygen and Hydrogen concentrations be lowered?

- A. Purge the Torus per DEOP 500-4 "Containment Venting", Attachment 5 through the Augmented Primary Containment Vent.
- B. Purge the Drywell per DEOP 500-4 "Containment Venting", Attachment 4 through the Augmented Primary Containment Vent.
- C. Secure the venting per DEOP 500-4 "Containment Venting", Attachment 5 and purge the Torus using the Nitrogen Inerting path .
- D. Secure the venting per DEOP 500-4 "Containment Venting", Attachment 4 and purge the Drywell using the Nitrogen Inerting path .

Answer: B

Question 80 Details

GT

03-1 NRC Exam (as submitted 6/30/04)

Comment:

Objective: 29502LK068 Reference: DEOP 0200-02 and DEOP 0500-04 K/A: 261000 K3.06 3.3 Level: High

Explanation: Torus level is too high to allow venting of the Torus so atachment 5 cannot be used. A Limitation and Action (F.2) in DEOP 500-4 states that purging without venting is NOT allowed. Attachment 4 Step 11 states that "If the Drywell hydrogen and oxygen concentrations cannot be controlled using SBGT and nitrogen purge, then purge with air as follows:" a description on how to line up APCV system follows. Pedigree: Modified from Dresden 01-1 NRC exam.

Provide DEOP 200-2 and DEOP 500-4 with Section H blanked out.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5891

Points: 1.00

Unit 3 is in a refuel outage with the following conditions:

•A fuel shuffle is currently in progress inside the vessel.

•DOS 5750-06, Control Room Train A Ventilation Automatic and Manual Smoke Purge System Test, is in progress.

When the CRM AIR FLOW CONTROL switch at the 923-9 panel was taken to OUTSIDE to perform the smoke purge test, the following damper positions were noted:

Intake Damper, 2/3-9472-023	OPEN
Recirc Damper, 2/3-9472-024	OPEN
Exhaust Damper, 2/3-5741-XCV-053A	CLOSED
Intake Damper, 2/3-5741-XCV-053B	OPEN 2000 cfm

What is the impact of the ventilation configuration on fuel shuffle operations?

Fuel moves are...

81

- A. suspended immediately.
- B. suspended within 15 minutes.
- C. suspended within 30 minutes.
- D. allowed to continue.

Answer: A

Question 81 Details

Question Type:	Multiple Choice
Topic:	81 DILTS.288LN003.02, 07 CREVS: inoperable smoke purge mode during fuel moves
System ID:	5891
User ID:	03-1 NRC-5891
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE288LN003.02, 07
	Reference: TS 3.7.4, DOS 5750-06, Fig. 288LN003-001 K/A: 288000 2.2.32 3.3

03-1 NRC Exam (as submitted 6/30/04)

Level: High

Explanation: For the smoke purge mode the air is taken in from the outside and exhausted back to the outside. The recirc damper should be closed and the exhaust damper should be open. This does not meet the acceptance criteria of the surveillance. The CREV system is required to be operable during core alterations. If it is not, fuel movements are to be suspended immediately per TS 3.7.4.

Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5869

Points: 1.00

Unit 3 was at 95% power when the following indications SUDDENLY changed:

Indicated total core flow increased.
Core thermal power decreased.
Main Generator power has decreased.
Core differential pressure has decreased.

82

Based on these indications what has occurred and what must be done?

- A. Jet pump failure has occurred and the affected recirc pump must be secured.
- B. Jet pump failure has occurred and the scoop tube for the affected recirc pump must be locked up.
- C. Recirc pump trip has occurred and the affected recirc loop must be isolated.
- D. Recirc pump trip has occurred and the scoop tube for the affected recirc pump must be locked up.

Answer:

Question 82 Details

А

Question Type: Topic:	Multiple Choice 82 DILTS.202LK016 Failed jet pump indication & actions to take
System ID:	5869
User ID:	03-1 NRC-5869
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 202LK016
	Reference: LP ILTS026
	K/A: 295001 AA2.05 3.4
	Level: High - Application
	Explanation: These are the indications of a failed jet
	pump. If a recirc pump tripped the core flow would go
	down. The action for a sudden jet pump failure is to
	secure the affected recirc pump per DOA 0201-01.
	assessed and the correct procedure entered to take the

03-1 NRC Exam (as submitted 6/30/04)

right actions) Pedigree: Dresden Bank (DSROA-273142)

03-1 NRC Exam (as submitted 6/30/04)

83

ID: 03-1 NRC-5899

Points: 1.00

With Unit 2 at 912 MWe the following conditions exist:

•Annunciator 902-8 G-9, 120V INST BUS TRANSFER TO EMERG SPLY, alarmed.

•An investigation revealed that MCC 28-2 lost power but has been re-energized.

•The NLO sent to investigate reports that the Instrument Bus ABT is lined up to MCC 25-2.

Based on the information given to him, the Unit Supervisor will...

- A. dispatch EMD to investigate the failure of the ABT and declare the Instrument Bus INOPERABLE.
- B. dispatch EMD to investigate the failure of the ABT and declare the Instrument Bus OPERABLE.
- C. dispatch an Operator to RESET the Instrument Bus ABT and declare the Instrument Bus INOPERABLE.
- D. dispatch an Operator to RESET the Instrument Bus ABT and consider the Instrument Bus OPERABLE.

Answer: A

Question 83 Details

Question Type: Topic:	Multiple Choice 83 DILTS.264LN004.07 Inst Bus: Failure of ABT, DAN actions and TS call
System ID:	5899
User ID:	03-1 NRC-5899
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE262LN005.07
	Reference: DAN 902(3)-8 G-9, DOP 6800-02, and TS
	3.8.7 and Bases
	K/A: 295003 2.4.31 3.4
	Level: High
	Explanation: The Inst Bus ABT is a normal seeking ABT which should swap back to its normal power supply, 28-2 when re-energized. The ESS Bus ABT has to be

[•]Annunciator 902-8 G-9 will NOT reset.
03-1 NRC Exam (as submitted 6/30/04)

transferred manually by using the RESET toggle switch. The Tech Specs say that the ABT is not required to be Operable to consider the Inst Bus operable however, it is NOT being powered from a safety bus so it is INOPERABLE.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5903

Points: 1.00

Given the following conditions on Unit 3:

84

- •Unit 3 had been operating at rated capacity for 412 days.
- •An electrical malfunction caused all Turbine stop and control valves to go full open.
- •The Reactor automatically scrammed.
- •The NSO reported the Mode switch will NOT move out of RUN.

Which of the following should the Unit Supervisor direct in order to remove the LEAST amount of decay heat from the Reactor and still maintain a cooldown rate 10 minutes after the scram?

- A. Jack open two of the Turbine Bypass valves per DGP 2-1, Unit Shutdown.
- B. Initiate HPCI in pressure control mode per DOP 2300-03, High Pressure Coolant Injection System Manual Startup and Operation.
- C. Initiate RWCU blowdown per DOP 1200-03, RWCU System Operation with the Reactor at Pressure.
- D. Initiate the Isolation Condenser to maximum flow per DOP 1300-03, Manual Operation of the Isolation Condenser.

Answer: D

Question 84 Details

Question Type:	Multiple Choice
Topic:	84 DILTS.29501LK046 DOA 1000-01: decay heat removal options after scram
System ID:	5903
User ID:	03-1 NRC-5903
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 29501LK046
	References: DOA 1000-01, GP Reactor Theory LP
	K/A: 295006 AK1.01 3.9
	Level: High
	Explanation: 10 minutes after the scram decay heat is approximately 59 MWth (2% of 2957 MWth). Initiating the Isolation Condenser to max will remove 74 MWth.

03-1 NRC Exam (as submitted 6/30/04)

With the Mode switch in run and a low main steam line pressure, the MSIVs will go closed on a Group 1 isolation and will not open without the installation of jumpers so the bypass valves are not available immediately and jacking open 2 of the bypass valves would remove 224 MWth. Increasing RWCU flow rate to the maximum will remove approximately 10 MWth. Initiating HPCI in the pressure control mode will remove approximately 37 MWth.

03-1 NRC Exam (as submitted 6/30/04)

85

ID: 03-1 NRC-5913

Points: 1.00

An accident has occured on Unit 3.

- •Three control rods are at position 04, all others are at position 00.
- •Feed pumps have been tripped and cannot be restarted.
- •Two Condensate/Condensate Booster pumps are running.
- •ALL RPV water level indications have been determined to be unreliable.
- •The Unit Supervisor has ordered all 5 ADS valves opened.
- •The NSO reported **ONLY** the Target Rock opened.

•Annunciator 903-3 B-11, HPCI TURB INLET DRN POT LVL HI, is in alarm.

RPV pressure is 60 psig and slowly rising. Drywell pressure is is 2.5 psig.

The NSO reports Target Rock tail-pipe temperature is 230°F.

Based on the above indications, the Unit Supervisor will order the NSO to...

- A. isolate all the steam lines.
- B. initiate the Isolation Condenser.
- C. slowly raise injection flowrate with LPCI.
- D. isolate all the steam lines **EXCEPT** HPCI.

Answer: A

Question 85 Details

Question Type:	Multiple Choice
Topic:	85 DILTS.29502LP023 DEOP 400-1 actions based on indications
System ID:	5913
User ID:	03-1 NRC-5913
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29502LP023
	Reference: DEOP 0400-01, 100, and DEOP 10 Give
	Examinee copy of DEOP 400-01 and DEOP 100 with
	entry conditions blanked out and a copy of the steam

03-1 NRC Exam (as submitted 6/30/04)

tables.

K/A: 295008 EA2.01 3.9 Level: High

Explanation: DEOP 400-01 should begin at 26 since DEOP 100 states if all all control rods are at 04 or less, continue on in DEOP 100. With only 1 ADS valve open, no RFP available, and RPV pressure is NOT greater than 66 psig above drywell pressure, the direction is given to flood up to the MSLs. The indication given by the NSO is that the RPV is flooded to the MSLs based on Target Rock tail-pipe temperature below saturation temperature for RPV pressure and the HPCI drain pot level Hi alarm. The IC will not be initiated due to pressure already being low in the RPV. The HPCI steam line would NOT be left unisolated because HPCI is NOT needed for injection and would be isolated (below 100 psig RPV pressure). LPCI is NOT needed for injection since indications are that RPV level is up to the MSLs using only the available Cond/Cond Booster pumps. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5849

Points: 1.00

Which of the following REQUIRES notification of the Site Vice President per OP-AA-106-101, Significant Event Reporting?

- A. The NRC has requested a copy of the Unit 3 Abnormality Log.
- B. An Operator cuts his finger requiring on-site medical attention.
- C. An Unusual Event is declared due to exceeding River Discharge Limits.
- D. Chemistry reports that two RWCU samples have Action Level 1 parameters.

Answer: C

Question 86 Details

Question Type:	Multiple Choice
Topic:	86 DILTS.299L136 Generic: Requirements to notify the Site VP
System ID:	5849
User ID:	03-1 NRC-5849
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE299L136
	Reference: OP-AA-106-101 and EP-MW-114-100
	K/A: 295017 2.1.14 3.3
	Level: Recall
	Explanation: Per OP-AA-106-101, When an ENS phone
	call is made, the Site VP must be notified. Chemistry
	levels must be at action level II, off-site medical
	attention needed, and the NRC non-routine and major

enforcement actions require Site VP notifications.

Pedigree: New for ILT 03-1 NRC exam.

86

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5922

Points: 1.00

Instrument Air on Unit 3 has been lost to the Scram Discharge Volume (SDV) vent and drain valves.

Unit 3 remains at 100% power.

87

It is expected that the SDV vent and drain valves will fail...

- A. CLOSED and be INOPERABLE since the SDV would be isolated from the scram outlet header.
- B. CLOSED and be INOPERABLE since proper venting and draining of the SDV could NOT be assured.
- C. CLOSED and remain OPERABLE since the reactor coolant system would be isolated from the containment.
- D. OPEN and be INOPERABLE since the reactor coolant system could NOT be isolated from the containment.

Answer: B

Question 87 Details

Question Type:	Multiple Choice
Topic:	87 DILTS.278LN001.12 IA: Loss of inst air to SDV vent
System ID:	5922
Liser ID.	03-1 NRC-5922
Status:	Active
Must Appear:	No
Difficulty:	
Time to Complete:	0.00
Point Value:	1 00
Cross Deference:	1.00
Closs Reference.	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE203LN001.02
	Reference: DOA 4700-01 and ITS 3.1.8 Bases.
	K/A: 295019 2.1.28 2.9
	Level: High
	Explanation: The SDV would close, for them to be operable they must be able to be opened and closed.
	Pediaree: Dresden 2002 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5886

Points: 1.00

DOS 2300-03, High Pressure Coolant Injection System Operability and Quarterly IST Verification Test, is in progress.

Unit 2 is at rated conditions with recorder TIRS 2-1640-200A, TORUS TEMP MON DIV I OOS due to a failed power supply.

TIRS 2-1640-200B currently indicates the following:

Point 1 Tor	us Bay 14 110	J⁰F	Point 5	Torus Bay 6	111ºF
Point 2 Tor	us Bay 13 104	4°F	Point 6	Torus Bay 5	109°F
Point 3 Tor	us Bay 10 108	3°F	Point 7	Torus Bay 2	104°F
Point 4 Tor	us Bay 9 103	3°F	Point 8	Torus Bay 1	107°F

Given the current conditions, the Torus is (1) and (2).

	1	2
A.	inoperable	immediately suspend DOS 2300-03.
B.	inoperable	immediately place the Mode Switch in Shutdown.
C.	inoperable	immediately reduce thermal power to less that or equal to 1% RTP.
D.	operable	NO actions are required at this time.

Answer: A

Question 88 Details

Question Type:	Multiple Choice
Topic:	88 DILTS.Torus temp monitor A oos, TS requirements with HPCI surv in progress
System ID:	5886
User ID:	03-1 NRC-5886
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 223L-S1-9
	Reference: ITS 3.6.2.1 and 295L-S2
	K/A: 295013 AA2.01 4.0

03-1 NRC Exam (as submitted 6/30/04)

Level: High

Explanation: Bulk water temperature is the average of points 1 through 8. Average water temperature would be 107°F. Immediately suspend all testing that adds heat to the suppression pool. The requirement of ITS section 3.6.2.1 specifically states that the temperature is average temperature, not the highest of any one area. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5871

Points: 1.00

The following conditions exist:

89

- •Unit 3 Recirc piping has a leak.
- •Drywell pressure is 11 psig and steady.
- •The LPCI system is being used for Torus sprays.
- •RPV pressure is 250 psig and steady.
- •RFPs are NOT available.
- •HPCI is being used for pressure and level control.
- •RPV water level is +20 inches and steady.

The Unit 3 NSO reports Torus water level has been trending up and is now 18.5 feet.

Based on the above conditions, what are the Unit Supervisors actions?

- A. Leave HPCI running, it is needed for core cooling.
- B. Secure HPCI injection **ONLY.** Control level with LPCI.
- C. Secure HPCI injection and blow down. Control level with the Condensate system.
- D. Secure HPCI injection **AND** Torus sprays. Control level with the Condensate system.

Answer: B

Question 89 Details

Question Type:	Multiple Choice
Topic:	89 DILTS.206L007 High level in torus, Unit Supervisor
	actions.
System ID:	5871
User ID:	03-1 NRC-5871
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE206L007
	Reference: DEOP 200-1 Give the examinees a copy of
	DEOP 200-01 with the entry conditions blanked out.
	K/A: 295029 A1.01 3.5
	Level: High
	Explanation: DEOP 200-1 has the Operators stop

03-1 NRC Exam (as submitted 6/30/04)

injection from outside the primary containment not needed for core cooling or to shut down the reactor. Reactor pressure is low enough that the LPCI system can provide water for injection and pressure can be controlled with the iso cond. The Torus sprays should not be secured due to drywell pressure being 11 psig. They do not need to be secured since their suction source is from the torus. HPCI is NOT needed for core cooling, LPCI can provide that function. There is no need to blow down yet since level should NOT continue to rise since water from outside containment is no longer being used for vessel makeup. Condensate system would not be used for makeup since it would be making the torus level problem worse.

03-1 NRC Exam (as submitted 6/30/04)

90

ID: 03-1 NRC-5892

Points: 1.00

The following conditions exist:

•Unit 2 and 3 are at full rated power.
•2/3 A SBGT SELECT control switch is in A PRI.
•2/3 B SBGT SELECT control switch is in B STBY.

The NSO reports:

•RX BLDG VENT CH A AND B process rad monitors on the 902-10 panel indicate 16 mR/hr.
•B SBGT train is running.
•RX BLDG TO ATMOS DP, 2-5740-22, indicates -0.1 inch of water and is steady.
•B SBGT system flow is 3000 scfm.

Based on the above conditions the Unit Supervisor will direct:

- A. Placing an OPERABLE SGT subsystem in operation immediately.
- B. Restoring one SGT subsystem to OPERABLE status within 1 hour.
- C. Restoring SGT subsystem to OPERABLE status within 7 days.
- D. Monitoring the SGT system for proper operation.

Answer: B

Question 90 Details

Question Type:	Multiple Choice
Topic:	90 DILTS.261LN001.07 SBGT: Operability with failure to
	start and low rx bldg dp
System ID:	5892
User ID:	03-1 NRC-5892
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE261LN001.07
	Reference: TS 3.6.4.3, DAN 902(3)-3 A-3 Provide a
	copy of TS3.6.4.3 with IMMEDIATE completion times
	blanked out.
	K/A: 295034 EA1.04 4.2
	Level: High

03-1 NRC Exam (as submitted 6/30/04)

Explanation: Per surveillance requirement 3.6.4.3.3 a SGT subsystem must actuate on an actual or simulated initiation signal. The rad level is above the RBV setpoint for tripping and the SGT system to start (\leq 4 mR/hr). The A SGT train should have started since it was in PRI. Since it did not it is inoperable. The SGT system is designed to maintain the secondary containment at a negative pressure of \geq 0.25 inches of water per 3.6.4.3 Bases, so the B SGT train is also inoperable. This meets the requirements for Condition D, and requires the restoration of one SGT subsystem to operable within 1 hr.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5918

Points: 1.00

An ATWS condition exists on Unit 3 with the following conditions:

•RPV pressure is 1000 psig.

91

•RPV water level has been lowered to -140 inches.

•APRMs indicate Reactor power is 5.8%.

Based on the above conditions, the Unit Supervisor will order the NSO to...

- A. immediately begin lowering RPV water level until the APRMs indicate downscale to ensure the Reactor is shutdown.
- B. immediately begin depressurizing the RPV in order to facilitate raising RPV water level to ensure the core has adequate cooling.
- C. wait until RPV pressure is less than 850 psig and then raise RPV water level to ensure the core is adequately cooled.
- D. wait until SBLC tank level drops to 14% prior to depressurizing the RPV to ensure the Reactor will stay shutdown once the cooldown begins.

Answer: D

Question 91 Details

Question Type: Topic:	Multiple Choice 91 DILTS.29502LK039 DEOP 400-5: US actions and reason for cold shutdown boron weight
System ID:	5918
User ID:	03-1 NRC-5918
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29502LK039
	Reference: DEOP 400-5, DRE LP295L-S08, DAN 902(3)-5 C-6 Give the student a copy of the DEOP charts with the entry conditions and SBLC tank percent values for cold shutdown boron weight 14% blanked out. K/A: 295037 EK3.05 3.7 Level: High Explanation: When the SBLC tank has lowered to 14%

03-1 NRC Exam (as submitted 6/30/04)

the cold shutdown weight of boron has been injected and the Reactor will remain shutdown under all conditions irregardless of rod position or RPV water temp. There is No guidance to continue lowering water level until IRMs indicate below Range 7.

The water level has been intentionally lowered to -140 inches in an attempt to lower Reactor power so the Unit Supervisor will NOT want to raise level yet. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

92 ID: 03-1 NRC-5924 Points: 1.00 Unit 3 is operating at rated conditions. •HPCI is running for a surveillance. •CRD exercising is in progress. •RWCU is rejecting 100 gpm to the Main Condenser for a post maintenance test. •Off Gas system is in a normal lineup. The FIRST offsite release indication due to a Fuel Element Failure would come from the (1) If the combined release rate has been stabile at 9.0E+5 µCi/sec for 20 minutes, the Unit Supervisor would order the NSO to isolate (2). 2 1 Isolate RWCU blowdown AND HPCI Α. 2/3 Chimney SPING Β. 2/3 Chimney SPING Isolate RWCU blowdown ONLY C. Reactor Building Chimney SPING Isolate RWCU blowdown AND HPCI D. Reactor Building Chimney SPING Isolate RWCU blowdown ONLY Answer: A **Question 92 Details** Question Type: **Multiple Choice** Topic: 92 DILTS.29502LP016 DEOP 300-1: Indentify possible source of leak and actions to take. System ID: 5924 User ID: 03-1 NRC-5924 Status: Active Must Appear: No Difficulty: 0.00 Time to Complete: 0 Point Value: 1.00 Cross Reference: User Text: User Number 1: 0.00 User Number 2: 0.00 Comment: Objective: DRE29502LP016 Reference: DEOP 300-2, EP-AA-1004 Table R-1 of DR 3-6 Give the examinees a copy of table R1 from EP-

AA-1004 of DR 3-6 K/A: 295038 A2.04 4.5 Level: High Explanation: The HPCI system is drawing steam directly off of the Reactor and SBGT is running discharging to

03-1 NRC Exam (as submitted 6/30/04)

the 2/3 Chimney so that is where the offsite release will be noticed first. Off Gas will have to go through the 6 hr holdup volume prior to going through the stack. The CRD exercising will not elevate release rates at all since no breach of containment is indicated. DEOP 300-2 directs isolating all primary system discharges outside the primary and secondary containment, of which the only one going on is the RWCU discharge to the main condenser.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5885

Points: 1.00

Unit 2 is in cold shutdown for a Main Turbine outage. Unit 3 is in hot shutdown.

•A large fire occured between the turbine lube oil sumps due to an oil leak.

•The fire brigade was on the scene and covered the equipment in the area with water and foam.

•The deluge piping in the area was damaged and had to be isolated.

Based on the equipment damaged by the fire and fire fighting activities, which of the following describes the fire watch requirements, if any?

- A. Continuous fire watch with backup fire suppression equipment.
- B. Hourly fire watch with backup fire suppression equipment.
- C. Once per 8 hour fire watch with backup fire suppression equipment.
- D. A fire watch is NOT required.

Answer: A

Question 93 Details

Question Type: Topic:	Multiple Choice 93 DILTS.299L019 requirements	Fire	at	SBGT,	fire	watch
System ID:	5885					
User ID:	03-1 NRC-5885					
Status:	Active					
Must Appear:	No					
Difficulty:	0.00					
Time to Complete:	0					
Point Value:	1.00					
Cross Reference:						
User Text:						
User Number 1:	0.00					
User Number 2:	0.00					
Comment:	Objective: 299L019					
	References: TRM 3.7	'.j and	Tec	h Spec	3.6.4.3	3 Give
	examinees a copy of	TRM3	.7.j			
	K/A: 600000 AA2.14	3.6				
	Level: High					
	Explanation: Per TS	3.6.4.3	, SB	GT is re	quirec	to be
	operable when a Unit i	is in M	ode 1	I, 2, 3. Gi	ven U	Init 3 is
	currently in Mode 3 (F	lot Shi	utdov	vn) it is re	equire	d to be
	operable. Given the U2	2 and 3	Turk	pine Build	ing Co	ommon
	Mezzanine Area We	et Pipe	e Sp	rinkler S	ystem	ı (534'

93

03-1 NRC Exam (as submitted 6/30/04)

elevation) is inoperable, TRM 3.7.j states a continuous fire watch with backup fire fire suppression equip must be established within 1 hour whenever equipment protected by the suppression system is required to be operable.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5865

Points: 1.00

Following the Unit 3 quarterly SBLC flow test for the 'A' SBLC pump, you receive a report that the results of the required concentration analysis are as follows:

•Tank Volume is 3890 gallons.

94

•Sodium Pentaborate Concentration is 15.6%.

•Tank Temperature is 103^o F.

Select the statement below that describes the actions required by the Technical Specifications:

- A. Restore concentration of boron in solution to within acceptable operating region within 8 hours of failure to meet the LCO, or else place the plant in cold shutdown within 12 hours.
- B. Restore concentration of boron in solution to within acceptable operating region within 7 days of failure to meet the LCO, or else place the plant in hot shutdown within 12 hours.
- C. Restore concentration of boron in solution to within acceptable operating region within 8 hours of failure to meet the LCO, or else place the plant in hot shutdown within 12 hours.
- D. No actions are required. Power operations may continue.

Answer: D

Question 94 Details

Question Type:	Multiple Choice
Topic:	94 DILTS.29501LP048 Generic: SBLC tech spec call
	based on chemistry report
System ID:	5865
User ID:	03-1 NRC-5865
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LP048
	Reference: Tech Spec 3.1.7 Provide copy of TS 3.1.7
	K/A: Generic 2.1.25 3.1
	Level: High
	Explanation: Based on information provided, Conditions
	on Fig. 3.1.7-2. Sodium Pentaborate Temperature

03-1 NRC Exam (as submitted 6/30/04)

Requirements, are acceptable. The Sodium Pentaborate Concentration, % by Weight (Fig. 3.1.7-1) is within the Acceptable Operating Region as well.

Pedigree: Modified from Pilgrim 2003 NRC exam question.

Following the quarterly SBLC flow test for the 'A' SBLC pump, you receive a report that the results of the required concentration analysis are as follows:

-Tank Volume 4226 gallons

-% Sodium Pentaborate 8.32

-Tank Temperature 68 degrees F

Select the statement below that describes the actions required by the Technical Specifications:

Restore concentration of boron in solution to within limits within 72 hours AND 10 days from discovery of failure to meet the LCO, or else place the plant in hot shutdown within 12 hours.

The plant must be placed in cold shutdown condition within 24 hours.

If the isotopic enrichment of Boron-10 is above 54.4 atom percent then a shutdown can be avoided if the sodium pentaborate solution meets the original design criteria.

Power operation may continue for the next 7 days provided that the 'B' SBLC pump passes the flow rate test immediately and daily thereafter.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5909

Points: 1.00

Unit 2 is at rated conditions.

95

DOS 1500-10, LPCI System Pump Operability Test with Torus Available and Inservice Testing (IST) Program, is in progress.

The A loop of the LPCI surveillance has been completed with all readings within the Acceptance Criteria.

The NSO was increasing flow in the B loop when the NLO called and requested the NSO stop flow adjustments due to an abnormal sound in the area.

The SRO walks over to the 902-3 panel to receive an update and notes the following parameters which have been steady for 2 minutes:

•2-1501-11B, HX BYPASS VLV CLOSED
•2-1501-13B, MIN FLOW VLV OPEN
•2-1501-18B, 19A TORUS SPRAY VLV CLOSED
•2-1501-20B, TORUS CLG/TEST OPEN
•2-1501-21B, LPCI VLV OPEN
•2-1501-22B. INJ VLV CLOSED
•Computer point C255, 2B LPCI FLOW, indicates 3050 gpm and steady.

The NSO reports the 2-1501-38B, TORUS CLG/TEST, valve is currently throttled open for 17 seconds.

Based on the above indications, the LPCI system is currently...

- A. inoperable due to the 11B valve being closed.
- B. inoperable due to the 13B valve being open.
- C. inoperable due to the 38B valve being throttled open for 17 seconds.
- D. operable.

Answer: D

Question 95 Details

Question Type:	Multiple Choice
Topic:	95 DILTS.203LN001.07 LPCI: Given lineup, abnormality
	and TS(min flow open)
System ID:	5909
User ID:	03-1 NRC-5909

03-1 NRC Exam (as submitted 6/30/04)

Status: Must Appear: Difficulty: Time to Complete: Point Value:	Active No 0.00 0 1.00
Cross Reference: User Text:	1.00
User Number 1:	0.00
Comment:	Objective: DRE203LN001.07 Reference: TS 3.3.5.1, DOS 1500-10, and Fig 203LN001-001 Provide a copy of TS 3.3.5.1 with completion times less than 1 hr blanked out. K/A: Generic 2.1.31 3.9 Level: High
	Explanation: The failure of the min flow valve to go closed does not render the system inoperable. The bases state that the min flow valve is only required to be operable in the open direction. Performance of the system is based on the valve not going closed. The low flow (bypass) does NOT pertain to the HX bypass valve. The 38B valve is allowed to be throttled open for 36 seconds prior to the system having to be declared inoperable. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

96

ID: 03-1 NRC-5923

Points: 1.00

The HPCI system isolation channel functional test is scheduled to begin early on day shift.

This will require entry into a (1) short duration time clock (SDTC). It is the responsibility of the Unit Supervisor to (2).

	1	2
A.	six hour	prepare the applicable SDTC ONLY
В.	twelve hour	prepare the applicable SDTC ONLY
C.	twelve hour	prepare and track the applicable SDTC
D.	six hour	prepare and track the applicable SDTC

Answer: A

Question 96 Details

Question Type: Topic:	Multiple Choice 96 DILTS.298L070 SDTC preparation, tracking, and logging
System ID:	5923
User ID:	03-1 NRC-5923
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE298L070
	Reference: OP-AA-108-104, TS 3.3.6.1 Bases
	K/A: Generic 2.2.23 3.8
	Level: Recall
	Explanation: TS 3.3.6.1 Bases state that when an
	instrument channel is placed in an inoperable status
	solely for performance of required surveillances, entry
	into associated Conditions and Required actions may be
	delayed for up to 6 hours provided the associated
	function maintains isolation capability. OP-AA-108-104
	states that it is the responsibility of the RO to log and
	track the SDTC and the responsibility of the Unit
	Supervisor to prepare the SDTC.
	Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

97

ID: 03-1 NRC-5868

Points: 1.00

The following conditions exist.

- The plant is in REFUEL with a spiral offload in progress.
- •13 fuel bundles remain to be removed.
- Fuel Bundle at location 17-43 is next to be removed.
- SRM 21 indicates 10 cps.
- •SRM 22 indicates 2 cps.
- SRM 23 indicates 2 cps.

•SRM 24 indicates 6 cps.



Which of the following describes the action(s) to be taken for the above stated conditions AND why?

- A. Continue spiral offload. Only 2 operable SRMs are required to be operable with one in the quadrant where core alterations are being performed.
- B. Continue spiral offload. No SRM is required to be operable in an adjacent quadrant with less than or equal to 4 fuel assemblies.
- C. Immediately suspend fuel moves. Too many SRMs have too low of a count rate.

03-1 NRC Exam (as submitted 6/30/04)

D. Immediately suspend fuel moves. The count rate is too low for the SRM in quadrant of fuel bundle 17-43.

Answer: A

Question 97 Details

Question Type:	Multiple Choice
Topic:	97 DILTS.Generic: Effect of alts on core configuration
System ID:	5868
User ID:	03-1 NRC-5868
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 29502LK018
	Reference: ITS 3.3.1.2 and Bases Provide students a
	copy of TS 3.3.1.2 pages 1-6. with completion times
	less than 1 hour blanked out.
	K/A: 2.2.32 3.3
	Level: High
	Explanation: 2 SRMs are required to be operable. One
	has to be in an adjacent quadrant and one has to be in
	the quadrant where core alterations are being
	performed. This condition is being met by an operable
	SRM 21 and adjacent SRM 24. There is no requirement
	for non-adjacent SRMs to be operable until core
	alterations will take place in that quadrant.

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5879 Points: 1.00

Given the following:

98

•A river discharge is required from the Waste Surge Tank.

•The off-stream liquid effluent monitor is unavailable for use.

Who must authorize this type of river discharge?

- A. Shift Manager AND Health Physics Supervisor.
- B. Shift Manager AND Chemistry Services Supervisor.
- C. Rad Protection Supervisor AND Health Physics Supervisor.
- D. Rad Protection Supervisor AND Chemistry Services Supervisor.

Answer: B

Question 98 Details

Question Type: Topic:	Multiple Choice 98 DSROS.268LN001.14 River Discharge: authorization
Overtexes ID:	required when monitor unavailable
System ID:	5879
User ID:	03-1 NRC-5879
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: 268LN001.14
	References: DOP 2000-111
	K/A: Generic 2.3.3 2.9
	l evel: Recall
	Explanation: DOP 2000-111 Waste Surge Tank
	Padwaste Discharge to Piver with the Off Stream Liquid
	Effluent Meniter Incorreble, requires that permission is
	Endent Monitor Inoperable, requires that permission is
	obtained from the Shift Manager AND Chemistry
	Services Supervisor prior to implementation of the
	procedure. SRO only as stated in task list.
	Pedigree: Dresden Bank (273100)

03-1 NRC Exam (as submitted 6/30/04)

ID: 03-1 NRC-5870

Points: 1.00

Given the following:

99

- •It is 0200 on a Sunday with a Rad Protection Supervisor on site.
- •An Operator must enter the RWCU Demin room to verify a valve position.
- •The dose rate in the area is 315 mrem/hr due to demin vessel drain line flushing. The RWP alarm setpoint is 300 mRem/hr.

In accordance with RP-MW-403-1001, Radiation Work Permit Processing, which of the following would be the **FASTEST** allowable method of entry into the room to verify the valve?

- A. Develop a new RWP.
- B. Perform an RWP field change.
- C. Formally revise the existing RWP.
- D. Make the entry and then document it in the RWP.

Answer: B

Question 99 Details

Question Type:	Multiple Choice
System ID:	5870
User ID:	03-1 NRC-5870
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE295L095
	Reference: RP-MW-403-1001
	K/A: Generic 2.3.7 3.3
	Level: Recall
	Explanation: Since this is not an emergency or for life saving, the entry would not be made until the proper process has been followed. RP-MW-403-1001, allows an RWP to be Field changed if the work is of short duration and the scope of the work is NOT significantly changed. Developing a new RWP or formally revising the existing RWP is NOT the quickest way to allow entry. Pedigree: New for 03-1 NRC exam.

03-1 NRC Exam (as submitted 6/30/04)

03-1 NRC Exam (as submitted 6/30/04)

100

ID: 03-1 NRC-5906

Points: 1.00

Unit 2 was at rated conditions when "ANNUN DC PWR FAILURE" alarms are received on several panels simultaneously.

A bell inside 902-4 sounds.

Which of the following describes the expected operator actions?

- A. Verify that the normal AC power supply is still available by performing an annunciator checks on each effected panel. Notification of the Shift Manager is NOT required.
- B. Verify that the normal AC power supply is still available by performing an annunciator checks on each effected panel. Notification of the Shift Manager is required.
- C. Determine the cause of the loss of annunciators. The Shift Manager should evaluate for a possible GSEP condition.
- D. Scram the reactor due to the loss of annunciators. The Shift Manager should evaluate for a possible GSEP condition.

Answer: C

Question 100 Details

Question Type:	Multiple Choice
Topic:	100 DILTS.29501LP059: Knowledge of operator response to loss of all annunciators
System ID:	5906
User ID:	03-1 NRC-5906
Status:	Active
Must Appear:	No
Difficulty:	0.00
Time to Complete:	0
Point Value:	1.00
Cross Reference:	
User Text:	
User Number 1:	0.00
User Number 2:	0.00
Comment:	Objective: DRE29501LP059
	Reference: 902(3)-5 H-3
	K/A: Generic 2.4.32 3.5
	Level: High
	Explanation: Receipt of these alarms indicates a failure
	of the panels Annunciator System. Operators should
	determine the cause of the loss of annunciators and
	attempt to restore. The Shift Manager should evaluate for a possible GSEP condition.

03-1 NRC Exam (as submitted 6/30/04)

Pedigree: Dresden 2002 NRC exam.