

×. .

Prairie Island Nuclear Generating Plant Operated by Nuclear Management Company, LLC

OCT 1 3 2004

目的にしいまいれます。

L-PI-04-115 Technical Specification 5.6.4

U S Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Units 1 and 2 Dockets 50-282 and 50-306 License Nos. DPR-42 and DPR-60

Monthly Operating Report - September 2004

Attached is the Monthly Operating Report for September 2004 for the Prairie Island Nuclear Generating Plant.

**Summary of Commitments** 

This letter contains no new commitments and no revisions to existing commitments.

Joseph M. Solvmossy

Site Vice President, Prairie Island Nuclear Generating Plant Units 1 and 2 Nuclear Management/Company, LLC

Enclosure (1)

cc: Regional Administrator, USNRC, Region III Project Manager, Prairie Island Nuclear Generating Plant, USNRC, NRR NRC Resident Inspector, Prairie Island Nuclear Generating Plant Glenn Wilson, State of Minnesota

TER

しい 一般 長知 たち 和田内

5 . . .

### ENCLOSURE 1

.

.

## **MONTHLY OPERATING REPORT - SEPTEMBER 2004**

	120 Q. 199	1.24 1.	17.10 21	<b>t</b> .	• • • • · · · ·
		~	the production		
1 1 1 1 1	. 14° .		SUPPON	•	Sec. March March 19
Carrie T	5 <b>3</b> - 1		actor ,	•. •.	and the second second
Alter Parts			real Elements	•	

n an as the construction of the second of as the construction of the second of the second of the second of the Res 1999 - Argentized and the construction of the second second second second second second second second second BLG - Argentized and the second se

-

٤.

PRINTED 10/11/2004 Page 1

DOCKET NO. 50-282

UNIT PRAIRIE ISLAND NO. 1

1. DATE 10/11/2004

COMPLETED BY BRIAN GLENNIE

PHONE 651-388-1121-4442

### NARRATIVE SUMMARY OF OPERATING EXPERIENCE

### MONTH: SEPTEMBER 2004

On 9/09/2004, Unit 1 Reactor experienced a power reduction due to #33 Inverter trip. The inverter trip caused the four Moisture Separator Reheater supply valves to close resulting in Bank D control rods to step in 11 steps causing reactor power to decrease 7%. Approximately 2 1/2 hours later, Bank D control rods were stepped out to increase reactor power to previous levels. Reactor power was restored within 12 hours of the event occurrence. The resultant loss of generation was 258 MWe-hrs. And a second second second 01-

During part of the month of September, Unit 1 was base loaded. Unit 1 continued coast down in preparation for 1R23 outage. On 9/1/2004, load was 442 MWe. Unit 1 Generator was taken off line on 9/10/2004 at 20:31:10 CDT to begin 1R23 Outage. Outage ended a continuous run of 509 days.

. . .

na tha na sa 14.11 (F. 14) 1.1.1 ME . . .

. C. . . 

 $i \rightarrow i$ 1.100

11 : . . . THE A STREET STREET

۶.

<u>/</u>, i

PRINTED 10/6/2004 Page 2

.

DOCKET NO. 50-282 UNIT PRAIRIE ISLAND NO. 1

DATE 10/6/2004 COMPLETED BY BRIAN GLENNIE PHONE 651-388-1121-4442

OPERATING DATA REPORT

#### OPERATING STATUS

1. UNIT NAME:	PRAIRIE ISLAND NO. 1			
2. REPORTING PERIOD:	SEPTEMBER 🔆 2004	in the second		1.1.
3. LICENSED THERMAL P	OWER (MWT): 1650	. ^ ^	1	
4. NAMEPLATE RATING (	GROSS MWE): 593			
5. DESIGN ELECTRICAL F	ATING (NET MWE): 536			
6. MAXIMUM DEPENDABL	E CAPACITY (GROSS MWE): Column	5.6697 <b>554</b> C.A.		
	E CAPACITY (NET MWE):	2 <b>522</b> 🖏		1. A
8. IF CHANGES OCCUR IN	N CAPACITY RATINGS (ITEMS 3 - 7)	) SINCE LAST REPOR	T, GIVE REAS	SON:
NONE				

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NONE

:

#### 10. REASONS FOR RESTRICTIONS, IF ANY: NONE

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	720	6575	269927
12. NUMBER OF HOURS REACTOR CRITICAL	236.7	6091.7	235071.1
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	5571.1
14. HOURS GENERATOR ON-LINE	236.5	6091.5	232954.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	289067	9732589	372133773
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	98200	3321660	122001160
18. NET ELECTRICAL ENERGY GENERATED (MWH)	88869	3135374	114895462
19. UNIT SERVICE FACTOR	32.8	92.6	86.3
20. UNIT AVAILABILITY FACTOR	· 32.8	92.6	86.3
21. UNIT CAPACITY FACTOR (MDC NET)	23.6	91.4	83.7
22. UNIT CAPACITY FACTOR (DER NET)	23.0	89.0	80.1
23. UNIT FORCED OUTAGE RATE	0.0	0.0	4.4
24. FORCED OUTAGE HOURS	0.0	0.0	10603.1

:

•

ريجه

:

#### DOCKET NO. 50-282 UNIT PRAIRIE ISLAND NO. 1

DATE 10/11/2004 COMPLETED BY BRIAN GLENNIE PHONE 651-388-1121-4442

### NAME NO PARTIES OF AN EXAMPLE UNIT SHUTDOWNS AND POWER REDUCTIONS

### MONTH: SEPTEMBER 2004

States and

DATE	UNIT	TYPE	HOURS	REAS	ON 1 METHOD	LER NUMBER	R SYSTEM	COMPONENT
9/1/2004	1	S	0	C	5012-14 <b>5</b>	N/A	N/A	N/A
NOTES:	Coa	st down i	n preparation for 1R2		<b>ge.</b> 10 1	1. Jac	•	
9/9/2004	1	F	· 0	~			EE ·	INVT
NOTES:	#33	INV trip,	MSR supply valves o	losed, i	Reactor power de	creased 7%.	1 A	
9/10/2004	'1	S	483.5	C	2	N/A	N/A	N/A
NOTES: '	Unit	1 taken o	483.5 off line for start of 1R	23 outa	ge ten a chuir		· · · · · · ·	

TYPE	REASON	METHOD	SYSTEM CODE
F-FORCED	A-EQUIPMENT FAILURE	1-MANUAL	DRAFT IEEE STD
S-SCHEDULED	B-MAINTENANCE OR TEST	2-MANUAL TRIP	800-1984(P805-D5)
	C-REFUELING	3-AUTO TRIP	
	D-REGULATORY RESTRICTION	4-CONTINUED	
	E-OPERATOR TRAINING AND LICENSE EXAMINATION	5-REDUCED LOAD	COMPONENT CODE
	LICENSE EXAMINATION	9-OTHER	IEEE STD 803A-1983
	F-ADMINISTRATIVE		
	G-OPERATIONAL ERROR		
	H-OTHER		

5

20

PRINTED 10/11/2004 Page 4

DOCKET NO. 50-306 UNIT PRAIRIE ISLAND NO. 2

DATE 10/11/2004 COMPLETED BY BRIAN GLENNIE PHONE 651-388-1121-4442

#### NARRATIVE SUMMARY OF OPERATING EXPERIENCE

#### MONTH: SEPTEMBER 2004

·

During the month of September, Unit 2 was base loaded.

On 9/20/2004, Unit 2 experienced a power reduction due to work being done on a Station and Instrument Air pipe leak. Upon isolation of the air supply in support of the work activity, a heating steam control valve to the deaerator closed, opening up an air path from the deaerator vent back to Unit 2 Condenser. Condenser vacuum dropped, causing generator output to fall from 562 to 544 MWe. A plant operator re-aligned deaerator drains to the turbine building sump allowing condenser vacuum to quickly return to previous levels. Generator output was restored to previous levels within 1 hour, 7 minutes of event start. Loss of generation was 9.5 MWe-hrs.

222.

62		e e r		ME.	÷ :		
¥ (	•	• 7	s NU				
				$\langle 0 \rangle$	• • •	(B. C.BAR	· · ·
						• :•	
					•••		
a the state of the state	· · · · ·	• •					
	• •	÷ :					
· · · · · · · · · · · · · · · · · · ·	•	•			•		,
· · · · ·	<b>`</b>						
n an							
•							

*....*-

\*

PRINTED 10/6/2004 Page 5

DOCKET NO. 50-306 UNIT PRAIRIE ISLAND NO. 2

\_\_\_\_

DATE 10/6/2004 COMPLETED BY BRIAN GLENNIE PHONE 651-388-1121-4442

#### **OPERATING DATA REPORT**

GET HEROLD AT LOOK SECURITIONS

1. UNIT NAME: PRAIRIE ISLAND NO. 2   2. REPORTING PERIOD: SEPTEMBER SE 2004 (cm)	the second se
3. LICENSED THERMAL POWER (MWT): 1650	
4. NAMEPLATE RATING (GROSS MWE): 593 5. DESIGN ELECTRICAL RATING (NET MWE): 536	C- Patrice
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE):	554
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE):	522
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 - 7) SI NONE	INCE LAST REPORT, GIVE REASON:
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE)	: NONE

10. REASONS FOR RESTRICTIONS, IF ANY: NONE

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	720	6575	261045
12. NUMBER OF HOURS REACTOR CRITICAL	720.0	6575.0	232799.8
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	1516.1
14. HOURS GENERATOR ON-LINE	720.0	6575.0	231045.6
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	1185143	10793671	370273639
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	403110	3692650	120519080
18. NET ELECTRICAL ENERGY GENERATED (MWH)	380792	3495697	113966571
19. UNIT SERVICE FACTOR	100.0	100.0	88.5
20. UNIT AVAILABILITY FACTOR	100.0	100.0	88.5
21. UNIT CAPACITY FACTOR (MDC NET)	101.3	101.9	86.2
22. UNIT CAPACITY FACTOR (DER NET)	98.7	99.2	82.2
23. UNIT FORCED OUTAGE RATE	0.0	0.0	2.7
24. FORCED OUTAGE HOURS	0.0	0.0	6435.4
		• . •	

.

a . . . .

· :

ب 🗠 تخشینی

PRINTED 10/11/2004 Page 6

DOCKET NO. 50-306 UNIT PRAIRIE ISLAND NO. 2

DATE 10/11/2004 COMPLETED BY BRIAN GLENNIE PHONE 651-388-1121-4442

### UNIT SHUTDOWNS AND POWER REDUCTIONS

# MONTH: SEPTEMBER 200

DATE	UNIT	TYPE	HOURS	REASON	METHOD	LER NUMBER	SYSTEM	COMPONENT
9/20/2004	2	F	0	В	5	N/A	LF	HCV
NOTES	: Powe	Power loss due to Unit 2 condenser vacuum loss-maintenance activity.						

TYPE	REASON	METHOD	SYSTEM CODE
F-FORCED	A-EQUIPMENT FAILURE	1-MANUAL	DRAFT IEEE STD
S-SCHEDULED	<b>B-MAINTENANCE OR TEST</b>	2-MANUAL TRIP	800-1984(P805-D5)
	C-REFUELING	3-AUTO TRIP	
	D-REGULATORY RESTRICTION	4-CONTINUED	
	E-OPERATOR TRAINING AND	5-REDUCED LOAD	COMPONENT CODE
	LICENSE EXAMINATION	9-OTHER	IEEE STD 803A-1983
	F-ADMINISTRATIVE		
	G-OPERATIONAL ERROR		
	H-OTHER		