

OCT 1 2 2004

L-2004-219 10 CFR 50.36

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

Re:

Turkey Point Unit 3

Docket No. 50-250

Core Operating Limits Report

In accordance with Technical Specification 6.9.1.7, the attached Core Operating Limits Report is provided for Turkey Point Unit 3. These curves are applicable for Unit 3 Cycle 21.

Should there be any questions, please contact Walter Parker, Licensing Manager, at 305-246-6632.

Very truly yours,

Terry O. Jones

Site Vice President

Turkey Point Nuclear Plant

OIH

Attachment

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC

A001

## **CORE OPERATING LIMITS REPORT - UNIT 3 CYCLE 21**

The Technical Specifications (TS) affected by this report are:

| 3.1.3.2 | Analog Rod Position Indication System                     |
|---------|---|
| 3.1.3.6 | Control Rod Insertion Limits                              |
| 3.2.1   | Axial Flux Difference (AFD)                               |
| 3.2.2   | Heat Flux Hot Channel Factor - FQ(Z)                      |
| 3.2.3   | Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}$ |

The Control Rod Insertion Limits, AFD,  $F_Q(Z)$ , K(Z), and  $F_{\Delta H}$  have been developed using the NRC approved methodology specified in TS 6.9.1.7.

## TS 3.1.3.2 Analog Rod Position Indication System

The All Rods Out position for all Shutdown Banks and Control Banks is defined to be 230 steps withdrawn.

## TS 3.1.3.6 Control Rod Insertion Limits

The control rod banks shall be limited in physical insertion as shown on Figure 1 for All Rods Out = 230 steps withdrawn.

## TS 3.2.1 Axial Flux Difference

The AFD limits are provided on Figure 2.

TS 3.2.2 Heat Flux Hot Channel Factor - 
$$F_0(Z)$$

$$[F_O]^L = 2.50$$

K(Z) = 1.0 for 0 ft.  $\leq Z \leq 12$  ft. where Z =core height.

TS 3.2.3 Nuclear Enthalpy Rise Hot Channel Factor

$$F_{\Lambda H}^{RTP} = 1.70$$

$$PF_{\Lambda H} = 0.3$$



