

Britt T. McKinney
Vice President-Nuclear Site Operations

PPL Susquehanna, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.3149 Fax 570.542.1504
btmckinney@pplweb.com



OCT 11 2004

U. S. Nuclear Regulatory Commission
Attn: Document Control Center
Mail Station OP1-17
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
10 CFR 50.46 – ANNUAL REPORT
PLA-5827

Docket Nos. 50-387
and 50-388

*Reference: Letter from B. L. Shriver (PPL) to the U. S. Nuclear Regulatory Commission,
"10 CFR 50.46 – Annual Report," dated October 31, 2003 (PLA-5687).*

This report is being sent in accordance with 10 CFR 50.46 (a)(3)(ii). 10 CFR 50.46(a)(3)(ii) requires (in part) annual reporting of changes to or errors in evaluation models used for calculating Emergency Core Cooling System (ECCS) performance, and an estimate of their effect on the limiting ECCS analysis. Additionally, a proposed schedule is required for reanalysis or identification of other actions necessary to show compliance with 10 CFR 50.46 requirements.


The ECCS performance evaluation methodology applicable to both Susquehanna SES Unit 1 and Unit 2 is the Framatome-ANP EXEM/BWR LOCA Analysis. Since the submittal of the last annual 10 CFR 50.46 report (Reference 1), there have been no non-zero PCT changes reported to PPL Susquehanna, LLC. Thus, the current licensing basis PCT remains valid and no further actions are required. This letter meets the annual reporting requirement.

PPL Susquehanna, LLC will continue to track future changes to the evaluation models used in the applicable LOCA analysis methods to ensure that the PCT values remain below the 10 CFR 50.46 limit, and to ensure that the 10 CFR 50.46 reporting requirements are met.

A001

Please contact Mr. Rocco R. Sgarro, Manager – Nuclear Regulatory Affairs at (610) 774-7552, if there are any questions concerning this letter.

Sincerely,

A handwritten signature in black ink, appearing to read "B. T. McKinney". The signature is written in a cursive style with a large initial "B" and a long, sweeping underline.

B. T. McKinney

copy: NRC Region I

Mr. A. J. Blamey, NRC Sr. Resident Inspector

Mr. R. V. Guzman, NRC Project Manager

Mr. R. Janati, DEP/BRP