

November 1, 2004

Mr. James F. Klapproth, Manager  
Engineering & Technology  
GE Nuclear Energy  
175 Curtner Avenue  
San Jose, CA 95125

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION – LICENSING TOPICAL  
REPORT NEDC-32983P-A, "GENERAL ELECTRIC METHODOLOGY FOR  
REACTOR PRESSURE VESSEL FAST NEUTRON FLUX EVALUATION"  
(TAC NO. MC3788)

Dear Mr. Klapproth:

By letters dated July 14 and September 10, 2004, GE Nuclear Energy (GENE) provided information to support the removal of limitations regarding BWR shroud fluence calculations in the subject licensing topical report. The NRC staff has reviewed this information and has prepared the enclosed request for additional information (RAI). This request was discussed with Mike Lalor of your staff and it was agreed that a response would be provided within 60 days of receipt of this letter.

If you have any questions regarding this RAI, please contact me at (301) 415-1445.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 710

Enclosure: Request for Additional Information

cc w/encl: See next page

November 1, 2004

Mr. James F. Klapproth, Manager  
Engineering & Technology  
GE Nuclear Energy  
175 Curtner Avenue  
San Jose, CA 95125

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION – LICENSING TOPICAL  
REPORT NEDC-32983P-A, "GENERAL ELECTRIC METHODOLOGY FOR  
REACTOR PRESSURE VESSEL FAST NEUTRON FLUX EVALUATION"  
(TAC NO. MC3788)

Dear Mr. Klapproth:

By letters dated July 14 and September 10, 2004, GE Nuclear Energy (GENE) provided information to support the removal of limitations regarding BWR shroud fluence calculations in the subject licensing topical report. The NRC staff has reviewed this information and has prepared the enclosed request for additional information (RAI). This request was discussed with Mike Lalor of your staff and it was agreed that a response would be provided within 60 days of receipt of this letter.

If you have any questions regarding this RAI, please contact me at (301) 415-1445.

Sincerely,

**/RA/**

Alan B. Wang, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Project No. 710

Enclosures: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC  
PDIV-2 Reading  
RidsNrrDlpmLpdiv (HBerkow)  
RidsNrrPMAWang  
RidsNrrPMMFields  
RidsNrrLAEPeyton  
RidsNrrDssaSrx (LLOis)  
FAskstulewicz  
RidsOgcRp  
RidsAcrsAcnwMailCenter

**ACCESSION NO.: ML042940656**

**NRR-088**

OFFICE	PDIV-2/PM	PDIV-2/LA	SXRB/SC	PDIV-2/SC
NAME	AWang:mp	DBaxley	FAkstulewicz	RGramm
DATE	10/25/04	10/22/04	10/29/04	11/1/04

DOCUMENT NAME: E:\Filenet\ML042940656.wpd

OFFICIAL RECORD COPY

GE Nuclear Energy

Project No. 710

cc:

Mr. George B. Stramback  
Regulatory Services Project Manager  
GE Nuclear Energy  
175 Curtner Avenue  
San Jose, CA 95125

Mr. Charles M. Vaughan, Manager  
Facility Licensing  
Global Nuclear Fuel  
P.O. Box 780  
Wilmington, NC 28402

Mr. Glen A. Watford, Manager  
Nuclear Fuel Engineering  
Global Nuclear Fuel  
P.O. Box 780  
Wilmington, NC 28402

REQUEST FOR ADDITIONAL INFORMATION

LICENSING TOPICAL REPORT NEDC-32983P-A, "GENERAL ELECTRIC METHODOLOGY  
FOR REACTOR PRESSURE VESSEL FAST NEUTRON FLUX EVALUATION"

GE NUCLEAR ENERGY (GENE)

PROJECT NO. 710

1. By letter dated July 14, 2004, GENE provided information and requested removal of the limitations regarding vessel fluence calculations in licensing topical report (TR) NEDC-32983P-A. The U.S. Nuclear Regulatory Commission (NRC) staff requests that GE provide the measured and calculated values in Figure A of the July 14, 2004, letter in a tabular form.
  
2. By letter dated September 10, 2004, GENE, supplemented the July 14, 2004, letter and provided additional information to support its request for removal of limitations regarding boiling water reactor (BWR) shroud fluence calculations in the licensing TR. Due to the limited information provided in the submittal, the NRC staff requests the following additional information:
  - a. Please clarify the purpose of this submittal and the basis for any request.
  
  - b. The main issue with the existing shroud calculations in the NEDC-32983P-A topical is the axial bias of the C/M values. The submittal indicates a radial dependence of the samples but does not indicate that there is elevation dependence of the samples. Given that the axial shroud weld cracking, attributed to irradiation assisted stress corrosion, is an important BWR issue, how do you justify lifting the limitation?
  
  - c. The samples were taken from two BWR4 plants H and V. Why is it appropriate to generalize these results to all BWRs?
  
  - d. The currently submitted data were from samples irradiated in the early 1990s, why was the data not part of the initial submittal? Are the old data to be ignored?