

Final Results for Palo Verde

- FV/UR's on average within plus/minus 20%

<u>Parameter</u>	<u>Plant PRA</u>	<u>SPAR Enhanced</u>	<u>SPAR 3i</u>
CDF	1.4E-05	1.2E-05	1.79E-05
Truncation	2E-11	1E-11	1E-15
<u>Contributors</u>			
Transients	35%	39%	26%
Loss of 4KV	29%	24%	0
SGTR	12%	6%	30%
Loss of MFW/COND	7%	9%	0
LOOP	7%	11%	34%
LOCA	4%	3%	7%
Loss of DC	2%	4%	1%
Other	3%	4%	1%
ISLOCA	<1%	<1%	<1%

B/2

K