

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

October 22, 2004

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 04-647A
NL&OS/ETS R0
Docket No. 50-281
License No. DPR-37

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
SURRY POWER STATION UNIT 2
WITHDRAWAL OF PROPOSED EMERGENCY TECHNICAL SPECIFICATION
CHANGE FOR ONE TIME EXTENSION OF THE COMPLETION TIME FOR
THE LOW HEAD SAFETY INJECTION (LHSI) TRAIN B

In an October 20, 2004 letter (Serial No. 04-647), Dominion requested an emergency amendment of the Facility Operating License, in the form of changes to the Technical Specifications to Facility Operating License Number DPR-37 for Surry Power Station Unit 2. Surry Unit 2 entered the 72-hours Allowed Outage Time of TS 3.3.B.3 at 1157 hours on October 19, 2004. The proposed change requested a revision to Technical Specification (TS) 3.3.B.3 to permit a one-time 7-day Allowed Outage Time to complete the repair of a leak on the "B" Low Head Safety Injection pump seal package which had rendered the pump inoperable. However, maintenance activities for repair of the pump seal package were completed and the "B" Low Head Safety Injection Pump was returned to service at 0638 hours on October, 22, 2004. Therefore, Dominion is withdrawing the proposed emergency Technical Specification change.

If you have any further questions or require additional information, please contact Mr. Thomas Shaub at (804) 273-2763.

Very truly yours,



Leslie N. Hartz
Vice President – Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Commissioner
Bureau of Radiological Health
1500 East Main Street
Suite 240
Richmond, VA 23218

Mr. N. P. Garrett
NRC Senior Resident Inspector
Surry Power Station

Mr. S. R. Monarque
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8-H12
Rockville, MD 20852