

From: David Loveless
To: Don Marksberry
Date: Thu, Jul 1, 2004 1:20 PM
Subject: Re: EOPs

40EP-9EO07, "Loss of Offsite Power/Loss of Forced Circulation," Revision 10

The copy I have has no place for a date.

>>> Don Marksberry 07/01/04 12:04PM >>>
David, Just the title and date is all I need for the ASP report.

Thanks.

>>> David Loveless 07/01/04 12:16PM >>>
Don,

EOP 9, does direct the operators to start the GTGs and load them. I can send you a portion of the procedure, but I need your fax number again.

David

>>> Don Marksberry 07/01/04 08:48AM >>>
David,

Do the EOPs instruct the operators to ensure or request that GTG are started and loaded given an LOOP? I want to make sure that recovery of power is a single action and not two independent actions (i.e., GTG/swtichyard operators and control room operators). If it's in the EOPs, then a single XHE is sufficient.

Do you have the EOPs handy that you could e-mail or send a copy to me?

B/40