

From: David Loveless
To: Don Marksberry
Date: Mon, Jun 28, 2004 10:18 AM
Subject: Re: S/U transformer soak times

My man says the same. Let's go with barely enough time to get offsite power within one hour.

Thanks,

David

>>> Don Marksberry 06/28/04 09:57AM >>>

Per Bill, a transformer that has been powered down on the high side (such as a startup transformer) for an hour or two (due to a LOOP) does not need soaking.

Soaking is important for cold transformers, which includes moisture and oil testing in addition to no load soak time.

B/32