

More Data

Gerald W. Sowers
PRA Section Leader
Palo Verde Nuclear Generating Station
Phone: 623-393-5647
gsowers@apsc.com

-----Original Message-----

From: Sowers, Gerald W(Z90174)
Sent: Tuesday, June 29, 2004 12:34 PM
To: David Loveless (dpl@nrc.gov)
Cc: Hamden Jr, Willard J(Z99687); Hulet, Mark A(Z52238); Lindquist Jr, Robert C(Z60942)
Subject: Gas Turbine Failures

David,

I said I would send more descriptive data on our gas turbine failures.
The numbers may not be completely consistent with what I provided earlier because we have changed rules for counting valid demands and failures. They should be similar.

Failure to Start

<u>Year</u>	<u>Demands</u>	<u>Failures</u>
1993	16	3
1994	63	6
1995	54	3
1996	80	6
1997	73	3
1998	47	4
1999	33	0
2000	48	3
2001	35	0
2002	33	0
2003	44	0
2004	8	0

Failure to Run

<u>Year</u>	<u>Failures</u>	<u>Run Hours</u>
1993	0	
1994	0	
1995	0	
1996	2	77.4
1997	0	54.4
1998	0	37.5
1999	0	31.6

B135

1

2000	0	39.3
2001	0	46.1
2002	0	36.5
2003	1	67
2004	0	7.8

Gerald W. Sowers
PRA Section Leader
Palo Verde Nuclear Generating Station
Phone: 623-393-5647
gsowers@apsc.com