

From: <DSTRAKA@apsc.com> Don Straka  
To: <atg@nrc.gov> Anthony Gady  
Date: 7/6/04 1:09PM  
Subject: FW: Oil Lift Pump

Tony:

Enclosed is information on the RCP thermal overload settings.

There was a question should the RCP starting procedures have a CAUTION statement regarding the lift pumps:

Procedure 40OP-9RC01 section 3.7 cautions that the lift pump must be run 7 minutes prior to starting the RCP and follow on sections for starting RCPs (4.3.18 for example) also contain a step for starting each pump.

Regards,  
Don Straka  
Senior Consultant - Regulatory Affairs  
dstraka@apsc.com  
phone: 623.393.5041  
pager: 602.509.6240  
mobile: 602.509.6240

> -----Original Message-----

> From: Custodio, Prudencio B(Z99694)  
> Sent: Tuesday, July 06, 2004 10:28 AM  
> To: Sahay, Prem P(Z83476); Withers, Douglas W(Z98444); Holmes, John J(Z98811); Kesler, Steven L(Z55768); Straka, Donald J(Z99942)  
> Subject: Oil Lift Pump  
>  
>  
> <<White Paper Oil Lift Pump.doc>>  
> Prem,  
> Here's my input.  
>  
> Thanks,  
> Denny

CC: <DMAULDIN@apsc.com>, <JTAYLO01@apsc.com>, <SKESLER@apsc.com>, <PBCUSTOD@apsc.com>, <DWITHERS@apsc.com>, <JHOLME01@apsc.com>, <Z75655@apsc.com>, <NHENRY01@apsc.com>

Cl48