

**From:** <GSOWERS@apsc.com>  
**To:** <dpl@nrc.gov>  
**Date:** Tue, Jun 29, 2004 2:35 PM  
**Subject:** Gas Turbine Failures

David,

I said I would send more descriptive data on our gas turbine failures. The numbers may not be completely consistent with what I provided earlier because we have changed rules for counting valid demands and failures. They should be similar.

#### Failure to Start

Year	Demands	Failures
1993	16	3
1994	63	6
1995	54	3
1996	80	6
1997	73	3
1998	47	4
1999	33	0
2000	48	3
2001	35	0
2002	33	0
2003	44	0
2004	8	0

#### Failure to Run

Year	Failures
1993	0
1994	0
1995	0
1996	2
1997	0
1998	0
1999	0
2000	0
2001	0
2002	0
2003	1
2004	0

Gerald W. Sowers  
PRA Section Leader  
Palo Verde Nuclear Generating Station  
Phone: 623-393-5647  
gsowers@apsc.com

**CC:** <WHARNDEN@apsc.com>, <MHULET@apsc.com>, <BLINDQUI@apsc.com>

B/36

David,

I said I would send more descriptive data on our gas turbine failures. The numbers may not be completely consistent with what I provided earlier because we have changed rules for counting valid demands and failures. They should be similar.

**Failure to Start**

<u>Year</u>	<u>Demands</u>	<u>Failures</u>
1993	16	3
1994	63	6
1995	54	3
1996	80	6
1997	73	3
1998	47	4
1999	33	0
2000	48	3
2001	35	0
2002	33	0
2003	44	0
2004	8	0

**Failure to Run**

<u>Year</u>	<u>Failures</u>
1993	0
1994	0
1995	0
1996	2
1997	0
1998	0
1999	0
2000	0
2001	0
2002	0
2003	1
2004	0

Gerald W. Sowers  
PRA Section Leader  
Palo Verde Nuclear Generating Station  
Phone: 623-393-5647  
gsowers@apsc.com