

EXELON GENERATION COMPANY, LLC

DOCKET NO. 50-237

DRESDEN NUCLEAR POWER STATION, UNIT 2

RENEWED FACILITY OPERATING LICENSE NO. DPR-19

1. The U.S. Nuclear Regulatory Commission (Commission) having previously made the findings set forth in License No. DPR-19 issued on February 20, 1991, has now found that:
 - A. The application to renew License No. DPR-19 filed by the Exelon Generation Company, LLC* (the licensee) complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I, and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the Dresden Nuclear Power Station, Unit 2 (the facility) has been completed in conformity with Construction Permit No. CPPR-18 and the application, as amended, the provisions of the Act, and the regulations of the Commission, and has been operating under a provisional license since December 22, 1969;
 - C. Actions have been identified and have been or will be taken with respect to (1) managing the effects of aging during the period of extended operation on the functionality of structures and components that have been identified to require review under 10 CFR 54.21(a)(1), and (2) time-limited aging analyses that have been identified to require review under 10 CFR 54.21(c), such that there is reasonable assurance that the activities authorized by this renewed operating license will continue to be conducted in accordance with the current licensing basis, as defined in 10 CFR 54.3, for Dresden Nuclear Power Station, Unit 2 (facility or plant), and that any changes made to the plant's current licensing basis in order to comply with 10 CFR 54.29(a) are in accord with the Act and the Commission's regulations;
 - D. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission (except as exempted from compliance in Section 2.D below);

*The Nuclear Regulatory Commission approved the transfer of the license from Commonwealth Edison Company to Exelon Generation Company, LLC on August 3, 2000.

- E. There is reasonable assurance: (i) that the activities authorized by this renewed operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I (except as exempted from compliance in Section 2.D below);
 - F. Exelon Generation Company, LLC, is technically qualified to engage in the activities authorized by this renewed operating license in accordance with the rules and regulations of the Commission;
 - G. Exelon Generation Company has satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements," of the Commission's regulations;
 - H. The issuance of this renewed operating license will not be inimical to the common defense and security or to the health and safety of the public;
 - I. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of this Renewed Facility Operating License No. DPR-19 is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied; and
 - J. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this renewed operating license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
2. On the basis of the foregoing findings regarding this facility, Facility Operating License No. DPR-19, issued February 20, 1991, is superseded by Renewed Facility Operating License No. DPR-19, which is hereby issued to Exelon Generation Company, LLC, to read as follows:
- A. This renewed operating license applies to the Dresden Nuclear Power Station, Unit 2, a boiling water reactor and associated equipment (the facility). The facility is located in Grundy County, Illinois, and is described in the licensee's Updated Final Safety Analysis Report, as supplemented and amended, and in the licensee's Environmental Report, as supplemented and amended.
 - B. Subject to the conditions and requirements incorporated herein, the Commission hereby licenses:
 - (1) Exelon Generation Company, LLC, pursuant to Section 104b of the Act and 10 CFR Part 50, to possess, use, and operate the facility at the designated location in Grundy County, Illinois, in accordance with the procedures and limitations set forth in this renewed operating license;

- (2) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Part 70, to receive, possess and use at any time special nuclear materials as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Updated Final Safety Analysis Report, as supplemented and amended;
- (3) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess and use at any time any byproduct, source and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40 and 70, to possess, but not separate, such byproduct special nuclear materials as may be produced by the operation of the facility.

C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2957 megawatts thermal (100 percent rated power) in accordance with the conditions specified herein.

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 211, are hereby incorporated into this renewed operating license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Operation in the coastdown mode is permitted to 40% power.

- (4) The valves in the equalizer piping between the recirculation loop shall be closed at all times during reactor operation.
- (5) The licensee shall maintain the commitments made in response to the March 14, 1983, NUREG-0737 Order, subject to the following provision:

The licensee may make changes to commitments made in response to the March 14, 1983, NUREG-0737 Order without prior approval of the Commission as long as the change would be permitted without NRC approval, pursuant to the requirements of 10 CFR 50.59. Consistent with this regulation, if the change results in an Unreviewed Safety Question, a license amendment shall be submitted to the NRC staff for review and approval prior to implementation of the change.

(6) Surveillance Requirements

The Surveillance Requirements contained in Appendix A Technical Specifications and listed below are not required to be performed immediately upon implementation of Amendment No. 150:

- a. Surveillance Requirement 4.1.A.2 - RPS Logic System Functional Test
- b. Surveillance Requirement 4.2.A.2 - Primary & Secondary Containment Logic System Functional Test
- c. Surveillance Requirement 4.2.J.2 - Feedwater Pump Trip Logic System Functional Test
- d. Surveillance Requirement 4.6.F.1.b - Relief Valve Logic System Functional Test
- e. Surveillance Requirement 4.9.A.9 - Simultaneous Diesel Generator Start
- f. Surveillance Requirement 4.9.A.10 - Diesel Storage Tank Cleaning (Unit 3 and Unit 2/3 only)

Each of the above Surveillance Requirements shall be successfully demonstrated prior to entering into MODE 2 on the first plant startup following the fifteenth refueling outage (D2R15).

(7) Additional Conditions

The Additional Conditions contained in Appendix B, as revised through Amendment No. 191, are hereby incorporated into this renewed operating license. The licensee shall operate the facility in accordance with the Additional Conditions.

(8) Deleted

(9) Fuel Burnup

The maximum rod average burnup for any rod shall be limited to 60 GWD/MTU until the completion of an NRC environmental assessment supporting an increased limit.

(10) Exelon Generation Company, LLC shall provide the Director of the Office of Nuclear Reactor Regulation a copy of any application, at the time it is filed, to transfer (excluding grants of security interests or liens) from Exelon Generation Company, LLC to its direct or indirect parent, or to any other affiliated company, facilities for the production, transmission, or distribution of electric energy having a depreciated book value exceeding ten percent (10%) of Exelon Generation Company, LLC's consolidated net utility plant, as recorded on Exelon Generation Company, LLC's books of account.

(11) Exelon Generation Company, LLC shall have decommissioning trust funds for Dresden, Unit 2, in the following minimum amount, when Dresden, Unit 2, is transferred to Exelon Generation Company, LLC:

| | |
|-----------------|---------------|
| Dresden, Unit 2 | \$288,233,336 |
|-----------------|---------------|

(12) The decommissioning trust agreement for Dresden, Unit 2, at the time the transfer of the unit to Exelon Generation Company, LLC is effected and thereafter, is subject to the following:

(a) The decommissioning trust agreement must be in a form acceptable to the NRC.

(b) With respect to the decommissioning trust fund, investments in the securities or other obligations of Exelon Corporation or affiliates thereof, or their successors or assigns are prohibited. Except for investments tied to market indexes or other non-nuclear sector mutual funds, investments in any entity owning one or more nuclear power plants are prohibited.

- (c) The decommissioning trust agreement for Dresden, Unit 2, must provide that no disbursements or payments from the trust shall be made by the trustee unless the trustee has first given the Director of the Office of Nuclear Reactor Regulation 30 days prior written notice of payment. The decommissioning trust agreement shall further contain a provision that no disbursements or payments from the trust shall be made if the trustee receives prior written notice of objection from the NRC.
 - (d) The decommissioning trust agreement must provide that the agreement can not be amended in any material respect without 30 days prior written notification to the Director of the Office of Nuclear Reactor Regulation.
 - (e) The appropriate section of the decommissioning trust agreement shall state that the trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a “prudent investor” standard, as specified in 18 CFR 35.32(a)(3) of the Federal Energy Regulatory Commission’s regulations.
- (13) Exelon Generation Company, LLC shall take all necessary steps to ensure that the decommissioning trust is maintained in accordance with the application for approval of the transfer of the Dresden, Unit 2, license and the requirements of the Order approving the transfer, and consistent with the safety evaluation supporting the Order.
- (14) Exelon Generation Company, LLC shall relocate certain Technical Specification requirements to EGC-controlled documents upon implementation of the Amendment No. 185. The items and appropriate documents are as described in Table LA, “Removal of Details Matrix,” and Table R, “Relocated Specifications,” that are attached to the NRC’s Safety Evaluation enclosed with Amendment No. 185.
- (15) The schedule for performing Surveillance Requirements (SRs) that are new or revised in Amendment No. 185 shall be as follows:
- For SRs that are new in this amendment, the first performance is due at the end of the first surveillance interval that begins on the date of implementation of Amendment No. 185.
- For SRs that existed prior to this amendment whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of Amendment No. 185.

For SRs that existed prior to this amendment that have modified acceptance criteria, the first performance is due at the end of the first surveillance interval that began on the date the surveillance was last performed prior to the implementation of Amendment No. 185.

For SRs that existed prior to this amendment whose intervals of performance are being extended, the first extended surveillance interval begins upon completion of the last surveillance performed prior to implementation of Amendment No. 185.

- (16) Following implementation of Amendment No. 185, the reactor protection system trip setpoint for main steam isolation valve closure shall be maintained at the previous setpoint (less than or equal to 10% closed) until startup after the first outage of sufficient duration to change the setpoint.
- (17) The license is amended to authorize changing the UFSAR to allow credit for containment overpressure as detailed below, to assure adequate Net Positive Suction Head is available for low pressure Emergency Core Cooling System pumps following a design-basis accident.

| From (sec) | To (sec) | Credit (psig) |
|----------------|--------------|---------------|
| Accident start | 290 | 9.5 |
| 290 | 5,000 | 4.8 |
| 5,000 | 30,000 | 6.6 |
| 30,000 | 40,000 | 6.0 |
| 40,000 | 45,500 | 5.4 |
| 45,500 | 52,500 | 4.9 |
| 52,500 | 60,500 | 4.4 |
| 60,500 | 70,000 | 3.8 |
| 70,000 | 84,000 | 3.2 |
| 84,000 | 104,000 | 2.5 |
| 104,000 | 136,000 | 1.8 |
| 136,000 | Accident end | 1.1 |

- D. The facility has been granted certain exemptions from the requirements of Section III.G of Appendix R to 10 CFR Part 50, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979." This section relates to fire protection features for ensuring the systems and associated circuits used to achieve and maintain safe shutdown are free of fire damage. These exemptions were granted and sent to the licensee in letters dated February 2, 1983, September 28, 1987, July 6, 1989, and August 15, 1989.

In addition, the facility has been granted certain exemptions from Sections II and III of Appendix J to 10 CFR Part 50, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors." This section contains leakage test

requirements, schedules and acceptance criteria for tests of the leak-tight integrity of the primary reactor containment and systems and components which penetrate the containment. These exemptions were granted and sent to the licensee in a letter dated June 25, 1982.

These exemptions granted pursuant to 10 CFR 50.12 are authorized by law, will not present an undue risk to the public health and safety, and are consistent with the common defense and security. With these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.

- E. The licensee shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report for the facility and as approved in the Safety Evaluation Reports dated March 22, 1978 with supplements dated December 2, 1980, and February 12, 1981; January 19, 1983; July 17, 1987; September 28, 1987; and January 5, 1989, subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

- F. The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, guard training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The plan, which contains Safeguards Information protected under 10 CFR 73.21, is entitled: "Dresden Nuclear Power Station Security Plan," with revisions submitted through October 30, 1990; "Dresden Nuclear Power Station Security Personnel Training and Qualification Plan," with revisions submitted through October 30, 1990; and "Dresden Nuclear Power Station Safeguards Contingency Plan," with revisions submitted through October 30, 1990. Changes made in accordance with 10 CFR 73.55 shall be implemented in accordance with the schedule set forth therein.
- G. The licensee shall report any violations of the requirements contained in Section 2, Items C(1), C(3), and C(4) of this license in the following manner: initial notification shall be made within 24 hours to the NRC Operations Center via the Emergency Notification System with written follow-up within 30 days in accordance with the procedures described in 10 CFR 50.73(b), (c), and (e).

H. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

I. Updated Final Safety Analysis Report

The Exelon Generation Company, LLC Updated Final Safety Analysis Report supplement, submitted pursuant to 10 CFR 54.21(d), describes certain future activities to be completed prior to the period of extended operation. The Exelon Generation Company, LLC shall complete these activities no later than December 22, 2009, and shall notify the NRC in writing when implementation of these activities is complete and can be verified by NRC inspection.

The Updated Final Safety Analysis Report supplement, as revised, shall be included in the next scheduled update to the Updated Final Safety Analysis Report required by 10 CFR 50.71(e)(4) following issuance of this renewed license. Until that update is complete, Exelon Generation Company, LLC may make changes to the programs and activities described in the supplement without prior Commission approval, provided that Exelon Generation Company, LLC evaluates such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

J. All capsules in the reactor vessel that are removed and tested must meet the test procedures and reporting requirements of ASTM E 185-82 to the extent practicable for the configuration of the specimens in the capsule. Any changes to the capsule withdrawal schedule, including spare capsules, must be approved by the NRC prior to implementation. All capsules placed in storage must be maintained for future insertion.

3. This renewed operating license is effective as of the date of issuance and shall expire at midnight on December 22, 2029.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Attachments:

1. Appendix A – Technical Specifications
2. Appendix B – Additional Conditions

Date of Issuance: October 28, 2004

Renewed License No. DPR-19