



Comanche Peak Steam Electric Station – Unit 1 Steam Generator Replacement Project

Anticipated Licensing Actions

October 19, 2004

Purpose of Discussions



- **Introduce key personnel**
- **Present SG Replacement Plans for CPSES-1**
- **Provide scopes and schedules of anticipated licensing actions**

Personnel Introductions



- **SG Replacement Project Manager**

- Ben Mays
 - 254-897-6816

rmays1@txu.com

- **Safety Analysis Manager**

- Whee Choe
 - 214-812-4371

wchoe1@txu.com

- **Engineering and Safety Analysis Point of Contact**

- James Boatwright
 - Consulting Nuclear Project Manager
 - 214-812-8232

jboatwright@txu.com

- **Regulatory Affairs Point of Contact**

- Bob Kidwell
 - 254-897-5310

rkidwell@txu.com

Agenda



- **Overview of Replacement SG Design Features**
- **Expected Effects on Analytical Methodologies**
- **Expected Changes to Technical Specifications**
- **Other Licensing Actions**
- **Tentative Schedules**
- **General Discussions**

Comanche Peak Steam Electric Station – Unit 1



- **4-loop Westinghouse Plant with large dry containment**
- **Part of two-unit site with shared control buildings**
- **Originally rated at 3411 MWth, now at 3458 MWth with MUR uprate**
- **Current SG: Westinghouse D-4 with integral preheater**
 - **Approximately 3% tube plugging level**

Replacement SG Design Features



- **Westinghouse ?76 feed ring design**
- **Similar to ?75 design in use at Shearon Harris and V.C. Summer**


RSG Design Features



RSG Design: Overview of Design Features

ENSA
Equipos Nucleares, S.A.

- Forged elliptical head with integral nozzle (eliminates nozzle weld)
- Auxiliary feedwater nozzle
- Inspection ports above each TSP (maintenance enhancement)
- Four 6 – inch handholes Above tubesheet (maintenance enhancement)
- Support ring to match existing supports



- Major nozzles with extra stock (aids installation)
- Relocated main feedwater nozzle on upper shell (Feeding RSG with simplified operation vs. OSG with preheater)
- Forged transition cone with cylindrical upstands (eliminates ISI welds)
- Forged shell barrels (minimizes ISI welds)
- Primary nozzle with safe end extension (aids installation)




RSG Design Overview



RSG Design: Overview of Design Features

ENSA
Equipos Nucleares, S.A.




- Peerless single tier secondary separators (enhancement for reduced moisture carryover)
- High capacity primary separators (enhancement for reduced moisture carryover)
- Elevated feedring with Alloy 690 spray nozzles (mitigates stratification and water hammer; traps loose parts)
- Enhanced materials throughout (high strength pressure boundary, Alloy 690 used, erosion resistant material in high velocity regions)
- Tubesheet secondary side tubelane free of obstructions (maintenance enhancement)

RSG Design Overview



RSG Design: Overview of Design Features

ENSA
Equipos Nucleares, S.A.




- Enhanced tube bundle with thermally treated Alloy 690 tubing
 - 5532 tubes with 0.75" OD and on ? pitch
 - Increased heat transfer area (76000 sq ft)
 - Provides for reduced T-hot operation
 - Provides margin for potential power uprate
- Field proven minimum gap AVB system
- Stainless steel broached tube support plates
- Increased secondary side circulation ratio (mitigates sludge deposition on tubes, tube dryout, tube degradation mechanisms)
- Enhanced tube to tubesheet joint




RSG: Design Overview

- Elevated feedring with top discharge nozzles
- Nozzle holes sized to trap loose parts
 - Hole diameter less than tube to tube clearance



Feedwater Distribution System



SG Comparisons



- **Relative to D-4 SG, the ?76 has:**
 - **76,000 ft² heat transfer area (vs. 48,000 ft²)**
 - **Essentially the same exterior envelope**
 - **Separate MFW and AFW piping**
 - **5532 U-tubes (vs. 4578)**
 - **3/4" tube OD (same)**
 - **1.03" triangular pitch (vs. 1.0625" square pitch)**
 - **Top of tube bundle 8 ft higher**

- **Relative to D-4 SG, the ?76 has:**
 - **5330 ft³ Shell-side volume (vs. 5954 ft³)**
 - **Increased Tube Side Volume**
 - **Approximately 1300 ft³ additional RCS volume**
 - **~ 13% increase**
 - **Circulation Ratio of ~ 4 (vs. ~2.4)**
 - **Slightly larger secondary fluid mass**
 - **251" narrow range water level span (vs. 233")**

Changes to Operating Strategies



- **Generically, design for a T_{avg} range of 589.2°F – 574.2°F , but:**
- **Limit Steam Pressure to 1000 psia**
 - Initially, set full power $T_{avg} \sim 585^{\circ}\text{F}$ @ 3458 MWth
 - Raise T_{avg} toward 589.2°F as SG heat transfer capability decreases (due to fouling or tube plugging)
- **Design to a much tighter T_{avg} range (e.g., $\pm 1^{\circ}\text{F}$) on cycle-specific basis**
- **Lower values of T_{avg} are intended for future use in T_{avg} coastdown**

Effects on FSAR Chapter 15 Analytical Methods



- **Chapter 15 Analytical Methods:**
 - Developed by CPSES
 - Approved by NRC
 - Listed in TS 5.6.5
 - (Core Operating Limits Report)
- **Primary Affected Transients and Accidents:**
 - FLB, LOAC, LOFW, MSLB
 - LOCAs (SB and LB)
 - SGTR

Methods for Non-LOCA Transients and Accidents



- **SG Model Changes:**
 - Approved CPSES SG model is coarse; includes explicit preheater representation; recirculation is not modeled
 - Chose to adopt feed ring SG model developed by Westinghouse
 - Uses RETRAN-02
 - Benchmarked against plant data
 - Methodology reviewed and approved by NRC
 - **WCAP-14882-P-A**

Affected non-LOCA Transients and Accidents



- **Feedline Break**
 - Due to elevated feed ring, initial transient similar to steamline break
 - Ensuing heat-up similar to original SG transient
 - Detailed model with circulation requires use of dP model to simulate steam generator water level trip functions
 - vs. mass, as described in the CPSES topical
- **No fundamental methodology differences**
 - Conservative initial conditions and system performance characteristics, backed up by sensitivity studies

- **Loss of non-emergency power to the station auxiliaries (Loss of AC power)**
 - Different SG model – no methodology changes
- **Loss of Normal Feedwater**
 - Different SG model – no methodology changes
- **Main Steamline Break**
 - Update existing simplified SG model with new dimensions; use existing methodology
- **SG tube rupture**
 - Update existing simplified SG model with new dimensions; use existing methodology

- **LBLOCA Methodology**
 - No methodology effects
 - New SG model
- **SBLOCA Methodology**
 - New SG noding consistent with non-LOCA model
 - Small modification to reactor vessel upper plenum model

Topical Report Supplements



- **RXE-91-001-A, "Transient Analysis Methods for Comanche Peak Steam Electric Station Licensing Applications", October 1993.**
- **To be supplemented to address more detailed SG model, SG Water Level indication, and Feedwater Line Break response**
- **Will continue to be used to support Unit 2**

Topical Report Supplements (cont.)



- ERX-2000-002-P, "Revised Large Break Loss of Coolant Accident Analysis Methodology", March 2000.
- RXE-95-001-P-A, "Small Break Loss of Coolant Accident Analysis Methodology," September 1996.
- ERX-2001-005-P, "ZIRLO™ Cladding and Boron Coating Models for TXU Electrics Loss of Coolant Accident Analysis Methodologies", October 2001.
- All to be supplemented (with a single supplement) to describe model changes per 10CFR50.46
- All will continue to be used to support Unit 2

Expected Technical Specification Changes



- **Reactor Trip System and ESFAS:**
 - **TS Table 3.3.1-1 and TS Table 3.3.2-1 and associated Bases Tables:**
 - **SG Water Level – low-low and high-high**
 - **Main Steamline Pressure – low**
 - **Allowable Values in the TS Tables**
 - **Nominal Trip Setpoints in the TS Bases Tables**
 - **AVs and NTSs calculated per methodology described in TS Bases**

Expected Technical Specification Changes (cont.)



- **SG Tube Surveillance Program**
 - **TS 5.5.9**
 - **Remove those allowances established for the Unit 1 SGs that are not applicable to the Unit 2 SGs**
 - **No new requirements anticipated specifically for the ?76 SGs**
 - **May adopt TSTF-449, Rev. 1, for both CPSES units via separate licensing action**

Expected Technical Specification Changes (cont.)



- **Core Operating Limits Report (COLR)**
 - **TS 5.6.5**
 - Update lists of methodologies used to determine the core operating limits with new CPSES Topical Supplements
- **Pressure and Temperature Limits Report (PTLR)**
 - **TS 5.6.6**
 - Resolve previous commitment to update methodology with WCAP-14040-P-A, Revision 4.

Other Potential Licensing Actions



- **General update of radiological dose consequences methodologies to be consistent with RG 1.195**
 - **Pending results of Engineering Analysis and ensuing 10CFR50.59 Evaluation**
- **General reviews of methodologies used throughout the RSG project**
 - **Methods identified to date have been previously approved by the NRC for the intended application, pending results of 10CFR50.59 Evaluation**

Tentative Schedule



- Spring 2007 Install replacement SGs
- February 2007 NRC approval of RSG-related licensing actions
- Spring 2006 Submit any License Amendments identified through 10CFR50.59 Evaluations
- Winter 2006 NRC Approval of Topical Report Supplements
- Fall 2005 Submit Proposed TS changes
- December 2004 Submit Topical Report Supplements (Presentation to NRC reviewers ~ 30 days later)

General Discussions



- Questions?