

November 30, 2004

Mr. Gordon Bischoff, Manager
Owners Group Program Management Office
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

SUBJECT: DRAFT SAFETY EVALUATION FOR TOPICAL REPORT WCAP-15973-P,
REVISION 01, "LOW-ALLOY STEEL COMPONENT CORROSION ANALYSIS
SUPPORTING SMALL-DIAMETER ALLOY 600/690 NOZZLE
REPAIR/REPLACEMENT PROGRAM" (TAC NO. MB6805)

Dear Mr. Bischoff:

By letter dated May 20, 2004, the Westinghouse Owners Group (WOG) submitted Topical Report (TR) WCAP-15973-P, Revision 01, "Low-alloy Steel Component Corrosion Analysis Supporting Small-diameter Alloy 600/690 Nozzle Repair/Replacement Program" to the staff for review. Approval of the TR was requested in order that licensees seeking relief to use half-nozzle or mechanical nozzle seal assembly (MNSA) repair methods may reference the TR as part of their basis for using the alternate repair methods on leaking Alloy 600 nozzles in the primary pressure boundary of Combustion Engineering plants. Enclosed for the WOG's review and comment is a copy of the staff's draft safety evaluation (SE) for WCAP-15973-P, Revision 01.

Pursuant to 10 CFR 2.390, we have determined that the enclosed draft SE does not contain proprietary information. However, we will delay placing the draft SE in the public document room for a period of ten working days from the date of this letter to provide you with the opportunity to comment on the proprietary aspects. If you believe that any information in the enclosure is proprietary, please identify such information line-by-line and define the basis pursuant to the criteria of 10 CFR 2.390. After ten working days, the draft SE will be made publicly available, and an additional ten working days are provided to you to comment on any factual errors or clarity concerns contained in the SE. The final SE will be issued after making any necessary changes and will be made publicly available. The staff's disposition of your comments on the draft SE will be discussed in the final SE.

G. Bischoff

- 2 -

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

Sincerely,

/RA/

Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl:
Mr. James A. Gresham, Manager
Regulatory Compliance and Plant Licensing
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

G. Bischoff

- 2 -

November 30, 2004

To facilitate the staff's review of your comments, please provide a marked-up copy of the draft SE showing proposed changes and provide a summary table of the proposed changes.

Sincerely,
/RA/

Robert A. Gramm, Chief, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Project No. 694

Enclosure: Draft Safety Evaluation

cc w/encl:
Mr. James A. Gresham, Manager
Regulatory Compliance and Plant Licensing
Westinghouse Electric Company
P.O. Box 355
Pittsburgh, PA 15230-0355

DISTRIBUTION:
PUBLIC (No DPC Folder for 10 working days)
PDIV-2 Reading
RidsNrrDlpmLpdiv (HBerkow)
RidsNrrPMGShukla
RidsNrrLAEPeyton
SCoffin
JHoncharik
CSheng
RidsOgcRp
RidsAcrsAcnwMailCenter

ADAMS Accession No.: ML043090373

NRR-106

OFFICE	PDIV-2/PM	PDIV-2/LA	EMCB/SC	PDIV-2/SC
NAME	GShukla	EPeyton	SCoffin	RGramm
DATE	11/23/04	11/23/04	10/4/04*	11/30/04

OFFICIAL RECORD COPY

DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

WCAP-15973-P, REVISION 01, "LOW-ALLOY STEEL COMPONENT CORROSION

ANALYSIS SUPPORTING SMALL-DIAMETER ALLOY 600/690

NOZZLE REPAIR/REPLACEMENT PROGRAM"

WESTINGHOUSE OWNERS GROUP

PROJECT NO. 694

1 1.0 INTRODUCTION

2 Vessels and piping in the reactor coolant pressure boundary of pressurized water reactors
3 (PWRs) are fabricated either from A 302, Grade B; SA 533, Grade B; or SA 508, Grade B
4 low-alloy steels (for fabrication of vessels), or SA 516, Grade 70 carbon steel (for the fabrication
5 of piping). These materials are classified as ferritic steel materials. These components are
6 typically clad on their internal surfaces using austenitic stainless steels to isolate the ferritic
7 material from the primary coolant, thereby minimizing corrosion and corrosion product release
8 into the coolant. Alloy 600 nozzles that penetrate through these components are typically
9 joined to the vessels or piping using partial penetrating J-groove welds that are fabricated from
10 Alloy 82/182 weld materials. These welds penetrate completely through the cladding and
11 partially into the ferritic portions of the vessels or piping. Therefore, in the as-built condition, the
12 ferritic material is not exposed to the borated primary coolant water. Inservice industry
13 experience has demonstrated that these Alloy 600 nozzles and Alloy 82/182 welds are
14 susceptible to primary water stress corrosion cracking (PWSCC) resulting in through-wall/weld
15 cracks. The half-nozzle and the mechanical nozzle seal assembly (MNSA) repairs leave the
16 through-wall cracks intact and potentially leaves the ferritic portions of the vessel or piping
17 exposed to borated water.

18 By safety evaluation (SE) dated February 8, 2002, the NRC staff reviewed and approved, with
19 limitations, the use of Topical Report (TR) CE-NPSD-1198-P, Revision 00, "Low-Alloy Steel
20 Component Corrosion Analysis Supporting Small-Diameter Alloy 600/690 Nozzle
21 Repair/Replacement Program" submitted by the Combustion Engineering Owners Group
22 (CEOG) on February 15, 2001. The CEOG was integrated into the Westinghouse Owners
23 Group (WOG) in 2002. Future references to the owners group will be made to as the WOG.
24 This TR provided an evaluation on potential degradation mechanisms of these repaired
25 components, which included corrosion, stress corrosion cracking and thermal fatigue.

26 By letter dated November 11, 2002, the WOG submitted TR WCAP-15973-P, Revision 00,
27 "Low Alloy Steel Component Corrosion Analysis Supporting Small-Diameter Alloy 600/690
28 Nozzle Repair/Replacement Program" for staff review and approval. The WOG seeks the
29 staff's approval of the TR in order that licensees seeking relief to use half-nozzle or MNSA

1 repair/replacement techniques may reference the TR as part of their basis for using the
2 alternate repair methods on leaking Alloy 600 nozzles in the primary pressure boundary. The
3 TR provides an evaluation on determining corrosion rates, stress corrosion cracking and
4 thermal fatigue relevant to these alternative repair methods. A non-proprietary version of the
5 TR was enclosed along with Calculation Report CN-CI-02-71 (Proprietary), entitled "Summary
6 of Fatigue Crack Growth Evaluation Associated with Small Diameter Nozzles in CE Plants,"
7 dated October 28, 2002. This TR corrected errors in the thermal fatigue calculations reported
8 in CE-NPSD-1198-P, Revision 00. These errors affect the predicted growth of thermal fatigue
9 cracks in limiting locations. In addition, WCAP-15973-P, Revision 00, addressed concerns
10 regarding boric acid corrosion discovered at Davis-Besse in response to NRC Bulletin 2001-01,
11 and also revised the general corrosion rates. Clarifications were also made to the stress
12 corrosion cracking evaluation.

13 By letter dated October 6, 2003, the WOG supplemented the information in the TR with
14 additional information. However, by letter dated March 5, 2004, the WOG withdrew Revision 00
15 to the TR due to errors discovered in the supporting fatigue crack growth analyses. By letter
16 dated May 20, 2004, the WOG submitted TR WCAP-15973, Revision 01, dated May 2004, and
17 the supporting Westinghouse Calculation Report CN-CI-02-71, Revision 01, to correct the
18 errors in Revision 00 of the TR and the calculation report. The WOG provided additional
19 information on the calculation report by letter dated August 11, 2004.

20 2.0 REGULATORY REQUIREMENTS

21 Section 50.55a(g) of Title 10 of the *Code of Federal Regulations* (10 CFR) requires nuclear
22 power facility piping and components to meet the applicable requirements of Section XI of the
23 American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (hereafter
24 referred to as the ASME Code). Currently, 10 CFR 50.55a endorses all versions of the ASME
25 Code, Section XI up to the 1998 Edition through the 2000 Addenda. Although the exact
26 wording may vary depending on the specific edition and addenda of the ASME Code used,
27 Article IWA-4000 requires that existing flaws in ASME Code Class 1 components either be
28 removed in their entirety or, if not removed, evaluated in accordance with the appropriate flaw
29 evaluation provisions of Section XI of the ASME Code. For example, paragraph IWA-4310 of
30 the 1995 Edition, with the 1995 and 1996 Addendum of Section XI to the ASME Code states:

31 Defects shall be removed or reduced in size in accordance with this Paragraph.
32 The component shall be acceptable for continued service if the resultant section
33 thickness created by the cavity is equal to or greater than the minimum design
34 thickness. If the resulting thickness is reduced below the minimum design
35 thickness, the component shall be repaired or replaced in accordance with this
36 Article. Alternatively, the defect removal area and any remaining portion of the
37 flaw may be evaluated and the component accepted in accordance with the
38 appropriate flaw evaluation rules of Section XI or the design rules of the Owner's
39 Requirements and either the Construction Code, or Section III. The
40 Repair/Replacement Program, Plan, and associated evaluation shall be subject
41 to review in accordance with IWA-4140(c).

1 Therefore, if the flaw is to be left in service, an evaluation is required to be performed and
2 reviewed by the NRC, as required by section IWA-4140(c) of the 1995 Edition, with the 1995
3 and 1996 Addendum of Section XI to the ASME Code, which states:

4 The Repair/Replacement Program, Plans, and evaluations required by IWA-
5 4150 shall be subject to review by enforcement and regulatory authorities having
6 jurisdiction at the plant site.

7 In addition, paragraph IWB-3142.4 of the 1995 Edition, with the 1995 and 1996 Addendas of
8 Section XI to the ASME Code provides acceptance requirements for flaws to be left in service
9 as follows:

10 Components containing relevant conditions shall be acceptable for continued
11 service if an analytical evaluation demonstrates the component's acceptability.
12 The evaluation analysis and evaluation acceptance criteria shall be specified by
13 the Owner. Components accepted for continued service based on analytical
14 evaluation shall be subsequently examined in accordance with IWB-2420(b) and
15 (c).

16 IWB-2420(b) and (c) of the 1995 Edition, with the 1995 and 1996 Addendas of Section XI to the
17 ASME Code provides information on performing successive inspections for flaws left in service
18 and accepted by analytical evaluation:

19 If components are accepted for continued service in accordance with IWB-
20 3132.4 or IWB-3142.4, the areas containing flaws or relevant conditions shall be
21 reexamined during the next three inspection periods listed in the schedule of the
22 inspection program of IWB-2400. If the reexamination required by IWB-2400(b)
23 reveals that the flaws or relevant conditions remain essentially unchanged for
24 three successive inspection periods, the component examination schedule may
25 revert to the original schedule for successive inspections.

26 Other editions of the ASME code provide similar guidance. In summary, the ASME Code
27 requires either the removal of the flaw, or the performance of an analysis with subsequent
28 examinations. This TR addresses the latter, by providing corrosion and fatigue analyses of the
29 cracked Alloy 600 nozzle and/or Alloy 82/182 weld since the half-nozzle and MNSA repairs
30 leave the flaw in service.

31 The discovery of leaks and nozzle cracking at the Davis-Besse Nuclear Power Station and
32 other PWR plants has made clear the need for flaw evaluation guidelines for control rod drive
33 mechanism (CRDM) type of penetrations and more effective inspections of reactor pressure
34 vessel (RPV) heads and associated penetration nozzles. To ensure that the inspections are
35 effective, the NRC issued Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure
36 Vessel Head Penetration Nozzles," Bulletin 2002-01, "Reactor Pressure Vessel Head
37 Degradation and Reactor Coolant Pressure Boundary Integrity," Bulletin 2002-02, "Reactor
38 Pressure Vessel Head and Vessel Head Penetration Nozzle Inspection Programs," Information
39 Notice 2003-02, "Recent Experience with Reactor Coolant System Leakage and Boric Acid
40 Corrosion," and Order EA-03-009, "Issuance of Order Establishing Interim Inspection

1 Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactors." Since
2 there is limited flaw evaluation guidelines for these conditions, the NRC developed flaw
3 evaluation guidelines for this application for appropriate use by the industry and the staff. The
4 original guidelines were enclosed in the letter dated November 21, 2001, from the NRC to the
5 Nuclear Energy Institute (NEI), and the revised guidelines were enclosed in the letter dated
6 April 11, 2003, from the NRC to NEI.

7 The TR was reviewed in accordance with the requirements of 10 CFR 50.55a (Section XI of the
8 ASME Code) and the April 11, 2003, guidelines.

9 3.0 EVALUATION

10 WCAP-15973-P, Revision 01, is only applicable to repairs/replacements of leaking Alloy 600
11 nozzles and/or Alloy 82/182 welds in the reactor coolant pressure boundary of Combustion
12 Engineering (CE) plants using either the MNSA or half-nozzle repair/replacement techniques.
13 The use of the half-nozzle or MNSA repair/replacement techniques of WCAP-15973-P,
14 Revision 01 leaves the through-wall crack in the Alloy 600 nozzle and/or Alloy 82/182 J-groove
15 weld intact and potentially allows the ferritic portions of the vessels or piping to be exposed to
16 the borated reactor coolant. WCAP-15973-P, Revision 01, accomplishes the following
17 objectives with respect to implementing these repair or replacement methods:

- 18 1. Provides an acceptable method for calculating the overall general/crevice corrosion rate
19 for the internal surfaces of the low-alloy steel materials that are now potentially exposed
20 to the reactor coolant, and for calculating the amount of time the ferritic portions of the
21 vessel or piping would be acceptable if corrosive wall thinning occurs. (See Section 3.1
22 of this SE for the evaluation.)
- 23 2. Provides an acceptable method of calculating the thermal-fatigue crack-growth life of
24 existing flaws in the Alloy 600 nozzles and/or Alloy 82/182 weld material into the ferritic
25 portion of the vessels or piping. (See Section 3.2 of this SE for the evaluation.)
- 26 3. Provides acceptable bases and arguments for concluding that unacceptable growth of
27 the existing flaw by stress corrosion into the vessel or piping is improbable. (See
28 Section 3.3 of this SE for the evaluation.)

29 The main difference between the half-nozzle and the MNSA repair is that the half-nozzle
30 provides a welded repair on the outside of the component, in contrast to the MNSA repair,
31 which mechanically seals a leak or potential leak on the outside surface of the component.
32 Since the complete alloy 600 nozzles are left in place, the MNSA repair is similar to the
33 half-nozzle condition in that the cracked nozzle and/or weld will remain in place and the crevice
34 regions will be filled with borated water. Therefore, the corrosion and crack growth evaluations
35 of the half-nozzles also applies to the MNSA repairs. However, since this is a mechanical
36 device in lieu of a weld, that provides both sealing and structural integrity for the leaking nozzle,
37 additional justification is required to approve MNSA for a long-term repair. As discussed in the
38 NRC letter dated December 8, 2003, to the WOG, an analysis of the pressure boundary
39 component to which the MNSA is attached and an inservice inspection program to be
40 maintained throughout the licensed life of the facility is required. As stated in a letter dated

1 February 18, 2004, the WOG is currently working with various Code Committees to resolve the
2 NRC's concerns in order that the application of MNSAs can be made as a long-term repair.
3 When these concerns are resolved, the corrosion and crack growth evaluations of
4 WCAP-15973-P, Revision 01, with respect to the flaws left in service can be applied to the
5 MNSA repair.

6 3.1 General and Crevice Corrosion Rate Evaluation (WCAP-15973-P, Revision 01)

7 The MNSA and half-nozzle repair/replacement designs will potentially leave the ferritic surfaces
8 of the vessels or piping exposed to the borated reactor coolant. The WOG evaluates the
9 potential for these surfaces to degrade by general or crevice corrosion in Section 2.0 of the TR.
10 The WOG makes its general/creviced corrosion rate evaluation based on the relative chemistry
11 and temperature conditions of the reactor coolant. According to a qualitative review of Figures
12 1 and 2 in the TR, exposure to the reactor coolant will be under crevice conditions for the
13 MNSA designs and under bulk coolant conditions for the half-nozzle designs.

14 The WOG's overall corrosion rate for general corrosion of low-alloy or carbon steel materials is
15 summarized in Equation 1 and Conclusion 1 of the TR and is based on a sum of contributing
16 corrosion rate factors for normal operating conditions, startup conditions, and low temperature
17 outage conditions. These "factors" are the multiplicative results of the corrosion rate values for
18 operating conditions and the WOG's best estimate for the amount of time (as a percentage of
19 total operating life) that a typical plant would operate in these modes. The WOG used
20 Conclusions 2 and 3 of the TR to support the overall corrosion rate given in Conclusion 1.

21 The WOG used the results of laboratory corrosion studies as its bases for establishing the
22 general corrosion rates for low-alloy or carbon steel materials during normal operating, startup,
23 and cold shutdown modes of operation. The laboratory studies used for determining the
24 bounding corrosion rate for normal operating conditions were performed under deaerated
25 conditions, and simulated maximum boron, lithium, and oxygen levels in the reactor coolant
26 under normal operating conditions for a CE-designed PWR. The laboratory studies used for
27 determining the corrosion rates for low alloy or carbon steel materials during startup or cold
28 shutdown conditions also simulated the boron, lithium, and oxygen levels for these conditions,
29 but were made under aerated conditions.

30 During normal operating conditions, the reactor coolant system (RCS) is closed off from the
31 reactor building environment, and the system is operated at temperatures in the range of
32 560-600EF and under hydrogen water chemistry conditions. At these temperatures, the
33 concentration of dissolved oxygen in the coolant is normally maintained well below 150 parts
34 per billion (ppb). During cold shutdown and startups, the RCS is normally opened up and
35 exposed to the reactor building environment. Under these conditions, the concentration of
36 dissolved oxygen in the RCS coolant is normally much higher than it would be during normal
37 operating conditions, when the RCS is sealed off from the reactor building environment. Since
38 the laboratory conditions for the corrosion studies were consistent with chemistry conditions in
39 the reactor coolant during normal operating, startup, and cold-shutdown conditions, the staff
40 concludes that the proposed corrosion rates for normal operating, startup, and cold shutdown
41 conditions provide an acceptable basis for calculating the overall corrosion rate for ferritic
42 carbon and low-alloy steel materials under the borated and hydrogen water chemistry

1 conditions for the reactor coolant. The general corrosion rates for normal operating, startup,
2 and cold shutdown conditions is based on limited laboratory and field data. Therefore, if new
3 laboratory or field data become available that invalidate the bounding general corrosion rates
4 given in the TR, the staff requests that the WOG submit an addendum to the TR that will
5 provide a summary of the analyses performed on the new data and a new overall general
6 corrosion rate calculation that is based on the results from these analyses.

7 The method for calculating the general overall corrosion rate is also dependent on the amount
8 of time the plants (in terms of percentage of total plant life) are estimated to be operating in the
9 normal operating, startup, and cold shutdown modes of operation, in addition to the
10 corresponding corrosion rates during each of the modes of operation as discussed above. The
11 amount of time in these modes of operation, which are normally provided in the design basis for
12 the plant, may vary from plant-to-plant and from the times used by the WOG in Equation (1) of
13 the TR. In this case, when the staff used a time at normal operation of 80 percent¹, the staff
14 calculated a general overall corrosion rate value that was approximately 40 percent in excess of
15 the corresponding value calculated by the WOG. This demonstrates that the overall general
16 corrosion rate for determining the repair lives of the nozzles is dependent on the plant-specific
17 times at normal operations, startups, and cold shutdowns of a given plant.

18 In addition, Section 2.2 of WCAP-15973-P, Revision 01, addressed concerns regarding boric
19 acid corrosion discovered at Davis-Besse in response to NRC Bulletin 2001-01. The TR bases
20 its conclusion that during plant operation, boric acid corrosion is low because there is no
21 mechanism for concentrating boric acid in the crevice region and free oxygen does not exist.
22 Davis-Besse and similar events involving corrosion of the RCS components and fasteners
23 exposed to the containment atmosphere (containing free oxygen) are not applicable because of
24 the dissimilarity in the environmental conditions. However, during shutdowns and refuelings,
25 the corrosion rate will increase since the crevice region may be filled with aerated water. The
26 report stated that some tests using SA 533 Grade B steel mockups which contained cracked
27 nozzles produced corrosion rates of up to two inches per year in aerated water conditions. In
28 addition, other laboratory data showed that corrosion rates in deaerated water are minimal.
29 Therefore, if the nozzles are not leaking, or exposed to aerated water, these corrosion rates will
30 be minimal. As stated above, the corrosion rates are dependent on the plant-specific times at
31 normal operations, startups, and cold-shutdowns, as well as plant-specific configurations, and
32 therefore must be demonstrated to be applicable on a plant-specific basis.

33 Licensees seeking to use the methods of the TR need to perform the following plant-specific
34 calculations in order to confirm that the ferritic portions of the vessels or piping within the scope
35 of the TR will be acceptable for service throughout the licensed lives of their plants (40 years if
36 the normal licensing basis plant life is used or 60 years if the facility is expected to be approved
37 for extension of the operating license):

- 38 1. Calculate the minimum acceptable wall thinning thickness for the ferritic vessel or piping
39 that will adjoin to the MNSA repair or half-nozzle replacement.

1 A significant number of licensees in the industry use 80 percent as the design basis for the amount of time at normal power operations. Use of this in the NRC's independent calculation of the overall corrosion rate for general or crevice-type corrosion is based on this time.

- 1 2. Calculate the overall general corrosion rate for the ferritic materials based on the
2 calculational methods in the TR using the general corrosion rates listed in the TR for
3 normal operations, startup conditions (including hot standby conditions), and cold
4 shutdown conditions, and the respective plant-specific times (in-percentage of total plant
5 life) at each of the operating modes.

- 6 3. Track the time at cold shutdown conditions to determine whether this time exceeds the
7 assumptions made in the analysis. If these assumptions are exceeded, the licensees
8 shall provide a revised analysis to the NRC, and provide a discussion on whether
9 volumetric inspection of the area is required.

- 10 4. Calculate the amount of general corrosion-based thinning for the vessels or piping over
11 the life of the plant, as based on the overall general corrosion rate calculated in Step 2
12 and the thickness of the ferritic vessel or piping that will adjoin to the MNSA repair or
13 half-nozzle replacement.

- 14 5. Determine whether the vessel or piping is acceptable over the remaining life of the plant
15 by comparing the worst case remaining wall thickness to the minimum acceptable wall
16 thickness for the vessel or pipe.

17 Plant-specific engineering evaluations that have been calculated in accordance with these
18 methods and that demonstrate that the ferritic materials will not be thinned by general corrosion
19 to a size less than the minimum allowable wall thickness for the component are sufficient to
20 satisfy the acceptability by analysis provisions of Section XI for defects induced by general
21 corrosion or crevice corrosion.

22 3.2 Fatigue Crack Growth Evaluation (Including Supporting Calculation Report CN-CI-02-71, 23 Revision 01)

24 The WOG's MNSA and the half-nozzle repair technique for small-bore nozzle repairs in hot-leg
25 piping, pressurizer lower head instrument nozzle, pressurizer lower head heater sleeve, and
26 pressurizer lower shells relocates the pressure boundary from the internal surface to the
27 external surface while leaving the flaw in the internal J-groove weld and/or nozzle. To justify not
28 removing the flaw, the WOG performed a flaw evaluation similar to the flaw evaluation
29 procedures of Appendix A to Section XI of the ASME Code to demonstrate the structural
30 integrity of the pressure boundary for the life of the plant (40 years).

31 As stated in Section 3.3 of WCAP-15973, Revision 01, a detailed evaluation of the fatigue crack
32 growth analysis is provided in Calculation Report CN-CI-02-71, Revision 01. A typical flaw
33 evaluation requires determination of the initial flaw size, the applied stress intensity factor
34 (K_{applied}) values, fatigue crack growth, and stability of the final crack size. These elements have
35 been revised significantly in Calculation Report CN-CI-02-71, Revision 01, which was
36 transmitted to the NRC on May 20, 2004, to reflect (1) the responses to the staff's requests for
37 additional information (RAI) as addressed in a letter dated October 6, 2003, (2) the inclusion of
38 in-surges in heatup and cooldown transients, and (3) additional modifications in the flaw
39 evaluation methodology initiated by the WOG and the licensee after submitting Revision 00 to
40 Calculation Report CN-CI-02-71. Therefore, the staff's discussion focuses on information in

1 Calculation Report CN-CI-02-71, Revision 01, and the WOG's response to the staff's RAI
2 regarding this revision, as addressed in a letter dated August 11, 2004. Calculation Report
3 CN-CI-02-71, Revision 00, and the WOG's response to the staff's RAI regarding it will only be
4 addressed when necessary. The technical elements of the flaw evaluation are evaluated by the
5 staff in the following sections.

6 3.2.1 Initial Flaw Size

7 The initial flaw is assumed to be a double-sided crack that has propagated through the
8 J-groove weld and touches the carbon steel material that comprises the pressure boundary.
9 The staff examined Calculation Report CN-CI-02-71, Revision 01, initial crack size calculations
10 for the above-mentioned four components and verified that each initial flaw size represents the
11 radial cross section of the J-groove weld (the worst possible radial crack that could exist in the
12 weld). This approach of characterizing a leaked flaw based on the worst assumption is
13 consistent with those in approved applications of similar nature and has become standard
14 industry practice now. Licensees seeking to reference this TR for future licensing applications
15 need to demonstrate that the geometry of the leaking penetration is bounded by the
16 corresponding penetration reported in Calculation Report CN-CI-02-71, Revision 01.

17 3.2.2 Applied Stress Intensity Factor Values

18 For a flaw subjected to fatigue crack growth or any type of stress-corrosion cracking (SCC), the
19 final crack size is needed for determining the operating time for the unit with the flawed
20 component. Since the crack growth equation is a function of the K_{applied} value, selecting the
21 appropriate K_{applied} formula in the calculation is important in the crack growth evaluation. In this
22 application, the WOG used the Raju-Newman formulation documented in NASA Technical
23 Memorandum 85793, "Stress-Intensity Factor Equations for Cracks in Three-Dimensional Finite
24 Bodies Subjected to Tension and Bending Loads." One of the staff's RAIs concerns the
25 applicability of the Raju-Newman K_{applied} solution to the current application, considering the
26 differences between the Raju-Newman model and the current model regarding relative hole
27 size and crack geometry. The WOG replied in its October 6, 2003, response that the subject
28 geometries are within the applicability range of the Raju-Newman K_{applied} solution for crack depth
29 to length ratios of 0.2 to 2.0 and for crack depth to plate thickness ratios of less than 0.8.
30 Actually, four applicability criteria are associated with this Raju-Newman solution. The staff
31 examined the other two applicability criteria that the WOG did not address and found that the
32 subject geometries satisfy the limit of less than 0.5 for the ratio of the extended hole size (hole
33 radius + crack length) to the component length, but does not satisfy the lower limit of 0.5 for the
34 ratio of the hole radius to the component thickness. Physically, this means that the subject
35 geometries have more material ahead of the crack front than that of the Raju-Newman model,
36 and therefore using the Raju-Newman solution is conservative in this application.

37 Revision 01 to Calculation Report CN-CI-02-71 reveals that the calculated K_{applied} values at the
38 final flaw sizes for the four components differ significantly from their corresponding values in
39 Revision 00. According to the August 11, 2004, response to the staff's RAI, the WOG
40 attributed three factors for this change: (1) the use of a realistic heat transfer coefficient,
41 instead of infinity, in the thermal analysis, (2) the use of a stress distribution postprocessing
42 methodology based on full three dimensional finite element calculations, instead of the peak

1 stress value, and (3) the use of one crack model for instrument nozzles and one for heater
2 sleeves, instead of one bounding model for both types of penetrations. These changes are
3 justified because these actions simply take excessive conservatism out from the model and
4 make the revised model more realistic. All three changes have the effect of reducing the
5 calculated K_{applied} values.

6 3.2.3 Fatigue Crack Growth

7 Fatigue crack growth of the flaw is calculated over a plant life of 40 years and is based on
8 transients and cycles specified in design specifications for a typical CE plant for normal (Level
9 A), upset (Level B), emergency (Level C), and faulted (Level D) conditions. Calculation Report
10 CN-CI-02-71, Revision 01, further combines similar transients and eliminates relatively
11 insignificant transients to simplify the fatigue crack growth calculation. The staff considers this
12 simplification reasonable because all important transients such as heatup/cooldown, leak tests,
13 and operating basis earthquake for hot legs have been captured. Turbine/reactor trips, which
14 were included in Revision 00 to Calculation Report CN-CI-02-71 were not considered in
15 Revision 01 because the calculations associated with Revision 00 showed only minor
16 contribution from these transients. Hence, fatigue crack growth of the assumed flaw
17 documented in Revision 01 is based on 500 cycles of a combined transient composed of
18 heatup, cooldown, and leak test. The staff accepts the current transient and cycle selection
19 since (1) inclusion of in-surges in the heatup and cooldown transients, which makes the
20 transients more severe than those of Revision 00, represents a more realistic plant operation,
21 and (2) the 500 heatup, cooldown, and test cycles are conservative for a 40-year operation.

22 Figure 6-2 (a) of Calculation Report CN-CI-02-71, Revision 01 depicts three curves: (1) the
23 heatup curve (100EF/hr) with an in-surge, (2) the cooldown curve (100EF/hr) with two in-surges,
24 and (3) the bi-rate (200EF/hr and 75EF/hr) cooldown curve. The first two curves are for the
25 fatigue crack growth calculation, and the last curve in addition to the cooldown curve with the
26 large in-surge are considered for the stability analysis of the final flaw. The pressure of these
27 transients is based on the pressurizer saturated pressure plus 200 psi ($P_{\text{saturated}} + 200 \text{ psi}$).
28 These generic transients are representative, but may not be bounding. Therefore, applicants
29 who use this TR for future licensing purposes need to demonstrate that their plant-specific
30 pressure and temperature profiles in the pressurizer water space for the limiting curves
31 (cooldown curves) do not exceed the analyzed profiles shown in Figure 6-2 (a) of Calculation
32 Report CN-CI-02-71, Revision 01.

33 The fatigue crack growth rate used in the calculations is Figure A-4300-2 of Section XI of the
34 1992 Edition of the ASME Code. This curve applies to carbon and low alloy ferritic steels
35 exposed to a water environment and is considered by the staff to be appropriate for this
36 application. Using the ASME fatigue curve and the calculated K_{applied} value for the assumed
37 initial crack geometry, the crack growth rate, and subsequently the crack growth for the first
38 cycle can be determined. This crack growth was added to the assumed initial crack geometry
39 to arrive at a revised crack geometry for the next round of calculation of K_{applied} , crack growth,
40 and the revised crack geometry. This process is repeated cycle after cycle until all transient
41 cycles have been exhausted. The revised crack geometry at the end of the last transient cycle
42 is the final crack geometry.

1 3.2.4 Final Crack Stability Evaluation

2 The final step in Calculation Report CN-CI-02-71, Revision 01, consists of a flaw evaluation
3 involving the calculation of the driving force and fracture resistance for the final flaw size.
4 When linear elastic fracture mechanics (LEFM) is applicable, the driving force is the K_{applied} and
5 the fracture resistance is the plain strain fracture toughness (K_{Ic}) and the crack arrest fracture
6 toughness (K_{Ia}). When elastic-plastic fracture mechanics (EPFM) is applicable, the driving
7 force is J_{applied} and its slope M_{applied}/A , and the fracture resistance is $J_{0.1}$ of the J-R curve
8 (J_{material}) at a crack extension of 0.1 inch and the slope M_{material}/A at the intersection of J_{applied}
9 and J_{material} . The crack stability evaluation examines the stability of a crack using either the
10 LEFM criteria specified in IWB-3612 of Section XI of the ASME Code or the EPFM criteria
11 specified in Regulatory Guide (RG) 1.161, "Evaluation of Reactor Pressure Vessels with Charpy
12 Upper-Shelf Energy Less than 50 ft-lb," and Appendix C to Section XI of the ASME Code. The
13 LEFM methodology, as described in Report CN-CI-02-71, Revision 01, is in accordance with
14 Appendix A to Section XI of the ASME Code, and is therefore acceptable to the staff. However,
15 the staff has concerns with the proposed EPFM methodology in two areas.

16 First, the WOG proposed to use a structural factor of 3 on J_{applied} for the EPFM analysis. The
17 staff believes that for current applications (flaws being identified through leaking), it is more
18 appropriate to use the structural factors for detected flaws such as those specified for the
19 EPFM analysis for piping, as appeared in Appendix C to Section XI of the ASME Code.
20 Appendix C specifies 2.7 and 2.3 as structural factors for membrane and bending stresses for
21 piping with detected flaws under the fracture modes of ductile fracture and plastic collapse.
22 This is equivalent to structural factors of 7.29 and 5.29 on J_{applied} . This staff concern prompted
23 the WOG to provide a sensitivity analysis in the August 11, 2004, response, using structural
24 factors up to 9.0 in the crack stability evaluation. The results of the sensitivity analysis plotted
25 in Figures 4 and 5 of the response demonstrate that the RG 1.161 criteria of $J_{\text{applied}} < J_{0.1}$ and
26 $M_{\text{applied}}/A < M_{\text{material}}/A$ at $J_{\text{applied}} = J_{\text{material}}$ are satisfied for both the pressurizer lower shell and
27 the pressurizer lower head heater sleeves, even when a structural factor of 9 on J_{applied} is used.
28

29 The second staff concern is that the proposed methodology did not apply a margin factor of
30 0.749 to the J-R curve as required by RG 1.161. This is not appropriate. However, the staff's
31 independent assessment indicates that after reducing the J-R curves of Figures 4 and 5 to
32 0.749 of their presented values, RG 1.161 criteria are still met.

33 Therefore, the calculated values using the EPFM methodology in Calculation Report
34 CN-CI-02-71, Revision 01, meet the RG 1.161 criteria based on the WOG's sensitivity analysis,
35 and the staff's independent assessment using a structural factor of 7.29 on J_{applied} and a
36 material margin factor of 0.749 on J_{material} . Licensees may use these bounding values when
37 referencing this TR. However, if the plant-specific application is not bounded by the analysis in
38 Calculation Report CN-CI-02-71, Revision 01, the EPFM methodology may only be used for
39 conducting the plant-specific analysis if adjusted using a structural factor of 7.29 on J_{applied} and a
40 material margin factor of 0.749 on J_{material} .

41 In summary, the EPFM results for pressurizer lower shell and pressurizer lower head heater
42 sleeves, which are documented in the WOG's August 11, 2004, response, are acceptable
43 because they meet the RG 1.161 criteria with a structural factor that is equivalent to that used

1 in Appendix C to Section XI of the ASME Code. Further, the LEFM results tabulated in Tables
2 2-2, 2-4, 2-6, and 2-8 of Calculation Report CN-CI-02-71, Revision 01, for the hot-leg piping,
3 pressurizer lower head instrument nozzles, pressurizer lower head heater sleeves, and
4 pressurizer lower shell are also acceptable because they meet ASME Code specified criteria
5 with additional margins. Based on the above evaluation, the staff has determined that the
6 crack can be left in the J-groove weld at small-bore locations in the pressurizer and hot-leg
7 piping for a plant life of 40 years.

8 For licensees who plan to use this TR for future licensing purposes need to demonstrate the
9 following:

- 10 1. The geometry of the leaking penetration is bounded by the corresponding penetration
11 reported in Calculation Report CN-CI-02-71, Revision 01.
- 12 2. The plant-specific pressure and temperature profiles in the pressurizer water space for
13 the limiting curves (cooldown curves) do not exceed the analyzed profiles shown in
14 Figure 6.2 (a) of Calculation Report CN-CI-02-71, Revision 01.
- 15 3. The plant-specific Charpy upper-shelf energy (USE) data showing a USE value of at
16 least 70 ft-lb to bound the USE value used in the analysis. If the plant-specific Charpy
17 USE data does not exist and the licensee plans to use Charpy USE data from other
18 plants' pressurizers and hot-leg piping, then justification (e.g., based on statistical or
19 lower bound analysis) has to be provided.

20 If the plant-specific application is not bounded by the analysis in Calculation Report
21 CN-CI-02-71, Revision 01, the EPFM methodology may be used if adjusted using a structural
22 factor of 7.29 on J_{applied} and a material margin factor of 0.749 on J_{material} .

23 3.3 Stress Corrosion Cracking (WCAP-15973-P, Revision 01)

24 In Conclusion 4 of WCAP-15973-P, Revision 01, the WOG concluded that growth of existing
25 flaws into the ferritic portions of the vessels or piping by stress corrosion was not plausible. The
26 WOG's analysis for supporting this conclusion is provided in Section 3.6 of the TR. In this
27 section, the WOG used the following arguments as its bases for concluding that there is a low
28 probability for growing the existing cracks in the original weld metal and/or nozzle by stress
29 corrosion into the ferritic material:

- 30 ● During normal operations of the RCS in CE-designed reactors, hydrogen overpressure
31 in the RCS significantly reduces the impurity levels of dissolved oxygen to a
32 concentration less than 10 ppb. At these levels, the electro-chemical potential of the
33 coolant is significantly less than required to grow a existing crack by stress corrosion.
- 34 ● Even if high oxygen concentrations exist in the crevice during the initial stages of normal
35 operations, the oxygen levels will quickly be reduced as a result of iron oxide formation
36 on the surfaces of the ferritic steel. Since the oxygen levels in the bulk-coolant are
37 typically less than 10 ppb during normal operations, there is no mechanism to replenish
38 oxygen in the crevice region, and as a result the low-oxygen condition in the crevice

1 region will quickly be re-established. Thus, the potential to grow the existing cracks by a
2 stress corrosion mechanism will be low.

- 3 ● Other contaminants (copper ions, sulfates, halides, etc.) that could increase the
4 potential for cracks to grow by stress corrosion are also maintained at extremely low
5 concentrations during normal operations.

6 The staff typically uses ! 200 MeV as the threshold potential for initiating and growing cracks by
7 stress corrosion. At chemical potentials above this value, the staff considers initiation and
8 growth of cracks by stress corrosion to be plausible. When the chemical potential of the reactor
9 coolant is controlled to magnitudes below this value, the staff considers the potential for cracks
10 to initiate and grow by stress corrosion to be significantly reduced.

11 At a typical PWR, control of contaminants that could lead to chemical potentials above
12 ! 200 MeV is accomplished by the combined efforts of the plant operators and chemistry
13 personnel. CE-designed reactors do not have any copper alloys in their RCS, therefore
14 incursion of copper ion contaminants is typically not an issue for CE-designed reactors. In
15 addition, licensees maintain the RCS chemistry by use of the chemical and volume control
16 system as the method for controlling oxygen, halide and sulfate contaminants to low levels.
17 This includes the use of ion exchangers to purify the reactor coolant. Plant chemistry
18 procedures require plant chemistry personnel to monitor the contaminant levels of the RCS at
19 regular daily intervals. Implementation of design changes to better ion exchange resins and
20 improve chemical monitoring equipment have enabled licensees to control the levels of
21 dissolved oxygen to concentrations less than 10 ppb, and halide and sulfate contaminants to
22 concentrations well below the maximum acceptable levels referred to in the Electric Power
23 Research Institute (EPRI) PWR Primary Water Chemistry Guidelines (i.e., well below 150 ppb).
24 Licensees owning CE-designed plants maintain a significant hydrogen overpressure on their
25 RCS. These practices allow the licensees for these facilities to maintain the electro-chemical
26 potential of the reactor coolant at levels below ! 200 MeV. The staff therefore concurs that the
27 probability for growing the existing flaws by stress corrosion is extremely low at these facilities.

28 In addition, Section 3.6.4 of the TR provides field experience which is consistent with the
29 laboratory observations that SCC into the ferritic portion of the component is not likely to occur
30 at CE plants. For example, in December 2000, an Oconee-1 CRDM nozzle exhibited stress
31 corrosion cracks in the Alloy 82 weld that propagated through the weld and also extended to the
32 Alloy 600 nozzle. However, the crack arrested when it reached the ferritic vessel head material.
33 Another example was the occurrence of PWSCC in the weld between a pressurizer relief valve
34 nozzle and a safe-end at the Japanese plant, Tsuruga-2. The cracking was discovered in the
35 weld metal and buttering, which is a nickel based alloy. However, destructive examination
36 showed that the crack extended to the interface between the weld and low alloy steel nozzle,
37 but did not extend into the low alloy steel. Therefore, current industry experience is consistent
38 with current laboratory observations that SCC into the ferritic portion is not likely to occur.

39 Licensees seeking to implement MNSA repairs or half-nozzle repairs may use the WOG's
40 stress corrosion assessment as the bases for concluding that existing flaws in the weld metal
41 will not grow by stress corrosion if they conduct appropriate plant chemistry reviews and if they
42 can demonstrate that a sufficient level of hydrogen overpressure has been implemented for the

1 RCS, and that the oxygen and halide/sulfate concentrations in the reactor coolant have been
2 typically maintained at levels below 10 ppb and 150 ppb, respectively. During the outage in
3 which the half-nozzle or MNSA repairs are scheduled to be implemented, licensees adopting
4 the TR's stress corrosion crack growth arguments will need to review their plant-specific RCS
5 coolant chemistry histories over the last two operating cycles for their plants, and confirm that
6 these conditions have been met over the last two operating cycles. Plant chemistry records are
7 covered under the scope of 10 CFR 50.70 as being items that may be designated for inspection
8 by the NRC.

9 4.0 CONCLUSIONS AND CONDITIONS

10 The staff's review of the methods in WCAP-15973-P, Revision 01, indicates that the WOG's
11 methods and analyses in the TR are generally acceptable. Specifically, WCAP-15973-P,
12 Revision 01, accomplishes the following objectives with respect to implementing these repair or
13 replacement methods:

- 14 1. Provides an acceptable method for calculating the overall general/crevice corrosion rate
15 for the internal surfaces of the low-alloy or carbon steel materials that will now be
16 exposed to the reactor coolant, and for calculating the amount of time the ferritic
17 portions of the vessel or piping would be acceptable if corrosive wall thinning had
18 occurred,
- 19 2. Provides an acceptable method of calculating the thermal-fatigue crack-growth life of
20 existing flaws in the Alloy 600 nozzles and/or Alloy 82/182 weld material into the ferritic
21 portion of the vessels or piping, and
- 22 3. Provides acceptable bases and arguments for concluding that unacceptable growth of
23 the existing flaw by stress corrosion into the vessels or piping is improbable.

24 The staff's conclusions and conditions regarding the WOG's general corrosion assessment,
25 thermal-fatigue crack growth assessment, and stress corrosion cracking growth assessment
26 are provided below in Sections 4.1, 4.2, and 4.3, respectively.

27 4.1 General Corrosion Assessment

28 The calculation of the general overall corrosion rate for the ferritic materials is dependent on
29 both the individual general corrosion rates for normal operating, startup (including hot-standby),
30 and coldshutdown conditions provided in Section 2.3.4 of the TR, and on the plant-specific
31 times (in terms of percentage of total plant life) that a respective nuclear plant is estimated to
32 operate in each of these operating modes. When the staff used a time at normal operation of
33 80 percent, the staff calculated a general overall corrosion rate that was 40 percent higher than
34 the value calculated by the WOG. Therefore, the general overall corrosion rate proposed in
35 Equation 1 of the TR may or may not be conservative, depending on what the plant-specific
36 times at normal operating, startup (including hot standby), and cold shutdown conditions are.
37 Licensees seeking to use the methods of the TR will need to perform the following plant-
38 specific calculations in order to confirm that the ferritic portions of the vessels or piping within
39 the scope of the TR will be acceptable for service throughout the licensed lives of their plants

1 (40 years if the normal licensing basis plant life is used or 60 years if the facility is expected to
2 be approved for extension of the operating license):

- 3 1. Calculate the minimum acceptable wall thinning thickness for the ferritic vessel or piping
4 that will adjoin to the MNSA repair or half-nozzle repair.
- 5 2. Calculate the overall general corrosion rate for the ferritic materials based on the
6 calculational methods in the TR, the general corrosion rates listed in the TR for normal
7 operations, startup conditions (including hot standby conditions), and cold shutdown
8 conditions, and the respective plant-specific times (in-percentage of total plant life) at
9 each of the operating modes.
- 10 3. Track the time at cold shutdown conditions to determine whether this time does not
11 exceed the assumptions made in the analysis. If these assumptions are exceeded, the
12 licensees shall provide a revised analysis to the NRC, and provide a discussion on
13 whether volumetric inspection of the area is required.
- 14 4. Calculate the amount of general corrosion-based thinning for the vessels or piping over
15 the life of the plant, as based on the overall general corrosion rate calculated in Step 2
16 and the thickness of the ferritic vessel or piping that will adjoin to the MNSA repair or
17 half-nozzle repair.
- 18 5. Determine whether the vessel or piping is acceptable over the remaining life of the plant
19 by comparing the worst case remaining wall thickness to the minimum acceptable wall
20 thickness for the vessel or pipe.

21 Plant-specific engineering evaluations that have been calculated in accordance with these
22 methods and that demonstrate that the ferritic materials will not be thinned by general corrosion
23 to a size less than the minimum allowable wall thickness for the component over the life of the
24 plant (40 years if the normal licensing basis plant life is used or 60 years if the facility is
25 expected to be approved for extension of the operating license) will be sufficient to satisfy the
26 acceptability by analysis provisions of Section XI of the ASME Code for defects induced by
27 general corrosion or crevice corrosion.

28 4.2 Thermal-Fatigue Crack Growth Assessment

29 The staff determined that the WOG's methods for calculating the thermal-fatigue repair life of
30 the existing flaws in the original weld metal was consistent with the methods of Appendix A to
31 Section XI of the ASME Code. Licensees seeking to reference this TR for future licensing
32 applications need to demonstrate that:

- 33 1. The geometry of the leaking penetration is bounded by the corresponding penetration
34 reported in Calculation Report CN-CI-02-71, Revision 01.
- 35 2. The plant-specific pressure and temperature profiles in the pressurizer water space for
36 the limiting curves (cooldown curves) do not exceed the analyzed profiles shown in

1 Figure 6-2 (a) of Calculation Report CN-CI-02-71, Revision 01, as stated in Section
2 3.2.3 of this SE.

- 3 3. The plant-specific Charpy USE data shows a USE value of at least 70 ft-lb to bound the
4 USE value used in the analysis. If the plant-specific Charpy USE data does not exist
5 and the licensee plans to use Charpy USE data from other plants' pressurizers and
6 hot-leg piping, then justification (e.g., based on statistical or lower bound analysis) has
7 to be provided.

8 If the plant-specific application is not bounded by the analysis in Calculation Report
9 CN-CI-02-71, Revision 01, the EPFM methodology may be used as adjusted in Section 3.2.4 of
10 this SE, which uses a structural factor of 7.29 on J_{applied} and a material margin factor of 0.749 on
11 J_{material} .

12 Based on the above evaluation, the staff has determined that the crack can be left in the
13 J-groove weld at small-bore locations for a plant life of 40 years. However, if the licensee plans
14 on using this alternative beyond the 40 years and through the license renewal period, the
15 thermal fatigue crack growth analysis shall be re-evaluated to include the extended period, as
16 applicable, and submitted as a time limited aging analysis in their license renewal application as
17 required by 10 CFR 54.21(c)(1).

18 4.3 Stress Corrosion Crack Growth Assessment

19 The WOG used water chemistry and contaminant arguments as its bases for concluding that
20 growth of the existing flaws by stress corrosion was not a plausible mechanism. Based on the
21 staff's assessment given in Section 3.3 of this SE, the staff concurs that the probability for
22 growing the existing flaws by stress corrosion into carbon or low alloy steels will be low as long
23 as concentrations of dissolved oxygen, halide, sulfate, or other harmful contaminants is
24 sufficiently controlled at the plants, and as long as hydrogen water chemistry is implemented at
25 the plants. Licensees seeking to implement MNSA repairs or half-nozzle replacements may
26 use the WOG's stress corrosion assessment as the bases for concluding that existing flaws in
27 the weld metal will not grow by stress corrosion if they meet the following conditions:

- 28 1. Conduct appropriate plant chemistry reviews and demonstrate that a sufficient level of
29 hydrogen overpressure has been implemented for the RCS, and that the contaminant
30 concentrations in the reactor coolant have been typically maintained at levels below 10
31 ppb for dissolved oxygen, 150 ppb for halide ions, and 150 ppb for sulfate ions.
- 32 2. During the outage in which the half-nozzle or MNSA repairs are scheduled to be
33 implemented, licensees adopting the TR's stress corrosion crack growth arguments will
34 need to review their plant-specific RCS coolant chemistry histories over the last two
35 operating cycles for their plants, and confirm that these conditions have been met over
36 the last two operating cycles.

1 4.4 Other Considerations

2 The WOG's general corrosion rates for normal operations, startups, and cold shutdown
3 conditions, as applied in Equation 1 of the TR, are considered by the staff to be acceptable, as
4 long as the existing corrosion data used to determine the bounding rates is applicable. If
5 additional laboratory or field data becomes available that invalidates the TR's general corrosion
6 rate values for normal operations, startups, and cold shutdown conditions, the WOG should
7 send in an addendum to the TR that evaluates the impact of the new data of the corrosion rate
8 values for normal operations, startups, and cold-shutdown conditions, and that provides a new
9 overall general corrosion rate assessment for the ferritic components under assessment.

10 The WOG's thermal fatigue crack growth analysis is only applicable to the evaluation of a single
11 flaw. Should the WOG desire to extend the scope of its thermal-fatigue crack growth analysis
12 to the analysis of multiple cracks in near proximity to one another, the WOG is requested to
13 submit an appropriate addendum to the TR that provides the new thermal-fatigue crack growth
14 assessment for the multiple flaw orientation.

15 The scope of WCAP-15973-P, Revision 01, does not address any welding considerations for
16 the MNSA or half-nozzle designs. Licensees seeking to implement half-nozzle replacements or
17 MNSA repairs of their Alloy 600 nozzles will need to assess the welding aspects of the design
18 and may need to submit a relief request to implement the alternatives to the requirements of the
19 ASME Code, Section XI as required by 10 CFR 50.55a.

20 The staff's review of the corrections to the flaw evaluation, changes in corrosion rate and
21 clarification of the stress corrosion cracking in carbon and low alloy steels to WCAP-15973-P,
22 Revision 01, indicates that the changes in the evaluation and analyses are generally
23 acceptable. The requirements addressed in Section 4.0 of this SE must be addressed, along
24 with the following, when this TR is used as the basis for the corrosion and fatigue crack growth
25 evaluation when implementing a half-nozzle or MNSA repair:

- 26 1. Licensees using the MNSA repairs as a permanent repair shall provide resolution to the
27 NRC concerns addressed in the NRC letter dated December 8, 2003, from H. Berkow to
28 H. Sepp (ADAMS Accession No. ML033440037) concerning the analysis of the pressure
29 boundary components to which the MNSA is attached, and the augmented inservice
30 inspection program.
- 31 2. Currently, half-nozzle and MNSA repairs are considered alternatives to the ASME Code,
32 Section XI. Therefore, licensees proposing to use the half-nozzle and MNSA repairs
33 shall submit the required information contained in WCAP-15973-P, Revision 01, by the
34 conditions of this SE, to the NRC as a relief request in accordance with 10 CFR 50.55a.

35 Principal Contributors: J. Honcharik
36 C. F. Sheng

37 Date: November 30, 2004