ExxonMobil Biomedical Sciences, Inc. Clinton Township 1545 Route 22 East, P. O. Box 971 Annandale, NJ 08801-0971 908-730-1028 Telephone 908-730-1190 Fax steven.e.lerman@exxonmobil.com Steven E. Lerman, M.D. Vice President

# **E**‰onMobil

03017541

Q-5

2

October 25, 2004

Licensing Assistant Section Nuclear Materials Safety Branch U.S. Nuclear Regulatory Commission, Region I 475 Allendale Road King of Prussia, PA 19406-1415

#### Subject: License Termination Request - NRC License Number 29-19396-01

Dear Sir or Madam:

We are requesting to terminate our US NRC Materials License number 29-19396-01. Attached is completed and signed NRC Form 314, "Certificate of Disposition of Materials."

All radiolabeled materials and associated wastes were removed from the licensed site for disposal in accordance with applicable NRC regulations during the period between August 23, 2004 and October 18, -2004. The sealed source containing Ni-63 was returned to the original vendor on October 19, 2005. These activities are summarized in section B, "Disposal of Radioactive Materials" on the attached NRC Form 314.

Regarding residual contamination, we routinely performed and documented radiation contamination surveys in all areas where licensed material was stored or used. The only radionuclides possessed at this site in unsealed form were H-3 and C-14. The only radionuclide actually used has been H-3 in the form if H-3 labeled thymidine for occasional animal studies using less than 1 mCi per study. This amounts to about 24 mCi over the past four years. About 165 mCi of C-14 and 55 mCi of H-3 labeled chemical compounds were possessed but remained in storage and were never used at this site. The H-3 labeled materials and associated wastes that were used in tests were stored and used in selected rooms as outlined in the license application and amendments. The remaining C-14 and H-3 labeled compounds that were not used were also stored as described in the license application and amendments.

We have made use of NRC regulation 10 CFR 20 Subpart E to determine that any residual radioactivity is below the associated 25 mrem/yr limit and is ALARA such that it would be releasable for unrestricted use. The surface contamination limits associated with 25 mrem/yr are  $1.2 \times 10^8$  dpm /100 cm<sup>2</sup> for H-3 and  $3.7 \times 10^6$  dpm/100 cm<sup>2</sup> for C-14. (See Appendix Q of NUREG-1556, Vol. 7, "Consolidated Guidance about Materials Licenses: Program-Specific Guidance about Academic, Research and Development, and Other Licenses of Limited Scope Including Gas Chromatographs and X-Ray Fluorescence Analyzers") Taking the more limiting  $3.7 \times 10^6$  dpm/100 cm<sup>2</sup> for C-14 and applying a planning factor of 10 for ALARA, we have established a conservative decontamination goal of  $3.7 \times 10^5$  dpm/100 cm<sup>2</sup>.

A review of the results of routine contamination surveys over the past four years shows contamination to be mostly non-detectable or well below any action level. As a precaution, we contracted with Radcor LLC to conduct a final contamination status survey after all unsealed radioactive materials had been disposed. The results of this final status survey are attached.

135896

NMSS/RGNI MATERIALS-002

An ExxonMobil Subsidiary

During the final contamination survey by Radcor, a small amount of contamination was found under the refrigerator in Room LG386. Although the contamination concentration was well under our goal of  $3.7 \times 10^5$  dpm/100 cm<sup>2</sup>, we decided to decontaminate the surfaces anyway, resulting in approximately 3 gallons of dry solid material (paper, plastic, glass sharps, etc.) containing less than an estimated 10 microcuries of H-3 plus C-14. These materials along with waste materials from liquid scintillation surveys and sample analyses were disposed on October 18, 2004.

Under license 29-19396-01 we possessed a single Ni-63 sealed source (plated foil electron capture detector cell for a gas chromatograph). As stated above this source was returned to the authorized vendor (Agilent Technologies, Inc., Wilmington, DE). Since we intend to continue to use this type of source in the future, we have requested from the vendor to possess any such sealed sources under a general license and we will comply with applicable regulations for a general licensee.

Please feel free to contact our Radiation Safety Officer (W. James Bover, Ph.D. at 908-730-1048) or me, if you need further information.

Very truly yours,

tin & Kim

Steven E. Lerman

NRC FORM 314 U.S. NUCLEAR REGULATORY COMMISSION	APPROVED BY OMB: NO. 3150-0028 EXPIRES: 07/31/2004
10 CFR 30.36(j)(1); 40.42(j)(1); 10 CFR 30.36(j)(1); 40.42(j)(1); 20 200(1) and 22 54(0/4)	Estimated burden per response to comply with this mandatory collection request: 30 minutes. This submittal is used by NRC as part of the basis for its determination that the facility is
70.38()(1); and 72.54()(1)	released for unrestricted use. Send comments regarding burden estimate to the Records
CERTIFICATE OF DISPOSITION OF MATERIALS	20555-0001, or by internet e-mail to bis1@nrc.gov, and to the Desk Officer, Office of Information
	and Regulatory Affairs, NEOB-10202, (3150-0028), Office of Management and Budget, Washington DC 20503. If a measure used to impose an information collection does not divide a
	currently valid OMB control number, the NRC may not conduct or sponsor, and a person is not
	required to respond to, the information collection.
LICENSEE NAME AND ADDRESS	
Austo Truschio	24-14346-01 230-11041
15215 Durle Do FAST P.D. BOX 971	LICENSE EXPIRATION DATE
Annandale AST DEED 1-0901	31 October 2011
A. LICENSE STATUS (Check the	e appropriate box)
This license has expired. This license has not yet expired; please to	erminate it.
B. DISPOSAL OF RADIOACTI	VE MATERIAL
(Check the appropriate boxes and complete as necessary/ If additional space is nee	ded, provide attachments)
The licensee, or any individual executing this certificate on behalf of the licensee,	certifies that:
1. No radioactive materials have ever been procured or possessed by the	licensee under this license.
2. All activities authorized by this license have ceased, and all radioactive	materials procured and/or possessed by the licensee
under this license number cited above have been disposed of in the fol	lowing manner.
a. Transfer of radioactive materials to the licensee listed below:	Echophonies IN (license# D7-28762-01)
13 mG, NI-63 Seuled source. to Hgi kent le	
b. Disposal of radioactive materials:	
1. Directly by the licensee:	
2. By licensed disposal site:	
3. By waste contractor:	
see attached to ble	
All radioactive materials have been removed such that any remaining	residual radioactivity is within the limits of 10 CER
Part 20, Subpart E, and is ALARA See attached lefter	and know of a land a lacoma ission of the most
C. SURVEYS PERFORMED AN	D REPORTED
I A radiation survey was conducted by the licensee. The survey confirms:	
I. A faulation survey was conducted by the inconsect. The survey community.	
b. that any remaining residual radioactivity is within the limits of 10 CFR	20, Subpart E, and is ALARA.
2. A copy of the radiation survey results:	
$\mathbb{Z}_{2}$ is attached; or $\square$ b, is not attached (Provide explanation); or $\square$ (	was forwarded to NRC on:
	Date
[] 3. A radiation survey is not required as only sealed sources were ever posse	ssed under this license, and
a. The results of the latest leak test are attached; and/or	. No leaking sources have ever been identified.
The person to be contacted regarding the information provided on this form:	TELEPHONE (Include Area Cada)
W. Junes Boyer RSD	1908 130-1049 W. I. OD VERDEXXONNUL
Mail all future correspondence regarding this license to:	to an Fact Anna da la ATTALLA MAN
EXONIVIDDI I DIOMEDICA I VELENCES, LIC. 1345 KOUT	- of EASL, MINUNULLE, NU DEBUHUT
C. CERTIFYING OFFICI I CERTIFY UNDER PENALTY OF PERJURY THAT THE FO	AL DREGOING IS TRUE AND CORRECT
PRINTED NAME AND TITLE	DATE DATE
Uteven E. Lerman, MD Vice. Hosident - The	10/L6/07
WARNING: FALSE STATEMENTS IN THIS CERTIFICATE MAY BE SUBJECT TO CIVIL AN	D/OR CRIMINAL PENALTIES. NRC REGULATIONS REQUIRE THAT
SUBMISSIONS TO THE ARC BE COMPLETE AND ACCORATE IN ALL MATERIAL RESPECT. I WILLFULLY FALSE STATEMENT OR REPRESENTATION TO ANY DEPARTMENT OR AGENCY OF	THE UNITED STATES AS TO ANY MATTER WITHIN ITS JURISDICTION.

NRC FORM 314 (7-2001)

#### Attachment to NRC Form 314 ExxonMobil Biomedical Sciences, Inc.

DISPOSAL OF RADIOACTIVE MATERIALS BY WASTE CONTRACTOR							
Disposal Shipment Date	Manifest No.	Waste Contractor	Licensed Disposal Site	Materials			
August 23, 2004	NJA 4122655	Onyx Environmental Services 1 Eden Lane Flanders, NJ 07836 Phone: 973-347-7111	Perma-Fix of Florida, Inc. 1940 NW 67th Place Gainesville, FL 32653 Phone: 352-373-6056	<ul> <li>Dry active waste (6) w/ H-3</li> <li>Labpack, urine, milk, blood w/ C-14</li> <li>Labpack, liquid wastes w/ C-14, H-3</li> <li>Labpack, liquid corrosive waste w/ C-14</li> </ul>			
August 23, 2004	NJA 4122658	Onyx Environmental Services 1 Eden Lane Flanders, NJ 07836 Phone: 973-347-7111	Diversified Sci. Services, Inc DSSI 657 Gallaher Road Kingston, TN 37763 Phone: 865-376-0084	<ul> <li>Labpack, liquid wastes w/ C-14, H-3</li> <li>Labpack, liquid wastes w/ C-14</li> </ul>			
August 24, 2004	Z132962	Onyx Environmental Services 1 Eden Lane Flanders, NJ 07836 Phone: 973-347-7111	Perma-Fix of Florida, Inc. 1940 NW 67th Place Gainesville, FL 32653 Phone: 352-373-6056	<ul> <li>Labpack, liquid waste w/C-14</li> </ul>			
August 30, 2004	15580	Radiation Service Organization, Inc. (RSO) 5204 Minnick, Rd. Laurel, MD 20725-1450 Phone: 301-953-2482	Barnwell Waste Management Facility Operated by Chem-Nuclear Systems 740 Osborne Road Barnwell, SC 29812 Phone: 803-259-1781	• Solid animal carcasses w/ H-3			
October 18, 2004	Z132906	Onyx Environmental Services 1 Eden Lane Flanders, NJ 07836 Phone: 973-347-7111	Perma-Fix of Florida, Inc. 1940 NW 67th Place Gainesville, FL 32653 Phone: 352-373-6056	<ul> <li>Exempt liquid Scint. Vials w/ H-3</li> <li>Labpack liquid waste w/ H-3</li> <li>Dry active waste w/ H-3 and C-14</li> </ul>			
	RETURN OF SEALED SOURCE						
Shipment Date	Shipping No.	Receiving Licensee:	Material				
October 19, 2004	82519	Agilent Technologies, Inc. Attn: ECD LAB 2850 Centerville Road Wilmington, DE 19808-1606 Phone: 302-633-8262	<ul> <li>Ni-63 sealed source (GC detector Serial No. K2041)</li> </ul>				

# RADIOLOGICAL DECOMMISSIONING REPORT

EXXONMOBIL BIOMEDICAL SCIENCES, INC. 1545 Route 22 East Annandale, New Jersey

October 4, 2004

Performed by Radcor, LLC 345 Laurelwood Drive Salem, CT 06420 (860) 887-1538

#### **EXECUTIVE SUMMARY**

Between September 20 and October 4, 2004, a radiological assessment for the purpose of decommissioning was performed at the ExxonMobil Biomedical Sciences, Inc. facility located at 1545 Route 22 East in Annandale, New Jersey. This assessment was conducted by Radcor, LLC of Salem, Connecticut.

After performing a radiological assessment and decontamination of the use and storage areas designated by the licensee, it is the opinion of Radcor, LLC that the areas assessed do not present any significant radiological hazard to facility personnel, the public, or the environment, and that these areas may be released for unrestricted use.

### SCOPE

Radcor, LLC of Salem, Connecticut was contracted to perform a radiological assessment of selected areas of the ExxonMobil Biomedical Sciences, Inc. facility located at 1545 Route 22 East, Annandale, New Jersey. This facility is licensed by the U.S. Nuclear Regulatory Commission (NRC) for the possession and use of radioactive materials under license No. 29-19396-01.

ExxonMobil Biomedical Sciences, Inc. no longer has a need to work with loose radioactive materials at this facility and therefore wishes to terminate their radioactive materials license for this facility.

## FACILITY DESCRIPTION

ExxonMobil Biomedical Sciences, Inc. used licensed material at their facility located at 1545 Route 22 East, Annandale, New Jersey, between April 23, 2001 and July 28, 2004. ExxonMobil's facility at this location comprises approximately 900,000 square feet of offices, laboratories, and outer buildings. The site is owned by ExxonMobil Capital Corporation, an ExxonMobil affiliate, and operated by ExxonMobil Research and Engineering, which occupies the majority of the laboratory and office space. Some laboratory and office space is also leased by non-ExxonMobil tenant companies.

The site covers approximately 755 acres in the southeastern portion of Clinton Township, New Jersey. The site is bounded on the north by New Jersey Route 22, on the east by Sand Hill Road, on the south by Valley Crest Road, and on the west by Route 31 and Allerton Road.

The areas where licensed materials were used and/or stored under this license comprised approximately 1,950 square feet of the facility. Floor plans identifying these areas are provided as Attachment A to this report.

## **Identity of Potential Contaminants**

ExxonMobil Biomedical Sciences, Inc. is currently licensed for the possession and use of hydrogen-3, carbon-14, and Ni-63. Work with loose radioisotopes was limited to 24 tests that consumed 1 mCi each of H-3 radiolabeled material. These tests were conducted in LE367 (solution preparation) and in selected animal rooms (PE101, PE103, PE112, PE113, PE114, and PE115) and in the necropsy lab (PE116). H-3 and C-14 labeled material was stored in LE367 (radioisotope lab) and WI-2 (walk-in freezer). Licensed material was not used in LE343/345, LG335, or LG359. A sealed Ni-63 source in an electron capture detector is located in LG337/343, but no other licensed materials were used in this lab.

Between September 20 and October 4, 2004, the areas where licensed materials were known to have been used and/or stored were assessed for the purpose of decommissioning.

## **RELEASE CRITERIA**

The applicable release criteria were based upon Appendix Q of NUREG-1556, Vol. 7, "Consolidated Guidance about Materials Licenses: Program–Specific Guidance About Academic, Research and Development, and Other Licenses of Limited Scope." The criteria used are presented in Table 1 below.

1

NUCLIDES	AVERAGE	MAXIMUM	REMOVABLE	
	(dpm/100 cm <sup>2</sup> )	(dpm/100 cm <sup>2</sup> )	(dpm/100 cm <sup>2</sup> )	
H-3, C-14	5,000 βγ	15,000 βγ	1,000 βγ	

#### **Table 1. Acceptable Surface Contamination Levels**

#### ASSESSMENT PERSONNEL

A professional health physicist, Mr. David J. Durkee, performed the radiological assessment. Mr. Durkee's resume is included as Attachment B to this report.

## **INSTRUMENTATION**

Table 2 lists the instruments used in the performance of the surveys, along with other parameters and detection sensitivities for the instrumentation, and survey techniques. All instruments used were calibrated using NIST-traceable standards. The calibration isotopes used for these instruments included H-3 and C-14. Minimum detectable activities (MDAs) were calculated in accordance with the *Manual for Conducting Radiological Surveys in Support of License Termination, NUREG/CR-5849.* These calculations are included as Attachment C to this report.

Operational and background checks were performed at least once each day of instrument use.

Type of	Instrumentation		Bkgd. <sup>a</sup>	$2\pi^{a}$ Eff & Cal	Detection
Measurement	Detector	Meter		Isotope	Sensitivity
Surface scans - β	Gas Prop. Det. Ludlum model 43-68	Count-rate meter <sup>b</sup> Ludlum mod. 2241-2	230 cpm	9% C-14	3,194 dpm/100 cm <sup>2</sup>
Integrated measurement - β	Gas Prop. Det. Ludlum model 43-68	Count-rate meter <sup>c</sup> Ludlum mod. 2241-2	230 cpm	9% C-14	814 dpm/100 cm <sup>2</sup>
Dose equivalent rates	Scintillation Bicron Microrem LE	(same as detector)	3 – 8 µrem/h	100%	1 μrem/h
Smears, β/γ	Liquid Scintillation Beckman LS 6500	(same as detector)	12 cpm H-3 6 cpm C-14	45% H-3 75% C-14	$54 \text{ dpm}/100 \text{ cm}^2$ 25 dpm/100 cm <sup>2</sup>

 Table 2. Instrumentation for Radiological Surveys

<sup>a</sup>Nominal Values

<sup>b</sup>Monitoring audible signal

<sup>c</sup>1 minute integrated count, slow response

## SURVEY PROCEDURES

Survey planning and procedures were based upon the Manual for Conducting Radiological Surveys in Support of License Termination, NUREG/CR-5849. Actual procedures are described below.

2

## Area Classification

The licensee identified nine (9) areas where licensed radioactive material may have been used and/or stored. The areas identified are as follows:

- LE367: Radioisotope laboratory
- LE116: Necropsy laboratory
- PE101, PE103, PE112, PE113, PE114, and PE115: Animal rooms
- WI-2: Walk in freezer

These areas were designated Affected Areas for the purpose of this survey. All other areas were designated Unaffected Areas.

Facility floor plans clearly identifying the above referenced areas have been included as Attachment A to this report.

## Site Conditions at Time of Survey

The designated Affected Areas were still occupied and in use at the time of the radiological assessment. Equipment, chemicals and other materials were stored within the laboratory areas.

All known licensed material and waste had been disposed of through a licensed waste broker prior to the assessment.

## **Reference Grids**

Affected areas were gridded at approximately 1-meter intervals, up to a height of 2 meters. Unaffected Areas were not gridded.

## **Dose Rate Measurements**

Gamma exposure rates were measured at 1 m above the floor using a gamma scintillation instrument. Recorded measurements in Affected Areas were spaced at approximately one measurement per 4  $m^2$ .

## Surface Activity Measurements

Removable Contamination Measurements

Wipe samples for removable contamination were taken in each accessible grid area (every  $1 \text{ m}^2$  of lower surfaces and walls up to a height of 2 meters). Additional samples were also obtained from areas where activity would have been likely to collect (i.e., fume hoods, sinks, inside cabinets, corners, etc.).

Wipes were also obtained from several Unaffected Areas. Spot checks were performed in the hallways between Affected Areas on the first floor as well as in 3<sup>rd</sup> floor laboratories listed in the initial license application. With the exception of LG337/343 where only the Ni-63 sealed source was used, licensed radioactive materials were supposedly never used in these areas.

## Surface Scans for Total Contamination

Scanning is an initial evaluation technique performed by moving the detection device over a surface at a constant speed and at a fixed distance above the surface to identify areas having elevated radiation levels. Areas thus identified are followed up by integrated measurements.

Instrumentation used for scanning is listed in Table 2. Scanning speeds did not exceed 1 detector-width per second. Audible indicators were used to help identify locations having elevated (>1.25 times ambient) levels of direct radiation.

Scanning of surfaces to identify locations of residual surface and near-surface activity was performed according to the following schedule:

- <u>Affected Area Surfaces:</u> 100% of accessible lower surfaces (floors, countertops, cabinets and walls up to 2 meters above the floor);
- <u>Upper Surfaces (>2 meters above the floor and/or countertop) in Affected Areas:</u> in the immediate vicinity of any elevated measurement found on the lower surfaces;
- <u>Unaffected Area Surfaces</u>: Wipes were also obtained from several Unaffected Areas. Spot checks were performed in the hallways between Affected Areas on the first floor as well as in 3<sup>rd</sup> floor laboratories listed in the initial license application. With the exception of LG337/343 where only the Ni-63 sealed source was used, licensed radioactive materials were supposedly never used in these areas.

Integrated measurements would be obtained from any area noted to have detectable activity.

#### **Background Level Determinations**

Background count rates were determined initially for the building interior by taking measurements in different unaffected locations near the Affected Areas.

#### Sample Analysis

Wipe samples for removable contamination were analyzed for activity using the Liquid Scintillation Counter (LSC) specified in Table 2.

#### **Data Interpretation**

Data conversions and evaluations were performed following guidance specified in NUREG/CR-5849. Measurement data were converted to units of dpm/100 cm<sup>2</sup> (surface activity) for comparison with guidelines. Average values for survey levels were determined and compared with established release criteria.

#### Records

A copy of the survey documentation is enclosed as Attachment D to this report.

## SURVEY FINDINGS AND RESULTS

#### **Background Levels**

Instrumentation background count rates are listed in Table 2.

#### **Dose Rate Measurements**

No areas in excess of normal background levels were identified at the facility.

4

#### **Surface Activity Measurements**

#### Surface Scans and Integrated Measurements

Surface scans of the Affected Areas identified one (1) area of contamination. The floor area under the freezer within LE367 was found to be contaminated to a level of  $18,144 \text{ dpm}/100 \text{ cm}^2$  (C-14). This area was decontaminated to a level indistinguishable from normal background.

Surface scans of Unaffected Areas did not identify any activity in excess of normal background levels.

#### Removable Contamination Measurements

A total of 879 wipes were obtained throughout the nine (9) designated Affected Areas and the seven (7) Unaffected Areas. One (1) sample was found to be in excess of the minimum detectable activity (MDA). This sample was obtained from the floor under the freezer in LE367 which was found to contain loose activity of 1,097 dpm/100 cm<sup>2</sup>. This area was decontaminated to a level indistinguishable from normal background.

#### SUMMARY

Between September 20 and October 4, 2004, a radiological assessment for the purpose of decommissioning was performed at the ExxonMobil Biomedical Sciences, Inc. facility located at 1545 Route 22 East in Annandale, New Jersey. This assessment was conducted by Radcor, LLC of Salem, Connecticut.

After performing a radiological assessment and decontamination of the use and storage areas designated by the licensee, it is the opinion of Radcor, LLC that the areas assessed do not present any significant radiological hazard to facility personnel, the public, or the environment, and that these areas may be released for unrestricted use.

David J. Durkee Health Physicist, RRPT

Attachment A

 $\smile$ 

Floor Plans



111-52

R V E W Α

D

**APPENDIX H - FACILITY FLOOR PLAN** 



9. TRIMMUL

ż



E-mail. may FOR AUTHO

FOR AUTHORIZED COMPANY USE ONLY

Attachment B

 $\sim$ 

Resume

Salem, CT 06420 (860) 887-1538

#### David J. Durkee

#### **EDUCATION:**

Regents College, NY. - B.S. Technology (Nuclear/Health Physics) University of Phoenix, AZ. - A.A. Nuclear Technology Health Physics Technician Level I Basic - Radiation Safety Associates, Inc. Health Physics Technician Level II - Radiation Safety Associates, Inc. Respiratory Protection at Nuclear Facilities - Radiation Safety Associates, Inc. Environmental Monitoring for Radioactivity - Oak Ridge Associated Universities. Liquid Scintillation and Gamma Spectrum Analysis - Rutgers University Health Physics Audits - Radiation Safety Associates, Inc. Navy

Naval Nuclear Power School (24 wks) Nuclear Prototype Training Unit (26 wks) Engineering Laboratory Technician School Machinist Mate "A" School Diesel Operator/Maint. School Scuba Diver School Advanced Auxiliary Package Course Quality Assurance Inspector School

#### **EXPERIENCE:**

December 1996 to Present

Radcor, LLC, Salem, Connecticut

**Health Physicist/Owner.** Responsible for providing radiological consulting services to general industry, academic institutions, and companies involved in research and development. These services include: development and presentation of professional training; performance of program audits; performance of radiological surveys, decontamination and decommissioning; development of license applications, amendments and safety procedures; radiation protection program oversite; and, regulatory compliance. Serve as the Radiation Safety Officer for ExxonMobil Research and Eng. Co., Paulsboro, New Jersey.

#### March 1994 to December 1996

Radiation Safety Associates, Inc., Hebron Connecticut

Vice President-Technical Services. Responsible for the preparation of job proposals and operating budgets; making technical and manpower recommendations; supervising workers at job sites; performing technical evaluations as required; writing, editing, and developing course materials, working procedures and technical articles; and, performed duties as a health physicist.

Responsible for oversite of various site decontamination/decommissioning projects. These involved: the development of decommissioning plans; hiring and oversite of workers; hands-on performance of radiological surveys and site decontamination efforts; and the development and submittal of final reports.

Instructor for the following professional training courses: Fundamentals of Radiological Protection; Health Physics Technician Level I and II; Radiation Safety Officer; Radiation Safety Officer Refresher; and, Basic Radiation Worker.

Assistant Editor of *Radiation Protection Management*, the Journal of Applied Health Physics. Assistant RSO and Quality Control Officer for a radioanalytical laboratory.

#### October 1991 to March 1994

#### Radiation Safety Associates, Inc., Hebron, Connecticut

**Health Physicist**. Responsible for providing consulting services to the nuclear industry; general industry; local, state, and federal governments; and academic institutions. These services included performing audits, radiological surveys, instrument calibrations, site decontamination services, writing license applications and amendments, maintaining radiological safety programs, providing technical advice and performing training.

#### September 1983 to October 1991

**United States Navy, Submarine Qualified.** Served on-board two nuclear-powered submarines. Qualified as Leading Engineering Laboratory Technician, Engineroom Supervisor, Quality Assurance Inspector, Duty Section Leading Mechanic and Ship's Diver.

Supervised and performed chemistry and radiological controls on reactor plant primary and secondary systems. Sampled primary coolant and secondary water chemistry and analyzed results to detect abnormal trends and out of specification conditions. Established and certified radiologically controlled areas, conducted radiation and contamination surveys, evaluated man-rem exposure and processed radioactive waste. Calibrated and operated radiation detectors and chemistry analytical equipment.

Directed the day-to-day efforts of five junior Laboratory Technicians. Awarded a Navy Achievement Medal for being "the driving force behind a dramatic turnaround in the professionalism of the (Reactor Laboratory) division." Instituted a training program that significantly upgraded the level of knowledge of the division.

Drafted detailed work procedures and quality assurance work packages for nuclear and non-nuclear maintenance efforts. Performed in-process inspections to verify that materials and procedures met required specifications.

#### **PROFESSIONAL ACTIVITIES:**

**Registered Radiation Protection Technologist** (NRRPT) **Plenary Member,** Health Physics Society **Member,** Connecticut Chapter, Health Physics Society

#### PUBLICATIONS

"NRC License Application, Renewal, or Amendment for Byproduct Material" *RSO Magazine*, 1:6: pp. 25-30; Nov/Dec, 1996.

"Personal Whole-Body Dosimetry" RSO Magazine, 1:4: pp. 26-28; Jul/Aug, 1996.

"Prenatal Radiation Exposure," RSO Magazine, 1:2: pp. 12-13; Mar/Apr, 1996.

"Loose Contamination Survey Methods," RSO Magazine, 1:1: pp. 19-20; Jan/Feb, 1996.

Steinmeyer, K. Paul, David J. Durkee and Paul R. Steinmeyer. *Mathematics Review for Health Physics Technicians*. Hebron, CT: RSA Publications, 1994. (393 pages).

## Attachment C

## Minimum Detectable Activity Calculations and Calibration Information

#### The equations used for determining the MDAs are as follows:

<u>Variables:</u> MDA = Minimum Detectable Activity in dpm/100  $cm^2$ 

- $R_{b}$  = Background count rate in cpm
- t = Counting time in minutes

 $\tau$  = Detector time constant in minutes

E = Detector efficiency in cpm/dpm'

 $A = Active detector area in cm^2$ 

X = Multiple of background audibly discernable to tech. as increase

MDA for surface scans using Ludlum Model 43-68:

 $MDA = (X)(R_b) \div (E)(A/100)$ 

 $MDA = (1.25)(230 \text{ cpm}) \div (0.09)(100/100) = 3,194 \text{ dpm}/100 \text{ cm}^2$ 

MDA for integrated measurement using Ludlum Model 43-68:

 $MDA = [2.71 + 4.65\sqrt{(R_b)(t)]} \div (t)(E)(A/100)$ 

$$MDA = [2.71 + 4.65\sqrt{(230 \text{ cpm})(1 \text{ min.})]} \div (1 \text{ min.})(0.09)(100/100) = 814 \text{ dpm}/100 \text{ cm}^2$$

MDA for counting 100 cm<sup>2</sup> wipe samples on LSC:

Beckman LS 6500: MDA =  $[2.71 + 4.65\sqrt{(R_b)(t)}] \div (t)(E)$ MDA (For H-3) =  $[2.71 + 4.65\sqrt{(22cpm)(1 min.)}] \div (1 min.)(0.45) = 54 dpm/100 cm<sup>2</sup>$ MDA (For C-14) =  $[2.71 + 4.65\sqrt{(12 cpm)(1 min.)}] \div (1 min.)(0.75) = 25 dpm/100 cm<sup>2</sup>$ MDA (Wide) =  $[2.71 + 4.65\sqrt{(46 cpm)(1 min.)}] \div (1 min.)(0.75) = 46 dpm/100 cm<sup>2</sup>$ 

#### **Instrument Calibration Information**

Ludlum Model 2241-2 with 43-68: Calibrated by RSCS of Stratham, NH on 4/6/04.

Bicron Microrem LE: Calibrated by RSCS of Stratham, NH on 1/05/04.

Beckman LS6500: Calibrated by the manufacturer on 5/26/04.



### Calibration Certificate

A Division of RSCS, Inc.

Contact: David J Durkee

Customer: Radcor, LLC. 345 Laurelwood Drive Salem, CT 06420Instrument Ludium Model 2241-2 Serial Number 137751

Probe Model Ludium 43-68 Serial Number 140899

Precision Check					
Test 1	Test 2	Tesi 3	Mean	Results	
16.10 kcpm	16.10 kcpm	16.00 kcpm	16.07 kcpm	Satisfactory	

Accuracy Check								
Range	Targ	ot Value	As F	ound		As L	eft	
X100	640	Kopm	642	Kepm	#	642	Kopm	#
×100	160	Kopm	157	Kopm	#	157	Kcpm	1;
X10	64	Kcpm	64	Kopm	#	64	Kepm	ĸ
X10	16	Kopm	16.1	Kcpm	#	16.1	Kepm	Ħ
X1	6.4	Kcpm	6.4	Kopm	#	6.4	Kepm	IJ
X1	1.6	Kcpm	1.6	Ксрт	#	1.6	Kopm	#
Readings in Blu	ie indicate ranges w	nere As-Found readin	igs are >20% of Target val	<i>i</i> e. Readir	ngs in red indicate As-left ree	dings are >10	% of Target valu	10
Probe Mo	del & S/N	isotope	Efficiency	N	list Source ID	Ge	ometry	
43-68	140899	P-32	0.2617 C/D	S	r/Y-90 (97SR47006	25) On	Flat Surfac	e
43-68	140899	C-14	0.1053 C/D	C	-14 (488-10-9)	On	Flat Surfac	e
43-68	140899	Pu-239	0.2662 C/D	P	u-239 (93Pu470-31	40) On	Flat Surfac	e
43-68	140899	Th-230	0.2692 C/D	Т	h-230 (S-963)	On	Flat Surfac	e

Outer Physical Check	Ø	Mechanical Zero	Ø
Internal Check	$\square$	Tap Test	
Geotropism Check	Ø	Dessicant Check	

Comments: # Indicates scale calibrated with pulser Model 500 SN: 134720,Other: As Found High Voltage- Det 1 1200 V / Det. 2 1650 V

Calibrated by: QA Review

Date: 04/06/2004

Expires: 04/06/2005

Ens culturation was performed using a NIST Transable radiation source, in conformance to the following standards - ANSI N323A (1997), NCRP 112 (1991). RSUS New House-for Radinactive Maturiat License Number: 361R. RSCS calibration services are performed in accordance with the RSCS Radiation Protection Program Munual and Standard Consulta-Fronadure 2.4

Radiation Safety and Control Services. Inc.

(603) 778-2871

91 Portsmouth Ave. Stratham, NH 03885

1-800-525-8339

Fax (603) 778-6879 www.radsafety.com

aic. 04/



## **Calibration** Certificate

A Division of RSCS, Inc.

Contact: David J Durkee

Customer: Radcor, LLC. 345 Laurelwood Drive Salem, CT 06420Instrument Bicron Model MicroRem Serial Number B466Y

Precision Check					
Test 1	Test 2	Test 3	Mean	Results	
4.00 mR/Hr	4.00 mR/Hr	4.00 mR/Hr	4.00 mR/Hr	Satisfactory	

Accuracy Check								
Range	Ta	arget Value	As	Found			As Left	
X1000	160	mrem/hr	170	mrem/hr		170	mrem/hr	
X1000	40	mrem/hr	40	mrem/hr		40	mrem/hr	
X100	16	mrem/hr	16.5	mrem/hr		16.5	mrem/hr	
X100	- 4	mrem/hr	4	mrem/hr		4	mrem/hr	ľ
X10	1.6	mrem/hr	1.65	mrem/hr		1.65	mrem/hr	
X10	0.4	mrem/hr	.4	mrem/hr		.4	mrem/hr	
X1	160	µrem/hr	160	µrem/hr	#	160	µrem/hr	#
X1	40	µrem/hr	40	µrem/hr	#	40	µrem/hr	#
X0.1	16	µrem/hr	16	µrem/hr	#	16	µ <b>re</b> m/hr	#
X0.1	4	µrem/hr	4	µrem/hr	#	4	µrem/hr	#

Readings in bold indicate ranges where As-Found readings are >20% of Target value

Outer Physical Check	Ø	Mechanical Zero	Ø
Internal Check	Ø	Tap Test	Ð
Geotropism Check		Dessicant Check	

Comments: # Indicates scale calibrated with pulser Model 500 SN: 134720

Fax (603) 778-6879

Calibrated by:

Date: 01/05/2004

Expires: 01/05/2005

This calibration was performed using a NIST Traceable radiation source, in conformance to the following standards: MIL-STD 45662, ANSI N323A (1997), NCRP 112 (1991). RSCS New Hampshire Radioactive Material License Number: 381R. RSCS calibration services are performed in accordance with the RSCS Radiation Protection Program Manual and all opplicable sections of 10 CFR 21. CS-137 Calibration source: S-364, Activity 145,300.00 uCi on 7/13/81

Radiation Safety and Control Services, Inc.

91 Portsmouth Ave. Stratham, NH 03885

1-800-525-8339 (603) 778-2871

www.radsafely.com

Attachment D

Survey Documentation

 Job Location:
 ExxonMobil Research and Eng. Clinton, NJ
 Page:
 1 of 3

 Survey Purpose:
 Decommissioning
 PE115
 Date:
 9/20/2004

 Performed By:
 David Durkee/Ed Gailor
 Date:
 9/20/2004

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludlum Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0715	1	Background	1	46	N/A	
	2	Door and Handle	1	46	0.0	
	3	Floor	1	54	10.7	
	4	Upper wall	1	57	14.7	
	5	Lower Wall	1	57	14.7	
	6	Upper wall	1	47	1.3	
	7	Lower Wall	1	50	5.3	
	8	Upper wall	1	66	26.7	
	9	Lower Wall	1	42	-5.3	
	10	Upper wall	1	51	6.7	
	11	Lower Wall	1	42	-5.3	
	12	Upper wall	1	47	1.3	
	13	Lower Wall	1	62	21.3	
	14	Upper wall	1	55	12.0	
	15	Lower Wall	1	39	-9.3	
	16	Upper wall	1	61	20.0	
	17	Lower Wall	1	23	-30.7	
	18	Upper wall	1	36	-13.3	
	19	Lower Wall	1	68	29.3	
	20	Upper wall	1	40	-8.0	
	21	Lower Wall	1	45	-1.3	
	22	Upper wall	1	68	29.3	
	23	Lower Wall	1	45	-1.3	
	24	Upper wall	1	32	-18.7	
	25	Lower Wall	1	57	14.7	
	26	Sink	1	55	12.0	
	27	Floor	1	53	9.3	
	28	Floor	1	48	2.7	
	29	Floor	1	50	5.3	
	30	Floor	1	41	-6.7	
	31	Floor	1	50	5.3	
	32	Floor	1	39	-9.3	
	33	Floor	1	45	-1.3	
	34	Floor	1	40	-8.0	
	35	Floor	1	44	-2.7	
	36	Floor	1	52	8.0	
	37	Floor	1	37	-12.0	

Job Location:	ExxonMobil Research and	Eng. Cli	inton, NJ	Page:	2 of 3
Survey Purpose:	Decommissioning	PE115		Date:	9/20/2004

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0715	38	Floor	1	48	2.7	
	39	Floor	1	47	1.3	
	40	Floor	1	48	2.7	<u> </u>
	41	Floor	1	61	20.0	
	42	Floor	1	43	-4.0	
	43	Floor	1	52	8.0	
	44	Floor	1	53	9.3	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



Page 3 of 3 9/20/04





Radiation readings in units of µrem/h

 Job Location:
 ExxonMobil Research and Eng. Clinton, NJ
 Page:
 1 of 3

 Survey Purpose:
 Decommissioning
 PE114
 Date:
 9/20/2004

 Performed By:
 David Durkee/Ed Gailor
 David Durkee/Ed Gailor
 David Durkee/Ed Gailor

Instrument No. 1	Instrument No. 2	Instrument No. 3	
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y	
	Ludlum Model 43-68 #140899		
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %	
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ	
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h	
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05	

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0745	1	Background	1	41	N/A	
	2	Door and handle	1	52	14.7	
	3	Floor	1	48	9.3	
	4	Upper wall	1	48	9.3	
	5	Lower Wall	1	35	-8.0	
	6	Upper wall	1	45	5.3	
	7	Lower Wall	1	49	10.7	
	8	Upper wall	1	49	10.7	····
	9	Lower Wall	1	29	-16.0	
	10	Upper wall	1	36	-6.7	
	11	Lower Wall	1	45	5.3	
	12	Upper wall	1	47	8.0	
	13	Lower Wall	1	45	5.3	
	14	Upper wall	1	39	-2.7	
	15	Lower Wall	1	50	12.0	
	16	Upper wall	1	43	2.7	
	17	Lower Wall	1	53	16.0	
	18	Upper wall	1	59	24.0	******
	19	Lower Wall	1	65	32.0	
	20	Upper wall	1	37	-5.3	
	21	Lower Wall	1	61	26.7	
	22	Upper wall	1	54	17.3	
	23	Lower Wall	1	46	6.7	
	24	Upper wall	1	50	12.0	
	25	Sink	1	46	6.7	
	26	Floor	1	41	0.0	
	27	Floor	1	53	16.0	
	28	Floor	1	37	-5.3	
	29	Floor	1	41	0.0	
	30	Floor	1	41	0.0	
	31	Floor	1	47	8.0	
	32	Floor	1	59	24.0	
	33	Floor	1	45	5.3	
	34	Floor	1	47	8.0	
	35	Floor	1	61	26.7	
	36	Floor	1	49	10.7	
	37	Floor	1	55	18.7	

Job Location:	ExxonMobil Researc	h and Eng. Clinton, NJ	Page	: <u>1 of 3</u>
Survey Purpose:	Decommissioning	PE114	Date	9/20/2004

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
0745	38	Floor	1	48	9.3	
	39	Floor	1	61	26.7	
	40	Floor	1	57	21.3	
	41	Floor	1	61	26.7	
	42	Floor	1	49	10.7	
	43	Floor	1	42	1.3	
	44	Floor	1	52	14.7	
	45	Floor	1	52	14.7	
	46	Floor	1	46	6.7	
	47	Floor	1	55	18.7	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



Page 3 of 3 9/20/04





Radiation readings in units of µrem/h

Job Location:	ExxonMobil Research and	IEng. Clinton,	NJ	Page:	1 of 3
Survey Purpose:	Decommissioning	PE113		Date:	9/20/2004
Performed By:	David Durkee/Ed Gailor		S		

		/	
Instrument No. 1	Instrument No. 2	Instrument No. 3	
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y	
	Ludlum Model 43-68 #140899		
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %	
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ	
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h	
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05	

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0835	1	Background	1	56	N/A	
	2	Door and handle	1	42	-18.7	
	3	Floor	1	55	-1.3	
	4	Upper wall	1	48	-10.7	
	5	Lower Wall	1	51	-6.7	
	6	Upper wall	1	42	-18.7	
	7	Lower Wall	1	54	-2.7	
	8	Upper wall	1	40	-21.3	
	9	Lower Wall	1	46	-13.3	
	10	Upper wall	1	39	-22.7	
	11	Lower Wall	1	53	-4.0	
	12	Upper wall	1	49	-9.3	
	13	Lower Wall	1	52	-5.3	
	14	Upper wall	1	69	17.3	
	15	Lower Wall	1	41	-20.0	
	16	Upper wall	1	43	-17.3	
	17	Lower Wall	1	51	<b>-6</b> .7	
	18	Upper wall	1	40	-21.3	
	19	Lower Wall	1	51	-6.7	
	20	Upper wall	1	56	0.0	
	21	Lower Wall	1	53	-4.0	
	22	Upper wall	1	40	-21.3	
	23	Lower Wall	1	36	-26.7	
	24	Upper wall	1	50	-8.0	
	25	Lower Wall	1	50	-8.0	
	26	Upper wall	1	36	-26.7	
	27	Lower Wall	1	43	-17.3	
	28	Upper wall	1	51	-6.7	
	29	Lower Wall	1	43	-17.3	
	30	Hood door and handle	1	47	-12.0	
	31	Inside, back of hood	1	38	-24.0	
	32	Inside, left side of hood	1	46	-13.3	
	33	Inside, right side of hood	1	34	-29.3	
	34	Inside, bottom of hood	1	55	-1.3	
	35	Outside, left side of hood	1	40	-21.3	
	36	Outside, right side of hood	1	36	-26.7	
	37	Outside back of hood	1	48	-10.7	

Job Location:	ExxonMobil Research and	Eng. Clinton, NJ	Page:	2 of 3
Survey Purpose:	Decommissioning	PE113	Date:	9/20/2004

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
0835	38	Floor	1	36	-26.7	<u> </u>
	39	Floor	1	47	-12.0	
	40	Floor	1	40	-21.3	<u> </u>
	41	Floor	1	39	-22.7	
	42	Floor	1	38	-24.0	
	43	Floor	1	43	-17.3	
	44	Floor	1	64	10.7	
	45	Floor	1	51	-6.7	
	46	Floor	1	54	-2.7	
	47	Floor	1	45	-14.7	
	48	Floor	1	58	2.7	
	49	Floor	1	52	-5.3	
	50	Floor	1	46	-13.3	
	51	Floor	1	49	-9.3	
	52	Floor	1	50	-8.0	
	53	Floor	1	46	-13.3	
	54	Floor	1	44	-16.0	
	55	Floor	1	53	-4.0	
	56	Floor	1	56	0.0	
	57	Floor	1	55	-1.3	
	58	Floor	1	40	-21.3	
	59	Floor	1	57	1.3	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



~

~\_\_\_

Page 3 of 3 9/20/04



O = wipe location Radiation readings in units of µrem/h

Job Location:	ExxonMobil Research an	d Eng. Clinton, NJ		Page:	1 of 3
Survey Purpose:	Decommissioning	PE112		Date:	9/20/2004
Performed By:	David Durkee/Ed Gailor	No.	XX		
			/		

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludium Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludium Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1000	1	Background	1	45	N/A	
	2	Door and handle	1	64	25.3	
	3	Floor	1	56	14.7	
	4	Upper wall	1	40	-6.7	
	5	Lower Wall	1	47	2.7	
	6	Upper wall	1	51	8.0	
	7	Lower Wall	1	35	-13.3	
	8	Upper wall	1	51	8.0	
	9	Lower Wall	1	56	14.7	
	10	Upper wall	1	64	25.3	
	11	Lower Wall	1	50	6.7	
	12	Upper wall	1	64	25.3	
	13	Lower Wall	_1	47	2.7	
	14	Upper wall	1	39	-8.0	
	15	Lower Wall	1	60	20.0	
	16	Upper wall	1	49	5.3	
	17	Lower Wall	1	53	10.7	
	18	Sink	1	41	-5.3	
	19	Upper wall	1	47	2.7	
	20	Lower Wall	1	54	12.0	
	21	Upper wall	1	27	-24.0	
	22	Lower Wall	1	47	2.7	
	23	Upper wall	1	47	2.7	
	24	Lower Wall	1	47	2.7	
	25	Upper wall	1	34	-14.7	
	26	Lower Wall	1	46	1.3	
	27	Upper wall	1	52	9.3	
	28	Lower Wall	1	44	-1.3	
-	29	Upper wall	1	47	2.7	
	30	Lower Wall	1	40	-6.7	
	31	Hood Doors and Handle	1	50	6.7	
	32	Outside, left side of hood	1	42	-4.0	
	33	Outside back of hood	1	52	9.3	
	34	Outside, right side of hood	1	37	-10.7	
	35	Inside, hood back	1	35	-13.3	
	36	Inside, left side of hood	1	31	-18.7	
	37	Inside, right side of hood	1	44	-1.3	

Job Location:		ExxonMobil Research and Eng. Clinton,	NJ		Page:	2 of 3
Survey F	Purpose:	e: Decommissioning PE112			Date: 9	0/20/2004
						· · · · · · · · · · · · · · · · · · ·
Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1000	38	Inside, hood bottom	1	44	-1.3	
	39	Inside, hood door	1	43	-2.7	
	40	Floor	1	49	5.3	
	41	Floor	1	37	-10.7	
	42	Floor	1	49	5.3	
	43	Floor	1	41	-5.3	
	44	Floor	1	57	16.0	
	45	Floor	1	41	-5.3	
	46	Floor	1	39	-8.0	
	47	Floor	1	46	1.3	
	48	Floor	1	47	2.7	
	49	Floor	1	31	-18.7	
	50	Floor	1	48	4.0	
	51	Floor	1	52	9.3	
	52	Floor	1	44	-1.3	
	53	Floor	1	57	16.0	
	54	Floor	1	44	-1.3	
	55	Floor	1	58	17.3	
	56	Floor	1	38	-9.3	
	57	Floor	1	42	-4.0	
	58	Floor	1	40	-6.7	
	59	Floor	1	42	-4.0	
	60	Floor	1	62	22.7	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



PE 112 - Animal Room

\_\_\_\_



Radiation readings in units of µrem/h

Page 3 of 3

9/20/04

 Job Location:
 ExxonMobil Research and Eng. Clinton, NJ
 Page:
 1 of 5

 Survey Purpose:
 Decommissioning
 PE116
 Date:
 9/20/2004

 Performed By:
 David Durkee/Ed Gailor
 Dock
 9/20/2004

	V	
Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludlum Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 7 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1035	1	Background	1	42	N/A	
	2	Door and handle	1	38	-5.3	
	3	Floor	1	45	4.0	
	4	Upper wall	1	47	6.7	
	5	Lower Wall	1	55	17.3	
	6	Floor	1	43	1.3	
	7	Behind sink	1	45	4.0	
	8	Inside sink	1	52	13.3	
	თ	Counter	1	37	-6.7	
	10	Counter	1	51	12.0	
	11	Behind sink	1	48	8.0	
	12	Inside sink	1	46	5.3	
	13	Left side of hood	1	46	5.3	
	14	Upper hood back	1	56	18.7	
	15	Middle hood back	1	61	25.3	
	16	Lower hood back	1	46	5.3	
	17	Vents left side	1	44	2.7	
	18	Upper back of hood	1	43	1.3	
	19	Middle hood back	1	45	4.0	
	20	Lower hood back	1	55	17.3	
and the second second	21	Vents	1	54	16.0	
	22	Bottom of hood	1	65	30.7	
	23	Bottom of hood	1	47	6.7	
	24	Bottom of hood	1	52	13.3	
	25	Right side of hood	1	48	8.0	
	26	Hood doors	1	47	6.7	
	27	Hood doors	1	39	-4.0	
	28	Hood doors	1	66	32.0	
	29	Cabinet doors	1	76	45.3	
	30	Top shelf	1	54	16.0	
	31	Middle shelf	1	55	17.3	
	32	Bottom shelf	1	50	10.7	
	33	Cabinet doors	1	41	-1.3	
	34	Top shelf	1	58	21.3	
	35	Middle shelf	1	36	-8.0	
	36	Bottom shelf	1	45	4.0	
	37	Cabinet doors	1	46	5.3	

		Exxonitiobili Research and Erig. Clinton, NJ		_ Faye		
Survey F	vey Purpose: Decommissioning PE116			1/20/2004		
Timo	Number	Location	Inst		Activity	Common
1 IIII <del>C</del>	Number	Location	list.	срш	(dom/100cm <sup>2</sup> )	Commen
1035	38	Ton shelf	1	46	5.3	<u> </u>
1000	39	Middle shelf	1	42	0.0	
	40	Bottom shelf	1	58	21.3	<u> </u>
	<u>40</u>	Cabinet doors	1	53	14 7	
	42	Inside cabinet	1	47	67	
	43	Drawers	1	51	12.0	
	40	Top drawer	1	62	26.7	
	45	2nd drawer	1	44	20.1	
110 1000	45	3rd drawer	1	44	2.7	
	40	Ath drawer		44	1.2	<u> </u>
	4/	Drowers	1	40	1.3	
	40	Top drawer		10	9.0	·
	49	2nd drawer		40 20	0.0	
	50	2rd drower		30	-10.0	× <del></del>
	57	Ath drawer	1	<u>44</u> 51	2.7	
	52			54	12.0	
	53	Drawers			10.0	
	54	Drawer Ochinet deere	1	42	0.0	
	50		1		14.7	
	50		1	49	9.3	
	57	Floor	1	54	16.0	
	58		1	30	-16.0	
	59		1	39	-4.0	
	60		1	4/	6.7	
	61	Floor	1	<u> </u>	2.7	<u></u>
	62	Retrig. Doors	1	63	9.3	
	63	Inside freezer	1	41	-20.0	
	64	Inside refrig.	1	56	0.0	
	65	Floor	1	54	-2.7	
	66	Door	1	58	2.7	
	67	Floor	1	47	-12.0	
	68	Counter	1	56	0.0	
	69	Counter	1	50	-8.0	
Y. State	70	Inside hood	1	53	-4.0	
	71	Counter	1	51	-6.7	40.4.
	72	Inside hood	1	39	-22.7	
	73	Counter	1	40	-21.3	
	74	Counter	1	97	77.3	
	75	Counter	1	37	-2.7	
	76	Inside hood	1	53	18.7	
	77	Counter	1	39	0.0	
	78	Inside hood	1	37	-2.7	
	79	Counter	1	42	4.0	
	80	Upper wall	1	57	24.0	
	81	Cabinet doors	1	33	-8.0	
	82	Top shelf	1	44	6.7	
	83	2nd shelf	1	49	13.3	

1

 $\sim$ 

Job Loca	ation:	ExxonMobil Research and Eng. Clinton, NJ		Page:	3 of 5	
Survey F	urpose:	Decommissioning <b>PE116</b>			Date:	<b>3/2</b> 0/2004
•	•					
Time	Number	Location	Inst.	com	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	0011101110
1035	84	Bottom shelf	1	45	8.0	· · · · · · · · · · · · · · · · · · ·
	85	Cabinet doors	1	44	6.7	
	86	Top shelf	1 1	51	16.0	
	87	2nd shelf	1	43	1.3	
	88	Bottom shelf	1	42	0.0	
	89	Cabinet doors	1	43	1.3	**
	90	Top shelf	1	41	-1.3	· · ·
en e	91	2nd shelf	1	47	6.7	
	92	Middle shelf	1	49	9.3	
	93	Cabinet doors	1	47	6.7	
	94	Top shelf	1	44	2.7	
	95	2nd shelf	1	50	10.7	nd -
	96	Bottom shelf	1	42	0.0	
	97	Cabinet doors	1	51	12.0	
	98	Top shelf	1	39	-4.0	
	99	2nd shelf	1	45	4.0	
	100	Bottom shelf	1	60	24.0	
	101	Drawers	1	49	9.3	
	102	Top drawer	1	52	13.3	
	103	2nd drawer	1	54	16.0	-
	104	3rd drawer	1	47	6.7	
	105	4th drawer	1	56	18.7	
	106	Drawers	1	55	17.3	
	107	Top drawer	1	50	10.7	
	108	2nd drawer	1	45	4.0	
	109	3rd drawer	1	53	14.7	
	110	4th drawer	1	47	6.7	
	111	Drawers	1	51	12.0	
	112	Top drawer	1	44	2.7	
	113	2nd drawer	1	47	6.7	
	114	3rd drawer	1	59	22.7	
	115	4th drawer	1	45	4.0	
	116	Drawers	1	46	5.3	
	117	Top drawer	1	47	6.7	
	118	2nd drawer	1	53	14.7	
	119	3rd drawer	1	44	2.7	
	120	4th drawer	1	49	9.3	
	121	Doors	1	53	14.7	
	122	Top drawer	1	46	5.3	
	123	2nd drawer	1	52	13.3	
	124	3rd drawer	1	44	2.7	
	125	4th drawer	1	47	6.7	
	126	Drawers	1	57	20.0	
	127	Top drawer	1	39	-4.0	
	128	2nd drawer	1	45	4.0	
	129	3rd drawer	1	43	1.3	

.

/

~

Job Location:		ExxonMobil Research and Eng. Clinton, NJ		Page:	4 of 5		
Survey Purpose: Decommissioning PE116					Date:	<b>9/2</b> 0/2004	
Time	Number	Locati	on	Inst.	срт	Activity	Comments

			Used.		(dpm/100cm*)	
1035	130	4th drawer	1	44	2.7	
	131	Left side of hood	1	46	5.3	
	132	Right side of hood	1	42	0.0	
	133	Upper back of hood	1	50	10.7	
	134	Lower back of hood	1	52	13.3	
	135	Upper back of hood	1	41	-1.3	
	136	Lower back of hood	1	51	12.0	
	137	Vents	1	44	2.7	
	138	Vents	1	46	5.3	
	139	Bottom of hood	1	52	13.3	
	140	Hood doors	1	58	21.3	
	141	Bottom of hood	1	53	14.7	
	142	Hood doors	1	52	13.3	
	143	Cabinet doors	1	47	6.7	
	144	Inside cabinet	1	41	-1.3	
	145	Cabinet doors	1	54	16.0	
	146	Inside cabinet	1	47	6.7	
	147	Cabinet doors	1	43	1.3	
	148	Inside cabinet	1	59	22.7	
	149	Cabinet doors	1	42	0.0	
	150	Inside cabinet	1	35	-9.3	
	151	Floor	1	54	16.0	
	152	Floor	1	41	-1.3	
	153	Floor	1	42	0.0	
	154	Floor	1	50	10.7	
	155	Floor	1	54	16.0	
	156	Floor	1	51	12.0	
	157	Floor	1	60	24.0	
	158	Floor	1	39	-4.0	
	159	Floor	1	51	12.0	
	160	Floor	1	39	-4.0	
	161	Floor	1	37	-6.7	
	162	Floor	1	51	12.0	
	163	Floor	1	49	9.3	
	164	Floor	1	42	0.0	
	165	Post Decon #74	1	33	-12.0	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.

Page 5 of 5 9/20/04



Radiation readings in units of urem/h

Job Location:	ExxonMobil Research and	d Eng. Clinton, NJ	Page:	1 of 3
Survey Purpose:	Decommissioning	PE101	Date:	<b>9/2</b> 0/2004
Performed By:	David Durkee/Ed Gailor			

Instrument No. 1	Instrument No. 2	Instrument No. 3	
Beckman LS6500 #7068276	Ludium Model 2241-2 #137751	Bicron Microrem LE #B466y	
	Ludium Model 43-68 #140899		
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %	
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ	
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h	
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05	

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1350	1	Background	1	44	N/A	
	2	Door and handle	1	44	0.0	
	3	Floor	1	49	6.7	
	4	Upper wall	1	33	-14.7	
	5	Lower Wall	1	41	-4.0	
	6	Upper wall	1	44	0.0	
	7	Lower Wall	1	37	-9.3	
	8	Upper wall	1	49	6.7	
к.,	9	Lower Wall	1	43	-1.3	
	10	Upper wall	1	30	-18.7	
	11	Lower Wall	1	71	36.0	
	12	Upper wall	1	47	4.0	
	13	Lower Wall	1	43	-1.3	
	14	Upper wall	1	46	2.7	
	15	Lower Wall	1	60	21.3	
	16	Upper wall	1	59	20.0	
	17	Lower Wall	1	43	-1.3	
	18	Sink	1	46	2.7	
	19	Upper wall	1	55	14.7	
	20	Lower Wall	1	54	13.3	
	21	Upper wall	1	47	4.0	
	22	Lower Wall	1	44	0.0	
	23	Upper wall	1	56	16.0	
	24	Lower Wall	1	44	0.0	
	25	Upper wall	1	35	-12.0	
	26	Lower Wall	1	53	12.0	
	27	Upper wall	1	52	10.7	
	28	Lower Wall	1	39	-6.7	
	29	Upper wall	1	48	5.3	
	30	Lower Wall	1	55	14.7	
	31	Hood Doors and Handle	1	72	37.3	
	32	Outside, left side of hood	1	51	9.3	
	33	Outside back of hood	1	52	10.7	
	34	Outside, right side of hood	1	58	18.7	
	35	Inside, hood back	1	55	14.7	
	36	Inside, left side of hood	1	68	32.0	
	37	Inside, right side of hood	1	49	6.7	

Job Location:	ExxonMobil Research	and Eng. Clinton, NJ	Page:	2 of 3
Survey Purpose:	Decommissioning	PE101	Date:	<b>9/</b> 20/2004

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
1350	38	Inside, hood bottom	1	45	1.3	
	39	Inside, hood door	1	53	12.0	
	40	Floor	1	59	20.0	
	41	Floor	1	39	-6.7	
	42	Floor	1	41	-4.0	
	43	Floor	1	45	1.3	
	44	Floor	1	40	-5.3	
	45	Floor	1	53	12.0	
	46	Floor		41	-4.0	
	47	Floor	1	58	18.7	
	48	Floor	1	56	16.0	
	49	Floor	1	39	-6.7	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



Page 3 of 3 9/20/04





Radiation readings in units of µrem/h

Job Location:	ExxonMobil Research and	d Eng. Clint	on, NJ	_ Page: _	1 of 3
Survey Purpose:	Decommissioning	PE103		Date:	<b>9/2</b> 0/2004
Performed By:	David Durkee/Ed Gailor		SOAN		

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludlum Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1410	1	Background	1	42	N/A	
	2	Door and handle	1	63	28.0	
	3	Floor	1	43	1.3	
	4	Upper wall	1	36	-8.0	
	5	Lower Wall	1	64	29.3	
	6	Upper wall	1	53	14.7	
	7	Lower Wall	1	46	5.3	
	8	Upper wall	1	72	40.0	
	9	Lower Wall	1	56	18.7	
	10	Upper wall	1	54	16.0	
	11	Lower Wall	1	44	2.7	
	12	Upper wall	1	39	-4.0	
e regele compa	13	Lower Wall	1	38	-5.3	
	14	Upper wall	1	47	6.7	
	15	Lower Wali	1	46	5.3	
	16	Upper wall	1	51	12.0	
	17	Lower Wall	1	57	20.0	
	18	Upper wall	1	46	5.3	
	19	Lower Wall	1	45	4.0	
	20	Sink	1	42	0.0	
	21	Upper wall	1	45	4.0	
	22	Lower Wall	1	42	0.0	
	23	Upper wall	1	60	24.0	
	24	Lower Wall	1	64	29.3	
	25	Upper wall	1	66	32.0	
	26	Lower Wall	1	55	17.3	
	27	Floor	1	48	8.0	
	28	Floor	1	45	4.0	
	29	Floor	1	50	10.7	
	30	Floor	1	47	6.7	
	31	Floor	1	44	2.7	
	32	Floor	1	37	-6.7	
	33	Floor	1	45	4.0	
	34	Floor	1	46	5.3	
	35	Floor	1	40	-2.7	
	36	Floor	1	47	6.7	
	37	Floor	1	54	16.0	

 $\sim$ 

Job Location:	ExxonMobil Research	and Eng. Clinton, NJ	Page: _	2 of 3
Survey Purpose:	Decommissioning	PE103	Date:	9/20/2004

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
1410	38	Floor	1	49	9.3	
	39	Floor	1	42	0.0	
	40	Floor	1	48	8.0	
	41	Floor	1	63	28.0	
	42	Floor	1	47	6.7	
	43	Floor	1	51	12.0	
	44	Floor	1	43	1.3	
	45	Floor	. 1	50	10.7	
	46	Floor	1	49	9.3	9 · · · · · · ·

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.



Page 3 of 3 9/20/04





Radiation readings in units of µrem/h

Job Location:	ExxonMobil Research and Eng. Clinton, NJ	Page:	1 of 3
Survey Purpose:	Decommissioning 1st Floor Hallway	Date:	<b>9/2</b> 0/2004
Performed By:	David Durkee/Ed Gailor		

Performed By: D	avid Durkee/	Ed Gailor	A Commentation of the comm
Instrument N	lo. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #70	68276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
		Ludium Model 43-68 #140899	
Efficiency: 45% H-3/7	'5% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ		Type Rad: β	Type Rad: y
Background (cpm): Se	ee #1 below	Background: 230 cpm	Background: 4 - 6 µrem/h
Cal. Due: 5/26/05		Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1445	1	Background	1	43	N/A	
	2	Platform	1	43	0.0	
	3	Platform	1	46	4.0	
	4	Outside door and handle	1	40	-4.0	
	5	Inside door and handle	1	45	2.7	
	6	Floor	1	64	28.0	
	7	Floor	1	49	8.0	
	8	Door	1	35	-10.7	
	9	Floor	1	40	-4.0	
	10	Door	1	38	-6.7	
	11	Floor	1	45	2.7	
	12	Floor	1	45	2.7	
	13	Floor	1	56	17.3	
	14	Floor	1	55	16.0	
	15	Floor	1	43	0.0	
	16	Door	1	40	-4.0	
	17	Floor	1	50	9.3	
	18	Door	1	50	9.3	
	19	Floor	1	50	9.3	
	20	Door	1	47	5.3	
	21	Floor	1	55	16.0	
	22	Door	1	36	-9.3	
	23	Floor	1	49	8.0	
	24	Floor	1	48	6.7	
	25	Floor	1	39	-5.3	
	26	Door	1	50	9.3	
	27	Floor	1	51	10.7	
	28	Door	1	47	5.3	
	29	Floor	1	41	-2.7	
16. L	30	Door	1	39	-5.3	
	31	Floor	1	38	-6.7	
	32	Door	1	50	9.3	
	33	Floor	1	48	6.7	
	34	Floor	1	57	18.7	
	35	Door	1	44	1.3	
	36	Floor	1	38	-6.7	
	37	Door	1	33	-13.3	

Job Location:	ExxonMobil Resear	ch and Eng.	Clinton, NJ	Page:	2 of 3
Survey Purpose:	Decommissioning	1st Floor Ha	allway	Date:	<b>9/2</b> 0/2004

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
1445	38	Floor	1	38	-6.7	
	39	Door	1	39	-5.3	
	40	Floor	1	49	8.0	
	41	Floor	1	48	6.7	<u>.</u>
	42	Door	1	47	5.3	
	43	Floor	1	57	18.7	
	44	Floor	1	45	2.7	
	45	Door	1	41	-2.7	
	46	Floor	1	43	0.0	
	47	Door	1	54	14.7	
	48	Door	1	47	5.3	
	49	Floor	1	48	6.7	
	50	Door	1	55	16.0	
	51	Floor	1	50	9.3	

Spot checked lower surfaces using instrument #2. All surfaces noted to be at normal background levels.



Job Location:	ExxonMobil Research and	Eng. Clinton, NJ	Page:	1 of 3
Survey Purpose:	Decommissioning	PE W1-2	Date:	<b>9/2</b> 0/2004
Performed By:	David Durkee/Ed Gailor	36000		

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludium Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 5 - 7 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1525	1	Background	1	58	N/A	
	2	Door and handle	1	49	-12.0	
	3	Floor	1	47	-14.7	
	4	Upper wall	1	46	-16.0	
	5	Lower Wall	1	55	-4.0	
	6	Upper wall	1	43	-20.0	
	7	Lower Wall	1	32	-34.7	
	8	Upper wall	1	31	-36.0	
A second s	9	Lower Wall	1	52	-8.0	
	10	Upper wall	1	53	-6.7	
	11	Lower Wall	1	53	-6.7	
	12	Upper wall	1	55	-4.0	
	13	Lower Wall	1	52	-8.0	
	14	Upper wall	1	46	-16.0	
	15	Lower Wall	1	52	-8.0	
	16	Upper wall	1	51	-9.3	
	17	Lower Wall	1	41	-22.7	
	18	Sink	1	51	-9.3	
	19	Upper wall	1	46	-16.0	
	20	Lower Wall	1	51	-9.3	
	21	Upper wall	1	63	6.7	
	22	Lower Wall	1	41	-22.7	-
	23	Upper wall	1	51	-9.3	
	24	Lower Wall	1	44	-18.7	
	25	Upper wall	1 .	39	-25.3	
	26	Lower Wall	1	50	-10.7	
	27	Upper wall	1	50	-10.7	
	28	Lower Wall	1	48	-13.3	
State of Section	29	Upper wall	1	37	-28.0	
	30	Lower Wall	1	34	-32.0	
	31	Hood Doors and Handle	1	52	-8.0	
	32	Outside, left side of hood	1	58	0.0	
2 (* 45) 1 (* 195	33	Outside back of hood	1	60	2.7	
	34	Outside, right side of hood	1	45	-17.3	
1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 -	35	Inside, hood back	1	48	-13.3	
	36	Inside, left side of hood	1	57	-1.3	
	37	Inside, right side of hood	1	44	-18.7	

Job Location:	ExxonMobil Research	and Eng. Clinton, NJ	Page:	_2 of 3
Survey Purpose:	Decommissioning	PE W1-2	Date:	9/20/04

Time	Number	Location	Inst. Used.	cpm	Activity (dpm/100cm <sup>2</sup> )	Comments
1525	38	Inside, hood bottom	1	42	-21.3	
	39	Inside, hood door	1	48	-13.3	
	40	Floor	1	65	9.3	
	41	Floor	1	39	-25.3	
	42	Floor	1	44	-18.7	
	43	Floor	1	48	-13.3	
	44	Floor	1	38	-26.7	
	45	Floor	1	36	-29.3	
	46	Floor	1	53	-6.7	
	47	Floor	1	43	-20.0	
	48	Floor	1	57	-1.3	

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels.

PE WI-2 - Freezer

Page 3 of 3 9/20/04



O = wipe location Radiation readings in units of µrem/h

Job Location:	ExxonMobil Research and	d Eng. Clinton, NJ	Page:	1 of 5
Survey Purpose:	Decommissioning	LE367	Date:	<b>9/</b> 21/2004
Performed By:	David Durkee/Ed Gailor			

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludium Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 4 - 8 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0640	1	Background	1	34	N/A	
	2	Door and handle	1	44	13.3	
	3	Floor	1	42	10.7	
	4	Wall	1	38	5.3	
	5	Wall	1	59	33.3	
	6	Inside sink	1	40	8.0	
	7	Counter	1	51	22.7	
_	8	Counter	1	53	25.3	
	9	Counter	1	63	38.7	
	10	Counter	1	58	32.0	
	11	Counter	1	51	22.7	
	12	Counter	1	47	17.3	
	13	Cabinet doors	1	33	-1.3	_
	14	Top shelf	1	42	10.7	
	15	2nd shelf	1	53	25.3	
	16	3rd shelf	1	50	21.3	
	17	Cabinet doors	1	55	28.0	
	18	Top shelf	1	46	16.0	
	19	2nd shelf	1	41	9.3	
	20	3rd shelf	1	63	38.7	
	21	Cabinet doors	1	39	6.7	
	22	Top shelf	1	54	26.7	
	23	Bottom shelf	1	54	26.7	
	24	Wall	1	52	24.0	
	25	Wall	1	51	22.7	
	26	Floor	1	53	25.3	
	27	Door and handle	1	41	9.3	
	28	Floor	1	65	41.3	
	29	Cabinet doors	1	34	0.0	
	30	Inside cabinet	1	43	12.0	
	31	Drawers	1	50	21.3	
	32	Tope left drawer	1	35	1.3	
	33	Top right drawer	1	53	25.3	
	34	2nd drawer	1	44	13.3	
	35	3rd drawer	1	38	5.3	
	36	4th drawer	1	50	21.3	
	37	Drawers	1	40	8.0	

 $\cup$ 

Job Location:	ExxonMobil Researc	h and Eng. Clinto	n, NJ	_ Page:	<u>2</u> of 5	
Survey Purpose:	Decommissioning	LE367		Date:	<b>9/2</b> 1/2004	

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0640	38	Left drawer	1	46	16.0	
	39	Right drawer	1	54	26.7	
	40	Drawers	1	32	-2.7	
	41	Top drawer	1	40	8.0	
	42	2nd drawer	1	42	10.7	
	43	3rd drawer	1	43	12.0	
	44	4th drawer	1	37	4.0	
	45	Drawers	1	40	8.0	
	46	Top drawer	1	37	4.0	
	47	2nd drawer	1	48	18.7	
	48	3rd drawer	1	56	29.3	
	49	4th drawer	1	44	13.3	
	50	Drawers	1	36	2.7	
	51	Top drawer	1	34	0.0	
	52	2nd drawer	1	54	26.7	
	53	3rd drawer	1	44	13.3	
	54	4th drawer	1	47	17.3	
	55	Drawers	1	40	8.0	
	56	Top drawer	1	43	12.0	
	57	2nd drawer	1	32	-2.7	
	58	3rd drawer	1	40	8.0	
	59	4th drawer	1	37	4.0	
	60	Drawers	1	47	17.3	
	61	Left drawer	1	50	10.7	
	62	Right drawer	1	50	10.7	
	63	Book shelf	1	40	-2.7	
	64	Desk	1	45	4.0	
	65	Wall	1	44	2.7	
a an	66	Desk	1	44	2.7	
	67	Floor	1	41	-1.3	
	68	Refrig. Door	1	48	8.0	
	69	Inside back of refrig.	1	48	8.0	
	70	Inside left side of refrig.	1	33	-12.0	
5	71	Inside right side of refrig.	1	52	13.3	
	72	Bottom of refrig.	1	41	-1.3	
	73	Floor	1	44	2.7	
	74	Cabinet doors	1	35	-8.0	
	75	Top shelf	1	42	1.3	
	76	2nd shelf	1	37	-5.3	
	77	3rd shelf	1	67	34.7	
	78	Cabinet doors	1	54	17.3	
	79	Top shelf	1	45	5.3	
	80	2nd shelf		48	9.3	
	81	3rd shelf	1	43	2.7	
	82	Cabinet doors	1	51	13.3	
	83	Top shelf	1	38	-4.0	

Job Location:	ExxonMobil Research and Eng.	Clinton, NJ	Page:	3 of 5
Survey Purpose:	Decommissioning LE36	57	Date:	<b>9/2</b> 1/2004

Time	Number	Location	Inst.	cpm	Activity	Comments
00.10			Used.		(dpm/100cm <sup>2</sup> )	
0640	84	2nd shelf	1	45	5.3	
	85	3rd shelf	1	49	10.7	
	86	Counter		38	-4.0	
	8/			38	5.3	
	88	Counter		35	1.3	
	89			48	18.7	
	90		1	35	1.3	
	91	l op drawer		35	1.3	
	92	2nd drawer	1	52	24.0	
	93	I 3rd drawer	1	43	12.0	<u></u> .
	94	Ath drawer	1	42	10.7	
	95		1	48	18.7	
	90	1 op drawer	1	41	9.3	
	97	2nd drawer	1	50	21.3	
	98	Srd drawer		40	8.0	
	99	Ath drawer		33	-1.3	
	100			35	1.3	
	101	l op leπ drawer	1	51	22.7	
	102	l op right drawer	1	44	13.3	
	103		1	50	21.3	
	104	Drawers	1	41	9.3	
	105	Len drawer	1	54	26.7	
	100	Right drawer		4/	17.3	
	107	Left side of nood	1	42	10.7	
	108	Upper back of hood	1	48	18.7	
	109		1	40	8.0	
	110	Lower back of hood	1	55	28.0	
	111	Upper back of hood	1	42	10.7	
	112		1	56	29.3	
	113	Lower back of hood		52	24.0	
	114	Upper back of hood	1	59	33.3	
	110	Vent		47	17.3	
	110	Lower back of hood		43	12.0	
	110	Right side of hood		33	-1.3	
	118		1	42	10.7	
	119		1	44	13.3	
	120			40	8.0	
	121			48	18.7	
	122		1	40	16.0	
	123	Robinst dess		41	9.3	
	124	Capinet doors		55	28.U	
	120				28.0	
	120	Cabinet 00015		51	22.1	
	12/			51	22.1	
	120	Cabinet doors		4/	17.3	
	129	Inside cabinet	1	56	29.3	

Job Location:		ExxonMobil Research and Eng. Clinton, NJ		Page:4 of 5_		
Survey Purpose:		Decommissioning LE367			Date:	0/21/2004
Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0640	130	Cabinet doors	1	55	28.0	
	131	Inside cabinet	1	51	22.7	
	132	Floor	1	47	17.3	
	133	Floor	1	42	10.7	
	134	Floor	1	46	16.0	
	135	Floor	1	54	26.7	
	136	Floor	1	47	17.3	
	137	Floor	1	53	25.3	
	138	Floor	1	60	34.7	
	139	Floor	1	62	37.3	
	140	Floor	1	46	16.0	
	141	Floor	1	47	17.3	
	142	Floor	1	44	13.3	
	143	Floor	1	55	28.0	
	144	Floor	1	35	1.3	
	145	Floor	1	37	4.0	
	146	Floor	1	39	6.7	
	147	Floor	1	48	18.7	
	148	Floor	1	44	13.3	
	149	Floor	1	857	1097.3	
	150	Post Decon #149	1	35	1.3	

 $\sim$ 

Scanned 100% of lower surfaces using instrument #2. All surfaces scanned were noted to be at normal background levels, with one exception: The floor under the freezer ( $600 \text{ cm}^2$ ) was found to be contaminated to a level of 18,144 dpm/100 cm<sup>2</sup> (C-14). This area was decontamined to a level indistinguishable from normal background level.

Page 5 of 5 9/21/04

# LE367 - Radioisotope Lab



Radiation readings in units of µrem/h



Job Location:	ExxonMobil Research and	d Eng. Clinton, NJ	_ Page:	1 of 6	
Survey Purpose:	Decommissioning	LG359/LG335/LE343/LE345	Date:	9/21/04	
Performed By:	David Durkee/Ed Gailor				

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludium Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludlum Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 3 - 5 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1000	1	Background	1	56	N/A	
	2	Door	1	52	-5.3	
	3	Counter	1	54	-2.7	
	4	Counter	1	52	-5.3	
	5	Counter	1	55	-1.3	
	6	Counter	1	48	-10.7	
	7	Counter	1	46	-13.3	
	8	Counter	1	48	-10.7	
	9	Counter	1	46	-13.3	
	10	Door	1	49	-9.3	
	11	Floor	1	51	-6.7	
	12	Counter	1	46	-13.3	
	13	Counter	1	47	-12.0	
	14	Counter	1	61	6.7	
	15	Counter	1	48	-10.7	
	16	Left side of hood	1	38	-24.0	
	17	Upper back of hood	1	56	0.0	
	18	Vent	1	43	-17.3	
	19	Lower back of hood	1	40	-21.3	
	20	Upper back of hood	1	45	-14.7	
	21	Vent	1	54	-2.7	
	22	Lower back of hood	1	42	-18.7	
	23	Right side of hood	1	38	-24.0	
	24	Hood Bottom	1	47	-12.0	
	25	Hood Bottom	1	54	-2.7	
	26	Hood glass	1	48	-10.7	
	27	Hood glass	1	44	-16.0	
	28	Left side of hood	1	35	-28.0	
	29	Upper back of hood	1	34	-29.3	
	30	Vent	1	37	-25.3	
	31	Lower back of hood	1	46	-13.3	
	32	Upper back of hood	1	39	-22.7	
	33	Vent	1	41	-20.0	
	34	Lower back of hood	1	52	-5.3	
	35	Right side of hood	1	44	-16.0	
	36	Bottom	1	48	-10.7	
	37	Bottom	1	47	-12.0	

Job Location:	ExxonMobil Research and	Eng. Clinton, NJ	Page:	_2 of 6
Survey Purpose:	Decommissioning	LG359/LG335/LE343/LE345	Date:	9/21/04

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
1000	38	Hood glass	1	60	5.3	
	39	Hood glass	1	55	-1.3	
	40	Floor	1	49	-9.3	
	41	Floor	1	56	0.0	_
	42	Floor	1	54	-2.7	
	43	Floor	1	54	-2.7	
	44	Floor	1	59	4.0	
	45	Floor	1	39	-22.7	
	46	Floor	1	55	-1.3	
	47	Floor	1	30	-34.7	
	48	Floor	1	48	-10.7	
	49	Floor	1	54	-2.7	
	50	Floor	1	57	1.3	
	51	Floor	1	50	-8.0	
	52	Floor	1	50	-8.0	
	53	Floor	1	41	-20.0	_
	54	Floor	1	48	-10.7	
	55	Door	1	41	-20.0	
	56	Floor	1	41	-20.0	
	57	Inside sink	1	61	6.7	
	58	Counter	1	60	5.3	
	59	Refrig. Door	1	47	-12.0	_
	60	Refrig. Door	1	54	-2.7	
	61	Cold box door	1	40	-21.3	
	62	Door	1	52	-5.3	
	63	Floor	1	54	-2.7	
	64	Counter	1	43	-17.3	
	65	Counter	1	41	-20.0	
	66	Floor	1	40	-21.3	
	67	Table Top	1	48	-10.7	
	68	Floor	1	39	-22.7	
	69	Door Env. Chamber	1	35	-28.0	
	70	Floor	1	57	1.3	
		Door Env. Chamber	1	50	-8.0	
		Floor	1	56	0.0	
	73	Door Env. Chamber	1	49	-9.3	
	74	Floor	1	60	5.3	
	75	Counter	1	44	-16.0	
	76	Counter	1	44	-16.0	
		Floor	1	45	-14.7	
	78	Door	1	52	-5.3	
	79	Floor	1	42	-18.7	
	80	Counter	1	48	-10.7	
	81	Counter	1	47	-12.0	
	82	Floor	1	38	-24.0	
	83	Floor	1	42	-18.7	

Job Location:	ExxonMobil Research	and Eng. Clinton, NJ	Page: _	3 of 6
Survey Purpose:	Decommissioning	LG359/LG335/LE343/LE345	Date:	9/21/04

Time	Number	Location	Inst.	срт	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
	84	Floor	1	46	-13.3	
	85	Floor	1	50	-8.0	
	86	Floor	1	42	-18.7	
	87	Door	1	58	2.7	
	88	Floor	1	56	0.0	
	89	Hood	1	54	-2.7	
	90	Hood	1	54	-2.7	
	91	Hood	1	49	-9.3	
	92	Counter	1	47	-12.0	
	93	Counter	1	49	-9.3	
	94	Counter	1	46	-13.3	
	95	Table Top	1	44	-16.0	
	96	Desk	1	56	0.0	
	97	Door	1	38	-24.0	
	98	Floor	1	47	-12.0	
	99	Table Top	1	42	-18.7	
	100	Inside sink	1	50	-8.0	
	101	Counter	1	31	-33.3	
	102	Counter	1	43	-17.3	
	103	Counter	1	35	-28.0	
	104	Counter	1	55	-1.3	
	105	Hood	1	47	-12.0	
	106	Hood	1	39	-22.7	
	107	Hood lip	1	44	-16.0	
	108	Hood lip	1	42	-18.7	
	109	Floor	1	37	-25.3	
	110	Floor	1	49	-9.3	
	111	Floor	1	38	-24.0	
	112	Floor	1	33	-30.7	
	113	Floor	1	44	-16.0	
	114	Floor	1	37	-25.3	
	115	Floor	1	37	-25.3	
	116	Floor	1	37	-25.3	
	117	Floor	1	30	-34.7	
	118	Floor	1	36	-26.7	
	119	Floor	1	47	-12.0	
	120	Floor	1	38	-24.0	
	121	Floor	1	37	-25.3	L
	122	Floor	1	44	-16.0	
	123	Floor	1	51	-6.7	

Spot checked lower surfaces using instrument #2. All surfaces noted to be at normal background levels.

pare 4 1 go



•

•

>

Þ



92 98 4 Tech Desk 96 Bench 99) 114 4 (113 123 95 2 100 US) 122 [0] 4 5 94 16 112 102 (93) 5 (121) LG335 III Counter Top 112 Counter Top 4 92 103 3 Ŷ (110) 118) 120 104 4 105) 90 Hood (07) Hood (119) 109 108 106 (88) 4 89 (87)

.

٠.

O = WIFF SAMPLE

RAD READINGS IN UN HEL

Page 5 6 1 4

Job Location:	ExxonMobil Research	and Eng. Clinton, NJ	Page:	_1 of 3
Survey Purpose:	Decommissioning	LG337/LG343	Date:	10/4/04
Performed By:	David Durkee		52	
-				

Instrument No. 1	Instrument No. 2	Instrument No. 3
Beckman LS6500 #7068276	Ludlum Model 2241-2 #137751	Bicron Microrem LE #B466y
	Ludlum Model 43-68 #140899	
Efficiency: 45% H-3/ 75% C-14	Efficiency: 9% C-14	Efficiency: 100 %
Type Rad: α/β/γ	Type Rad: β	Type Rad: γ
Background (cpm): See #1 below	Background: 230 cpm	Background: 3 - 6 µrem/h
Cal. Due: 5/26/05	Cal. Due: 4/6/05	Cal. Due: 1/5/05

Time	Number	Location	Inst.	cpm	Activity	Comments
			Used.		(dpm/100cm <sup>2</sup> )	
0715	1	Background	11	45	N/A	
	2	Door	1	47	2.7	
	3	Floor	1	49	5.3	
	4	Hood ledge	1	46	1.3	
	5	Hood left side	1	45	0.0	
	6	Hood flow path (behind panels)	1	43	-2.7	
	7	Hood right side	1	40	-6.7	
	8	Floor	11	51	8.0	
	9	Front of cabinets	1	43	-2.7	
	10	Counter/equipment	1	46	1.3	
	11	Counter/equipment	1	41	-5.3	
	12	Front of cabinets	1	31	-18.7	
	13	Counter/equipment	1	53	10.7	
	14	Counter/equipment	1	52	9.3	
	15	Floor	1	40	-6.7	
	16	Floor	1	41	-5.3	
	17	Benchtop	1	47	2.7	
	18	Shelves	1	41	-5.3	
	19	Door	1	55	13.3	
	20	Floor	1	55	13.3	
	21	Counter	1	50	6.7	
	22	Floor	1	40	-6.7	
	23	Counter/equipment	1	45	0.0	
	24	Counter/equipment	1	43	-2.7	
	25	Counter/equipment	1	57	16.0	
	26	Counter	1	43	-2.7	
	27	Front of cabinets	1	48	4.0	
	28	Front of cabinets	1	55	13.3	_
	29	Floor	1	43	-2.7	
	30	Floor	1	47	2.7	
	31	Hood lip/sash	1	52	9.3	_
	32	Hood right side	1	37	-10.7	
	33	Hood flow path (behind panels)	1	56	14.7	
	34	Hood left side	1	49	5.3	
	35	Sink	1	37	-10.7	
	36	Counter	1	49	5.3	
	37	Floor	1	52	9.3	

Job Location:	ExxonMobil Research an	nd Eng. Clinton, NJ	Page:	2 of 3
Survey Purpose:	Decommissioning	LG337/LG343	Date:	10/4/04

Spot checked lower surfaces using instrument #2. All surfaces noted to be at normal background levels.



of yremth.

This is to acknowledge the receipt of your letter/application dated

includes an administrative review has been performed.

#### TEAM 29-19396-01

There were no administrative omissions. Your application was assigned to a technical reviewer. Please note that the technical review may identify additional omissions or require additional information.

Please provide to this office within 30 days of your receipt of this card

A copy of your action has been forwarded to our License Fee & Accounts Receivable Branch, who will contact you separately if there is a fee issue involved.

Your action has been assigned Mail Control Number 135896. When calling to inquire about this action, please refer to this control number. You may call us on (610) 337-5398, or 337-5260.

NRC FORM 532 (RI) (6-96) Sincerely, Licensing Assistance Team Leader

	: (FOR LFMS USE)
	: INFORMATION FROM LTS
BETWEEN:	
	:
License Fee Management Branch, ARM	: Program Code: 03620
and	: Status Code: 0
Regional Licensing Sections	: Fee Category: 3M
	: Exp. Date: 20111031
	: Fee Comments: 3M EFF 6/12/85
	: Decom Fin Assur Reqd: Y

LICENSE FEE TRANSMITTAL

T A. REGION

1. APPLICATION ATTACHED

Applicant/Licensee:	EXXONMOBIL BIOMEDICAL SCIENCES, INC	
Received Date:	20041027	
Docket No:	3017541	
Control No.:	135896	
License No.:	29-19396-01	
Action Type:	Termination	

2. FEE ATTACHED Amount:

Check No.:

3. COMMENTS

Signed Mr. a. barkins Date 10/28 have

B. LICENSE FEE MANAGEMENT BRANCH (Check when milestone 03 is entered /\_\_/)

1. Fee Category and Amount: \_\_\_\_\_

2. Correct Fee Paid. Application may be processed for: Amendment \_\_\_\_\_\_\_ Renewal \_\_\_\_\_\_\_ License \_\_\_\_\_\_

•

3. OTHER \_\_\_\_\_

Signed \_\_\_\_\_\_