

November 18, 2004

Mr. D. M. Jamil  
Vice President  
Catawba Nuclear Station  
Duke Energy Corporation  
4800 Concord Road  
York, SC 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: REQUEST FOR  
ADDITIONAL INFORMATION (TAC NOS. MC2547 AND MC2548)

Dear Mr. Jamil:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated March 22, 2004, Duke Energy Corporation, the licensee for Catawba Nuclear Station (Catawba), Units 1 and 2, submitted an application for amendments to the Catawba technical specifications. These amendments would revise the surveillance frequency on selected Engineered Safety Features Actuation System slave relays from 92 days to 18 months. The NRC technical staff has reviewed the application and has determined that additional information is required, as identified in the Enclosure.

I discussed these issues with your staff on November 1, 2004. Your staff indicated that you would attempt to provide your response by January 17, 2005.

Please contact me at (301) 415-1842, if you have any questions on these issues.

Sincerely,  
*/RA/*

Sean E. Peters, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: As stated

cc w/encl: See next page

November 18, 2004

Mr. D. M. Jamil  
Vice President  
Catawba Nuclear Station  
Duke Energy Corporation  
4800 Concord Road  
York, SC 29745

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: REQUEST FOR  
ADDITIONAL INFORMATION (TAC NOS. MC2547 AND MC2548)

Dear Mr. Jamil:

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated March 22, 2004, Duke Energy Corporation, the licensee for Catawba Nuclear Station (Catawba), Units 1 and 2, submitted an application for amendments to the Catawba technical specifications. These amendments would revise the surveillance frequency on selected Engineered Safety Features Actuation System slave relays from 92 days to 18 months. The NRC technical staff has reviewed the application and has determined that additional information is required, as identified in the Enclosure.

I discussed these issues with your staff on November 1, 2004. Your staff indicated that you would attempt to provide your response by January 17, 2005.

Please contact me at (301) 415-1842, if you have any questions on these issues.

Sincerely,  
*/RA/*

Sean E. Peters, Project Manager, Section 1  
Project Directorate II  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	PDII-1 R/F	MRoss-Lee
DClarke	SPeters	OGC
ACRS	RHaag, RII	DLPM DPR
PRebstock		

**ADAMS Accession Number: ML043130194**

**NRR-088**

OFFICE	PDII-1/PM	PDII-1/LA (A)	PDII-1/SC (A)
NAME	SPeters	DClarke	MRoss-Lee
DATE	11/18/04	11/18/04	11/18/04

**OFFICIAL RECORD COPY**

REQUEST FOR ADDITIONAL INFORMATION

DUKE POWER COMPANY

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-413 AND 50-414

The U.S. Nuclear Regulatory Commission (NRC) staff has reviewed the licensee's submittal dated March 22, 2004, regarding a request to change the surveillance frequency on selected Engineered Safety Features Actuation System slave relays from 92 days to 18 months. The NRC staff has identified the following information that is needed to enable the continuation of its review.

In Attachment 3, Page 2 of your submittal, you describe the program that evaluates the adequacy of the proposed surveillance interval if two or more Type AR relays fail within a 12-month period. Given that the proposed surveillance interval is 18 months, describe the situations in which two failures could be detected within 12 months. Furthermore, describe how you would use operating experience at other units in your evaluation of the adequacy of the 18-month interval.

cc:

Mr. Lee Keller, Manager  
Regulatory Compliance  
Duke Energy Corporation  
4800 Concord Road  
York, South Carolina 29745

Ms. Lisa F. Vaughn  
Duke Energy Corporation  
Mail Code - PB05E  
422 South Church Street  
P.O. Box 1244  
Charlotte, North Carolina 28201-1244

Ms. Anne Cottingham, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

North Carolina Municipal Power  
Agency Number 1  
1427 Meadowood Boulevard  
P.O. Box 29513  
Raleigh, North Carolina 27626

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

NCEM REP Program Manager  
4713 Mail Service Center  
Raleigh, North Carolina 27699-4713

North Carolina Electric Membership Corp.  
P.O. Box 27306  
Raleigh, North Carolina 27611

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
4830 Concord Road  
York, South Carolina 29745

Mr. Henry Porter, Assistant Director  
Division of Waste Management  
Bureau of Land and Waste Management  
Dept. of Health and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201-1708

Mr. R.L. Gill, Jr., Manager  
Nuclear Regulatory Issues  
and Industry Affairs  
Duke Energy Corporation  
526 South Church Street  
Mail Stop EC05P  
Charlotte, North Carolina 28202

Saluda River Electric  
P.O. Box 929  
Laurens, South Carolina 29360

Mr. Peter R. Harden, IV, Vice President  
Customer Relations and Sales  
Westinghouse Electric Company  
6000 Fairview Road  
12th Floor  
Charlotte, North Carolina 28210

Ms. Mary Olson  
Director of the Southeast Office  
Nuclear Information and Resource Service  
729 Haywood Road, 1-A  
P.O. Box 7586  
Asheville, North Carolina 28802

cc:

Mr. T. Richard Puryear  
Owners Group (NCEMC)  
Duke Energy Corporation  
4800 Concord Road  
York, South Carolina 29745

Mr. Richard M. Fry, Director  
Division of Radiation Protection  
NC Dept. of Environment, Health,  
and Natural Resources  
3825 Barrett Drive  
Raleigh, North Carolina 27609-7721

Mr. Henry Barron  
Group Vice President, Nuclear Generation  
and Chief Nuclear Officer  
P.O. Box 1006-EC07H  
Charlotte, NC 28201-1006

Diane Curran  
Harmon, Curran, Spielberg &  
Eisenberg, LLP  
1726 M Street, NW  
Suite 600  
Washington, DC 20036