

November 8, 2004

Mrs. Mary G. Korsnick
Vice President R.E. Ginna Nuclear Power Plant
R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, NY 14519

SUBJECT: R. E. GINNA NUCLEAR POWER PLANT - RESPONSE TO NRC
BULLETIN 2003-02, "LEAKAGE FROM REACTOR PRESSURE VESSEL
LOWER HEAD PENETRATIONS AND REACTOR COOLANT PRESSURE
BOUNDARY INTEGRITY" (TAC NO. MC0540)

Dear Mrs. Korsnick:

On August 21, 2003, the U.S. Nuclear Regulatory Commission (NRC) issued NRC Bulletin 2003-02, "Leakage from Reactor Pressure Vessel Lower Head Penetrations and Reactor Coolant Pressure Boundary Integrity," to the industry. This Bulletin informed addressees that current methods of inspecting the reactor pressure vessel (RPV) lower heads may need to be supplemented with bare-metal visual inspections in order to detect reactor coolant pressure boundary leakage and requested these addressees to provide the NRC with information related to inspections that have been performed to verify the integrity of the RPV lower head penetrations.

The Bulletin requested that addressees provide a description of the RPV lower head penetration inspection program that would be implemented at their respective plants during the next and subsequent refueling outages. This description was to include the extent of the inspection, the inspection methods to be used, the qualification standards for the inspection methods, the process used to resolve the source of findings of boric acid deposits or corrosion, the inspection documentation to be generated, and the basis for concluding that their plant satisfied applicable regulatory requirements related to the structural and leakage integrity of the RPV lower head penetrations.

By letter dated September 19, 2003, Rochester Gas and Electric Corporation (RG&E, the former licensee) provided its response to this request. RG&E stated that a bare-metal visual examination of the RPV lower head penetrations would be performed during the fall 2003 refueling outage at R. E. Ginna Nuclear Power Plant (Ginna). In addition, RG&E committed to perform a bare-metal examination of the RPV lower head penetrations each refueling outage at Ginna until changes to the American Society of Mechanical Engineers Boiler Pressure and Vessel Code or industry recommendations justify a change in the examination frequency. As such, R. E. Ginna Nuclear Power Plant, LLC (Ginna LLC), the current licensee, is requested to notify the NRC staff in writing of any changes to this regulatory commitment prior to implementation.

The Bulletin also requested that addressees provide a summary of the RPV lower head penetration inspection that was performed at their plants, the extent of the inspection and the

M. Korsnick

- 2 -

methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated December 9, 2003, RG&E provided a summary of its inspection results at Ginna. RG&E reported it had performed a 360-degree bare-metal visual examination on all 36 RPV lower head penetrations with no evidence of penetration leakage observed.

Based on its review of RG&E's responses to NRC Bulletin 2003-02, the NRC staff finds that Ginna LLC has met the reporting requirements of the Bulletin and no further action is required.

Sincerely,

/RA/

Robert Clark, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-244

cc: See next page

M. Korsnick

- 2 -

methods used, a description of the as-found condition of the lower head, any findings of relevant indications of through-wall leakage, and a summary of the disposition of any findings of boric acid deposits and any corrective actions taken as a result of indications found.

By letter dated December 9, 2003, RG&E provided a summary of its inspection results at Ginna. RG&E reported it had performed a 360-degree bare-metal visual examination on all 36 RPV lower head penetrations with no evidence of penetration leakage observed.

Based on its review of RG&E's responses to NRC Bulletin 2003-02, the NRC staff finds that Ginna LLC has met the reporting requirements of the Bulletin and no further action is required.

Sincerely,

/RA/

Robert Clark, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-244

cc: See next page

Distribution:

PUBLIC	SMonarque	RGramm
PDI-1 RF	RClark	RLaufer
GCherukenki	ESullivan	GMatakas, RI
LMarsh	OGC	

ADAMS ACCESSION NUMBER: ML043130364

OFFICE	PDI-1/PM	PDI-1/LA	LPM	EMCB	PDI-1/SC
NAME	RClark	SLittle	SMonarque	ESullivan	RLaufer
DATE	10/21/04	10/21/04	10/29/04	11/1/04	11/1/04

OFFICIAL RECORD COPY

R.E. Ginna Nuclear Power Plant

cc:

Mr. Michael J. Wallace
President
R.E. Ginna Nuclear Power Plant, LLC
c/o Constellation Energy
750 East Pratt Street
Baltimore, MD 21202

Mr. John M. Heffley
Senior Vice President and
Chief Nuclear Officer
Constellation Generation Group
1997 Annapolis Exchange Parkway
Suite 500
Annapolis, MD 21401

Kenneth Kolaczyk, Sr. Resident Inspector
R.E. Ginna Nuclear Power Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Peter R. Smith, President
New York State Energy, Research,
and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

James M. Petro, Jr., Esquire
Counsel
Constellation Energy
750 East Pratt Street, 5th Floor
Baltimore, MD 21202

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Daniel F. Stenger
Ballard Spahr Andrews & Ingersoll, LLP
601 13th Street, N.W., Suite 1000 South
Washington, DC 20005

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations
Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
1190 Scottsville Road, Suite 200
Rochester, NY 14624

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223