



NOV 01 2004

LR-N04-0476

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

**10CFR21 FINAL REPORT
Loose Internal Terminal Strip, Barksdale Pressure Switch
HOPE CREEK GENERATING STATION
FACILITY OPERATING LICENSE NO. NPF-57
DOCKET NOS. 50-354**

This letter transmits PSEG's final evaluation to the potential 10CFR21.21(b) received from General Electric. Pursuant to the notification requirements of 10CFR21.21(b), PSEG Nuclear LLC (PSEG) provided an interim report, LR-N04-0376, dated August 20, 2004. The subject General Electric report, SC04-05, "Loose Internal Terminal Strip, Barksdale Pressure Switch" was issued on May 7, 2004. PSEG has completed the evaluation of the report mentioned above and has determined that a substantial safety hazard does not exist and that the cited condition is not reportable under 10CFR21.21(b).

Should you have any questions regarding this submittal, please contact K. Myers at (856) 339-2328.

Sincerely,

A handwritten signature in cursive script, appearing to read "Christina Perino".

Christina Perino
Director – Licensing & Nuclear Safety

IE19

NOV 01 2004

C Mr. S. Collins, Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. D. Collins, Project Manager – Salem & Hope Creek
U. S. Nuclear Regulatory Commission
Mail Stop 08C2
Washington D.C. 20555

USNRC Senior Resident Inspector – Hope Creek (X24)

Mr. K. Tosch, Manager IV
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, NJ 08625