

Request for Additional Information for General Electric – Morris Operation License Renewal Application

General Electric Corporation
Morris Operation
Docket No. 72-1
SNM-2500

SECTION 1 -IDENTIFICATION OF SSCS SUBJECT TO AGING MANAGEMENT

1-1 Provide a list of SSCs that are subject to an AMR and a list of SSCs that are not subject to an AMR. Describe the process used to determine the SSCs that are subject to an AMR.

Response – SSCs subject to an AMR specified in Section 11.3 of the CSAR and part of the original licensing basis for Morris Operation and SSCs identified through process described below.

SSCs subject to an AMR

- Fuel storage basin - concrete walls, floors, and expansion gate.
- Fuel storage basin - stainless steel liner.
- Fuel storage system, including baskets and supporting grids.
- Unloading pit doorway guard.
- Filter cell structure.
- Fuel Storage Basin building.
- Fuel Basket Grapples.
- Fuel Grapples.
- Fuel Basin Crane.
- Fuel Handling Crane.
- Cask Crane.
- Spent Fuel Cladding

SSCs not subject to an AMR as determined through the evaluation process below.

- SSCs not subject to an AMR
- Air compressors
- Basin leak detection system
- Basin water chillers
- Basin water level monitor
- Basin filter system
- Demineralized water system
- Fuel handling cranes and associated fuel handling equipment
- Ground water monitoring well network
- Off-site power
- Standby diesel generator
- Ventilation system
- Water supply well
- Water tower

The process used to determine the SSCs that are subject to an AMR is the following:

The proposed Part 72 license renewal process is summarized in the two principles of license renewal from the Part 54 Final Rule Statements of Consideration published in Federal Register Vol. 60, No. 88, May 8, 1995, pages 22464. *“The first principle of license renewal was that, with the exception of age-*

Request for Additional Information for General Electric – Morris Operation License Renewal Application

related degradation unique to license renewal and possible a few other issues related to safety only during the period of extended operation of nuclear power plants, the regulatory process is adequate to ensure that the licensing basis of all currently operating plants provides and maintains an acceptable level of safety so that operation will not be inimical to public health and safety or common defense and security. Moreover, consideration of the range of issues relevant only to extended operation led the Commission to conclude that the detrimental effects of aging is probably the only issue generally applicable to all plants. As a result, continuing this regulatory process in the future will ensure that this principle remains valid during any period of extended operation if the regulatory process is modified to address age-related degradation that is of unique relevance to license renewal.

The second and equally important principle of license renewal holds that the plant-specific licensing basis must be maintained during the renewal term in the same manner and to the same extent as during the original licensing term. This principle would be accomplished, in part, through a program of age-related degradation management for systems, structures, and components that are important to license renewal...”

Per the NRC issued RAI, *“The GE-MO ISFSI request for license renewal is unique in that it is the first ISFSI to request a license renewal and it is the only operating commercial water basin ISFSI not co-located at a nuclear power plant site in the United States. Storage of spent nuclear fuel in a water basin are held to the same 10 CFR Part 72 regulations as a dry cask ISFSI. The NRC has provided preliminary guidance for 10 CFR Part 72 license renewal to Virginia Electric and Power Company’s (VEPCO) dry cask ISFSI (Ref. 2, 3, & 7) but has not issued any written guidance for wet storage ISFSIs. Since the design and operation of the GE-MO ISFSI is similar to a spent fuel storage pool at a nuclear power plant, the NRC has used applicable portions of NUREG1800, Standard Review Plan for*

Review of License Renewal Applications for Nuclear Power Plants (Ref. 9) and NUREG-1801, Generic Aging Lessons Learned (GALL) Report (Ref. 10) during the review of the GE-MO ISFSI. While both of the NUREGs contain guidance that is not applicable to the GE-MO ISFSI; the NRC staff believes that the general processes covering the spent fuel pool, its support systems, and historic information on age related degradation of nuclear power plant SSCs are appropriate for renewing the GE-MO ISFSI license. For these reasons, the staff has decided to apply the guidance developed for dry cask ISFSI license renewal and for those applicable sections of NUREG-1800 and 1801 to the license renewal of the GE-MO ISFSI in addition to the appropriate regulations of 10 CFR Part 72.”

In broad, generic terms, the design and operation of the GE-MO spent fuel pool is similar to a spent fuel storage pool at a nuclear power plant and some aspects of the reference NUREGs may be applicable, however, significant differences between GE-MO basins and support systems and a nuclear power plants fuel storage basins and the fuel stored in both must also be taken into account. The GE-MO basins are below ground, in native bedrock, water level is maintained at or below grade level. All stored fuel is held in GE-MO unique stainless steel baskets (CSAR Section 5.0, ¶ 5.4.4.2) that that are a “can” style container minus a lid, providing individual support and additional containment and shielding for each fuel bundle. Fuel is not routinely shuffled nor is new fuel added unlike the spent fuel pool in a nuclear power plant, (last fuel moved was January 1989) and there are no plans to do so. The static state of the GE-MO fuel assures there are no mechanical or dynamic stresses placed on the fuel. The large basin water volume and low decay heat input (RAI Question 2-7 and 5-3) from the stored fuel provide an extended period of time to take corrective action in case of a malfunction of any of the basin support systems. In the event of an earthquake or other extreme natural phenomena, sufficient makeup water is available through either on-site or off-site means to maintain safe storage conditions.

Fuel stored at GE-MO has reactor discharge dates that range from April, 1970 through October 1986. The last fuel was received at GE-MO in January 1989. Burn up rates range from a high of 36.71 GWD/MTU to a low of 0.18 GWD/MTU, and an average burn up of 17.74 GWD/MTU. Due to the robust design of the pool (CSAR Section 5.0, ¶ 5.5) and the time interval from reactor discharge, there

Request for Additional Information for General Electric – Morris Operation License Renewal Application

are no postulated events that would result in exposure to a member of the public in excess of the limits of 10CFR72.104, as stated in the CSAR, Section 8.0, ¶ 8.1.1. The condition of the fuel is monitored as part of routine activities conducted at GE-MO through basin water analysis (RAI Question 3-7 and 3-8) and air quality monitoring (RAI Question 2-18). The design of the pool, and operational requirements for the basin area assure a depth of water over the stored fuel, which provides for extended passive heat dissipation capability. This heat dissipation capability has been verified through testing (RAI Question 5-3, J. D. Kesman Report of November 27, 2001 and Fuel Basin Water Evaluation: Conductivity Change and Evaporation Rate conducted 05/005/04 thru 06/24/04) demonstrated that a minimum of 54 days is available following a loss of basin cooling and make-up capability before the water level will approach the Technical Specification limit, 9 feet above the fuel, or a drop of 3.5 feet from normal pool level.

In general, safe storage of the spent fuel is achieved by maintaining the integrity of the fuel cladding through maintaining a high quality of basin water (CSAR Section 10.0, ¶ 10.4.5). Fuel cladding is designed to withstand a far more severe environment in a reactor than in static storage at GE-MO. The low temperature conditions, removal of both particulate and ionized impurities from the basin water, and absence of chemical materials provides high water clarity, limits corrosion and maintains radiation exposure rates in the vicinity of the basin as low as reasonably achievable. The cladding provides an effective primary barrier to the escape of fission or activation products from stored fuel. The basin water is an effective secondary barrier for the confinement of the small amounts of radioactive materials that may be released from the spent fuel.

The GE-MO radiation protection program is previously established in the current approved revision of the GE-MO Consolidated Safety Analysis Report (CSAR) Section 7.0, Radiation Protection. Subsection 7.7, Estimated Man-Rem Off Site Dose Assessment, specifies the current approved environmental monitoring program. Under normal operating conditions, Kr-85 provides essentially all the exposure from the GE-MO ventilation exhaust stack. The sum of the values for annual whole body exposure due to inhalation and skin dose out to a radius of 50 miles gives a total of less than 2×10^{-6} man-Rem/yr whole body and less than 0.12 man-Rem skin dose. Routine air samples continue to show that exhaust emissions are below detectable limit, as followings:

	Vent Supply	Stack Inlet
Alpha ($\mu\text{Ci/ml}$)	4.79×10^{-13}	MDA ($\sim 1 \times 10^{-15}$)
Beta ($\mu\text{Ci/ml}$)	1.07×10^{-12}	MDA ($\sim 1 \times 10^{-15}$)

The vent supply is air intake to the facility and stack inlet is air being released to the exhaust stack.

There are no planned or unplanned releases of liquid wastes from the site boundaries.

Analysis of postulated accidents including the causes of such events, consequences, and the ability of GE-MO to cope with each are previously established in the CSAR, Section 8.0, Accident Safety Analysis. The Structures, Systems, and Components (SSCs) Important to Safety are described in Section 11.0, Quality Assurance. Given the robust design of the Morris pool and the passive nature of the SSCs Important to Safety, no scenario involving a support system would result in an exposure to the public in excess of the criteria established in 10CRF72.104.

The current approved safety basis for the Morris facility as defined in the CSAR, designated items important to safety (CSAR Section 11.0, sub-section 11.3) demonstrates that no accident postulated (CSAR Section 8.0) will result in exceeding the limits of 10 CFR 72.104 and 10 CFR 100.20 to demonstrate protection of the public.

As shown in CSAR Sections 7.0 and 8.0, the low value of credible doses that could be received from normal operating and credible accident releases are many orders of magnitude below regulatory limits.

Request for Additional Information for General Electric – Morris Operation License Renewal Application

Unlike similar support systems at a nuclear power plant, the combination of the GE-MO radiation safety program, and accident analysis demonstrates that failure of a SSC supporting fuel storage basin operation will not cause an immediately reportable event. Ample time has been demonstrated for repair, temporary substitution, or permanent replacement of any SSC to prevent any Technical Specification violation and no exceedance of regulatory limits for radiation exposure is postulated.

The first step in the license renewal process involved the identification of the in-scope SSCs. This was done by evaluating the SSCs against the following scoping criteria. Consistent with the current licensing basis, the following SSC types are considered important to safety and consistent with the guidance in NEI-95-10, R3, Section 3.1 are considered in scope for the purpose of license renewal:

3.1 *Systems, Structures, and Components Within the Scope of License Renewal*

Part 54 Reference

54.4

(a) Plant systems, structures and components within the scope of this part are --

- (1) Safety-related systems, structures and components which are those relied upon to remain functional during and following design-basis events (as defined as in 10 CFR 50.49 (b)(1)) to ensure the following functions --
 - (i) The integrity of the reactor coolant pressure boundary;
 - (ii) The capability to shut down the reactor and maintain it in a safe shutdown condition;
 - (iii) The capability to prevent or mitigate the consequences of accidents that could result in potential offsite exposure comparable to the guidelines in 4 50.34(a)(1), 50.67(b)(2), or 100.11 of this chapter, as applicable.
- (2) *All nonsafety-related systems, structures, and components whose failure prevent satisfactory accomplishment of any of the functions identified in paragraphs (a)(1)(i), (ii), or (iii) of this section.*
- (3) *All systems, structures, and components relied on in safety analyses or plant evaluations to perform a function that demonstrates compliance with the Commission's regulations for fire protection (10 CFR 50.48), environmental qualification (10 CFR 50.49) pressurized thermal shock (10 CFR 50.61), anticipated transients without scram (10 CFR 50.62), and station blackout (10 CFR 50.63).*


As Morris is licensed under 10 CFR 72 and functions as a stand alone ISFSI the requirements of 10CFR50 do not apply.

The basis for evaluating Structures, Systems and Components within the scope for license renewal under 10CFR72 was developed consistent with NEI 95-10 Rev 3, Figure 3.0-1. The process developed is similar to the process described in the GALL report (NUREG 1801) and is consistent, where practical, with the application provided in support of the Surrey application for a dry storage ISFSI. This figure was modified to remove references to 10 CFR 54.4(a)(3) and incorporate guidance from the Surrey application for ISFSI site-specific license renewal.

Request for Additional Information for General Electric – Morris Operation License Renewal Application

**Basis for evaluating Structures, Systems and Components within the scope for license renewal.
(Figure 3.0-1)**

For each Structure, System and Component in the Plant
Process the SSC through the following flow path using applicable information sources
consistent with NEI 95-10 Rev 3, Table 3.1-1



* Important to safety related SSCs are those which are relied upon to remain functional during and following design basis events to ensure the capability to prevent or mitigate the consequences of accidents that could result in off site exposure exceeding 10 CFR 72.104

Request for Additional Information for General Electric – Morris Operation License Renewal Application

- 1-2 The SER and the EA for the license renewal will require an assessment of the AMR for each SSC relied on in the applicant's Consolidated Safety Analysis Report (CSAR) (Ref. 4). This RAI is necessary for the staff to determine if all appropriate SSCs have been included within the scope of license renewal review and which will support the staff development of the SER and the EA.

Identify those SSCs, other than the SSCs important to safety listed in Section 11.3 of the Consolidated Safety Analysis Report (CSAR), that are relied upon to:

- a. Maintain the conditions required to store spent fuel safely;
- b. Prevent damage to the spent fuel or the high-level radioactive waste container during handling and storage; or
- c. Provide reasonable assurance that spent fuel can be possessed, stored, and transferred without undue risk to the health and safety of the public.

Response – There are no SSCs, other than the SSCs important to safety listed in Section 11.3 of the Consolidated Safety Analysis Report (CSAR), that are relied upon to meet conditions described in a, b, and c of question 102.

Request for Additional Information for General Electric – Morris Operation License Renewal Application

- 1-3 The SER and the EA for the license renewal will require an assessment of the AMR for all SSCs relied on in the applicant's CSAR. This RAI is necessary for the staff to determine if all appropriate SSCs have been included within the scope of the license renewal review and which will support the staff development of the SER and the EA.

Provide a list of SSCs that are not important to safety but whose failure could prevent an important to safety function from being fulfilled or whose failure as a support SSC could prevent an important to safety function from being fulfilled. Also, describe the process used to determine this list of SSCs and the functions performed by these SSCs.

The SER and the EA for the license renewal will require an assessment of the AMR for all SSCs relied on in the applicant's CSAR. This RAI is necessary for the staff to determine if all appropriate SSCs have been included within the scope of license renewal review and which will support the staff development of the SER and the EA.

Response – There are no SSCs, other than the SSCs important to safety listed in Section 11.3 of the Consolidated Safety Analysis Report (CSAR), whose failure as a support SSC that could prevent an important to safety function from being fulfilled.

The process used to determine which SSCs would be subject to an AMR is described in the response to Question 1-1. The results are presented in tabular format below to justify the decision to place a SSC either in scope or out of scope for Aging Management Review. The question numbers refer to specific question on the flow chart provided in the answer to 1-1.

Request for Additional Information for General Electric – Morris Operation License Renewal Application

SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion
Spent fuel cladding	Yes	N/A	N/A	Yes	Yes	Spent fuel in the GE-MO basins are clad with both stainless steel and zircalloy. Per IAEA-TECDOC-1012, “Durability of Spent Nuclear Fuels and Facility Components in Wet Storage”, the zirconium alloys represent a class of materials that is highly resistant to degradation in wet storage, including some experience in aggressive waters. The database for the zirconium alloys supports a judgment of satisfactory wet storage in the time frame of 50 to 100 years or more.” (IAEA 5). Stainless steel components in wet storage facilities have an excellent history of performance, including service in aggressive waters. Specific examinations of LWR SS fuel claddings indicate no evidence of degradation after periods of wet storage. Satisfactory service of SS clad fuels and facility components can be expected for several decades if materials with favorable microstructures and low stress levels are involved (IAEA 5). Results of basin air and water sampling since the last fuel was received in January 1989 have been consistent, indicating the fuel cladding isn’t deteriorating.
Basin building above grade	Yes	N/A	N/A	Yes	Yes	Original construction was performed in accordance with the Uniform Building Code as a freestanding structure that would not be subject to any abnormal stresses. Plant maintenance has been ongoing since construction of the fuel storage basin and during the plants continuing operation. The continuing structure inspections are performed to verify all coatings are in tact and there are no signs of deterioration that would have deleterious affects on the integrity of the building..
Air compressors	No	No	N/A	No	No	These units were replaced in 1998. The compressors are redundant, one compressor can supply all the air needs for the site. The system has the capability to operate both compressor simultaneously should a greater volume be required. Impact of loss of the compressor systems on basin related activities are as follows: The compressors provide air to the basin level indicator (see Basin Level below), basin LDS pumpout (see Basin Leak Detection System below), ventilation dampers (dampers fail open) and the Basin Filter System flow control valve (fails as is). The impact of a failure of each of these

Request for Additional Information for General Electric – Morris Operation License Renewal Application

						systems is discussed individually below, demonstrating failure of the compressors would not cause a failure in any important to safety system. SOP 8-1, Air Compressor Operation provides guidance for the start-up and sequential operation of the air compressors along with operational checks and emergency operation instructions. Correct operation of the compressors is monitored by operators during normal shift rounds. Failure of the air compressors is produces both Site Information Management System (SIMS System) and Control Room alarms.
SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion
Basin filter system	No	No	N/A	No	No	The basin filter system continuously draws water from the basin skimmers maintaining outstanding water clarity. This system’s simple robust design (CSAR Section 1, 1.4.3) and operation (CSAR Section 5, 5.5.2) maintains high reliability of the filter system. During periods when the basin filter was shut down, sometimes in excess of 6 weeks for maintenance activities, no measurable degradation of basin water quality was observed. Basin water quality is routinely monitored through SOP 16-10, Basin Water Analysis Compliance Test and SOP 1-20, Basin Filter Operation. Operation of the system is verified by operations personnel twice each shift. Once during normal operator rounds and once by normal mid-shift instrumentation monitoring on the SIMS system. There is no failure alarm on the system, but loss of filter function would not exceed 4 hours without detection. The intake is located at the basin water surface, and the system return is located approximately 31 inches from the top of the basin ensuring a system leak will not approach a Basin water level technical specification limit.
Basin leak detection system	No	No	N/A	No	No	Pump outs are continuously recorded on a strip-chart recorder and the information reviewed by the duty operator on rounds. The system also has localized instrumentation that is monitored shiftly by the operator on rounds. Failure of the system causes both Control Room and SIMS alarms. Failure of the pump does not pose a hazard, as a back-up pump is available. Should both pumps fail, the water level in the leak detection system will equalize with the basin water level. In the event of a system outage, increased surveillance of the pool level is

Request for Additional Information for General Electric – Morris Operation License Renewal Application

SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion
Basin water chillers	No	No	N/A	No	No	<p>sufficient to mitigate any loss of this system. System failure would result in an alarm at the guard station?? The following SOPs are routinely performed, 16-11, "Basin Leak Detection Alarm Operability Test"; 16-12 Basin Leak Detection Calibration Compliance Test" in order to assure proper system operation.</p> <p>As described in the CSAR, the chillers, and associated piping, pumps, valves, and heat exchangers were installed new in 2000. These units are redundant; only one set is necessary to maintain basin water temperature. The only scenario that could cause both chillers to be inoperable would be loss of both off-site power feeds and the stand-by diesel generator, an event that has never happened in the history of GE-MO. However, as discussed in RAI question 2-7, in the report on basin heat-up, if this event occurred, normal makeup water to off-set effects of evaporation and the slow evaporation rate allow more than ample time to repair/replace the chillers, including bringing in skid mounted units to temporarily cool the basin water while the permanent units are being replaced. Maintenance of cooling with makeup water addition only, can be supported indefinitely. SOP 1-22, Basin Cooler System, describes operation of the basin cooling system. Abnormal system operation is indicated by alarms on the SIMS and in the Control Room. The duty operator checks each chiller shiftly. The new system employs heat pumps (versus external radiator assemblies in the original system) resulting in no basin liquid systems extending external of the pool building.</p>
Basin water level monitor	No	No	N/A	No	No	<p>Basin water level is continuously computer monitored through the SIMS System that will automatically monitor water level and provide an alarm at the guard station. Operations personnel also monitor basin water level during rounds on mechanical depth gages fastened to the basin wall and manual record the basin water level 6 times a day. If this system failed, visual observation by the shift operator would detect any decrease in water level. Pool level is also visible via remote cameras located in the basin area, providing monitoring of the basin from the Central Alarm Station. In addition, due to the location of the</p>

Request for Additional Information for General Electric – Morris Operation License Renewal Application

SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion
						suction lines for the basin water chillers, after a drop of less than 31 inches, which doesn't cause a technical specification violation, the basin chiller system would show a Control Room and SIMS alarm.
Demineralized water system	No	No	N/A	No	No	The demineralized water system (including piping) was replaced in 1996. It is a skid mounted resin bed system with its own computer monitoring ties to a phone line. If output water quality is out of specification, the system automatically notifies the supplier and sounds a local alarm. The supplier normally arrives within 24 hours to replace the system resin beds. Typically the basin makeup water is 236 gallons per day. It takes a loss of approximately 1,983 gallons to drop the basin water level one (1) inch. The computer runs on 110 volts, so if all site power was lost, this unit could be connected to one of several on-site 110/220 volt generators. Demineralized water is also routinely sampled per SOP 16-10, Basin Water Analysis Compliance Test. The duty operator verifies system function shiftly once a day totalized and capacity flow and water quality is recorded.
Fuel handling cranes and associated fuel handling equipment	Yes	N/A	N/A	Yes	Yes	The fuel handling cranes are maintained under the GE-MO preventative maintenance program, and inspected in accordance with the requirements specified in 10 CFR 1910.179 and ANSI B30-2. Yearly inspections are performed by an independent contractor whose crane inspection services are accredited by the U.S. Department of Labor under 29 CFR 1919 to inspect, test and certify cranes. All grapples and associated equipment used to handle fuel or fuel baskets are laid away, and prior to use will be inspected using the same criteria as original manufacture. Repair and/or replacement will be accomplished as required based on the results of the inspections. All are described in Section 5.0 of the CSAR.
Ground water well monitoring network	No	No	N/A	No	No	The eight NRC reviewed and approved ground water sampling wells at MO are used to monitor for any potential leakage of basin water to the surrounding soil. The wells are sampled routinely per SOP 16-102, Sample Well Analysis Compliance Test. In addition, 3 of the wells positioned around the basin

Request for Additional Information for General Electric – Morris Operation License Renewal Application

SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion
						are used to monitor for ground water potential effects on below grade concrete.
Off-site power	No	No	N/A	No	No	Morris Operation is fed by 2 separate off site power sources with the primary feed coming from Dresden Station. Off-site power is extremely stable with no more than 2 or 3 failures of both feeds at the same time in over 30 years. Those were all during winter periods and were the result of heavy ice storms. In the event of a complete loss of off-site power, a stand-by diesel generator can provide power to operate all systems at GE-MO. Failure of the operating incoming power feed produces both Control Room and SIMS alarms. SOP 14-1, Loss of Incoming Power Line, SOP 14-2 Total Power Loss, and SOP 14-3 Cross-Tie of Incoming Power Busses describe operation of the off-site electrical supply system.
Standby diesel generator	No	No	N/A	No	No	The diesel generator can supply backup power to all site systems, including lighting. It is inspected yearly by a diesel generator contractor. Additionally, it is tested bi-weekly as specified in Operability Test 16-90 and subjected to an emergency start/loading scenario yearly as specified in Operability Test 16-91. SOP 14-4 describes Diesel Generator Operation. Also the duty operator performs a visual inspection of the diesel and checks oil temperature and jacket water temperature each shift and diesel fuel storage tank is checked once a day. In approximately 30 years, total off-site power failed an estimated approximately 2 or 3 times, but the generator never failed to start. If off-site power were lost and the stand-by diesel failed to start, a portable 400kVA diesel driven generator could be brought in operate all systems at MO.
Ventilation system	No	No	N/A	No	No	Air is taken in through the air inlet plenum is distributed through the process building, passed through the sand filter and exhausted out the 300 foot tall exhaust stack. The sand filter was sized to provide filtering for the original reprocessing facility. Air quality is monitored at the facility inlet, at the sand filter inlet and sand filter exhaust. Until 1983 the ventilation system was configured to operate as originally designed for a fuel reprocessing plant with a flow of 24,000 CFM through the

Request for Additional Information for General Electric – Morris Operation License Renewal Application

						<p>filter. During 1983, the ventilation system was re-configured to operate as it does today, at a flow of 14,000 CFM through the filter. The sand filter D/P has stayed effectively constant over the 20 years since the change in flow velocity. Routine air samples continue to show the following emissions:</p> <table border="0"> <tr> <td></td> <td align="center">Vent Supply</td> <td align="center">Stack Inlet</td> </tr> <tr> <td>Alpha (µCi/ml)</td> <td align="center">4.79x10⁻¹³</td> <td align="center">MDA (~1x10⁻¹⁵)</td> </tr> <tr> <td>Beta (µCi/ml)</td> <td align="center">1.07x10⁻¹²</td> <td align="center">MDA (~1x10⁻¹⁵)</td> </tr> </table> <p>The ventilation system is monitored through SOP 16-81, "Ventilation System Operability Test"; SOP 16-82, "Sand Filter Delta P Operability Test"; SOP 16-84, "Exhaust Sample Analysis Compliance Test". Ventilation system inlet and outlet blowers and air flow are checked on a shiftly basis by the duty operator. Failure of exhaust blowers produce Control Room and SIMS alarms. The concrete structure was designed and constructed in accordance with applicable national standards in effect at the time, specifically, as a minimum, ACI 318-63, and meets conditions consistent with longevity as described by the GALL report, section A1.1 for concrete containments. While it may not be possible to state the expected life of the concrete exactly, the existing conditions avoid the degradation mechanisms that would adversely affect the structural integrity of the concrete.</p>		Vent Supply	Stack Inlet	Alpha (µCi/ml)	4.79x10 ⁻¹³	MDA (~1x10 ⁻¹⁵)	Beta (µCi/ml)	1.07x10 ⁻¹²	MDA (~1x10 ⁻¹⁵)
	Vent Supply	Stack Inlet													
Alpha (µCi/ml)	4.79x10 ⁻¹³	MDA (~1x10 ⁻¹⁵)													
Beta (µCi/ml)	1.07x10 ⁻¹²	MDA (~1x10 ⁻¹⁵)													
SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion									
Water supply well	No	No	N/A	No	No	The well had a new pump and discharge pipe installed in March, 2002. The pump has a 150 gpm capacity. If a complete loss of site power occurred the site would rely on gravity feed from the tower (see Water Tower). In the very unlikely event of an extended outage, water can be trucked in and pumped to the tower using truck borne pumps, or pumped from the truck directly to the water system. Flow of water from the well is verified by the duty operator each shift when the well is in operation.									
Water tower	No	No	N/A	No	No	Inspected by a nationally established contract company specializing in tanks and towers with the ability to inspect to API and AWWA standards. The tower is divided to provide 10,000 gallons for normal use and approximately 40,000 gallons for									

Request for Additional Information for General Electric – Morris Operation License Renewal Application

						emergency use. The tower provides gravity feed to the site. With current water usage (~427.4 total gallons per day), it could continue to supply site needs for over 90 days. Water conservation measures could be implemented to extend this capability. Additionally, water can be pumped from the well directly to the site water system bypassing the tower. The duty operator verifies water level at the beginning of each shift and then once a day water pumped from the well is verified.
SSC	Question 1	Question 2	Question 3	In Scope	AMR Required	Discussion

|