



State of New Jersey

James E. McGreevey
Governor

Department of Environmental Protection
Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

Bradley M. Campbell
Commissioner

November 5, 2004

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Salem Generating Station Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S04-03
Request for Change to Technical Specifications
Extension of the Inspection Interval for Reactor Coolant Pump
Flywheels Using the Consolidated Line Item Improvement Process

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated September 27, 2004. The proposed amendment would revise the required frequency for reactor coolant pump (RCP) motor flywheel inspection from the current 10-year inspection interval, to an interval not to exceed 20 years. This change is consistent with Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)". The availability of this technical specification improvement was announced in the Federal Register on October 22, 2003 as part of the consolidated line item improvement process (CLIIP).

The BNE has no comments on the proposed change. If you need to discuss the subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

Ditribution

Dr. Jill Lipoti, DEP

Dennis Zannoni, DEP

Dr. Robert Bores, NRC

Daniel Collins, NRC Licensing Project Manager

Daniel Orr, Sr Resident Inspector

Christina Perino, Licensing and Nuclear Safety Director, PSEG Nuclear LLC
