

November 12, 2004

LICENSEE: Indiana Michigan Power Company  
FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2  
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
OCTOBER 19, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND INDIANA MICHIGAN POWER COMPANY, PERTAINING  
TO THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2, LICENSE  
RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the NRC or the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information (RAIs) concerning the Donald C. Cook Nuclear Plant, Units 1 and 2, license renewal application (LRA). The conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains the item discussed with the applicant, including a brief description on the status of the item.

The applicant has had an opportunity to comment on this summary.

***/RA/***

Jonathan G. Rowley, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/encls: See next page

November 12, 2004

LICENSEE: Indiana Michigan Power Company  
FACILITY: Donald C. Cook Nuclear Plant, Units 1 and 2  
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON  
OCTOBER 19, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND INDIANA MICHIGAN POWER COMPANY, PERTAINING  
TO THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2, LICENSE  
RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the NRC or the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information (RAIs) concerning the Donald C. Cook Nuclear Plant, Units 1 and 2, license renewal application (LRA). The conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the telephone conference call participants. Enclosure 2 contains the item discussed with the applicant, including a brief description on the status of the item.

The applicant has had an opportunity to comment on this summary.

**/RA/**

Jonathan G. Rowley, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos.: 50-315 and 50-316

Enclosures: As stated

cc w/encls: See next page

ADAMS Accession No.: **ML043170666**

DOCUMENT NAME: E:\Filenet\ML043170666.wpd

OFFICE	PM:RLEP	LA:RLEP	SC:RLEP
NAME	JRowley	YEdmonds	SLee
DATE	11/9/04	11/9/04	11/12/04

OFFICIAL RECORD COPY

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
2443 Warrenville Road, Suite 210  
Lisle, IL 60532-4351

Township Supervisor  
Lake Township Hall  
P.O. Box 818  
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
7700 Red Arrow Highway  
Stevensville, MI 49127

David W. Jenkins, Esquire  
Indiana Michigan Power Company  
One Cook Place  
Bridgman, MI 49106

Mayor, City of Bridgman  
P.O. Box 366  
Bridgman, MI 49106

Special Assistant to the Governor  
Room 1 - State Capitol  
Lansing, MI 48909

Mr. John A. Zwolinski  
Director, Design Engineering and  
Regulatory Affairs  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

Patricia Lougheed  
2443 Warrenville Rd.  
Lisle, IL 60532

Michigan Department of Environmental  
Quality  
Waste and Hazardous Materials Div.  
Hazardous Waste & Radiological  
Protection Section  
Nuclear Facilities Unit  
Constitution Hall, Lower-Level North  
525 West Allegan Street  
P.O. Box 30241  
Lansing, MI 48909-7741

Michael J. Finissi, Plant Manager  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Mr. Joseph N. Jensen, Site Vice President  
Indiana Michigan Power Company  
Nuclear Generation Group  
One Cook Place  
Bridgman, MI 49106

Mr. Fred Emerson  
Nuclear Energy Institute  
1776 I Street, N.W., Suite 400  
Washington, DC 20006-3708

Richard J. Grumbir  
Project Manager, License Renewal  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

Mr. Mano K. Nazar  
Senior Vice President and Chief Nuclear  
Officer  
Indiana Michigan Power Company  
Nuclear Generation Group  
500 Circle Drive  
Buchanan, MI 49107

DISTRIBUTION: Licensee: Indiana Michigan Power Co., Re: Donald C.Cook Plant, Units 1 and 2, Dated: November 12, 2004 Accession No: **ML043170666**

**HARD COPY**

RLEP RF  
J. Rowley (PM)

**E-MAIL:**

RidsNrrDrip  
RidsNrrDe  
G. Bagchi  
K. Manoly  
W. Bateman  
J. Calvo  
R. Jenkins  
P. Shemanski  
J. Fair  
RidsNrrDssa  
RidsNrrDipm  
D. Thatcher  
R. Pettis  
C. Li  
M. Itzkowitz (RidsOgcMailCenter)  
R. Weisman  
M. Mayfield  
A. Murphy  
S. Smith (srs3)  
S. Duraiswamy  
Y. L. (Renee) Li  
RLEP Staff

-----  
K. Coyne  
L. Lund  
S. Coffin  
T. Chan  
R. Gramm  
A. Howell  
M. Shuaibi  
J. Strasma, RIV  
M. Kotzalas  
OPA  
NRR/ADPT secretary (RidsNrrAdpt)

LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL  
TO DISCUSS THE DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2  
LICENSE RENEWAL APPLICATION  
OCTOBER 19, 2004

**Participants**

Jonathan Rowley  
Om Chopra  
Robert Kalinowski  
Neil Haggerty  
Roger Rucker  
Mike Stroud

**Affiliations**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
Indiana Michigan Power Company (I&M)  
I&M  
Entergy\*  
Entergy

\* I&M Contractor

**REQUEST FOR ADDITIONAL INFORMATION  
DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2  
LICENSE RENEWAL APPLICATION**

OCTOBER 19, 2004

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Indiana Michigan Power Company (I&M) held a telephone conference call on October 19, 2004, to discuss and clarify requests for additional information concerning the Donald C. Cook Nuclear Plant, Units 1 and 2 (CNP), license renewal application (LRA).

**RAI 3.6-2 and RAI 3.6-5**

The staff pointed out a discrepancy between the supplemental responses to the request for additional information (RAI) 3.6-2 (letter AEP:NRC:4034-17) and RAI 3.6-5 (letter AEP:NRC:4034-15).

**Additional Information Requested**

The staff requested that the applicant clarify which version of the Non-EQ Instrumentation Circuits Test Review Program stated in the two letters is correct.

**Status**

The part of each response detailing the Non-EQ Instrumentation Circuits Test Review Program should have been the same but were not. The applicant acknowledged the error and provided a correction which is a combination of the two responses. The original two versions of the Non-EQ Instrumentation Circuits Test Review Program and the combination are provided below. The applicant will submit this information on the docket.

From letter AEP:NRC:4034-15

**A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program**

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals, such as radiation monitoring and nuclear instrumentation, which are exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope at a frequency not to exceed 10 years or as part of

Enclosure 2

corrective actions when acceptance criteria are exceeded at the normal calibration frequency. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.

From letter AEP:NRC:4034-17

**A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program**

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope. A proven cable test for detecting insulation deterioration on in-scope instrumentation cables that are disconnected during calibration will be performed at a frequency determined by engineering evaluation, but will not be less than once per ten years. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.

Combined:

**A.2.1.24 Non-EQ Instrumentation Circuits Test Review Program**

The Non-EQ Instrumentation Circuits Test Review Program will manage aging effects for electrical cables that:

1. Are not subject to the environmental qualification requirements of 10 CFR 50.49, and
2. Are used in instrumentation circuits with sensitive, high-voltage, low-level signals, such as radiation monitoring and nuclear instrumentation, which are exposed to adverse localized environments caused by heat, radiation, or moisture.

An adverse localized environment is defined as being significantly more severe than the specified service environment for the cable. This program will detect aging effects by reviewing calibration or surveillance results for components within the program scope at a frequency of not less than once per ten years or as part of corrective actions when acceptance criteria are exceeded at the normal calibration frequency. A proven cable test for detecting insulation deterioration on in-scope instrumentation cables that are disconnected during calibration will be performed at a frequency determined by engineering evaluation, but will not be less than once per ten years. The Non-EQ Instrumentation Circuits Test Review Program will be implemented prior to the period of extended operation.