

Don E. Grissette
Vice President

Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Tel 205.992.6474
Fax 205.992.0341



Energy to Serve Your World™

NL-04-2208

November 11, 2004

Docket Nos.: 50-424
50-425

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant
Monthly Operating Reports

Ladies and Gentlemen:

Enclosed are the October 2004 Monthly Operating Reports as required by Section 5.6.4 of the Technical Specifications.

If you have any questions, please advise.

Sincerely,

Don E. Grissette

DEG/DWM/daj

Enclosures: E1 – VEGP Unit 1 Monthly Operating Report
E2 – VEGP Unit 2 Monthly Operating Report

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President
Mr. W. F. Kitchens, General Manager – Plant Vogtle
RType: CVC7000

U. S. Nuclear Regulatory Commission
Dr. W. D. Travers, Regional Administrator
Mr. C. Gratton, NRR Project Manager – Vogtle
Mr. G. J. McCoy, Senior Resident Inspector – Vogtle

FE24

OPERATING DATA REPORT

DOCKET NO. 50-424
UNIT NAME Vogtle 1
DATE November 10, 2004
COMPLETED BY Tim A. Ruckman
TELEPHONE 706-826-3208

REPORTING PERIOD: October 2004

1. Design Electrical Rating	1,169.00		
2. Maximum Dependable Capacity (MWe-Net)	1,152.00		
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours the Reactor was Critical	745.00	7,287.18	137,618.01
4. Number of Hours Generator On-line	745.00	7,230.63	135,951.90
5. Reserve Shutdown Hours	0.00	0.00	0.00
6. Net Electrical Energy Generated (MWHrs)	871,647.00	8,434,735.00	152,931,035.0

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments

SUMMARY: Unit 1 was at approximately 100% power with no significant operating problems during the month of October 2004. There were no challenges to the Pressurizer PORV's and Pressurizer Safety Valves.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

OPERATING DATA REPORT

DOCKET NO. 50-425
UNIT NAME Vogtle 2
DATE November 10, 2004
COMPLETED BY Tim A. Ruckman
TELEPHONE 706-826-3208

REPORTING PERIOD: October 2004

1. Design Electrical Rating	1,169.00		
2. Maximum Dependable Capacity (MWe-Net)	1,149.00		
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours the Reactor was Critical	745.00	6,626.59	123,515.19
4. Number of Hours Generator On-line	745.00	6,557.20	122,528.40
5. Reserve Shutdown Hours	0.00	0.00	0.00
6. Net Electrical Energy Generated (MWHrs)	872,633.00	7,549,079.00	138,497,087.0

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments

SUMMARY: Unit 2 was at approximately 100% power with no significant operating problems during the month of October 2004. There were no challenges to the Pressurizer PORV's and Pressurizer Safety Valves.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)