

*PRELIMINARY - DETAILED ANALYSES  
STILL IN PROGRESS*



---

## **B&WOG/NRC Meeting BAW-2374 Rev 2**

Eric Henshaw

November 9-10, 2004  
Lynchburg VA

---



## **Oconee Nuclear Station**

---

- **Current Status**
  - Unit 1 replaced SGs in Fall 2003
  - Unit 2 replaced SGs in Spring 2004
  - Unit 3 replaced SGs in Fall 2004
  - Original OTSGs no longer in service
  - Replacement OTSGs have Inconel-690 tubes
  - Replacement OTSGs are analyzed for the LBLOCA transient described in Appendix A of BAW-2374 Revision 0



## Oconee ROTSG Tube Stress

---

- Summary of Oconee ROTSG Stress Analysis
  - FANP generated thermal stress inputs for LBLOCA & SBLOCA transients
  - Duke Power generated thermal stress inputs for MSLB
  - BWC used inputs to define acceptable tube flaw sizes for all 3 events
  - Acceptable results obtained to enable tube surveillance to be performed.
    - LBLOCA = 38% TW for 360 uniform part through wall crack
    - SBLOCA = 56% TW for 360 uniform part through wall crack
    - MSLB = 56% TW for 360 uniform part through wall crack

---

BWOG/NRC Meeting - Nov 2004

3



## Oconee ROTSG Tube Stress

---

- Summary of Oconee ROTSG Stress Analysis (cont'd)
  - LBLOCA transient analyzed is a large hot leg break
    - Maximum tube-to-shell  $\Delta T = -374$  degF
  - SBLOCA transient analyzed is a pressurizer surge line break
    - Maximum tube-to-shell  $\Delta T = -248$  degF

---


BWOG/NRC Meeting - Nov 2004

4



## Oconee ROTSG LBLOCA

FANP ROTSG LBLOCA HLB Case  
Reference FANP Document 86-5011502-00




BWOG/NRC Meeting - Nov 2004

5



## Oconee ROTSG SBLOCA

FANP ROTSG SBLOCA PSLB Case  
Reference FANP Document 86-5011314-00



BWOG/NRC Meeting - Nov 2004

6



## Duke Oconee Tube Stress

---

- Duke Analysis of LBLOCA Tube Stress
  - The analysis performed parallels that performed by FANP for BAW-2374
  - Cases performed for Replacement OTSGs
  - Base cases performed to evaluate limiting tube-to-shell temperature difference (aka tube stress)
  - Sensitivity cases performed to assess
    - Variation of tube stress with break area
    - Variation of tube stress with break location
    - Variation of tube stress with BWST temperature
    - Variation of tube stress with decay heat assumption

---

BWOG/NRC Meeting - Nov 2004

7



## Duke Oconee Tube Stress

---

- Duke Analysis of LBLOCA Tube Stress (cont'd)
  - Analysis designed to support NPSH evaluation, candidate single failures to maximize postulated tube leakage
    - RBS pump
    - RBCU
    - LPI suction valve from RBES
  - Initial QA review is not complete
  - Final cases remain to be performed

---

BWOG/NRC Meeting - Nov 2004

8



## Duke Oconee Tube Stress

---

- Break Spectrum Case Description
    - Maximum LPI performance – passive cross-connect
    - Maximum HPI performance
    - Minimum EFW flow
    - Minimum RBS flow
    - AFIS actuation modeled to limit EFW flow
    - Rapid MFW coastdown
    - BWST temperature = 45 °F
    - EFW temperature = 130 °F
    - BOC decay heat (4 EFPD for 480 EFPD core)
    - Operator action to secure HPI at 15 ft BWST level
- 

BWOG/NRC Meeting - Nov 2004



## Duke Oconee Tube Stress

---

- Duke LBLOCA Tube Stress Analysis Status
    - Break Spectrum – uses consistent set of assumptions to evaluate variation of tube-to-shell  $\Delta T$  with break area. Break located at the top of the hot leg
    - Maximum Tube-to-shell  $\Delta T$  preliminary break spectrum results
      - 14.1 ft<sup>2</sup> = -238 °F
      - 5.0 ft<sup>2</sup> = -230 °F
      - 2.0 ft<sup>2</sup> = -250 °F
      - 1.5 ft<sup>2</sup> = -245 °F
      - 1.0 ft<sup>2</sup> = -260 °F (limiting case)
      - 0.5 ft<sup>2</sup> = -257 °F
      - 0.3 ft<sup>2</sup> = -245 °F
- 

BWOG/NRC Meeting - Nov 2004

10



## Duke Oconee Tube Stress

- Duke LBLOCA Tube Stress Analysis Status
  - Sensitivity case maximum tube-to-shell  $\Delta T$  preliminary results, all assume break area = 1.0 ft<sup>2</sup>
    - Break spectrum case = -260 °F
    - Break location = -246 °F (SG inlet nozzle)
    - EOC decay heat = -244 °F (480 EFPD)
    - BWST temperature = -251 °F (70°F)
  - NPSH case to maximize RB sump temperature (70°F BWST, EOC decay heat)
    - maximum tube-to-shell  $\Delta T$  = -248 °F (preliminary)

BWOG/NRC Meeting - Nov 2004

11



## Duke Oconee Tube Stress

- Limiting Break Spectrum Case (1.0 ft<sup>2</sup> case)
  - Sequence of Events
  - 0.0 sec Break initiation
  - 0.0 sec Turbine Trip
  - 0.0 sec Main Feedwater trip
  - 28 sec ECCS actuation (HPI/LPI pumps start)
  - 69 sec EFW flow to SGs begins
  - 100 sec RBS flow starts
  - 187 sec AFIS actuation on SG A terminates EFW to Loop A
  - ~ 200 sec Loop A main feedwater line starts to flash
  - 528 sec AFIS actuation on SG B terminates EFW to Loop B

BWOG/NRC Meeting - Nov 2004

12



## Duke Oconee Tube Stress

---

- 1.0 ft<sup>2</sup> case Sequence of Events (cont'd)
  - ~ 530 sec Loop B main feedwater line starts to flash
  - ~ 1460 sec Loop A SG pressure drops below Patm
  - 2495 sec HPI pumps secured on 15 ft BWST level
  - ~ 3280 sec Maximum tube-to-shell  $\Delta T$  occurs
  - 3301 sec End of simulation
  - BWST level = 6 feet, beginning of sump recirculation



## Duke Oconee Tube Stress

---

- Oconee RELAP5 Model Description
  - Based upon RELAP5 model described in DPC-NE-3003-PA, Oconee Containment Response Methodology
  - Uses RELAP5/MOD2-B&W Version 13 (per licensed method)
  - Renodalized SG upper & lower downcomers
    - Defined fluid nodes based upon shell thickness
    - Increased number of nodes
  - Added detailed steam line nodalization
  - Added detailed main feedwater line nodalization

## Duke Oconee Tube Stress

---

- Differences between FANP & Duke Calculations
  - Primary difference is secondary side liquid level assumed
    - Duke water level higher than FANP
  - Duke analysis assumes
    - Bounding high downcomer orifice plate flow area
    - Conservative main feedwater coastdown
    - Error adjusted control setpoints
    - Minimum EFW performance
    - AFIS actuation
    - Account for main feedwater piping volume from SG to control valve (minimum pipe length utilized)
  - Oconee specific boundary conditions for ECCS

## Duke Oconee Tube Stress

---

- Conclusions of Analysis
  - Tube stress is not sufficient to cause tube failure in the replacement OTSGs
  - Results expected to produce loads well within the current tube surveillance criteria
  - Therefore, no need to perform:
    - Postulated BAW-2374 tube failure cases
    - Associated NPSH evaluations
    - Additional dose analyses





## Duke Oconee Tube Stress


- Duke LBLOCA Tube Stress Analysis – Future
  - Limiting case for defining tube stress to be performed
    - Limiting break area from break spectrum
    - Need to consider single failure to eliminate EFW to faulted SG
  - Tube stress inputs from final case to be transmitted to BWC for incorporation into revised tube surveillance criteria
  - When the analyses have been completed, Duke will prepare a submittal based upon BAW-2374 Revision 1 to address this issue for Oconee.

BWOG/NRC Meeting - Nov 2004

17




## Oconee ROTSG Result (14.1 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

18


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

19


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

20


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

21


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

22


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

23


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

24


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

25


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

26


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

27


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

28


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

29


## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

30

## Oconee ROTSG Result (1.0 ft<sup>2</sup>)



BWOG/NRC Meeting - Nov 2004

31

## GBS notes

- Describe limiting case (scenario/sequence of events)
- Show limiting case plots
- Explain why better
- Conclude where we are with these results
- Where will these results take us in the SG tube surveillance
- We will have BWC us the final QA'd case going forward
- No need to consider SGTR and consequences

BWOG/NRC Meeting - Nov 2004

32