

**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
*Plant License Renewal* ✓

Docket Number: (not applicable)

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005

Location: Rockville, Maryland

Date: Wednesday, November 3, 2004

Work Order No.: NRC-091

Pages 1-164

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

**ACRS OFFICE COPY  
RETAIN FOR THE LIFE OF THE COMMITTEE**

*TROY*

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

November 3, 2004

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on November 3, 2004, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION  
3 + + + + +  
4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
5 (ACRS)  
6 PLANT LICENSE RENEWAL SUBCOMMITTEE

7 + + + + +  
8 WEDNESDAY,  
9 NOVEMBER 3, 2004

10 + + + + +  
11 ROCKVILLE, MARYLAND

12 + + + + +  
13 The Subcommittee met at the Nuclear  
14 Regulatory Commission, Two White Flint North, Room  
15 T2B3, 11545 Rockville Pike, at 1:30 p.m., Mario V.  
16 Bonaca, Chairman, presiding.

17  
18 COMMITTEE MEMBERS:

19	MARIO V. BONACA	Chairman
20	RICHARD S. DENNING	Member
21	GRAHAM M. LEITCH	Consultant
22	VICTOR H. RANSOM	Member
23	WILLIAM J. SHACK	Member
24	JOHN D. SIEBER	Member
25	GRAHAM B. WALLIS	Member

NEAL R. GROSS  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ACRS STAFF PRESENT:

2 CAYATANO SANTOS

3  
4 OTHER NRC STAFF PRESENT:

5 KENNETH C. CHANG, NRR

6 CAUDLE A. JULIAN, Region II

7 PT KUO, NRR

8 SAM LEE, NRR

9 TILDA LIU, NRR

10  
11 ALSO PRESENT:

12 JAN FRIDRICHSEN, Southern Nuclear Operating Company

13 PARTHA GHOSAL, Southern Nuclear Operating Company

14 WAYNE LUNCEFORD, Southern Nuclear Operating Company

15 MICHAEL MACFARLANE, Southern Nuclear Operating

16 Company

17 CHARLES PIERCE, Southern Nuclear Operating Company

## A-G-E-N-D-A

I.	Opening Remarks, M. Bonaca, ACRS . . . . .	4
II.	Staff Introduction, P. T. Kuo, NRR . . . . .	5
III.	Farley License Renewal Application, Jan Fridrichsen, Southern Nuclear Operating Company . . . . .	14
IV.	SER Overview:  T. Liu, NRR . . . . .  C. Julian, Region II . . . . .	83 94
V.	Aging Management Program Review and Audits:  T. Liu, NRR . . . . .  K. Chang, NRR . . . . .	102 109
VI.	Time Limited Aging Analyses (TLAAs),  T. Liu, NRR . . . . .	133
VII.	Subcommittee Discussions, M. Bonaca, ACRS	161
VIII.	Adjourn, M. Bonaca, ACRS . . . . .	164

P-R-O-C-E-E-D-I-N-G-S

1:30 p.m.

DR. BONACA: Good afternoon. The meeting will now come to order. This is a meeting of the Plant License Renewal Subcommittee. I am Mario Bonaca, Chairman of the Plant License Renewal Subcommittee. The members in attendance are Richard Denning, Victor Ransom, Steven Rosen, William Shack, Jack Sieber, and Graham Wallis. ACRS consultant Graham Leitch is also present. Cayatano Santos of the ACRS staff is the designated federal official for this meeting.

The purpose of this meeting is to discuss the license renewal application of the Joseph M. Farley Nuclear Station Units I and II. We will hear presentations from the NRC Office of Nuclear Reactor Regulation, the representatives of the Southern Nuclear Operating Company.

The Subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for deliberation by the full committee. The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal Register on October 5, 2004.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   We have received noted incumbent's request  
2                   for time to make oral statements from members of the  
3                   public regarding today's meeting. The transcript of  
4                   the meeting is being kept and will be made available  
5                   as stated in the Federal Register notice. Therefore,  
6                   we request that participants in this meeting use the  
7                   microphones located throughout the meeting room when  
8                   addressing the subcommittee. The participants should  
9                   first identify themselves and speak with sufficient  
10                  clarity and volume so they may be readily heard.

11                  We will not proceed with the meeting. I  
12                  call upon Mr. Kuo of the Office of Nuclear Reactor  
13                  Regulations to begin.

14                  DR. KUO: Thank you, Dr. Bonaca. Good  
15                  afternoon. For the record, I'm P.T. Kuo, the Program  
16                  Director for the License Renewal and Environmental  
17                  Impacts Program. On my right is Dr. Sam Lee who is  
18                  the Second Chief for Project Management Section. To  
19                  my extreme right is Tilda Liu who is the Senior  
20                  Project Manager for this project.

21                  As you indicated, today the staff will  
22                  brief the committee on the Farley License Renewal  
23                  Application Review. You may recall that Farley is the  
24                  first power plant that uses what we called audit  
25                  review process for the Aging Management Program parts

1 that are consistent with GALL, consistent with our  
2 previous staff approved positions.

3 This presentation will have three parts.  
4 The first part will be led by Tilda who will discuss  
5 the general review of the whole project. And the  
6 second part will be the inspection review that will be  
7 lead by Caudle Julian from Region II. He is the team  
8 leader of the inspection. And then the third part is  
9 audit review process led by Dr. Kenneth Chan who is a  
10 team leader for the audit team.

11 Because the audit process is new and this  
12 is the first plant, I would really like to say a few  
13 words specifically about the audit process. As you  
14 may recall, we have briefed the committee some time  
15 ago that we generally have a team that consist of  
16 about seven to 10 people that include both the staff  
17 members and contractors with different enduring  
18 disciplines that includes material structures,  
19 mechanical, and electrical.

20 They will stay on site about two to three  
21 times during the audit. Each time is about a week.  
22 They stay on site, perform their review. When they  
23 come back they prepare the report, address all the  
24 issues that they have discussed with the applicant.

25 We believe this process so far as been



1 very successful. From the feedback we got from the  
2 industry, I think all the feedback appears to be  
3 pretty positive. We applied this process to all our  
4 recently received applications. So for that purpose  
5 we really appreciate if you have any comments on this  
6 process and we would like to have them.

7 MR. LEITCH: PT, one of the measures of  
8 success was going to be, at least in part, the number  
9 of RAIs. Did this result in less RAIs than previous?

10 DR. KUO: Well, we have been successful to  
11 some extent. We have not reached the degree that we  
12 really like to see. For Farley I think we had about  
13 186 or 187 RAIs. 153, okay. That's even better.  
14 Previously we had between 200 and 300. The reduction  
15 is not as significant as I would like to have but  
16 because this is the first audit plan, I give it some  
17 time. I would expect that the RAIs will go down  
18 somewhat more.

19 MR. LEITCH: I'm a little confused. I  
20 read a report that was about in the April 2004 time  
21 frame, the result of a team. I think it was led by  
22 Jimi Yerokun that looked at the process and looked for  
23 ways to improve the process. They had a number of  
24 recommendations, coordination, communication, and some  
25 improvement to the flow of the process. Is this a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 result of that report or is there still some further  
2 improvement to the process based on the  
3 recommendations of that report? Are you familiar with  
4 the report I'm speaking of?

5 DR. KUO: Yeah, I know. They are  
6 separate. Jimi Yerokun's assessment team was to  
7 assess the effectiveness of these scoping and  
8 screening part of review. That is being done by  
9 another division. The process that I'm talking about  
10 now is the process that deals with the Aging  
11 Management Program.

12 MR. LEITCH: Okay. Is there a plan to  
13 implement the recommendations, or at least consider  
14 the recommendations that were in that April report?

15 DR. KUO: The recommendations are being  
16 implemented right now.

17 MR. LEITCH: Okay.

18 DR. KUO: Actually, the Browns Ferry --  
19 I'm sorry, Brunswick will be the first implementation.  
20 For instance, at the end of the recommendation we talk  
21 about the 54.4(a)(2) issue that would be probably  
22 better to be done by the region because they are at  
23 the site. They look at the spacial arrangement of all  
24 the hardware.

25 MR. LEITCH: Largely dependent on spacial.

1 DR. KUO: Right. That would be done by  
2 the region for Brunswick. We are, of course,  
3 improving our coordination and communication among our  
4 different groups.

5 DR. BONACA: You were asking about this  
6 report, our opinions. This is the report that was the  
7 audit review of the report. Right?

8 DR. KUO: Right.

9 DR. BONACA: Okay. I think it's a very  
10 good audit actually. I think it was very insightful.  
11 For a reviewer such as me complicated life because it  
12 was repetition within the SER and this report so it  
13 wasn't clear how you incorporated. I was sure that  
14 you did but I had to look at it separately. The  
15 question I would have is for the future are you  
16 planning to still have a separate report like this or  
17 are you trying to document it within the SER?

18 DR. KUO: No, separate audit report.  
19 Every audit we will produce a report.

20 DR. BONACA: But you're reflecting these  
21 insights already also in the SER because you are  
22 referring to that.

23 DR. KUO: Right.

24 DR. BONACA: So you plan to maintain it as  
25 an audit document.

1 DR. KUO: Yes, sir.

2 MR. LEITCH: I had kind of the same  
3 question as Dr. Bonaca. I had the audit and review  
4 report before I had the draft SER and I reviewed it  
5 and found it very helpful, by the way. I thought it  
6 was well organized, easy to follow. Perhaps -- not  
7 perhaps, it definitely was somewhat repetitive but it  
8 was easy to follow and navigate one's way through. I  
9 sort of thought when I got the draft SER what I might  
10 find is this almost as a section in its entirety just  
11 inserted in the SER because it did seem to be  
12 repetitive to a lot of the information that was in the  
13 SER.

14 DR. KUO: Some of it may be repetitive but  
15 it was purposely done. We wrote the report with the  
16 mind that this is going to be transferred to the SER.  
17 The audit team is responsible for about 50 to 70  
18 percent of the review consistent with GALL and  
19 previously approved staff positions.

20 If after the audit report if we have to  
21 write another SER, that is just too consuming and not  
22 the efficient use of time. We prepared the audit  
23 report with the mind that some of the content could be  
24 transferred to SER so that we don't have to spend time  
25 to just simply write in this SER. But they did report

1 it has more details in it.

2 MR. LEITCH: I was thinking of just  
3 further improvements in the efficiency of the process.  
4 It seemed to me that this could almost be lifted and  
5 become the major part of the SER.

6 DR. KUO: Maybe. We are constantly  
7 looking at it and see if we can still improve on it.  
8 If it turns out that we really don't have to prepare  
9 an audit report and just go into the SER, we will do  
10 that but what I'm afraid of is that some of the  
11 details that now is currently in the report will  
12 somehow not be seen.

13 DR. BONACA: Yes. Let me just say that  
14 this has nothing to do with Farley specifically, of  
15 course. For the purpose of a reviewer, I go in with  
16 very specific operating interest in experience for  
17 this plant, any plant, what they have gone through and  
18 the applicable operating experience from other sites  
19 and plants.

20 Second, the site characteristics, which  
21 are unique to that site, which should make for the  
22 kind of challenges there may be to the buried cable,  
23 buried structures, the licensee's actions to improve  
24 the plant, to maintain it, all those things. The more  
25 paper we get, the more difficult it is to focus on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 same issues because that's really the same issues. To  
2 the degree to which it can be streamlined by including  
3 one document into the other, I really wish you well.  
4 I would like you to attempt it.

5 DR. KUO: Thank you.

6 DR. BONACA: Anyway, I don't want to  
7 criticize the report. I thought it was an excellent  
8 audit and, in fact, it provided a lot of good  
9 information about the aging management problems.

10 DR. KUO: Thank you.

11 DR. SHACK: On the other hand, let me just  
12 say I thought the SER was very good. This was really  
13 one of the best SERs that we've seen on the license  
14 renewal process. I thought it was very well organized  
15 that a person reviewing the process could go through  
16 and get all the information in a rather compact form.

17 DR. BONACA: It even had sections  
18 separations, tabs.

19 DR. KUO: Thank you very much. Tilda will  
20 be happy to hear that.

21 DR. BONACA: Okay. Well, with that --

22 DR. KUO: With that I would call the  
23 Farley Southern Services to make a presentation first  
24 and then the staff briefing will follow.

25 MR. PIERCE: My name is Charles Pierce.

1 I'm the manager for the License Renewal Program for  
2 Southern Nuclear, and specifically for Farley. Jan  
3 Fridrichsen, who is the license renewal licensing  
4 manager for us, is now walking up to the front to make  
5 his presentation. To my right now is Mike MacFarlane  
6 who is our license renewal technical manager for  
7 Farley as well.

8 I'm just going to make one or two quick  
9 remarks. One, I do appreciate the opportunity to  
10 speak to you all today. I do think that the NRC's  
11 review has been very, very comprehensive. I think  
12 consistent with the GALL process that was developed  
13 has been a factor in that. I think if we go through  
14 that you'll see how it has worked to improve the  
15 overall process.

16 As another note, I've been working in  
17 license renewal now since 1994. I'm an old timer  
18 here. I've been working in licensing since the early  
19 '80s off and on in various projects. Just as a point  
20 of note, I do find that on the license renewal project  
21 for the NRC that the NRC has been very progressive in  
22 considering changes both internally in the industry  
23 and moving ahead with those changes.

24 I think you see that with things  
25 consistent with GALL issues that we have today, and

1 overall improving the process over time. I think that  
2 speaks to their efforts and I'm glad to see that. I  
3 think there are other changes that are being  
4 considered now that I think would further improve the  
5 process as well. Thank you very much.

6 MR. FRIDRICHSEN: Good afternoon. My name  
7 is Jan Fridrichsen and I'll be conducting our part of  
8 the presentation. Just to give you a rather quick  
9 introduction of what we're going to talk about, we'll  
10 talk a little bit about the application and its  
11 background. Talk a little bit about the description  
12 of Farley Nuclear Plant and features of the plant. A  
13 little bit of our operating history. Talk a little  
14 bit about the scoping process that we went through for  
15 developing our application.

16 How we applied the GALL to developing our  
17 application. We understand there's some interest in  
18 the commitment process and how we manage commitments  
19 and I'll have a little discussion on that and then  
20 touch on some of the basic industry issues that are of  
21 note before us this day and give you a little briefing  
22 on what Farley is doing on those.

23 We submitted the application on September  
24 12, 2003. Our original license exploration dates are  
25 in 2017, 2021 for Units I and II respectively. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 application itself was a new process. It consisted of  
2 -- it had to be consistent with GALL audits. It was  
3 the first of its kind.

4 We had three inspections or audits and it  
5 was focused on assessing our determinations consistent  
6 with GALL adequate for the staff. We felt like, as  
7 was commented before, it was a very successful  
8 process. A lot of information was brought forward and  
9 a lot of clarity was brought to the process.

10 What is Farley Nuclear Plant? It's a  
11 three-loop, Westinghouse pressurized water reactor.  
12 We had dual engineering services on the construction  
13 of the plant. Bechtel was the interface between  
14 Westinghouse and they did the engineering of the  
15 Westinghouse systems and their integration plant.

16 Then Southern Company Services was our  
17 power generation end of the plant, term building and  
18 outside structures. They engineered that. Initial  
19 operations, Unit 1 in 1977 and Unit 2 in 1981. We  
20 generate approximately 910 megawatts per unit.

21 MR. LEITCH: Jan, perhaps this would be a  
22 good time to raise this question while you have the  
23 photograph there. I have a little trouble  
24 understanding just what the general circulating water  
25 versus safety service water, essential service water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 or whatever you call it, is. Is there a lake some  
2 place? In other words, I couldn't quite understand.  
3 All the circulating water system and so forth is not  
4 in scope. I guess that's primarily for the  
5 condensers. Could you just talk about the essential  
6 service water?

7 MR. FRIDRICHSEN: Okay. Not seen in that  
8 photograph but the supply source water for plant  
9 Farley is the Chattahoochee River. It's on the  
10 Georgia/Alabama border. From that we pump to the  
11 seismic, safety-related service water pond. From that  
12 pond we supply essentially all the plant water needs,  
13 safety-related needs and the makeup to the circulating  
14 water system.

15 MR. LEITCH: Okay, but the circulating  
16 water itself.

17 MR. FRIDRICHSEN: Well, it comes from the  
18 service water system supply to the circulating water  
19 system. Our service water, for example, our supply  
20 flow per unit is about 40,000 gallons a minute and our  
21 typical makeup to the circulating water system is  
22 about 10,000 gallons a minute so once through is  
23 approximately 30,000 gallons of water.

24 MR. LEITCH: So this pond is in scope  
25 then?

1 MR. FRIDRICHSEN: Yes.

2 MR. LEITCH: And the pumps that feed the  
3 water into the pond are not?

4 MR. FRIDRICHSEN: That's correct.

5 MR. LEITCH: Okay. I understand. Thank  
6 you. I saw the picture but --

7 MR. FRIDRICHSEN: To give you a little bit  
8 of information relative to plant performance for  
9 Farley over the last five years, this graph represents  
10 our capacity factors for Unit 1, Unit 2 outage  
11 durations. You'll notice in the 2000/2001 time frames  
12 we have asterisked data. Those two years we replaced  
13 steam generators on each unit so the outages were a  
14 little longer. Radiation exposure was a little  
15 higher.

16 If you'll notice, though, as we go out  
17 into 2002/2003 the exposure information or the  
18 exposure data is extremely low. We have a very  
19 aggressive dose program at the site. We attribute  
20 quite a bit of that dose reduction to our zinc  
21 injection project. I have some information on a later  
22 slide about that. Farley's dose exposure for calendar  
23 years is dramatically lower after we begin the zinc  
24 injection.

25 DR. SHACK: Are your steam generators

1 sized to allow you to operate power?

2 MR. FRIDRICHSEN: Mike is the best one to  
3 answer that. He was involved in the --

4 MR. MACFARLANE: Steam generator  
5 replacement, the size of the steam generators was  
6 actually picked to be a equivalent replacement to the  
7 original steam generators. The original steam  
8 generators were 50,000 square foot surface area design  
9 but that was an alloy 600 tube. When the replacement  
10 is in it's a 54,000 square foot to make up for the  
11 difference in heat transfer characteristics. That's  
12 not to say that the plant cannot support another up-  
13 rate but the generators themselves were not really  
14 selected on that basis.

15 MR. SIEBER: What's T-hot in that point at  
16 full power?

17 MR. SIEBER: About 609 approximately.  
18 Maybe 607.

19 MR. MACFARLANE: It's licensed to 613,  
20 609 or 610 is what we actually run.

21 MR. FRIDRICHSEN: Our next slide is the  
22 indicator of our NRC performance indicators were all  
23 green and have been since the first order of 2001.  
24 All our indicators have been green.

25 Some of the features of Farley. The main

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 point on the first one is that it's pre-stressed/post-  
2 tension dry containment. We don't have the ice  
3 condenser design. We have a safety related cooling  
4 water pond. We have six off-site power sources  
5 through interconnections with Southern Electric  
6 System.

7 Five emergency diesel generators on site.  
8 Four of those are the safety diesel generators. One  
9 is the alternate AC power supply for station blackout.  
10 Forced-draft cooling towers and we operate on 18-month  
11 fuel cycles.

12 MR. SIEBER: What's the size of the off-  
13 site power diesel generator in horsepower?

14 MR. FRIDRICHSEN: Twenty-eight-fifty  
15 kilowatts.

16 MR. SIEBER: Okay.

17 MR. FRIDRICHSEN: And we have three 4075s  
18 and another 2850.

19 MR. SIEBER: And they're 4160 volts?

20 MR. FRIDRICHSEN: That's correct.

21 MR. LEITCH: So in a station blackout you  
22 don't assume -- I mean, the fifth diesel generator is  
23 not lost. Right?

24 MR. FRIDRICHSEN: That's the assumption.  
25

1 MR. LEITCH: The assumption is that the  
2 fifth diesel generators will still work in a station  
3 blackout?

4 MR. FRIDRICHSEN: Yes. Mike is the  
5 technical lead on all this stuff.

6 MR. MACFARLANE: Yes, the fifth diesel  
7 dedicated to station blackout service. However, it  
8 can be started and if you had an event where one of  
9 your emergency diesels failed to operate, you could  
10 start this SBO diesel and realign it but it is a B-  
11 train setup and it serves strictly as the SBO diesel.  
12 It was originally part of the emergency diesel  
13 generator design and when the blackout rule came out  
14 it was separated off as part of our licensing basis  
15 for SBO.

16 MR. LEITCH: And that's the one that is  
17 referred to as 2C.

18 MR. MACFARLANE: Correct.

19 MR. LEITCH: I was a little confused by  
20 that as I looked through it. Now, do you have  
21 ignitors in your containment?

22 MR. MACFARLANE: No. We have electrical  
23 recombiners.

24 MR. SIEBER: Do you have cross-connects on  
25 the 4160s between the units?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. FRIDRICHSEN: The way our normal  
2 distribution system is is that there's an A and B  
3 start-up transformer per unit. There is a capability  
4 to supply power from one unit to -- from one start-up  
5 transformer. The Bravo start-up transformer could  
6 supply the A-train and the B-train if it has to. They  
7 are interlocked not to allow that but they can.

8 MR. SIEBER: If you have one unit that was  
9 black and the other one was on diesels, could you  
10 cross-feed to the black unit? That would have been a  
11 design change for you.

12 MR. FRIDRICHSEN: I'm not sure I can  
13 answer that not knowing the latest procedures.

14 MR. LUNCEFORD: Are you talking about  
15 doing it from the diesels crossing over one use  
16 diesels to another one?

17 MR. SIEBER: Yeah.

18 MR. LUNCEFORD: I don't believe that can  
19 be done other than this 2C diesel which can do either  
20 units B-train and it's got the interlocks to allow  
21 that to happen.

22 MR. SIEBER: Some plants can and some  
23 can't.

24 MR. LEITCH: So except for the electrical  
25 lash-up the five diesels are identical. Is that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 correct?

2 MR. FRIDRICHSEN: No, sir. There are  
3 three large diesels and two small diesels. The large  
4 diesels are 4070 kilowatt and the smaller is 2850.

5 MR. LEITCH: 2C is one of the smaller  
6 ones.

7 MR. FRIDRICHSEN: That's correct.

8 MR. LEITCH: As is the 1C.

9 DR. BONACA: Your site is characterized by  
10 non-aggressive groundwater. Right?

11 MR. FRIDRICHSEN: That's correct.

12 DR. BONACA: Okay. And you do have -- I  
13 was speaking of the containment building and the  
14 history is good there, although you had one cracked  
15 tendon but that was a different issue, I guess.

16 MR. FRIDRICHSEN: I'll get to that on the  
17 next slide.

18 To give a little bit of our operating  
19 history, in 1983 we performed the up-flow mod on Unit  
20 1. This was in response to a design issue with the  
21 Westinghouse reactor vessels and the original design  
22 was down-flow mod and that created a pressure stress  
23 on the baffle former joint and it would open and it  
24 caused baffle jetting on the fuel. We had some fuel  
25 failures in 1983 so we did that up-flow mod to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 alleviate that problem.

2 In 1985 we had the cracked anchor head on  
3 containment tendon on Unit 2. It was on the field-  
4 installed end of the tendon and was due to hydrogen-  
5 induced stress cracking. Then in 1988 Farley was the  
6 subject of a Bulletin 88-08. We had a thermal cycling  
7 event that was occurring due to bypass valve leakage  
8 that caused a weld to crack on a safety injection to  
9 reactor coolant loop. It was sort of the source of  
10 a --

11 DR. BONACA: That was on a charge nozzle,  
12 right?

13 MR. FRIDRICHSEN: That's correct.

14 DR. BONACA: And that was due to thermal  
15 cycling?

16 MR. FRIDRICHSEN: That's right. Then --

17 DR. BONACA: How was it fixed? You must  
18 have done some modification.

19 MR. FRIDRICHSEN: Well, on Farley's design  
20 we pulled out the bypass line. There was no real need  
21 for it so we cut and capped it. That source of  
22 leakage was taken out.

23 MR. MACFARLANE: Just as an add we also  
24 installed some temporary monitoring thermocouples to  
25 demonstrate that we don't have cycling going on on a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 lot of the other lines and also that line.

2 MR. FRIDRICHSEN: We still monitor that  
3 information.

4 Then in 1994, as I mentioned earlier, we  
5 started the zinc injection project on Unit 2. We  
6 started on Unit 1 in 1999. We feel strongly that the  
7 dose reduction benefit is obvious. The laboratory  
8 information shows that the reduction in initiation of  
9 stress erosion cracking and infirmity water stress  
10 erosion cracking is reduced by the zinc injection.

11 DR. BONACA: It has nothing to do with  
12 license renewal but could I ask why you are at 18-  
13 month cycles? Most people have moved toward 24-month  
14 cycle.

15 MR. MACFARLANE: The way I've had it  
16 explained to me, and I can't say I can really give you  
17 a total explanation, is that the economics from the  
18 fuel go to a two-year cycle on PWRs. I've actually  
19 gotten this from a Westinghouse person. It's just not  
20 there when you look at the total cycle and economics  
21 of it that you don't get to two years. That's not to  
22 say it might change. To my understanding right now  
23 that's kind of what the thinking process is, is that  
24 the economics don't bear it out.

25 MR. SIEBER: You're balancing an increased

1 fuel cost against the extra downtime. Let me ask you  
2 a question on this slide before you go on. Back in  
3 the '80s there was a problem on Westinghouse three-  
4 loopers with split pins that were breaking.

5 MR. FRIDRICHSEN: That's correct.

6 MR. SIEBER: Did you replace your split  
7 pins?

8 MR. FRIDRICHSEN: As a matter of fact, we  
9 have just finished our second replacement on Unit 1.

10 MR. SIEBER: Oh, really?

11 MR. FRIDRICHSEN: Yes.

12 MR. SIEBER: What did you find this time?

13 MR. FRIDRICHSEN: It's just been completed  
14 this week. We did a replacement in the early '80s and  
15 we subsequently have done another replacement on Unit  
16 1.

17 MR. SIEBER: And that was based on your  
18 own inspection or some code requirement or what caused  
19 you to inspect them and find cracks?

20 MR. FRIDRICHSEN: I'm going to ask my  
21 associate, Wayne Lunceford, to address this.

22 MR. LUNCEFORD: Yes, this is Wayne  
23 Lunceford. The split pins on Unit 1, the original  
24 design were Alloy 750. They were replaced with a  
25 subsequent design, still Alloy 750 split pin. Even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       though there were lower stresses, there had been  
2       industry experience now with that second generation  
3       design failing due to stress corroding and cracking  
4       notably at Wolf Creek.

5               The issue for them was economics and that  
6       the nut portion of the split pin was carried out and  
7       did a pretty good banging job on their tube sheet of  
8       their recently replaced steam generators so Farley  
9       decided to preemptively replace those X-750 pins with  
10      316 co-work pins.

11             MR. SIEBER: Thank you.

12             MR. LUNCEFORD: Unit 2, by the way,  
13      already has replaced their split pins with 316 co-work  
14      stainless steel.

15             MR. SIEBER: Well, the original problem,  
16      as I understand it, was the sharp edges in the machine  
17      to make the pin in the first place. The steam  
18      generators where you had the loose part, those are the  
19      new steam generators?

20

21             MR. MACFARLANE: He was speaking of Wolf  
22      Creek. Farley has not had that experience.

23             MR. SIEBER: You don't have that problem.

24             MR. FRIDRICHSEN: Not with the new steam  
25      generators. We did in the early '80s have one split

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pin break and get into the primary system on one of  
2 the steam generators.

3 MR. SIEBER: That makes them hard to  
4 inspect after you bang the tube shut.

5 MR. FRIDRICHSEN: Moving along with  
6 operating history, we operated each unit in 1998 by  
7 123 megawatts thermal per unit. Then in 2000 and  
8 2001, as I already discussed, we replaced steam  
9 generators on both units. We replaced it with the  
10 Model 54F Westinghouse design, Alloy 690 tubing with  
11 stainless steel support plates and full depth roll.

12 DR. BONACA: And they are thermally  
13 treated, right, that 690 TT?

14 MR. MACFARLANE: That's correct.

15 MR. FRIDRICHSEN: And as we move on, we  
16 are currently in the process of doing the first  
17 reactor vessel head replacement on Unit 1 and we'll do  
18 Unit 2 next fall, next October.

19 DR. BONACA: But where are you on the  
20 subceptability curve for the vessel head?

21 MR. LUNCEFORD: The original heads were in  
22 the high category. That was part of the rationale for  
23 preemptive replacement of the reactor vessel heads  
24 even though there has been no cracking detected to  
25 date at Farley.

1 MR. SIEBER: Are you a hot head or a cold  
2 head?

3 MR. LUNCEFORD: It is a hot head design,  
4 597.

5 MR. SIEBER: Okay. Let me ask another  
6 question. You don't have to go back to the slide but  
7 slide 5 gave things like passing factors and outage  
8 duration for all the way to 1999. I noticed the  
9 capacity factor for Unit 2 in 1999 was pretty low.  
10 What happened that year? It didn't look like your  
11 outage was too long. You must have had some trips or  
12 something.

13 MR. FRIDRICHSEN: I'll have to defer. I  
14 was out of the country at that time.

15 MR. SIEBER: Well, I'm curious. You don't  
16 have to provide me with an answer if you don't have  
17 one readily available.

18 DR. BONACA: So now in your reactor vessel  
19 head inspections you didn't find any leaking CRDMs?

20 MR. FRIDRICHSEN: That's correct.

21 DR. BONACA: You inspected those so your  
22 bottom heads?

23 MR. FRIDRICHSEN: Yes, sir. One of my  
24 later slides we talk about it.

25 DR. BONACA: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. FRIDRICHSEN: We've done bottom head  
2 inspections on both units with no indications.

3 DR. BONACA: You replaced the thimble  
4 tubes in one of them. Right?

5 MR. FRIDRICHSEN: Yes, sir. I think we  
6 replaced them in both units now. We've done some on  
7 -- I know we did Unit 1 in the 1998 time frame.

8 DR. BONACA: I mean, I was trying to  
9 understand the criterion you have. I mean, you  
10 replaced them because you had a defect in them that  
11 you identified or thinning was beyond a certain  
12 criterion or just a precautionary step?

13 MR. FRIDRICHSEN: We had undertaken a  
14 program of eddy current testing since either a  
15 bulletin or information that came in the early '90s.  
16 We had been doing eddy current and had seen  
17 progressive wear and decided at that time to replace  
18 the thimbles with, I want to say, the chromium. It  
19 had a hard surface at the interface where it  
20 penetrates the vessel.

21 The purpose of this slide is to show that  
22 our management, our company, has made consideration  
23 for long-term operation at plant Farley. We've done  
24 a lot of things that we consider focused on the long-  
25 term. Of course, steam generator replacement and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reactor vessel head replacement were two big issues.  
2 We have just completed earlier this year a complete  
3 replacement of the cooling towers. The original  
4 construction had become kind of frail and we replaced  
5 them with new design, new construction.

6 We are also in the midst of getting our  
7 dry cask storage installation completed and get  
8 started with loading casks. I don't know the exact  
9 schedule for when we'll commence with that but that is  
10 in our long-term plan.

11 Additionally in the 1998/'99 time frame we  
12 conducted baffle former bolt replacement on both  
13 reactor vessels for concern of lose parts. There was  
14 an issue at the time. I think it was primary water  
15 stress erosion cracking of those bolts. We went ahead  
16 and we inspected all of them. The modeling showed and  
17 we had prepared to replace about 275 on Unit 1 and 200  
18 on Unit 2. We did that in '98 and 99 respectively.

19 Now we'll move a little bit to the meat  
20 and potatoes of license renewal. This slide we say is  
21 consistent with past applicants. That is where we  
22 ended when we originally started. We had adopted the  
23 NEI methodology, (a) (2) methodology. (a) (2) was going  
24 to include electrical targets at a 20-foot radius from  
25 a water source.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1           After discussions with the staff and some  
2 work we did between ourselves we decided to revised  
3 the process to go with that consistent with prior  
4 applicants for the (a)(2) scoping. We say consistent  
5 with past applicants but there was an iteration in the  
6 development of that.

7           MR. LEITCH: It looked like it took a  
8 couple of iterations to get that resolved but you did  
9 eventually do away with the 20-foot criteria?

10          MR. FRIDRICHSEN: That's correct.

11          MR. LEITCH: And you also now consider in  
12 addition to electrical components both mechanical and  
13 structural components.

14          MR. FRIDRICHSEN: That's correct.

15          MR. LEITCH: The one part of that, I think  
16 that RAI had like five questions in it. 20-foot was  
17 one of them and mechanical versus electrical  
18 structural. There's another. The one part that  
19 surprised me a little bit, and maybe this is  
20 consistent with past applications, where there were  
21 gas-filled systems you considered the failure of those  
22 systems to be noncredible.

23               I guess I was surprised at that. I could  
24 see perhaps saying what happens if one of those  
25 systems fails and rationalizing that was not probable

1 or not troublesome but I didn't understand the  
2 rationale that said that the failure of the gas-filled  
3 system was not credible.

4 MR. MACFARLANE: The failure of the gas  
5 systems is actually addressed in the NRC ISG and what  
6 they ask you to do is to deal with your plant specific  
7 operating experience that you've had on those systems.  
8 The focus is on a failure type that can lead to the  
9 failure of such related equipment so it's not just the  
10 failure of the gas system itself but it's also leading  
11 to a failure of such related system.

12 If you did get a breach in a gas system,  
13 whether or not that has the potential to cause a  
14 failure in another system you have no water spray  
15 effect and you've got rapid expansion of the gas if  
16 it's a compressed gas. Most of the gas systems are  
17 not on extremely high pressure anyway. They are 100-  
18 pound pipe systems.

19 Then the issue that would be remaining is  
20 could the system fail and that has already been shown  
21 through industry-wide type operating experience  
22 looking at not just nuclear but other facilities that  
23 those systems do not -- we have the supports already  
24 in scope and age managed and then the gas systems do  
25 not fall essentially. You don't have a failure hazard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 as long as you are managing the supports.

2 MR. LEITCH: Perhaps my question is really  
3 with the NRC staff because I agree that what you did  
4 seems to me to be in conformance with their position.  
5 I could visualize a 100-pound air system failing in  
6 such a way that the jet of air coming out the failure  
7 might damage some electrical equipment like a limit  
8 switch or pressure switch or something in the area.  
9 I guess the NRC was happy with the resolution of this  
10 ISG. I guess I'm just not happy with the resolution  
11 of this issue. Maybe you can talk to that when you  
12 get to that part of your presentation or now,  
13 whatever.

14 DR. KUO: Yes. Maybe when we get to that  
15 part of the presentation we will try to answer.

16 MR. LEITCH: Okay. Let me just make sure  
17 you understand what my question is. RAI 2.1-1 there  
18 were five issues that you raised. All five of those  
19 issues were satisfactorily resolved.

20 DR. KUO: Right.

21 MR. LEITCH: I agree that the resolution  
22 of four of those five. My question is that one of  
23 those says basically gas-filled system failure is not  
24 credible. Therefore, we're not going to consider  
25 that. That's the one I would like to hear a little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 more discussion about.

2 DR. KUO: Okay.

3 MR. LEITCH: Thank you.

4 DR. BONACA: I had some questions about  
5 some components. They are not in scope and I would  
6 like to hear why they are not. I mean, CRDM cooling  
7 system is not in scope.

8 MR. MACFARLANE: The CRDM system itself is  
9 part of the normal rod control. In terms of the  
10 safety system when you talk about doing a rod  
11 insertion, that mechanism is not really what comes  
12 into play. You basically release the rod and gravity  
13 drops it down. It doesn't actually perform a safety  
14 function and that's why it was not put in scope. The  
15 cooling system is not relied on for any type of  
16 containment analysis or anything like that.

17 DR. BONACA: Okay. Now, the screen wash  
18 system we have seen this before but I always have that  
19 question. I mean, the screen washes them up?

20 MR. MACFARLANE: The screen wash was not  
21 in scope. That is handled through the operators. The  
22 intakes themselves, the traveling screens AR were put  
23 in the structural side of the house.

24 DR. BONACA: Those are the river water  
25 intake structure. That is not in scope, is it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. MACFARLANE: No. The river water  
2 intake structure, the situation there is that's the  
3 structure at the river, the river water system that  
4 feeds the pond and then the pond becomes the ultimate  
5 heat sink so that structure, although is important to  
6 operation, is not important to safe shutdown.

7 DR. BONACA: Finally, the in-core  
8 instrumentation, I guess you can use it for NSFT  
9 related application?

10 MR. MACFARLANE: No, not in-core.

11 DR. BONACA: Not tied to any --

12 MR. MACFARLANE: In-core is for flux  
13 mapping and those issues. The ex-core is what's  
14 actually --

15 DR. BONACA: The tech specs. Any  
16 connection to that?

17 MR. MACFARLANE: Well, we are required to  
18 do flux maps and those types of things and that's just  
19 during normal operations. In terms of responding to  
20 an event for detection ex-core system is what actually  
21 does that. It's part of the reactor protection  
22 system.

23 MR. SIEBER: Your tech specs for flux map  
24 and your launch for 30 days and if you fail to do it  
25 you shut down so nothing is really required.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. LEITCH: I had another question about  
2 scope and the license renewal application, page 2.1-  
3 15. It says, "SNC has included in scope those  
4 switchyard components controlled by the plant that are  
5 necessary for recovery of off-site power." Should I  
6 be focusing on the words "controlled by the plant?"

7 In other words, I don't know who controls  
8 what. That's kind of a utility unique decision.  
9 Sometimes the breakers in the switchyard are  
10 controlled by others and sometimes they aren't  
11 controlled by the plant but I don't see what that has  
12 to do with whether or not that equipment should be  
13 included in the scope. It sounds like you're saying  
14 here that only those things that are controlled by the  
15 plant that are necessary for recovery of off-site  
16 power are included in the scope. I just don't  
17 understand.

18 I mean, we have some plants, for example,  
19 where there is an adjacent hydro plant that is  
20 controlled by a totally different organization. Those  
21 portions of the hydro plant that are necessary for  
22 recovery of off-site power are included in the scope  
23 even though they are beyond the control of the  
24 organization that is operating the nuclear power  
25 plant. I guess I was puzzled by the words "controlled

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 by the plant."

2 MR. MACFARLANE: The way that particular  
3 scoping was done is, you know, he talked earlier about  
4 we've got six different off-site feeds and they all go  
5 into the high-voltage switchyard. Then from that  
6 switchyard there's a point where it connects into our  
7 feeder system and goes down into our low-voltage  
8 switchyard. Then there is actually a site procedure  
9 when you want to restore off-site power if you have a  
10 loss of off-site power in the event of a blackout type  
11 situation.

12 That is what we put in scope is that  
13 primary means to feed to switchyard in responding to  
14 that event. It makes an interface in that switchyard  
15 but in that switchyard you define the high-voltage  
16 sign and then the feeder sign going to the low-voltage  
17 switchyard.

18 The actual switchyard itself is considered  
19 -- it has kind of a unique ownership in that it's  
20 partly run by the plant and partly run by Alabama  
21 Power. Controlled by the plant, I guess, I can see  
22 where that would be confusing but that really doesn't  
23 have any bearing in terms of where that distinction  
24 was picked. It's really picked based on the  
25 procedures for restoring off-site power.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. LEITCH: So the fact that some of  
2 those breakers may be under the control of Alabama  
3 Power doesn't exclude those from the scope.

4 MR. MACFARLANE: Right now all those  
5 breakers are under the control of -- the site has an  
6 operator that goes out into the switchyard.

7 MR. LUNCEFORD: But you're right, it  
8 doesn't exclude them from the scope.

9 MR. LEITCH: Okay. Thanks.

10 MR. FRIDRICHSEN: The next slide will talk  
11 a little bit about the GALL comparison. Wherever  
12 possible we use the GALL tool as much as possible. We  
13 did note that in our review that there were some  
14 material environment program combinations that were  
15 not in GALL but we had components and systems that  
16 needed to be in scope.

17 The aging management wasn't identified in  
18 GALL and the best example we can site is that we have  
19 in scope in some places some stainless steel piping in  
20 a varied environment and that series of combinations  
21 is not addressed in GALL so we were not able to use  
22 GALL in those applications.

23 Then also in some plant specific programs,  
24 for example, the flux thimble program and external  
25 surfaces monitoring programs were two programs that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 were generated plant specific for our application.

2 DR. BONACA: One thing that I notice, and  
3 this is not the first application, is that on the fire  
4 protection issue there are frequency of inspection of  
5 CO2, halon systems, and so on. Typically licensees  
6 are proposing whatever they are doing now, like in  
7 your case 18 months. GALL says it should be inspected  
8 every six months.

9 Typically NRC says, "Okay, it's acceptable  
10 the way it is." I have already raised this issue  
11 before. If it's acceptable to go to longer time, I  
12 think GALL should be relaxed to include that and maybe  
13 there is a plan to do so or vice versa. Then if it  
14 isn't acceptable in GALL, then you should go to a more  
15 frequent interval. The question I have is like on the  
16 issue of CO2 and halon inspection. Why do you feel  
17 18-month inspection is adequate?

18 MR. MACFARLANE: In the case of the halon  
19 and CO2 what you really end up with is a center of gas  
20 that is maintained in a dry state. We really haven't  
21 had any trouble in terms of internal operating  
22 experience. I don't want to say it was called an  
23 exception. I can't remember if it was classified as  
24 an exception or a clarification but we did use an 18-  
25 month frequency and it was accepted by the staff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 It's consistent with what you're talking about with  
2 other applicants.

3 DR. BONACA: I understand it's a dry  
4 system. But the question I raise why does GALL still  
5 having a requirement for six months? I mean, I'm just  
6 raising the question. The guy who reviews it why is  
7 it always acceptable to relax because this is the  
8 first time. If so, then why not make it -- relax the  
9 requirement into GALL?

10 DR. KUO: This is really a good question  
11 and this is the whole purpose of updating the GALL  
12 right now.

13 DR. BONACA: So you do agree, in fact,  
14 that a longer interval between inspections is  
15 acceptable for this kind of --

16 DR. KUO: For this plant, for Farley case,  
17 we did agree with it and that we will provide you the  
18 basis for that during the audit presentation.

19 MR. MACFARLANE: Just to add to what was  
20 said there, I think you're correct. There are several  
21 programs that have those kind of little issues and I  
22 believe the staff is trying to look at addressing that  
23 in the GALL update. The industry is also updating its  
24 documentation and the schedule for that is sometime  
25 next year in terms of getting it all the way through

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the process. There are several instances of that kind  
2 of thing where there's a lot of precedence on it that  
3 should be incorporated into the future goal.

4 MR. LEITCH: I had another scope question.  
5 The tank atmospheric events, there was apparently some  
6 omissions or inconsistency regarding whether they were  
7 or were not in scope. This was mentioned in the NRC  
8 inspection report.

9 I guess specifically the RWST, CST, RMU,  
10 some of the events were in scope and some were in  
11 scope. I guess it's all been straightened out now and  
12 they are all in scope, but my question really was was  
13 that just one of a kind or was there any process type  
14 of issue that was uncovered by that inconsistency?

15 MR. MACFARLANE: The tank vent issue  
16 really got into in resolving it we did go back and  
17 look at all of our atmospheric type tanks. What you  
18 have is a couple different situations that can occur  
19 on a tank vent and you can have some tank vent systems  
20 that actually are a pipe system and they might have  
21 some supports that might be inside the structure.  
22 When you start looking at aging of a tank vent, you  
23 are actually going to increase the vent area so it  
24 doesn't become an issue in terms of being able to  
25 impact the ability to do the event.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           You try to maintain your vent as opposed  
2           to in a couple of these tanks the situation was you  
3           had a fairly significant length of piping on top of  
4           the tank that is the vent. The issue became if you  
5           did have some aging that thing could potentially,  
6           although somewhat of a remote possibility, crimp or  
7           collapse and close off or reduce your vent capability.

8           It was done inconsistently among a couple  
9           of preparers and that's what set that whole thing off  
10          so we went back and looked at all of those and put all  
11          of them in scope. We don't have any of those that  
12          really fall into the supported type piping vent  
13          system. Really most of them mount right on the tanks.

14          MR. LEITCH: So I guess what you're saying  
15          is it was one-of-a-kind situation that didn't reveal  
16          some underlying flaw in their scoping process.

17          MR. MACFARLANE: The thought process at  
18          the time was that the aging event would not be an  
19          issue from an (a)(2) standpoint and that the event  
20          surface would increase. They had not considered the  
21          crimping off aspect so that was really what was the  
22          change, I guess, in terms of an additional failure  
23          mode, so to speak.

24          MR. LEITCH: I guess my question goes more  
25          to communication between the groups that were doing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the work. Evidently there was one group --

2 COURT REPORTER: Mr. Leitch, I can't hear  
3 you.

4 MR. LEITCH: Evidently there was one group  
5 that did consider the crimping and another group that  
6 did not consider the crimping.

7 MR. MACFARLANE: It's really the  
8 difference in individual preparers and different  
9 thought processes on or between the two. Since that  
10 time we did get everybody together on that particular  
11 issue and reviewed it and that's where we made the  
12 decision as a project to consider that a credible  
13 mechanism. That's not part of our process in that we  
14 consider that mechanism.

15 We did look at some other plants and what  
16 they had done and they had different situations on the  
17 same tanks. They had piped supported systems so they  
18 have a different conclusion. Interestingly enough,  
19 you can look at an event on the same tank at different  
20 plants and you will actually get a different result  
21 and it has to do with the physical installation.

22 MR. LEITCH: My question, though, is not  
23 so much about the tanks as it is with communication of  
24 thought processes and experience between different  
25 groups that are doing similar work.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. MACFARLANE: It's actually not a  
2 different group. It's all in one group. It's just  
3 two different mechanical engineers doing the  
4 preparations and I can't really tell you who the  
5 checkers are. I don't have that information off the  
6 top of my head but it was just a difference of how  
7 they did it, it could happen type thing.

8 It was not really a communication  
9 standpoint. They actually sit right across from each  
10 other. They are looking at a lot of different things  
11 in that particular case. In some cases they just  
12 didn't view that as a real possibility. We actually  
13 had a long discussion about whether or not to  
14 challenge the position taken by the inspectors on  
15 this. We decided that from our standpoint it was  
16 conservative to put it in and we decided to do that.  
17 It was still subject to some debate in terms of is it  
18 really a valid mechanism.

19 MR. LEITCH: Okay. Thank you.

20 MR. FRIDRICHSEN: And moving on we'll talk  
21 about some of the key exceptions, differences we have  
22 with some of the GALL programs. These are our key,  
23 some of the things we consider more significant. We  
24 have a slide a little bit later that talks about some  
25 of the minor things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The first example is the reactor vessel  
2   surveillance program. The GALL recommends that all  
3   capsules be removed at an exposure of 60 years  
4   fluence. At Farley those capsules will remain in  
5   until 80 years of exposure. That's one difference  
6   that we have with the GALL recommended program.

7           Another one is relative to the Reactor  
8   Vessel Internals Program and that's really a function  
9   of the evolution of this issue in the industry and  
10   that the activities going on in the industry now are  
11   somewhat at a different level than what the GALL  
12   recognized and, therefore, there's a higher tension  
13   being applied to it.

14          We're going to go beyond what's in the  
15   GALL for that program. We're going to sort of follow  
16   what's on with research in the industry. We'll follow  
17   what the EPRI-MRP is doing. Somewhere in the two  
18   years prior to the period of extended operation time  
19   frame we'll submit the program for staff review and  
20   approval.

21          Another exception is with the non-EQ  
22   cables and instrumentation circuits. We are going to  
23   base our program on the alternate program composed by  
24   the Electrical Working Group. This program is  
25   different from what's recommended in GALL.

1           The last example that I'll cite is that  
2           with the Water Chemistry Control Program for closed  
3           cycle cooling water the GALL recommends forms testing  
4           for pumps and heat exchanges and our program is going  
5           to credit every monitoring guidelines. Those are the  
6           four or four of the more significant differences we  
7           have with GALL. In our mind that's not -- these  
8           programs are not enormous exceptions to what's in  
9           GALL.

10           Then some of the minor things are relative  
11           to. We'll even use the term clarifications. There  
12           were different or later versions of codes and  
13           standards that we're applying that are referenced in  
14           the GALL or that we may expand our program beyond  
15           what's in GALL or that there is later NRC guidance for  
16           those programs and, therefore, we are citing that as  
17           our reference as opposed to GALL.

18           MR. LEITCH: I have a question about  
19           compliance with interim staff guidance. You go  
20           through the license renewal application a kind of  
21           detailed explanation of your compliance with the  
22           various ISGs. That all looked good and I thought it  
23           was pretty helpful but I was puzzled by the one about  
24           fuse holders.

25           You say, "Since fuse holders at Farley



1 have no aging effects requiring management, the  
2 attributes of ISG-05 do not apply." I guess my  
3 question is what's different about your fuse holders?  
4 Don't they corrode like other people's fuse holders?  
5 I just don't understand what's different there.

6 MR. NGUYEN: My name is Duc Nguyen from  
7 the electrical engineer branch. We are the one who  
8 issued ISG. The fuse holder has two parts, one the  
9 installation portion and one the metallic portion.  
10 The installation portion include the GALL XI.E1. We  
11 use inspection to inspect the installation material  
12 due to local line by heat or radiation, hot spots.

13 For the metallic portion E1 is not  
14 applicable because of the concern we have. We had a  
15 contract go to 30 on the fuse holder and we found that  
16 some of the metallic portion have a crack. The  
17 problem was when they do the maintenance they took out  
18 the fuse element and it was in and out so many times  
19 the fuse clip have fatigue. That a problem we found  
20 in one of the 30. Therefore, we issued ISG. We say  
21 that for your particular plant you have to address  
22 aging effect of fatigue, corrosion, and vibration.

23 Salt land that aging effect is not  
24 applicable and they provide a reason why. For the  
25 fatigue they say we don't remove the fuse element. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have the upstream of that fuse. When you run through  
2 maintenance you go through breaker and we trip it off  
3 so fatigue is not applicable to us.

4 Some plants are applicable to them because  
5 they say every time we go to maintenance we have to  
6 remove the fuse. That why if you did that, then we  
7 require them to have again management program. If you  
8 don't do that, then that aging effect is not  
9 applicable.

10 For corrosion for particular filing they  
11 say they are the fuse holder is contained in a cabinet  
12 inside the drum so the moisture and it's not an  
13 applicable aging effect. In ISG we say that you have  
14 to evaluate your plan and tell us why aging effect is  
15 not applicable. That is plant specific. Farley  
16 provide information and they address why they don't  
17 have that aging effect and we agree with that.

18 MR. LEITCH: So if I can summarize that in  
19 the aging effect due to fatiguing doesn't apply  
20 because they don't routinely take the fuses out.

21 MR. NGUYEN: They took off the breaker  
22 upstream.

23 MR. LEITCH: And the aging effect due to  
24 corrosion --

25 MR. NGUYEN: Because you're inside a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cabinet and low to moisture. And another thing they  
2 say is the fuse clip also coat it with silver or  
3 something, the material that prevent corrosion. That  
4 makes sense. Some applicant they won't get that and  
5 then they have to provide us the Aging Management  
6 Program. In the new GALL update we are going to  
7 propose a new program, XI.E4. That program will tell  
8 you what to do and we are going to do that in the next  
9 GALL update.

10 MR. LEITCH: Thanks very much. That's a  
11 very good answer.

12 MR. FRIDRICHSEN: It's very rare for us to  
13 do safety isolation by pulling a fuse. That's very  
14 rare. From here I'll transition --

15 DR. BONACA: Before you go on I have just  
16 a couple of questions. First of all, for your in-  
17 service inspection you found a bulge in the  
18 containment lining. That's a no-never-mind?

19 MR. FRIDRICHSEN: It was evaluated and  
20 disposition is acceptable.

21 DR. BONACA: What is the size of this  
22 bulge?

23 MR. FRIDRICHSEN: Partha, could you answer  
24 that?

25 Partha actually did the inspection.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. GHOSAL: There were two or three found  
2 by doing our inspection. The lining is quarter-inch  
3 thick and bulging is in between the support points so  
4 you do a meet span and each considered. We evaluated  
5 the situation and we measured the thickness of the  
6 liner and there was no decrease in the depth of the  
7 liner or anything so that kind of eliminated that  
8 there is any deterioration behind the liner. It was  
9 determined that it was during the construction time  
10 the bulging happened. It was nothing related to the  
11 age-related degradation.

12 DR. BONACA: It doesn't affect in any way  
13 functionality.

14 MR. GHOSAL: Right. Yes. There is no  
15 crack. There is no indication or anything.

16 DR. BONACA: The other question I had was  
17 regarding again the mainstream support failure.

18 MR. GHOSAL: You mean the concrete support  
19 failure?

20 DR. BONACA: Yeah. I think it was the  
21 mainstream line. Was it?

22 MR. MACFARLANE: I'm not sure exactly  
23 which question --

24 DR. BONACA: In-service inspection. I  
25 have to get the document out.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. MACFARLANE: We did have -- I suspect  
2 what you're talking about is during Unit 2 steam  
3 generator replacement we discovered several mainstream  
4 support hangers had failed. There was an extensive  
5 root cause investigation of that. We actually hired  
6 in Altran and some high-powered consultants and we  
7 actually did some modeling.

8 We installed some transducers actually in  
9 the mainstream system trying to pinpoint what was  
10 going on. We also did a lot of mitigative work.  
11 There was some vibration damper in the isolators that  
12 were put into both containment and into the aux  
13 building. I take that back, not the aux building,  
14 into the turbine building.

15 What they found out is when we did the  
16 upgrade I guess it had a little bit of an effect but  
17 the main issue was where our three lines that come out  
18 of containment go into a common header and they go  
19 into two lines into the turbine building, that header  
20 was causing -- it was actually initiating this flow-  
21 induced vibration.

22 The resolution was really putting in this  
23 dampener and isolators and those kinds of things. It  
24 was practical to try to change out that header.  
25 That's a pretty tight area and a major size header.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 That was a real extensive effort that went on in that  
2 time frame and that was our operating experience. It  
3 was really treated as an initiating event. It's not  
4 an ongoing type of event.

5 They did analysis to make sure it had not  
6 been over-stressed and then we did monitoring after we  
7 did all of these modifications to prove that the  
8 modifications that were done did bring the amplitudes  
9 down to where they were in allowable limits and  
10 everything was fine. That's what was done.

11 DR. BONACA: So you don't have anymore of  
12 the conditions that cause the high-cycle fatigue, the  
13 ameliorating.

14 MR. MACFARLANE: Right. The piping we  
15 keep monitoring. We do hanger inspections when we  
16 shut down for an outage to make sure that we don't  
17 have any. The conclusion was that those made a  
18 significant reduction.

19 DR. BONACA: And you are still inspecting  
20 anyway. You in-service inspection looks at those  
21 areas.

22 MR. MACFARLANE: Right. We also inspect  
23 out in the turbine building area which is outside the  
24 ISI scope. We do check entire mainstream lines.

25 DR. BONACA: On a separate issue on the

1 diesel oil fuel, you have a discrepancy from GALL  
2 where you do not test for particulate.

3 MR. MACFARLANE: That's correct.

4 DR. BONACA: And I didn't understand. I  
5 assume that particulate meant impurities in the diesel  
6 fuel. The answer was that it was acceptable because  
7 it does not significantly impact on pressure boundary  
8 integrity. The question I had was what about the  
9 long-term work functioning of the diesel? I mean,  
10 would the particulate, for example, if it was  
11 impurities mean that the diesels may not function for  
12 the long haul as well as it should?

13 MR. MACFARLANE: I think what happened is  
14 we really just have a different set of standards that  
15 we use. That does happen to be one of the  
16 differences. The standards that we are committed to  
17 is actually in the tech specs and so we took the  
18 exception from the standpoint that the tech specs  
19 govern what we had. In terms of the quality of the  
20 fuel oil in terms of aging, what you're really looking  
21 for is whether or not you're looking for water and  
22 those kinds of things and we do do that.

23 DR. BONACA: Maybe the problem is -- I  
24 mean, I'm trying to understand. I understand you are  
25 testing for water and I understand what water does.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Sediment, I understand that, and viscosity. Maybe I  
2 should ask the staff what is this particulate that  
3 they are testing for. Are they impurities of a  
4 different type?

5 DR. KUO: Let me find out.

6 DR. CHANG: My name is Ken Chang. I'm the  
7 auditing leader of the Farley review. When the  
8 auditing was on site we did review the fuel oil  
9 chemistry control program and we identified -- we  
10 noticed the differences of the two standards, ASTM D  
11 270-75 and GALL prescribed ASTM D 4057. We looked  
12 into the basics documents and the applicant did a  
13 comparison study of the ASTM D 270 and the D 4057.

14 Based on the parameters important to the  
15 corrosion these are properly monitored by both  
16 standards and also no significant differences exist in  
17 the ability of the program to manage aging following  
18 ASTM D 270-75 versus D 4057. Also, the operating  
19 experience confirmed that AMP B.4.2 has been effective  
20 in managing the aging effect. They also are following  
21 the tech spec requirements as part of the CLB which  
22 takes precedence over the GALL. It is accepted by the  
23 auditing.

24 DR. BONACA: I understand but it doesn't  
25 answer my question. I was trying to learn something



1 that I haven't learned. Specifically it says they  
2 should test for impurities and for particulates and  
3 they don't so I'm left with the question what is a  
4 particulate here? Some kind of impurity.

5 Clearly it can't be water because they've  
6 tested for water. It cannot be sediment because they  
7 are testing for settlement and they tested for  
8 viscosity so it can't be any of those issues. It has  
9 to be something else and I'm not getting the answer to  
10 what particulate means in GALL.

11 DR. CHANG: I don't think I have provide  
12 you the answer to that particular part of the question  
13 but the auditing and the main purpose is to verify  
14 that these AMPs are adequate to managing the aging  
15 effects for that purpose. If you are interested in  
16 knowing the answer to the other part of your question,  
17 I can look into it and provide you the answer.

18 DR. BONACA: If you could. I mean,  
19 clearly GALL must specify --

20 DR. CHANG: GALL must be for a reason.

21 DR. BONACA: -- for a particulate. I  
22 would like to know what it means.

23 MR. LUNCEFORD: If I could provide a  
24 clarification maybe. We're talking about total  
25 particulate. I believe it's ASTM D 2276 and you look

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 in there for a particulate that has a similar specific  
2 gravity as the fuel that doesn't settle to the bottom.

3 The test there is a toluene test where you  
4 are actually vacuuming through a filter cloth so you  
5 look in what remains on the filter cloth. From our  
6 perspective that has more to do with the active  
7 function of the diesel, not something that would  
8 settle to the bottom of the tank like water or heavy  
9 sediment that would contribute to corrosion on the  
10 bottom of the tanks.

11 DR. BONACA: But this particulate could  
12 hurt the diesel.

13 MR. LUNCEFORD: Agreed, but we consider  
14 that to be part of the active function of the diesel.  
15 We were concerned with remaining the integrity of the  
16 fuel system components, especially the storage tanks  
17 where corrosion would tend to occur on the bottom.

18 DR. BONACA: Okay. If I have an expensive  
19 diesel engine car, I would make sure there are no  
20 particulates there either. I understand now. This  
21 provides an answer to my question.

22 MR. SIEBER: You might even get a fuel  
23 filter.

24 MR. LEITCH: While we're right on that  
25 point, I had another slightly different question about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fuel oil. It seems as though the fuel oil sampling  
2 program for the diesel-driven fire pump, not the  
3 emergency vehicle but the diesel-driven fire pump, is  
4 not the same as the sampling procedure or the testing  
5 procedure for the emergency diesels. Why is that? It  
6 wasn't clear to me whether we were going to make that  
7 testing procedure the same as for the emergency diesel  
8 fuel oil supply.

9 MR. MACFARLANE: You're correct in that  
10 the way we monitored the fuel oil tanks for the fire  
11 pumps was quite a bit less -- you know, it's not under  
12 tech spec type surveillance. That was a weakness we  
13 identified during our review so changes to the fuel  
14 oil monitoring program are being implemented as a  
15 result of renewal to remedy that situation.

16 The actual source of the fuel oil that's  
17 used in that tank, though, comes from the same source.  
18 The way we actually bring fuel oil on site is we take  
19 our old aux boiler fuel tank and we off-load the  
20 tanker truck into that tank and then sample there so  
21 we verify the quality of our fuel oil before it ever  
22 enters into the actual storage tanks for the diesels.

23 The same thing for the fire pump diesel.  
24 Some of the things we're doing in that program to  
25 address the fire pump diesel storage tank, one of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 items we added was a periodic draining and sampling of  
2 the bottom of the tank that didn't currently exist.  
3 During the AMP/AMR inspections from the region some  
4 questions were asked about that tank and we actually  
5 did some things.

6 We went out and did some UT on the bottom  
7 of the tank just to confirm that there hasn't been any  
8 adverse corrosion going on in that tank and that was  
9 done in response to an inspector's questions. We did  
10 recognize that was a weakness in the program. That's  
11 why in the application we stated that we would have to  
12 enhance that part of the program because it wasn't to  
13 the level we felt we needed.

14 MR. LEITCH: Okay. Thanks.

15 DR. BONACA: I had a question again on the  
16 issue of buried piping in tanks. There you are really  
17 -- first of all, you do have a lot of stainless steel  
18 and cooper alloy material resistant to corrosion. You  
19 are essentially having an opportunistic problem to  
20 inspect whenever you discover this piping which the  
21 standard has been used. I mean, everybody is using  
22 this so that's what GALL recommends.

23 Then the operating experience says that  
24 you experience three underground leaks over the past  
25 four years of in-scope and out-of-scope systems and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that you were successfully identifying the problem  
2 before system loss of function. I was kind of taken  
3 aback by three and four years seems to be a pretty  
4 significant number. Are you concerned about this  
5 frequency? Is it expected? Is it normal?

6 MR. MACFARLANE: What we see is the coding  
7 system on these carbon steel pipe has held up well and  
8 remained intact. What happens is you can get a stray  
9 rock or something in the back fill when this stuff was  
10 installed and it will nick that coating and we're  
11 seeing localized type attack that will manifest itself  
12 into a leak.

13 What we're trying to get across, I guess,  
14 with that operating experience was what happens is  
15 we'll see that leak and that leak becomes evident and  
16 we are able to detect those way before there is any  
17 significant potential for the loss of the line. They  
18 are very random and occur in different locations.  
19 There is really --

20 DR. BONACA: But if it was from original  
21 list, wouldn't it have manifested itself before? This  
22 plant has been around for 25 years.

23 MR. MACFARLANE: What you're saying is for  
24 an exposed surface of carbon steel how long will it  
25 take for that to actually corrode through from the

1 outside. Of course, then you also have corrosion  
2 issues on the inside as well going on with the service  
3 water itself. Our cast iron stuff has held up  
4 extremely well. We have no issues really with the  
5 cast iron but the carbon steel we do have cathodic  
6 protection system on it that we don't credit.

7 It is in use and does protect the piping  
8 in the majority of locations. There are a few  
9 locations that the cathodic protection system is not  
10 effective and that's why it's not credited in renewal  
11 space because there is some problem areas mainly  
12 around the structures because the structures act as a  
13 big sink for the current so we didn't feel we could  
14 use that as a viable renewal program. The failures  
15 we've seen have been mainly on nonsafety sections but  
16 we have had a little bit on some of the safety-related  
17 piping but nothing that would alarm us to my  
18 understanding.

19 DR. BONACA: Does the system have common  
20 experience at other sites? I would like to know.

21 MR. MACFARLANE: To my knowledge it is.  
22 It's pretty common.

23 DR. BONACA: I mean, I emphasize again  
24 that this is the approach that GALL recommends, too,  
25 for inspections but I guess we have to keep an eye on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it as we get into license renewal and plants get older  
2 we'll see if, in fact, what we're doing right now is  
3 still adequate.

4 MR. SIEBER: It's been a problem at some  
5 plants. I mean, a severe problem. It's not something  
6 that should be ignored.

7 MR. LEITCH: But I guess what I hear you  
8 describing it's not a couple of failures as a result  
9 of a general attack, but rather failures as a result  
10 of a specific damage site.

11 MR. MACFARLANE: That's correct. We have  
12 had a couple of things that are outside the power  
13 block area and on safety lines where you've got a  
14 crushing type of failure where a heavy load ran over  
15 top of it but we've never had that on the safety  
16 systems. Those are all protected.

17 We've had fire protection out in -- we  
18 have some old warehouses that are out far from the  
19 site from old construction days where something is run  
20 over and crushed that kind of thing and that's not  
21 aging at all. That's really related to the depth that  
22 was buried at the time it was installed.

23 MR. FRIDRICHSEN: From here I'll  
24 transition into commitment tracking to talk a little  
25 bit about our process for doing this. Naturally,

1 we've made commitments through both the renewal  
2 application process and the RAI and audit inspection  
3 processes. We track all those with an on-site  
4 commitment tracking system, a database, software that  
5 enters the commitment, assigns it a number, and then  
6 a responsible manager is assigned to follow up and  
7 implement that commitment by the required date.

8 The region, Region II, will be coming very  
9 early in March in 2005 to do an inspection on our  
10 commitment implementation process. After this process  
11 we'll get started loading those into the commitment  
12 tracking database so that will be ready for the region  
13 when they come down to see how we are getting all  
14 those implemented.

15 To this point we have made approximately  
16 130 commitments by our tracking. What this is  
17 intended to illustrate is kind of the process. There  
18 are a lot of arrowheads on this thing but it's trying  
19 to show the variety of different things that are going  
20 on.

21 Through the applications and the letters  
22 we make our commitments and we have provided the staff  
23 an independent list that we call the future actions  
24 list. This is a subset of the commitments that  
25 reflect those activities that have to be completed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 prior to the period of extended operation.

2 In addition to that, or as a greater set  
3 of those future actions, we have the overall  
4 commitments. Once we receive the safety evaluation --  
5 let me back up. Let me say it differently. We will  
6 begin loading commitments based on what is in the  
7 draft safety evaluation. Our normal process would be  
8 after the safety evaluation before it's issued to  
9 enter the commitments.

10 For license renewal we're going to do that  
11 ahead of time. We'll load those commitments out of  
12 what's in the SER into the commitment tracking system  
13 and that will instigate the actions for the  
14 responsible managers on-site to make their procedure  
15 changes, program changes, budget changes, etc., to  
16 implement the commitment.

17 Independent of the commitment tracking  
18 system is our internal action tracking, action item  
19 tracking, and that is a program which at the  
20 discretion of the responsible manager he can implement  
21 an AI whereby he'll assign someone in his organization  
22 the responsibility to do the implementation.

23 That process is independent of the  
24 commitment tracking. If we are asked to status where  
25 we stand on our commitment tracking, it won't be on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the basis of what action item tracking has recorded.  
2 It's on what's out of the commitment tracking system  
3 process.

4 The future actions list, as I said, is  
5 really a subset of all the commitments and we've  
6 provided that to staff and they will follow up on that  
7 but there are other commitments and program revisions  
8 that may be necessary to complete a GALL program.  
9 Those are internal to the system already. We will be  
10 getting started getting those loaded and getting ready  
11 for Region II so they can come down prior to their  
12 inspection and have everything ready for them to see  
13 that we've got them all included.

14 MR. LEITCH: You have then a complete list  
15 of commitments?

16 MR. FRIDRICHSEN: That's true, yes.

17 MR. LEITCH: I guess I saw something that  
18 raised a question in my mind concerning whether  
19 something like this would be a commitment or not.  
20 There's a table, I think, where we're talking about  
21 TLAA's regarding fatigue. It's page 4.3-4, note 4.  
22 It's talking about fatigue on a certain piping  
23 section.

24 I forget exactly what it is but basically  
25 the answer is not to worry because that number of

1 cycles is based upon a load following plant and Farley  
2 doesn't follow load so it's a base-load plant  
3 basically so that cycling is not nearly approached.  
4 I'm wondering how do we know that, say, five years  
5 from now Farley does go into a cycling mode. Would  
6 there be something that would flag that and say,  
7 "Whoa, we've got to go back and relook at the number  
8 of cycles."

9 MR. MACFARLANE: The Fatigue Monitoring  
10 Program itself is set up to track all the significant  
11 fatigue cycles so if you were to change how you  
12 operated, you would have to go back in and look at the  
13 impact of the plant and then that would have to pick  
14 up that impact. The change process involved in doing  
15 something like that would pick that up so that's more  
16 in terms of process than terms of commitment.

17 The commitment itself is really the  
18 Fatigue Monitoring Program which addresses a set  
19 number of cycles. Also talks about our commitment to  
20 do a phone line monitoring. Those are commitments.  
21 Just as a little clarification to what was said, the  
22 commitment list is comprehensive of things we  
23 currently are doing but we've made a commitment into  
24 the application as well as things we will do in the  
25 future.

1           The future action list is really those  
2 things that still have to be done in the future. That  
3 is the difference between them. The commitment is the  
4 whole list. The future action list is really those  
5 things that are not yet complete which end up being  
6 like, you know, the Reactor Vessels Internals Program  
7 where we are going to submit to you two years prior to  
8 the period of operation. That's a future action.

9           So just to help clarify the distinction  
10 between the two nomenclatures, the staff a lot of  
11 times will call that same thing a commitment so there  
12 is a little bit of a terminology issue but just so  
13 you're aware that when we say commitment, it's has a  
14 little bit different meaning than when the staff says  
15 it. They are really talking about the future action  
16 list items.

17           MR. LEITCH: So there is no commitment  
18 then as such that says Farley will not load follow.  
19 But in the Fatigue Monitoring Program if there was a  
20 change in the operation, you would pick that up in  
21 your routine review of that program?

22           MR. MACFARLANE: Correct, because we've  
23 taken the hardware out to do the load following.

24           MR. LEITCH: Yeah, I know, but I'm just  
25 trying to understand if sometime in the future you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 decided to load follow.

2 MR. MACFARLANE: Right. The change  
3 process itself. Just like anytime if we do an upright  
4 or any kind of change, you go through what are all  
5 your impacts and that would be part of that process.

6 MR. LEITCH: Okay. Not part of it but  
7 you're calling it commitment here.

8 MR. MACFARLANE: No, it's more looking at  
9 did it introduce any new fatigue cycles or fatigue  
10 usages and that would start feeding into the  
11 downstream calculations potentially impacted. You  
12 would have monitoring potentially impacted so the  
13 change process itself would have to look into all  
14 those things.

15 MR. LEITCH: Okay. thank you.

16 MR. SIEBER: Actually, load following  
17 doesn't introduce very many very deep transients that  
18 would cause fatigues, start-ups and shutdowns that do  
19 that, cool-downs. That's where the big cycles comes  
20 from.

21 DR. BONACA: Right.

22 DR. SHACK: You can have lots of little  
23 ones or a few big ones.

24 MR. FRIDRICHSEN: Industry issues. This  
25 slide is just to discuss some of the -- we've already

1 discussed the bottom-mounted instrumentation  
2 inspection results. We've done those visuals.

3 DR. BONACA: How easy to inspect those  
4 bottom head of the reactors?

5 MR. FRIDRICHSEN: Well, it's --

6 DR. BONACA: Is it accessible?

7 MR. FRIDRICHSEN: It's accessible.  
8 There's insulation that needs to be moved and  
9 scaffolding to be constructed but it can be done.  
10 Just recently I received a photo package that showed  
11 all the inspections they had just completed on Unit 1  
12 this fall.

13 DR. BONACA: Unit 1 has new thimbles?

14 MR. FRIDRICHSEN: Yes, but the thimble is  
15 actually a tube within a tube. You have the conduit  
16 piping that the thimble passes within and then the  
17 detector passes within the thimble.

18 DR. BONACA: That's what was replaced.

19 MR. FRIDRICHSEN: The thimbles were  
20 replaced.

21 DR. BONACA: Okay.

22 MR. FRIDRICHSEN: The piping is still  
23 original. The VC Summer inspections in accordance  
24 with the MRP guidance, we've done those inspections  
25 also and we've seen no degradation in those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 instances..

2 DR. BONACA: VC Summer inspections, I  
3 mean, those are inspections that were mandated because  
4 of the cracks identified in the nozzle of VC Summer?

5 MR. FRIDRICHSEN: Yes, sir.

6 DR. BONACA: Did you have to -- I thought  
7 that because of the insides of VC Summer your in-  
8 service inspection when you do volumetric would be  
9 somewhat affected by that issue. Have you changed  
10 your inspection process or procedure?

11 MR. LUNCEFORD: For those belt welds there  
12 was an MRP letter issued in 2003 which recommended  
13 that the bare metal visual examination be performed on  
14 all these welds. Farley has done most of those visual  
15 examinations with no indication of any cracking. No  
16 boric acid residue. None of those indications. When  
17 you are referring to the volumetric examinations, you  
18 are speaking of, I believe, Appendix 8, the  
19 performance demonstrated volumetrics. Is that  
20 correct?

21 DR. BONACA: No, I was referring to the  
22 fact that when they found the crack and leaking they  
23 went back to older nozzles and they perform at the  
24 current to identify superficial cracks and then when  
25 they found those they went in and they did volumetric.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Then they identified where were these cracks. I was  
2 wondering if that was part of these inspections.

3 MR. LUNCEFORD: To my knowledge, Farley  
4 has not done anything like that. There's the review  
5 of the data which didn't show any weld repair issues  
6 like VC Summer had on the weld. All of the  
7 examinations to date have not shown any issues and the  
8 visuals obviously came back good as well. Beginning  
9 with the next Unit 1 outage, Farley will be required  
10 to do performance demonstrated volumetric exams  
11 according to the new AME criteria.

12 DR. SHACK: When you do the performance  
13 demonstration for these welds, what's your performance  
14 demonstration going to be on? It's not going to be on  
15 the PWSCC crack presumably. You don't have any.

16 MR. LUNCEFORD: I'm not sure I'm going to  
17 be able to answer that question. They are still  
18 working on insuring that they get qualified  
19 examinations. We're working with Westinghouse and  
20 with Framatome to some extent to ensure that we are  
21 going to meet all of those criteria. That is still in  
22 process at this time.

23 DR. SHACK: The other thing, on that MRP  
24 exam there was some language that said you had to do  
25 a bear metal visual within two cycles. Are you then

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 committed to do a bare metal visual some time in the  
2 future on some periodic basis?

3 MR. LUNCEFORD: As far as I understand,  
4 there is not a periodic requirement for that bare  
5 metal visual, although as we've just discussed, we'll  
6 begin doing qualified volumetrics at that time.

7 DR. SHACK: Also, you do a leak detection  
8 according to Section 11 requirements. Again, what is  
9 the frequency of that leak inspection?

10 MR. LUNCEFORD: If you are referring to  
11 the VT-2 exam that is performed, that's a normal  
12 pressure test that is performed at the end of every  
13 refueling outage so once every 18 months.

14 MR. MACFARLANE: Just as an add, what they  
15 do now is when we shut down we have what we call the  
16 sandbox covers that go over the reactor vessel nozzle  
17 areas which is the area where VC Summer had their  
18 crack. When we pulled those off we go in and we do a  
19 visual inspection of that area looking for any change,  
20 particularly indications of boric acid leakage and  
21 that's done every outage.

22 DR. SHACK: What is your insulation in  
23 that area, mirror?

24 MR. MACFARLANE: All our RCS piping and  
25 vessel and stuff is reflective metal insulation, RMI.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. LUNCEFORD: And I'd also add while  
2 we're on the topic, we had performed the bare metal  
3 visual examinations on all the pressurizer 82, 182  
4 welds as well for both units 1 and 2 now with no  
5 unacceptable results.

6 MR. FRIDRICHSEN: Well, that --

7 DR. BONACA: I have one last question.

8 MR. FRIDRICHSEN: Okay.

9 DR. BONACA: There is a hot issue on the  
10 table and I'm sure there is a sump recirculation  
11 issue. Any insights on that?

12 MR. FRIDRICHSEN: We're prepared for that.

13 MR. MACFARLANE: I'd say we are prepared  
14 for that. In terms of the containment sump for  
15 Farley, just to give you a little brief background  
16 into our sump design, the Farley containment sumps are  
17 located on the bottom floor and it is essentially a  
18 screen box structure over top an intake pipe. It's  
19 not a recess sump like some plants will have.

20 They stood outside the bio wall and,  
21 therefore, the main loop piping and vessel are remote  
22 from where these sumps are located. The Farley  
23 containment design ever since original construction  
24 essentially have minimized any type of fibrous  
25 insulation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The initial thought was that we had none  
2           but we have done a little research and found a couple  
3           locations. Primarily on all the reactor vessel and  
4           primary piping is reflective metal insulation, same  
5           thing with main steam and feed water.

6           MR. SIEBER: Steam generators?

7           MR. MACFARLANE: Steam generators. When  
8           we did steam generator replacement we actually looked  
9           at possibly using the thermal lag type insulation like  
10          -- I forget the brand names, Newcon and those types of  
11          insulation that are fibrous with a metal jacket.

12          We actually decided in that process that  
13          we had gotten a lot of benefit at minimizing any  
14          fibrous insulation in our containment so we made a  
15          conscious decision to go back with reflective metal  
16          insulation, even though we thought we got a little  
17          better performance out of the other types of  
18          insulation from a thermal insulation factor.

19          Right now we are doing this head  
20          replacement. When we did containment inspections as  
21          the result of some of the bulletins that came out on  
22          this sump issue, they found that around some of the  
23          penetrations where like the CRDMs penetrate the  
24          insulation package, there was this insulation material  
25          called Tempmat which is a fibrous -- it's like a cloth

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 but it's fibrous.

2 In going back with the new insulation  
3 package on the new head it will not have that so we're  
4 aggressively trying to eliminate those type of things  
5 where we can. The only other location, there's a  
6 little bit on the bottom head. However, that is  
7 limited by the reactor cavity which really does not  
8 come in contact with the containment sump. That is  
9 actually at an even lower elevation and it's enclosed  
10 to not flood during a recir event.

11 The only other place we have it is on  
12 sensing lines on the steam generators and they are  
13 located up above all the main loops. They are  
14 actually not in -- the only impingement zone they're  
15 in is their own. If that sensing line itself were to  
16 fail that you might get some damage there.

17 Overall we think we have pretty robust  
18 design features in terms of minimizing some of these  
19 aspects in terms of insulation. We've done coatings  
20 inspections. Overall our coatings are in excellent  
21 shape. We've actually had some comments from  
22 inspectors when they walked in there.

23 We have aggressively been looking at that  
24 and some of the way you are going to quantify this  
25 stuff is still up in the air in terms of how to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 evaluate your sump so we are still waiting on  
2 resolution. There is a proposed NEI process and I  
3 know ACRS looked at that here recently and had some  
4 comments on it.

5 What we're doing is what we can today. We  
6 suspect if the conservatisms that are currently in the  
7 methodologies continue to exist that we will probably  
8 have to change out our sump screens but we have not  
9 reached that conclusion yet but we do believe that is  
10 probably where we will end up.

11 DR. BONACA: Okay.

12 DR. RANSOM: I have one question on the  
13 flow-accelerated corrosion program. I know it was  
14 discussed there and they mentioned extending the  
15 auxiliary feedwater turbine exhaust line or extending  
16 the program to that but there was no detail on how  
17 these inspections are performed or how often they're  
18 performed or how thoroughly they're performed.

19 What I'm thinking is that flow-accelerated  
20 corrosion is often times a very localized effect  
21 having to do with the scrubbing and the piping or  
22 steam droplet impingement or cavitation response. The  
23 question would be how do you find that sort of thing?

24 MR. MACFARLANE: We use a combination of  
25 methods. We do all our FAC program in-house. It's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 all done at Southern Nuclear.

2 DR. RANSOM: How often is that done?

3 MR. MACFARLANE: We do inspections every  
4 outage and, of course, what we look at is -- the  
5 process they go through to determine what we look at  
6 is we use Checkworks which is the industry program for  
7 modeling FAC. We also use -- that's about 40 or 50  
8 percent of the effort but then other parts we've got  
9 is really operating experienced based and industry  
10 based where they go in and you have to refine what  
11 you're going to go look at.

12 The model is not perfect. We look at  
13 those kinds of things every time an issue comes up.  
14 There was an issue on I think backside FAC on some  
15 welds and we did inspections related to that. The  
16 Japanese event that just happened recently we went in  
17 and looked at our programs to see if we had any  
18 equivalent areas and whether or not we had inspected  
19 it. Essentially we don't have a similar system to  
20 theirs in that they have de-aerated feed tank that is  
21 part of that issue.

22 However, we did find what was our closest  
23 equivalent to that which we had inspected in the past  
24 and we went ahead and did enhanced inspections  
25 subsequent to the Japanese event just to double check

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it. We are proactively staying in this. They  
2 participate in the industry, the EPRI FAC Working  
3 Group and those types of things.

4 DR. SHACK: It says you are replacing  
5 piping with the chrome-moly stuff. What fraction of  
6 the piping is now chrome-moly?

7 MR. MACFARLANE: Essentially, the areas  
8 that have had to have FAC replacement so far have been  
9 limited to the turbine building. We just recently had  
10 some go into the aux building. That was a recent  
11 occurrence. Essentially your worse locations tend to  
12 be out in your MSR areas and then your cross-under  
13 piping under your turbine and the condenser and those  
14 kinds of things.

15 Then it progressively starts to move out.  
16 We do inspections throughout just to make sure we  
17 properly predicting what is going on. That is kind of  
18 what has been going on. We don't always replace  
19 chrome-moly. It's going to depend on what it is and  
20 then how expensive it is and those kinds of things and  
21 what kind of wear rates we're seeing. I can't answer  
22 your question on how much is chrome-moly. I don't  
23 have that familiarity with it.

24 DR. SHACK: Just while -- you replaced  
25 some nozzles with Alloy 508 and, again, in the SER it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 says when you replace with the resistant materials you  
2 keep the piping in the program, although presumably  
3 you take credit for the lower wear rates. When you  
4 replace the nozzles with 508 will they stay in the  
5 program?

6 MR. MACFARLANE: To what nozzles are you  
7 referring?

8 DR. SHACK: Steam nozzles.

9 MR. MACFARLANE: Oh, in the steam  
10 generator itself? In terms of the replacement steam  
11 generator the main steam out of the generator has an  
12 extremely low moisture content so the main steamlines  
13 themselves are not actually FAC-susceptible due to the  
14 actual environment. That is talked about in the LRA  
15 and was evaluated by the staff.

16 It's really when you get into the drains  
17 and downstream is where you start seeing the FAC. So,  
18 to answer your question, that is really is not  
19 considered an aging effect for that. The moisture  
20 carryover when we did the testing post-SGR replacement  
21 was in the -- let me see if I get this right -- .04  
22 percent or something like that. It's extremely low,  
23 the actual moisture carryover.

24 MR. SIEBER: I think Vic's question  
25 related to what resolution do you get out of one of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 these inspections. The way I've seen them done in a  
2 lot of plants for the inspection people to establish  
3 a grid over an area the Checkworks tells them to look  
4 at in the spacing of the lines on that grid determine  
5 what the resolution is. Maybe you can tell me what  
6 your spacing is. Is it 1 inch by 1 inch or that kind  
7 of range?

8 MR. MACFARLANE: I don't actually know  
9 what the spacing is to be honest with you. I've seen  
10 them actually drawn on the pipes out there. They seem  
11 like reasonable grids. The actual selection of what  
12 gets inspected is actually not dictated by Checkworks.  
13 It's dictated by the FAC engineer who determines where  
14 they are going to go inspect.

15 He's got Checkworks and he's also looking  
16 at other industry inputs in terms of things that have  
17 been seen. The grids themselves, you know, they're  
18 covering -- you know, they do say they are looking at  
19 a weld location or a component location. They do  
20 quite a bit upstream and downstream to make sure they  
21 get a good look at what's going on in the vicinity  
22 because FAC is generated by a flow disturbance in a  
23 lot of ways.

24 MR. SIEBER: It's turbulence a lot of  
25 times that causes an eating out and that disturbance

1 in the wall reduction usually varies depending on the  
2 flow or the fluid conditions. If you have a plant  
3 that starts up and shuts down or cycles load or  
4 something like that, that can be a wider area than the  
5 plant that's running 100 percent power all the time  
6 because then the flow disturbance issues are fixed in  
7 one place.

8 Basically that's how this is done in one  
9 inch. Even though we won't hold you exactly to that  
10 number, this is typically what everybody uses so you  
11 have a series of data points that you can map out and  
12 determine where the wall thickness is reduced and  
13 where you have to do something.

14 DR. BONACA: Right.

15 MR. LEITCH: I had another question about  
16 a fact while we are right in that area. You mentioned  
17 in the commitments that the aux feed water turbine  
18 exhaust piping will be included in the flow-  
19 accelerated corrosion program prior to the period of  
20 extended operation.

21 Does that mean that is not going to be  
22 looked at until right prior to the period of extended  
23 operation? That sounds a little lax. I don't know if  
24 that's an area that is not particularly subject to  
25 flow-accelerated corrosion. Why wouldn't you be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 looking at it sooner I guess is my question.

2 MR. MACFARLANE: The reality of what we're  
3 doing actually is going into the program. As we speak  
4 I'm not sure that the program document has been  
5 totally revised yet but it has been communicated to  
6 the FAC engineer and he is in the current revision of  
7 this FAC program, which I can't remember has come out  
8 yet or not, is going to include that item.

9 In terms of susceptibility it is a low  
10 susceptibility area. It's just one that we felt we  
11 would be better off putting in is really the  
12 determination we made. Of course, we're not the FAC  
13 experts, per se, but he agreed with this in terms of  
14 adding it into the scope. That would be a reasonable  
15 and conservative approach.

16 It will be in the program. In general our  
17 philosophy for most of these programs is that they  
18 will be implemented well in advance of the period of  
19 operation. It's just the language that was used in  
20 terms of making the commitment.

21 MR. LEITCH: Okay. I understand. Thank  
22 you.

23 DR. BONACA: Why don't we take a -- this,  
24 I think, will close the presentation.

25 MR. FRIDRICHSEN: Just some closing

1 remarks. We think that the staff's process was very  
2 thorough, very rigorous. We think they gave us quite  
3 a good scrubbing. We think that the new process, the  
4 new consistent GALL process added a lot of depth and  
5 clarity, a lot of better understanding of our programs  
6 by the staff. That had value, I think, to both staff  
7 and us. Other than that we are grateful for the  
8 subcommittee's time and your attention and willing to  
9 listen to us. That's all I have.

10 DR. BONACA: Thank you. With that we'll  
11 take a break for 15 minutes. Do you have a question?

12 DR. SHACK: No, just cheering.

13 DR. BONACA: Okay. Get back at 3:35.

14 (Whereupon, at 3:19 p.m. off the record  
15 until 3:36 p.m.)

16 DR. BONACA: Okay. Let's resume the  
17 meeting. Before we start the presentation, just a  
18 brief announcement. The red line on the Metro Rail is  
19 shut down for tonight because there has been an  
20 accident. Apparently there has been a crash on the  
21 Red Line. Just to let you know in case you use it.  
22 I use it.

23 MR. SIEBER: We could just keep on going.

24 DR. BONACA: It's not easy but we'll find  
25 some way.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. SHACK: Hitchhike.

2 DR. BONACA: Hitchhike, yes. We'll try  
3 not to delay too much the meeting. We have now the  
4 presentation of the NRC so we'll proceed with that.

5 MS. LIU: Thank you for that information,  
6 Dr. Bonaca. Dr. Bonaca and distinguished members of  
7 the subcommittee, good afternoon. My name is Tilda  
8 Liu and I'm the

9 DR. SHACK: What about the rest of us, but  
10 that's okay.

11 MS. LIU: All of you are distinguished.  
12 I am the project manager for the Farley License  
13 Renewal Application with the Office of Nuclear Reactor  
14 Regulation. This afternoon's agenda is as follows.  
15 I'll go over overview and highlights and we'll go over  
16 the review process, SER Section 2 on scoping and  
17 screening. And Caudle Julian will be talking about  
18 license renewal inspections. We'll talk about SER  
19 Section 3, AMPs and AMRs. Finally, Section 4 on  
20 TLAAAs. We'll sum it up with a conclusion.

21 This slide provides an overview of the  
22 Farley application. Farley is the very first renewal  
23 application that used the newly revised NEI format.  
24 That includes Table 1, Table 2, and standard notes for  
25 the tables.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           This is also the first pilot renewal to  
2           fully implement the consistency with GALL audits for  
3           AMPs as well as AMRs otherwise known as the new review  
4           process. Before I go further into the presentation,  
5           I would like to point out the staff's conclusion which  
6           is Farley has met the requirements of 10 C.F.R. 54 in  
7           terms of scoping and screening AMPs, AMRs, and TLAAAs.

8           Highlights of the review. The draft SER  
9           was issued on October 15, 2004. There was no open or  
10          confirmatory item associated with the review. The  
11          staff noted that efficiencies were gained from the new  
12          review process. This is evidenced by a reduction in  
13          the number of REIs as well as on-site audits provided  
14          very effective interaction between the applicant and  
15          the staff which resulted in minimum number of formal  
16          correspondence.

17          I would like to provide your perspective  
18          on REI related statistics. There were a total of 163  
19          REIs issued by 17 letters. Particularly, there were  
20          64 on scoping and screening, 15 on AMPs, 70 on AMRs,  
21          and 16 on TLAAAs. I would like to point out that the  
22          70 questions from AMRs only three of which were from  
23          the audit team.

24          I would like to give you another  
25          perspective on the number of REIs from the other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 applications. There were 280 for Summer, Robinson  
2 there were 360, and Ginna there were 224. These are  
3 all very similar Westinghouse designs to the Farley  
4 plant.

5 I also would like to point out the efforts  
6 involved for the staff in this new process. We held  
7 two meetings to discuss REIs and 56 telephone  
8 conferences to discuss these REIs. Because these REIs  
9 came in batches from the staff and we discussed them  
10 as we went along, we might have had two big phone  
11 calls or two big meetings. In addition to the REI  
12 responses provided by the applicant, the applicant  
13 also provided supplemental information to the  
14 application as well.

15 Continue on the highlights of the review.  
16 We had three license conditions. The first is very  
17 standard that you see in all the other applications.  
18 It's the FSAR update to be followed for the issuance  
19 of renewal license and that the commitments will be  
20 completed in accordance with the schedule.

21 The third license condition, I understand  
22 was added to Dresden/Quad as well, relates to the  
23 Reactor Vessel Surveillance Program. This third  
24 license condition requires that all capsules in the  
25 reactor vessel that are removed and tested must meet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the test procedures and requirements of ASTM standards  
2 to the extent practicable and that any changes  
3 associated with the capsule withdrawal schedule and  
4 capsule storage requirements must be reviewed and  
5 approved by the NRC staff.

6 More on highlights of the review.  
7 Additional components from eight systems, auxiliary  
8 systems, were brought into scope as a result of the  
9 applicant's revised methodology to 10 CRF 54.4(a)(2)  
10 as the applicant mentioned earlier. Of the eight  
11 systems three resulted Table 2 in Section 3 revised  
12 for AMR line items.

13 There was one Aging Management Program  
14 that was added after the application submittal. That  
15 was a plant specific AMP. It is Periodic Surveillance  
16 and Preventive Maintenance Activities Program.

17 MR. LEITCH: Regarding systems that were  
18 added to the scope -- brought into scope, I guess fire  
19 protection is an (a)(3) system.

20 MS. LIU: Correct.

21 MR. LEITCH: Were there any major  
22 additions to the fire protection program? I guess it  
23 just seems to me that a number of applicants in the  
24 past have had problems and it's been kind of a  
25 contentious area about whether certain things are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 included or not included with respect to fire  
2 protection. Do you have that here?

3 MS. LIU: Fire protection was not one of  
4 the systems that was brought in scope.

5 MR. LEITCH: Okay. So I guess you feel  
6 quite confident about the scoping of the fire  
7 protection program.

8 MS. LIU: Yes. We went through a lot of  
9 details with the applicant and a lot of effort between  
10 the applicant and staff resolved the differences.

11 Moving onto the review process, this slide  
12 provides a listing of the activities associated with  
13 the staff's review process which includes scoping and  
14 screening methodology audit. As you know, there's  
15 consistency with GALL audits, table-top which is the  
16 in-house safety review, and regional inspections which  
17 Caudle will be talking about earlier. This next slide  
18 shows dates associated with the various inspections in  
19 August that I have just mentioned in the previous  
20 slide.

21 If I may provide you a conclusion  
22 statement first before I go further into discussion on  
23 Section 2 associated with the staff's review on  
24 scoping and screening. The staff concluded that the  
25 applicant's scoping methodology meets the requirements

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of Part 54 and that the applicant's scoping and  
2 screening results included all SSCs within the scope  
3 of the license renewal.

4 Section 2 on scoping and screening  
5 methodology. Staff review and on-site audit  
6 determined that the applicant's scoping and screening  
7 methodology meets the rule. As I mentioned already,  
8 staff identified SSCs that meet the Part 54 for (a) (2)  
9 criterion and additional components regarding the  
10 scope for eight systems from the auxiliary systems.

11 There was an RAI, as Dr. Leitch pointed  
12 out earlier, to do with (a) (2) and I'll be discussing  
13 that in the next slide. The initial methodology that  
14 was presented by the applicant was as follows. It  
15 uses the spaces approach and eliminate the 20-foot  
16 criterion and extended valid targets to include  
17 mechanical and structural -- I'm sorry, valid targets  
18 include mechanical and structural SSC. That was the  
19 revised scope. The original scope, like I said, was  
20 only a 20-foot radius and limited only to electrical  
21 targets. Upon this revision included all targets,  
22 electrical, mechanical, as well as structural. That's  
23 all I have for that.

24 DR. WALLIS: They replaced this 20 feet  
25 with some spacing?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. LIU: Spaces approach. Correct.

2 DR. WALLIS: What was the physical basis  
3 of that?

4 MS. LIU: I'd like to defer that to Greg  
5 Galletti. He will be giving more details about that  
6 one.

7 MR. GALLETTI: My name is Greg Galletti.  
8 I'm with the Plant Support Branch. We did the scoping  
9 and screening audit. With respect to the 20-foot  
10 criteria, once the applicant had decided to abandon  
11 that criteria in support of going to a spaces  
12 approach, the space as defined here would be a  
13 continuous room that you have solid walls that would  
14 isolate that room from another location. Or you could  
15 have, for instance, a long hallway. That entire  
16 hallway would be considered a contiguous space.

17 DR. KUO: And, Greg, at this time could  
18 you also say something about the question before on  
19 the REI 2.1-1?

20 MR. GALLETTI: Sure. This is with respect  
21 to Dr. Leitch's question regarding the air gas  
22 systems. Just as a brief history, as you know, this  
23 issue goes way back to the early hatch days where we  
24 were discussing the fluid-filled piping and the  
25 likelihood of a pipe falling or calling an interaction

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with a safety-related component.

2 As part of the resolution to those issues,  
3 we had put together the ISG. The ISG actually came as  
4 two independent letters. The first letter really  
5 addressed the fluid-filled portions of the system.  
6 The second letter then went on to address nonfluid-  
7 filled systems, air gas systems in particular.

8 In the second letter what we requested and  
9 required the applicants to do is to perform an  
10 evaluation, if you will, based on industry operating  
11 experience as well site specific operating experience  
12 to determine whether there could be the potential for  
13 air gas system interaction with those safety-related  
14 SSEs. In particular, what we were looking for is for  
15 them to discern "hypothetical failures" from true  
16 failures. Again, to be consistent with the rule and  
17 also to try to limit broadening the scope beyond what  
18 was reasonable for the regulation.

19 With that, what we found in this  
20 particular case is the application didn't have  
21 explicit information in there with regard to the  
22 evaluation of the air gas systems. Section 2.132, I  
23 believe, is the (a)(2) evaluation. It goes through  
24 the various criteria but it was, again, not explicit  
25 with their gas.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   During the audit we went into that level  
2 of discussion to understand what implementing guidance  
3 they had to review this sort of thing and through  
4 interaction with their staff we came to understand  
5 that, in fact, they did perform both a site specific  
6 evaluation looking at corrective action, incident  
7 reports, things of that nature, things that happened  
8 at their particular plant which may lead to  
9 understanding for the potential of air gas  
10 interactions.

11                   As a result of that conversation, we felt  
12 it was appropriate to ask the RAI simply because we  
13 wanted to get that better documented and be able to  
14 respond to that in the safety evaluation. That's  
15 really the genesis of why that question came up in  
16 this particular case.

17                   MR. LEITCH: I guess I was just puzzled by  
18 the approach which seems to be to say based on  
19 operating experience this is a noncredible scenario.  
20 That is, it's noncredible that the line would fail.

21                   MR. GALLETTI: Well, again --

22                   MR. LEITCH: Well, I mean, I can  
23 understand an approach that perhaps said given a  
24 failure we don't expect to see any damage to a safety  
25 related system but it sounds like from the RAI and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 response to the RAI that basically what the argument  
2 is is that a failure is not credible. Not that damage  
3 from the failure is not credible but the failure is  
4 not credible.

5 MR. GALLETTI: Well, quite frankly, it  
6 would be both but, in this case over the course of  
7 years of review and discussion with NEI, we have not  
8 identified either industry or, in this case, site  
9 specific operating experience that shows that you  
10 would have those sorts of failures of these air gas  
11 systems which would, in fact, compromise your safety-  
12 related components. I think that is a fair factual  
13 statement as far as what we have been able to  
14 determine through review of operating experience as a  
15 whole.

16 MR. LEITCH: Well, I can think of cases  
17 where -- maybe this isn't -- maybe this doesn't fit  
18 the classification. I'm thinking of systems where an  
19 instrument airline in containment has failed causing  
20 the misoperation of an MSIV, for example. I guess  
21 it's not really -- the instrument airline is not  
22 safety related but the MSIV is. It's not an  
23 impingement kind of a problem. It's the failure that  
24 causes the --

25 MR. GALLETTI: Well, I think in most cases

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 where you have a true safety-related component that  
2 relies on a non-safety-related subsystem, if you will,  
3 to perform its function. In most cases those  
4 subsystems are designated as safety related for those  
5 particular plants so you are not going to have this  
6 (a)(2) interaction. In fact, you'll probably see  
7 those things brought in the scope for (a)(1) purposes.

8 MR. LEITCH: Yeah, I think that's right.  
9 I think the cases I was thinking of, as you correctly  
10 point out, would probably be (a)(1) situations. Yeah,  
11 okay. That's good. Thank you.

12 MR. GALLETTI: Sure.

13 MS. LIU: Okay. We're on slide No. 14.  
14 Section 2.2, plant-level scoping results. The staff  
15 identified SSEs that met the (a)(2) criteria and  
16 additional components requiring the scope for eight  
17 aux systems as I mentioned earlier.

18 For the scoping screening results related  
19 to mechanical systems, we looked at reactor vessel,  
20 reactor systems, ESF systems, aux systems, and steam  
21 power conversion systems. In addition to these, part  
22 of the staff review included a plant scope inspection  
23 conducted by the region. The inspection was conducted  
24 in May of this year.

25 Slide No. 15 continues on with the scoping

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 results. We looked at for the containment systems  
2 which includes PWR concrete containment, aux building,  
3 diesel generator building, turbine building, and other  
4 structures and supports. Finally, for electrical and  
5 INC systems there were 10 electrical and I&C commodity  
6 groups subject to AMR and the staff concluded that all  
7 were included.

8 The summary of scoping and screening, the  
9 staff has concluded that the applicant included all  
10 the SSEs within the scope of license renewal and that  
11 the applicant's scoping methodology meets the  
12 requirements of Part 54.

13 At this time I will turn over the  
14 presentation to Mr. Caudle Julian to brief you on the  
15 results of the license renewal inspections. Caudle  
16 was a team leader in these inspection efforts.

17 MR. JULIAN: Thank you, Tilda. My name is  
18 Caudle Julian from NRC Region II out of Atlanta.  
19 Myself and my inspection team have been doing all the  
20 inspections for Region II. We try to keep the same  
21 team together and have hopefully consistent results  
22 that way.

23 You've seen these slides before so we'll  
24 not spend time on 17. It's pretty self evident.  
25 We've talked about how the program goes before. Slide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 18 talks about the scoping and screening inspection  
2 and I'm sure you are well aware of the purposes of  
3 that inspection.

4 The scoping and screening results at  
5 Farley were very, very good. We had nearly no issues  
6 to talk about there at all. I think maybe the issue  
7 you mentioned about the inconsistency and the tank  
8 vents being in scope was one that came up and all we  
9 know for sure it's an inconsistency in the drawing.  
10 Some drawing showed it in scope and some didn't and  
11 they corrected that issue now.

12 The next inspection, which is two weeks  
13 long, the Aging Management Program inspection. Again,  
14 slide 19 speaks for itself and we have seen it before.  
15 At Farley, again, we had very few issues to talk  
16 about. We were doing this one in conjunction with  
17 this time a pilot inspection of the service water  
18 system.

19 That's another issue that the regions have  
20 been tasked with pursuing now and we are doing three  
21 of those in Region II and Farley was selected as one.  
22 The same people who would be on my team doing the  
23 license renewal inspection went a week or two before  
24 and looked hard at the service water system and its  
25 monitoring and performance and found it in good

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 condition.

2 During the Aging Management Programs we  
3 looked at existing programs that have been there for  
4 years and we thought that in general they are all  
5 functioning very well. The only problems we ran into  
6 there were some what I'm going to call anomalies in  
7 results of fire protection surveillances where there  
8 were some fire protection routine surveillances that  
9 over time had shifted in our methods of performance  
10 and so the criteria that was traditionally there from  
11 the day the plant was started up was not being fully  
12 met.

13 The licensee is looking into that matter  
14 and we are going to pursue that, Region II is, in the  
15 future inspection. We have our routine fire  
16 protection inspection coming up in the spring. But  
17 that was not an aging issue. That's just a routine  
18 day-by-day issue. As we discussed before, those we  
19 turn over to routine follow-up by the region.

20 MR. LEITCH: Caudle, I have a question  
21 about your methodology a little bit. In the  
22 inspection report, attachment 2, pages 17 and 18 list  
23 a list of systems that are in scope it says yes, or  
24 not in scope it says no. Some of your methodology  
25 looks at those not in-scope systems and confirm with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the applicant that they, indeed, did not have  
2 components that should be in scope.

3 Now, what I was wondering is how did that  
4 list -- let me ask the question this way. Were there  
5 other not-in-scope systems that were not on that list?  
6 In other words, that was the licensee's list of in  
7 scope and not in scope. Did you look at any other  
8 not-in-scope systems other than the ones that the  
9 licensee said were not in scope?

10 MR. JULIAN: No, we have not been doing  
11 that. On the scoping and screening inspections we  
12 typically have started with the licensee's conclusion  
13 that you've seen in his license renewal application  
14 and there is always some inclusion of marginal ones,  
15 I guess, that they consider to be in scope and  
16 concluded no and our purpose is to go down and talk  
17 with them and look at the system in more detail than  
18 you could from the application and agree with their  
19 conclusion.

20 MR. LEITCH: So you agree with their  
21 conclusions that those systems ought not be in scope  
22 but you didn't really test -- if I'm understanding you  
23 correctly, you didn't really test whether there might  
24 be other systems that were not in scope that should  
25 have been in scope.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. JULIAN: We have not been doing that  
2 in the past. There's probably a wide variety of  
3 things in the plant that you could do that with but  
4 most things become self-evident most of the systems  
5 that you look at. I mean, if you move over to the  
6 warehouses and so on, it's obviously not close.

7 Most of them are not close really. One I  
8 mentioned earlier that I think we challenged in other  
9 places is control rod drive cooling systems. That was  
10 mentioned, I think, earlier in the meeting and we have  
11 concluded that they are right. That system is not  
12 needed to make the reactor trip.

13 MR. LEITCH: Okay. I just wanted to  
14 understand the methodology.

15 MR. JULIAN: Yeah, that's it. Again,  
16 returning to Aging Management Program inspection with  
17 respect to new programs, the applicant had there for  
18 our review some proposed implementation plans and  
19 proposed procedures that they intend to use in the  
20 future and that gave us a good feel for what their  
21 future plans are like. Some people are that advanced  
22 and some people are not at this stage but we thought  
23 that Farley did a good job in that area.

24 We did lots of equipment walk-downs,  
25 visual observation of the equipment in the plant. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 concluded that the material condition is being  
2 maintained adequately at Farley. We had very few  
3 things we ran into that caused us any problem at all.

4 In the fire pump house we saw a few, one,  
5 two, three, rusty components, mainly pipe supports  
6 than actually structural beams and they come from  
7 water being continually flooded on the floor. That  
8 condition had already been identified by the applicant  
9 and they had already written a condition report on it  
10 and that's good if they are out ahead of us  
11 identifying things and write them up. We like that.

12 We had a question about some service water  
13 piping where it comes out of the service water intake  
14 structure that's in a concrete vault that has  
15 obviously been flooded in the past. Some of my  
16 inspectors raised the question about, "Gee, that big  
17 pipe looks rather rusty on the outside and it's been  
18 flooded and exposed to air again off and on over the  
19 years. Don't you worry about the pipe corroding  
20 through from the outside?"

21 I understand that the applicant wrote a CR  
22 on that and there's numerous other little conditions  
23 like pipe supports and things in that area that could  
24 be flooded that they've written up and intend to  
25 repair in due course.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   So our conclusion about the Farley plant  
2 as we saw it is that we saw nothing major in terms of  
3 material condition that presented any kind of a  
4 serious aging concern to us. We think Farley is in  
5 good shape and they are working hard to keep it that  
6 way.

7                   In fact, one of the inspectors on my team  
8 again turned out to be a previously assigned resident  
9 inspector at Farley several years ago, six or eight  
10 years ago, and his conclusion personally was that the  
11 plant looks better today than it did when he was there  
12 several years ago and that's always good for us to  
13 hear. That concludes what I have to say with respect  
14 to inspections.

15                  On the next slides we'll put up the  
16 performance indicators. That's already been  
17 mentioned, I think, by the Farley folks, Unit 1. The  
18 next slide is Unit 2. They are very much identical.  
19 Farley is all green with respect to the reactor  
20 oversight process. We've had no significant findings  
21 in the last few years that would even approach moving  
22 into the white or other area more significant so  
23 Farley is a good performer as far as we are concerned.

24                  MR. SIEBER: I take it, though, even if  
25 the performance was not as good as this, it would not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 factor into license renewal under the rule.

2 MR. JULIAN: Yes, that is correct but the  
3 reason we address this issue is because the committee  
4 seems interested in it. Every time the question is  
5 asked so we bring the information forward each time.

6 That concludes what I have to say. Tilda,  
7 I turn it back to you.

8 MS. LIU: All right. Thank you. Caudle.

9 DR. BONACA: I'll take just another second  
10 to make a correction to my previous announcement of  
11 the Red Line. I found additional information. The  
12 Red Line is closed between Dupont Circle and Van Ness  
13 but is open in other areas and they have a bus service  
14 going from one station to the other. The problem is  
15 only for those who have to go through that track of  
16 road.

17 MR. JULIAN: That's good news.

18 DR. BONACA: That is better than what was  
19 given to me before that I announced.

20 MS. LIU: Well, Dr. Bonaca, thank you for  
21 that wonderful news. I feel so much better now.

22 DR. BONACA: With that --

23 MR. MACFARLANE: Do you if it's in both  
24 directions?

25 DR. BONACA: It sounds as if both

1 directions are closed but they have a bus service.

2 MS. LIU: Thank you again, Caudle. Moving  
3 on to Section 3 of the SER. I would like to summarize  
4 first that, again, the staff found that the applicant  
5 met the 10 CFR Part 54 for AMPs and AMRs. In the SER  
6 Section 3.0.3 is where we discuss the AMPs.

7 DR. KUO: Please speak louder.

8 MS. LIU: Okay. Thank you. Sections 3.1  
9 through 3.6 is what you see in the application and  
10 that is how the staff presented in the same order in  
11 our SER as well. Can everyone hear me better now?

12 DR. KUO: Louder.

13 MS. LIU: Maybe it's the mike. Thank you,  
14 Ken. Moving on to GALL review and audit. Again, this  
15 is the first pilot that we fully utilized consistency  
16 with GALL audits for AMPs and AMRs. These audits were  
17 conducted on site as SNC headquarters in Birmingham,  
18 Alabama. The staff's review process is described in  
19 SER Section 3.0.2.

20 I want to give you another perspective on  
21 how we decided which ones were going to be GALL  
22 audited. The first is, of course, being consistent  
23 with GALL and that there should be no associated  
24 emerging issues or interim staff guidance on the  
25 development. In the case for Farley past precedents

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 was not used for the review by the audit team.

2 Continue on the review and audits. The  
3 audits consisted of NRC staff and contractors and a  
4 site specific audit plan was developed and used to  
5 conduct the AMP and AMR audits. The AMP audit was a  
6 week in length. The audit team evaluated the AMPs  
7 that are consistent with GALL including those with the  
8 exceptions and enhancements. Again, this is  
9 documented in staff's SER in Section 3.0.3.

10 The AMR audit was about a week and a half  
11 in length. The staff reviewed those AMR line items  
12 are consistent with GALL and for both AMP and AMR  
13 audits the staff performed extensive in-house review  
14 prior to going on site at the applicant's Birmingham's  
15 office.

16 DR. WALLIS: When you said they are  
17 consistent with GALL, does this mean they had a C+  
18 grade or do they get an A grade? How good are they?  
19 Are they barely consistent or do they go way beyond  
20 what is necessary?

21 MS. LIU: The applicant's claim is  
22 consistent.

23 DR. WALLIS: They are barely adequate  
24 then?

25 MS. LIU: I believe Dr. Ken Chang will

1 discuss that further later on.

2 DR. CHANG: What Tilda say is the  
3 applicant claim that these AMP are consistent with  
4 GALL. The other team's job is to go there to dig into  
5 the antenna documents, the basis documents, supporting  
6 references, calculations, etc., to verify what they  
7 say consistent with GALL is whether that is A+ or C-  
8 and we find most cases that GALL is B+.

9 DR. WALLIS: B+.

10 DR. CHANG: Above.

11 DR. WALLIS: Above B+.

12 DR. SHACK: On your previous one when you  
13 said that past precedents is not used for FMP review,  
14 that's strictly for this audit. I presume when you're  
15 writing the SER you do go back to past precedents but  
16 that is strictly for the audit?

17 MS. LIU: That is correct. In Farley's  
18 case because Farley was very kind we asked them to  
19 participate in the audit process, but the time frame  
20 was very short so Farley did not have the opportunity  
21 to conduct a thorough review to prepare that for us so  
22 we agreed in the case for Farley, the three pilot  
23 plants, Farley being the very first pilot, Farley we  
24 denied past precedent for the purpose of the audit but  
25 for the other two --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. SHACK: Okay. So this won't be  
2 practiced in the future?

3 MS. LIU: Correct. Correct. For all the  
4 others after Farley past precedents will be used.

5 DR. KUO: If I may, Tilda, this is an area  
6 that we try to explain the GALL scope. What we think  
7 is that, you know, with those positions that staff  
8 previously approved that we could incorporate this  
9 experience into GALL but because Farley was the first  
10 pilot plan and the time was short, they were not able  
11 to compare their program with the past staff approved  
12 positions so they said no, we are not going to do  
13 that. We just look at the GALL.

14 However, for those positions where we had  
15 the previously approved positions, they would have to  
16 provide the detailed description of the program in  
17 their application so they are just not taking  
18 advantage of the so-called previously-staffed  
19 position.

20 DR. CHANG: To support PT's statement, in  
21 the subsequent audits following Farley it's about  
22 evenly divided. Maybe two or three they use past  
23 precedent. Two or three they don't use past  
24 precedent. Regardless of whether they use past  
25 precedent or not, past precedent is just a road map to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 direct staff's attention to say, "Hey, this is our  
2 basis. We say everything. We quote past precedents."

3 But the audit team cannot rely on the past  
4 precedent to say, "Since there's past precedent, we  
5 don't review it." We also go in there to review the  
6 assumptions, the conditions, the limitations, all this  
7 are consistent with GALL. It just provide us a  
8 direction so we just don't look all over the place.  
9 We look focused.

10 DR. SHACK: How do you cite past  
11 precedent? Do you really say in the SER for Hatch  
12 you --

13 DR. CHANG: No. The past precedents, the  
14 utilities and the applicants normally put in the book  
15 called past precedent book. In the past precedent  
16 book they pointed out what are the past precedent book  
17 they pointed out what are the past precedents. How  
18 many plants did you use as the directions to pick past  
19 precedents.

20 When they pick one they don't go to the  
21 next one so they each plan may have five plants they  
22 pick past precedents from. You go to the past  
23 precedent book and you find out and if you go into the  
24 past precedents SER you find the justification  
25 adequate. You quote that. That becomes your basis of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 review and conclusion.

2 If you don't find that adequate, you go to  
3 the backup justification like RAIs, like other things.  
4 I don't know what other things yet but you look into  
5 mainly RAI process to see whether the question was  
6 discussed and how it was finished and you use that as  
7 a basis.

8 DR. WALLIS: Do you ever find anything  
9 wrong with GALL? I mean, GALL is treated as absolute  
10 gospel. Is it really as good as that? Aren't there  
11 some times when you question GALL itself?

12 DR. CHANG: We treat GALL as a  
13 recommendation, as a guideline, especially for  
14 somebody like me joining NRC only three years ago. I  
15 just put my industrial hat together with the  
16 regulatory hat and we conduct the audit in that way so  
17 we do impose regulatory check and technical check.

18 DR. KUO: And, Dr. Wallis, to answer your  
19 question, yes we did define a few areas that the GALL  
20 was not complete. We are updating it and we are  
21 trying to improve.

22 MS. LIU: Okay. Moving on to slide No. 26  
23 on Aging Management Programs. There are a total of 22  
24 Aging Management Programs associated with the Farley  
25 review. After 22 nine are considered common AMPs and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 13 are considered component and structural group  
2 specific AMPs.

3 Of these 22 AMPs eight of them are  
4 considered existing AMPs, five are enhanced, and nine  
5 are new AMPs. In terms of GALL consistency eight of  
6 these AMPs are considered consistent with GALL and of  
7 those eight two are new AMPs for Farley. There are  
8 five AMPs that are consistent with GALL but with  
9 enhancements and five with exceptions. There are four  
10 AMPs that are new AMPs that are not consistent with  
11 GALL and they are also plant specific AMPs.

12 MR. LEITCH: One of those new Aging  
13 Management Programs, and I guess it's really a  
14 question for the applicant, is the External Surface  
15 Monitoring Program. That might be one to conclude  
16 that there was no such program. I would hope the  
17 answer is that there has been pieces of that perhaps  
18 not formally documented and this is assembling and  
19 formalizing such a program. Is that a correct  
20 assumption?

21 MR. MACFARLANE: Is your question  
22 concerning how we do that in current space?

23 MR. LEITCH: Yeah, right. Is there an  
24 external surface monitoring program now?

25 MR. MACFARLANE: Not in the context of the

1 10 elements for license renewal. There is system  
2 engineering walk-downs and similar types of activities  
3 that are currently conducted at the plant. In reality  
4 it's kind of a day-to-day thing as well as if you come  
5 across something that is in a degraded condition you  
6 write a condition report to get it addressed.  
7 The renewal process what we had to do there was do a  
8 little more formal program and also to make it more  
9 rigid in terms of what areas are looked at to make  
10 sure all the areas are covered.

11 It pulls in elements from existing  
12 programs and will create some new things that will go  
13 into it to encompass the entire scope that follows  
14 into renewal. So the answer to your question is there  
15 is things going on in current term space but there is  
16 more to the renewal program than what we are doing in  
17 current terms so it's a new program.

18 MR. LEITCH: Okay. Thank you.

19 MS. LIU: The next slide is dealing with  
20 examples of AMPs with GALL deviations. I will now  
21 turn over the presentation to Dr. Ken Chang who was  
22 the team leader on these GALL audits. He will be  
23 sharing his insights and findings associated with  
24 these audits.

25 DR. CHANG: Thank you. My name is Ken

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Chang again. Before I go into the examples I would  
2 like to give a little introduction of how the audit  
3 teams are formed. I think I gave one before. If not  
4 interested, I'm not going to talk about it. I'll move  
5 right into the examples.

6 We pick three examples to discuss in  
7 detail here. One is Fatigue Monitoring Program. We  
8 say it consistent. Why do we talk about some programs  
9 consistent with Gall? Because this program interest  
10 many people including myself and it's so complicated  
11 but it's so beautiful, so beautiful that I like to  
12 talk about it.

13 The second one is One-Time Inspection and  
14 the other one is Non-EQ Cables in Instrumentation  
15 Circuits Programs. Those are with exceptions, with  
16 enhancement, and enhancement and exceptions.

17 Talking about the Fatigue Monitoring  
18 Program it's a new program. It will be consistent  
19 with GALL when fully implemented and specific  
20 components included in this program are listed. The  
21 top six, four of them are exactly the same as  
22 NUREG/CR-6260. Two are reasonable substitutes for the  
23 two components in NUREG/CR-6260. Why don't appear  
24 exactly the same? Because the plant is not the same.

25 In the NUREG/CR-6260 the sample plant was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 Westinghouse four-loopers and finally the three-  
2 loopers. You pick the comparable component in the  
3 systems which sees the similar transients is loading  
4 so we picked those. I don't mean we. I mean  
5 applicant picked those. In addition, this applicant  
6 did more than 6260 requires because it also monitors  
7 RCL.

8 It also monitors other Class 1 piping  
9 greater than one inch in diameter including RHR which  
10 is substitute of the NUREG/CR-626-. Also other Class  
11 1 components as they see fit. When I say when they  
12 see fit means they see high usage factor, fatigue  
13 damage. That's a very conscientious decision. So go  
14 beyond 6260 which is the basis of the GALL.

15 Farley is currently using cycle counting  
16 method for counting the fatigue loading. That cycle  
17 counting is not manual counting. They consider both  
18 manual counting and automatic counting. Within the  
19 automatic counting currently they track 17 locations  
20 and will be expanded to include 12 more locations for  
21 a total of 29 locations.

22 In the manual counting currently there are  
23 three and they are going to add in two so there will  
24 be five so all together it's 34 monitoring locations.  
25 That's plenty. That's more excessive than most of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 plants I know.

2 MR. LEITCH: It looks like a good program  
3 going forward but to they have good data from the  
4 beginning of plant operation or is that just an  
5 estimate or go back through the records or how do they  
6 come up with that?

7 DR. CHANG: Let me go one line more on my  
8 slides.

9 MR. LEITCH: Okay.

10 DR. CHANG: But this cycle counting method  
11 would be modified to use fatigue monitoring software  
12 which everybody knows is the Fatigue Pro, Rev. 3. In  
13 order to use Fatigue Monitoring Program you need to  
14 know the past, current, and future. Also you need to  
15 know the transfer function.

16 So for the past it depends on the analysis  
17 and estimates. You put an estimate value for the  
18 past. As technology advances, you may modify and  
19 perform more additional analysis so this assumed value  
20 conservative value, can be modified to benefit more to  
21 give more room.

22 DR. WALLIS: Does this count the cycles  
23 and assumes that each cycle is the same?

24 DR. CHANG: No.

25 DR. WALLIS: Aren't some cycles more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 intense than others?

2 DR. CHANG: Right now it's counting cycles  
3 but when they implement Fatigue Pro, Rev. 3 it's a  
4 Fatigue Monitoring Program. It records Data T, Data  
5 P, how many times, ramp, how fast the transient is,  
6 flow rate, all those parameters. It's sophisticated.  
7 Previously other plants like Ginna has approved  
8 similarly. They also go the full nine yards.

9 About the past, some critical fatigue  
10 systems like surge line, like the 88-08 lines -- I'm  
11 not following this, sorry -- they have a recorded data  
12 from April '94 to October '95 for the surge line  
13 recorded. They have temperature data, transients,  
14 cycles, everything. That is the basis of generating  
15 a Westinghouse generic WCAP for fatigue and pressure  
16 surge line reports.

17 Also from that monitoring it created  
18 modified operating mode to improve the system  
19 performance. They call that modified steam bubble,  
20 heat-up and cool-down. You implement that operating  
21 mode trending less cycles. Trending is less severe.  
22 They are doing that. I'm sure you're still doing  
23 that, right?

24 So by reviewing that auditing finds three  
25 comments and those three comments are implemented in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a basis document as of now. It's good for one but  
2 other team still find something.

3 They reduced stress-based on-line fatigue  
4 monitoring on the surge line and the low head  
5 pressurizer including stratification as we talk a  
6 little less. They also evaluated six locations for  
7 the environmental impact on fatigue. That's quite up  
8 to date. They used FEA methods for fatigue lab  
9 reduction factor and used conservative numbers to  
10 define the limiting case. All these are very good.

11 From operating experience everybody know  
12 the IE Bulletin 88-08 started from the ECCS safety  
13 injection line to the loop B of Unit 2 at Farley.  
14 Since then they have a very accurate cycle counting  
15 and now they plan to implement the fatigue monitoring  
16 software so all this will be implemented so I believe  
17 -- the audit team believe this program for  
18 implementing will be totally agreed, totally compliant  
19 and consistent with GALL.

20 The next program I would like to talk  
21 about is One-Time Inspection. It's a new and plant  
22 specific AMP. I forgot to mention at the beginning  
23 the audit team is only auditing 17 out of the 22  
24 programs. The audit team is only responsible for 17  
25 of the 22 AMPs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 But since this is the first time the audit  
2 team goes out there, we take the liberty of looking to  
3 all 22 programs but out of five programs we look at,  
4 only four have review purpose only for reference.  
5 It's not for using in SER. Whoever responsible for  
6 that's the Division of Engineering. They are  
7 responsible for input into the SER.

8 The One-Time Inspection Program is  
9 addressed in commitment No. 10. The One-Time  
10 Inspection Program selects and inspects representative  
11 locations based on combinations of applicable  
12 material, environment, and aging effect, MEA. We use  
13 acronym MEA. It's normally MEAP but this time this is  
14 a program.

15 The purpose of this One-Time Inspection is  
16 for three purposes. One is used for location where  
17 aging effect is not expected to occur such as used for  
18 water chemistry control to verify that corrosion does  
19 not occur. Another purpose is to validate the  
20 effectiveness of other credited AMPs such as fire  
21 protection and Water Chemistry Control Program. We  
22 used the One-Time Inspection to verify the  
23 effectiveness of other programs used to manage aging.  
24 One-Time Inspection is not managing aging. It's to  
25 verify it's effective.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Another purpose is for locations where  
2 aging is expected to progress very slowly for any  
3 location which to manage the change of material  
4 property, loss of material which normally occurs very  
5 slowly. That One-Time Inspection is used to verify  
6 that.

7 DR. WALLIS: Very slowly means nothing  
8 significant happens in 40 years or something?

9 DR. CHANG: Not significant up to the  
10 point of inspection.

11 DR. WALLIS: From the beginning of  
12 operation?

13 DR. CHANG: From the beginning of  
14 operation to the point you do the One-Time Inspection.

15 DR. WALLIS: So we're talking about  
16 decades.

17 DR. CHANG: Yeah, yeah. Next slide,  
18 please.

19 DR. SHACK: What's the basis of choosing  
20 the One-Time Inspection to validate the effective of  
21 accredited AMP? Presumably if you've got a GALL  
22 compliant AMP you don't have to validate it. You guys  
23 accept it.

24 DR. CHANG: In principle it's true but if  
25 you see how many areas that this One-Time Inspection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is applied to, then you say it's beyond that. Even  
2 when GALL says aging is not significant, you use that  
3 to verify it is not significant.

4 DR. WALLIS: Because it's not expected to  
5 occur.

6 DR. CHANG: That may be true.

7 DR. KUO: Actually, even in GALL programs  
8 the combination -- I mean, in many areas the  
9 combination of the two is the acceptable program like  
10 water program to control corrosion and all that. The  
11 GALL actually says you have One-Time Inspection to  
12 verify the effectiveness of the program.

13 DR. CHANG: Okay. So the next slide  
14 presented a number of components in different systems  
15 that One-Time Inspection is applied. This is only a  
16 sample population and there are dozens more which is  
17 not here.

18 DR. BONACA: Isn't this a scope  
19 significantly larger than what we have seen in some  
20 other unit?

21 DR. CHANG: I can't speak to that.

22 Mike, do you have anything you can say  
23 about it?

24 MR. MACFARLANE: In my estimation I would  
25 say no, it's consistent with what has been done on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 previous applicants. The spray head issue has been a  
2 common issue on Westinghouse PWRs. Small bore butt-  
3 welded piping is another issue that is pretty  
4 consistent.

5 DR. BONACA: I was commenting not on this  
6 list but on the statement by the presenter that there  
7 is a long list in addition to this.

8 DR. CHANG: Maybe this long list belong to  
9 every plant.

10 MR. MACFARLANE: What you see a lot in  
11 One-Time Inspection is the staff is requesting One-  
12 Times for programs that are preventative in nature.  
13 In other words, those programs don't really do  
14 inspections like you're not going to see a One-Time  
15 trying to verify a ISI inspection but you'll see it  
16 trying to verify water chemistry is adequate.

17 Typically when -- we were pretty  
18 aggressive in trying to use where we had operating  
19 experience to not do One-Time Inspection so we made an  
20 attempt to keep this population to a reasonable level.  
21 Some cases we won those arguments and in some cases we  
22 did not.

23 DR. BONACA: Now I also remember some  
24 applicants use the strategy of using existing programs  
25 to perform the function of a One-Time Inspection.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 They simply say, We will perform an inspection under  
2 the ISI Program," but it's still a One-Time Inspection  
3 identified as such.

4 DR. CHANG: All right. Thank you. And  
5 the example I would like to bring up is the Non-EQ  
6 Cables Program. It's a new program that will be  
7 consistent with GALL with exception. The exception is  
8 the Non-EQ cable used in circuit with sensitive high-  
9 voltage low-level signals are tested in accordance  
10 with the alternate XI.E2 program.

11 This to me doesn't seem to be an  
12 exception. It's just an acceptable alternative. It's  
13 recognized. Through the audit we are able to find two  
14 things that need to be changed to make this program  
15 really consistent with GALL. One is the program  
16 itself originally said you test selective sample.  
17 GALL requires that you test all cables.

18 The GALL apply this program to the cables  
19 and connectors. Originally the program only includes  
20 cables, no connectors. We also change the basis  
21 document and necessary documents to include this  
22 change. These are two changes identified by the audit  
23 team and it's in the program now.

24 Before I turn it over to the Reactor  
25 Vessel Surveillance -- oh, okay.

1 MS. LIU: Thank you, Ken. I want to brief  
2 the subcommittee on this AMP because we had a license  
3 condition associated with it as I mentioned earlier  
4 which resulted from the staff's review of the AMP.  
5 The Reactor Vessel Surveillance Program is an existing  
6 AMP that is consistent with GALL with one exception.  
7 The single exception is the proposed surveillance  
8 capsule withdrawal schedule. GALL specifies that all  
9 remaining capsules are to be removed at a 60-year  
10 fluence and alternative dosimetry is to be installed.

11 For Unit 1 at Farley SSE has removed one  
12 capsule at a fluence approximately equivalent to 60  
13 years. For Farley Unit 2 SSE will remove one capsule  
14 at a fluence approximately equal to six years.  
15 Therefore, for each unit one capsule will remain in  
16 the reactor vessel until fluence of approximately six  
17 years.

18 The future action is addressed by  
19 commitment No. 18 in the Appendix A of the SER.  
20 Furthermore, the applicant committed that for each  
21 unit alternative dosimetry will be installed.

22 DR. WALLIS: Do we know what kind it is,  
23 what kind of dosimetry?

24 MS. LIU: SNC, would you respond to that?

25 MR. MACFARLANE: The plans are to -- it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 a Westinghouse design. It's external dosimetry.

2 DR. WALLIS: Backed by calculating?

3 MR. MACFARLANE: That's my understanding.  
4 It's just validating the fluence levels that it's  
5 seeing that are consistent. They are monitoring for  
6 change.

7 MS. LIU: I believe Lambros Lois would  
8 like to address this issue.

9 MR. LOIS: My name is Lambros Lois,  
10 Reactor Systems Branch. I've been doing the fluence  
11 for vessels for quite a while. Actually we have  
12 developed computational tools which are quite adequate  
13 to predict fluence quite into the future. Although it  
14 is desirable to have additional dosimetry to verify  
15 actually what the calculations will show, we have  
16 quite a bit of confidence.

17 Regulatory Guide 1.190 which was published  
18 in 2001 actually requires that the calculations -- not  
19 measurements but calculations be used for the  
20 predictive capability, the prediction of fluence in  
21 the future. I hope I've answered the question.

22 DR. WALLIS: Do you have to have some  
23 experimental verification of this on the outside?

24 MR. LOIS: Yes, we do have continued  
25 verification of that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. SHACK: Why is GALL so dogmatic about  
2 removing all the capsules at 60 years since we hear  
3 stories at least that somebody might come in looking  
4 for another 20?

5 MR. MEDOFF: This is Jim Medoff. I'm with  
6 Materials and Chemical Engineering Branch. For the  
7 Farley units that was the one exception where they did  
8 not agree that to take out the fifth capsules and put  
9 the remaining capsules in storage.

10 What they did do is provide us with an  
11 updated reactor vessel surveillance capsule removal  
12 schedule and demonstrated to us that the removal of  
13 the 6th capsules for each unit would be done at  
14 approximately the 80-year fluence equivalent so that  
15 if they came in for another proposal for renewal that  
16 they would have data that would be applicable.

17 MS. LIU: Thank you, Jim. Therefore, the  
18 license condition, as he stated earlier, is to  
19 continue meeting the ASTM standards and that for any  
20 changes for the capsule withdrawal schedule storage  
21 requirements must be approved by the staff.

22 Slide No. 34, this is NiCrFe Component  
23 Assessment Program, otherwise known as the Alloy 600  
24 program. This is a new AMP. This program will  
25 include nickel-based alloy RCS boundary components

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with no potential susceptibility to primary water  
2 stress corrosion cracking.

3 Farley has committed by Commitment No. 11  
4 in the Appendix A to the SER that you will continue  
5 participation in industry initiatives such as  
6 Westinghouse Owners Group and EPRI-MRP. The  
7 susceptibility rankings and program inspection  
8 requirements will be consistent with the latest  
9 version of the EPRI and Materials Reliability Program  
10 safety assessment.

11 At this time I want to turn over to Ken.  
12 He would like to address certain AMPs that might be to  
13 your interest.

14 DR. CHANG: In the earlier presentation  
15 some discussion already had on some of my backup AMP  
16 slides so I would like to go to the backup slide 76,  
17 Water Chemistry Control Program. Early SNC has  
18 indicated Water Chemistry Program has an exception.  
19 The AMP addresses performance monitoring while GALL  
20 emphasize on some hydraulic performance testing.

21 I have to say something why it is  
22 acceptable. The audit team reviewed the Water  
23 Chemistry Control Program TR 107396 and also reviewed  
24 the component cooling water pump surveillance test  
25 results, heat exchanger condition reports, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 history of performance, and the FNP Mechanical  
2 Operating Experience reports. Reviewing those we find  
3 that the AMP based on performance monitoring is  
4 adequately managing these aging effects. On that  
5 basis we accept the exception.

6 Let's go to backup slide 78, flow FAC  
7 program. In addition to all the discussion held, the  
8 audit team went into the operating experience and  
9 found that through the FAC program which is in line  
10 with the IN 2001-09, the program recommended eight  
11 components for Unit 1 to be replaced in IR18 and one  
12 component and 25 feet of piping on Unit 2 to be  
13 replaced during 2R16. This gives evidence that the  
14 FAC program the applicant implementing is working, at  
15 least find the things they want to find, find the  
16 things they should find.

17 DR. WALLIS: And taking appropriate  
18 action.

19 DR. CHANG: Yes, naturally. Replacement  
20 is appropriate action. Now, that means they are  
21 sincere about implementing effective Aging Management  
22 Program.

23 Let's go to backup slide No. 82, fire  
24 protection system. A question was raised regarding  
25 the acceptability of the 18 months interval. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 audit team reviewed applicant's basis document, the  
2 plant operating experience, and the fire surveillance  
3 procedures. On the basis that these aging effects  
4 occurs over a considerable period of time, the staff  
5 judged that 18-month interval would be sufficient to  
6 detect aging effects. On that basis, we say the 18-  
7 month period is acceptable. And I have --

8 DR. WALLIS: What does this have to do  
9 with 50 years?

10 DR. CHANG: That's 50 years. That's  
11 enhancement. They put four different enhancement on  
12 the program to make it better.

13 DR. WALLIS: That's an awful long time to  
14 wait.

15 MR. SIEBER: That's part of the code for  
16 sprinklers.

17 DR. CHANG: At or before. At or before.

18 DR. WALLIS: Nothing happens to sprinkler  
19 heads before 50 years?

20 DR. CHANG: After 40 years you don't have  
21 to inspect and that is in the extended period of  
22 operation.

23 MR. SIEBER: NFPA code. It's in the code.

24 DR. SHACK: That makes you feel a lot  
25 better. Doesn't it?

1 MR. SIEBER: The sprinkler will last  
2 longer than we will.

3 DR. CHANG: We go by the rules. Okay.  
4 That's all the backup slides I want to bring up for  
5 the Aging Management Program.

6 DR. WALLIS: So heads are made of  
7 different metals?

8 MR. SIEBER: Yes.

9 DR. WALLIS: All kinds of things could  
10 happen if you have a leak. But, anyway --

11 MR. SIEBER: If they fail to put out  
12 fires.

13 DR. CHANG: I'm not either but I'm just  
14 looking into what I should look into.

15 Okay. Back to you.

16 MS. LIU: Okay. Thank you, Ken. Moving  
17 on to AMR results on Section 3.1, this is the reactor  
18 systems. Reactor systems include vessel, internals,  
19 RCS and connected lines, as well as steam generators.  
20 The staff concluded that the aging facts associated  
21 with reactor systems will be adequately managed  
22 through the period of extended operation. Issues  
23 requiring further evaluation in GALL were evaluated by  
24 the audit team and found to be acceptable.

25 I will once again turn over the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 presentation to Dr. Ken Chang who will discuss his  
2 review and findings associated with the AMR results of  
3 the reactor systems.

4 DR. CHANG: For the AMR part, I just want  
5 to mention two examples which I think is of  
6 significance. One is loss of fracture toughness due  
7 to thermal aging. GALL requires for CASS material  
8 it's either enhanced volumetric inspection or flaw  
9 tolerance evaluation needed to be performed. That is  
10 GALL recommendation. Sorry, I did say requirement.

11 The applicant originally want to credit  
12 leak before break analysis for the renewal period as  
13 the flaw tolerance evaluation. The audit team noted  
14 that leak-before-break analysis and flaw tolerance  
15 evaluation they both using pressure mechanics  
16 methodology to evaluate crack propagation. But these  
17 two analyses or two programs are for the different  
18 purposes.

19 Say like leak before break in the mid-'80s  
20 is for the elimination of protection devices like,  
21 wood break strains, jet shearing, and those for that  
22 purpose. It's not really evaluating how the crack  
23 propagates. You just want to say it's safe.

24 That's the whole purpose, but flaw  
25 tolerance evaluation is for different purposes and for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 different purposes, for different initial flaw, for  
2 different load combinations, for different acceptance  
3 criteria so they are different animals. You cannot  
4 use the leak-before-break analysis, fracture mechanics  
5 analysis just to demonstrate it's a flaw tolerance  
6 evaluation.

7 After we were through several discussions,  
8 the applicant brought into argument and now by letter  
9 dated August 19 the applicant revised and committed to  
10 follow the GALL requirements.

11 DR. SHACK: I can't remember on the age-  
12 cast stainless steel, what is the flaw tolerance  
13 acceptance criteria? Is it gross failure or does it  
14 pop through the crack?

15 DR. CHANG: I would ask Robert Hsu to  
16 stand up and explain.

17 MR. HSU: Robert Hsu, License Renewal.  
18 The acceptance criteria is in ASME Section 11 and I  
19 think Appendix C have described based on the current  
20 ASME code you can have up to 75 percent wall  
21 thickness.

22 DR. SHACK: Okay. It's the 75 percent  
23 criterion.

24 MR. HSU: Yeah.

25 DR. WALLIS: Seventy-five percent through

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 wall?

2 MR. HSU: The rule on that is go through  
3 wall based on the ASME code. Only go to 75 percent.

4 DR. SHACK: Well, it's clearly very  
5 different than leak before break.

6 MR. HSU: Leak before break allow run  
7 through completely.

8 DR. WALLIS: But it didn't break.

9 DR. CHANG: As long as it's only a leak,  
10 drips not break.

11 DR. SHACK: No drips.

12 DR. CHANG: If you perforate it, it will  
13 just drip.

14 MR. SIEBER: Drip before break.

15 DR. CHANG: The second item worth  
16 mentioning is under the crack initiation and growth  
17 due to cyclic loading or stress corrosion cracking the  
18 staff approved Farley's risk-informed ISI program in  
19 March of 2004. We questioned into that, "What do you  
20 use risk-informed ISI to select the location or to  
21 eliminate inspection?"

22 The SNC respondent is saying we only use  
23 this to select location. We do not eliminate  
24 location. Then we continued to ask, "Where do you  
25 inspect for small bore volumetric inspection?" They

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 responded in July '04, "We inspect the 2X3 drain  
2 connection on the normal letdown line by UT," which is  
3 a form of volumetric inspection. Those are --

4 DR. WALLIS: That's the only thing they  
5 inspected?

6 DR. CHANG: That's through the risk-  
7 informed ISI process to identify the most susceptible,  
8 most critical location. We don't judge whether it's  
9 adequate by one or two or three.

10 So back to you.

11 MS. LIU: Thank you again, Ken. Moving on  
12 to Section 3.4 -- I'm sorry, 3.2 ESF systems. ESF  
13 systems include containment spray, isolation, and  
14 ECCS. As you can tell from the slide, we have a total  
15 of four AMPs managing ESF systems. Again, the staff  
16 concluded that the aging effects associated with the  
17 ESF systems will be adequately managed by these AMPs  
18 during the period of extended operation.

19 DR. WALLIS: There's nothing much  
20 happening on the external surfaces of these. Nothing  
21 much should be happening at all.

22 MS. LIU: Correct. Moving onto Aux  
23 Systems, Section 3. --

24 DR. WALLIS: Unless there's borated water  
25 leaking and hanging around and cooling down.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. LIU: Section 3.3, Aux Systems. There  
2 are 23 plant specific systems associated with the Aux  
3 Systems. For those there are 11 AMPs that manage  
4 aging effects for the Aux System components. Once  
5 again, the staff concluded that the aging effects  
6 associated with auxiliary systems will be adequately  
7 managed during the period of operation.

8 Moving onto Section 3.4, Steam and Power  
9 Conversion Systems. These systems include main steam,  
10 feedwater, steam generator blow-down and so on. There  
11 are a total of seven AMPs associated with steam and  
12 power convergence systems in terms of Aging Management  
13 Programs. Once again, the staff concluded that the  
14 aging effects associated with these will be adequately  
15 managed.

16 3.5, Containment Systems. Containment  
17 Systems include PWR concrete containment, aux  
18 building, diesel generator, and so on as you can see  
19 from that list. There are a total of six Aging  
20 Management Programs, four containment systems. Once  
21 again, the staff concluded that these aging effects  
22 will be managed by the associate AMPs during the  
23 period of operation.

24 This slide we have the aging management of  
25 in-scope inaccessible concrete. As you can tell from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this table, the below-grade environment at Farley is  
2 nonaggressive and there are no history of aging  
3 degradation or failure of concrete components exposed  
4 to a below-grade environment. You can tell from the  
5 pH level, chlorides and sulfates, they are all within  
6 the limits that are considered nonaggressive.

7 DR. BONACA: It looks like distilled  
8 water.

9 MS. LIU: Right. I want to point out for  
10 you at the phosphate level is .03 ppm sample from the  
11 service water pond. The last sample day for the  
12 phosphate was March 11th of this year.

13 MR. SIEBER: They must not grow anything  
14 there. No fertilizer.

15 MS. LIU: Sampling is not performed on a  
16 routine basis and the service water pond is the source  
17 of water for the service water system. The structures  
18 exposed to pond water are service water structures and  
19 other structures are exposed to ground water.

20 DR. WALLIS: Is this the one with the  
21 clams in it?

22 DR. BONACA: Yes, live clams.

23 DR. WALLIS: They eat the phosphates.

24 MS. LIU: Possibly. And there was no  
25 detectable phosphate in the ground water samples.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Finally, Section 3.6, Electrical Components. There  
2 are 10 component types subject to AMR. The AMPs that  
3 will be used to manage the electrical components are  
4 non-EQ Cables Program, External Surface Monitoring  
5 Program, and Buried Piping and Tank Inspection  
6 Program.

7 Once more, the staff concluded that the  
8 aging effects associated with electrical components  
9 will be adequately managed during the period of  
10 extended operation.

11 Moving on to TLAAs, I want to summarize  
12 first by saying that the staff found the applicant  
13 TLAAs met the requirements of Part 54. The TLAAs  
14 include five sections as you can see from the slide.  
15 On Section 4.2, Reactor Vessel Neutron Embrittlement,  
16 there are five analysis affected by neutron  
17 irradiation embrittlement and they are neutron  
18 fluence, upper shelf energy, PTS, adjusted reference  
19 temperature and P-T limits.

20 For neutron fluence the applicant's  
21 analysis methods used to calculate the Farley neutron  
22 fluence values as projected through the end of the  
23 period extending the operation follows the guidance of  
24 Re Guide 1.190. On reactor vessel upper shelf energy,  
25 as you can tell from this table --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WALLIS: These are your numbers?

2 MS. LIU: That is correct.

3 DR. WALLIS: What are Farley's numbers?

4 MS. LIU: If you look at the table, Dr.  
5 Wallis, the table shows the staff calculated value.  
6 But for your convenience, I have also listed here on  
7 this --

8 DR. WALLIS: They used it on bullet 2?

9 MS. LIU: No, on the same slide if you  
10 look at bullet -- yes, bullet No. 2, as you stated,  
11 the applicant's values are listed there as well. As  
12 you can tell, the values are very close between the  
13 applicant's and the staff's.

14 DR. WALLIS: They all use the phone  
15 number.

16 DR. KUO: I hope so.

17 MS. LIU: Okay. Moving onto PTS, the  
18 limiting belt-line materials at Farley Unit 1 is the  
19 lower shell plate and for Unit 2 is the intermediate  
20 shell plate. Again, for Dr. Wallis, the table list  
21 staff calculated values.

22 As you can tell, they are all within the  
23 acceptable range. Again, the applicant's values are  
24 191 and 208. Again, they are very close to what the  
25 staff has calculated it. These values are based on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the fluence values for clad-to-base metal locations of  
2 the reactor vessels. We used the latest report  
3 surveillance capsule data for Units 1 and 2.

4 Moving onto adjusted reference  
5 temperature. This table list, just for your  
6 information, a comparison of the values at 1/4 T and  
7 3/4 T locations for adjusted reference temperatures.  
8 I have listed there for you both the staff calculated  
9 value as well as the applicant calculated value.  
10 Again, the values are very close between the two  
11 parties.

12 On P-T limits Farley's 54 effective full  
13 power P-T limits were for this based on an NRC  
14 approved PTLR process. The staff approved the  
15 applicant's PTLR by an SC dated March 31st of 1998  
16 which allowed the applicant to generate the P-T limit  
17 curves for a period of extended operation without the  
18 need for a licensed amendment for the curves.

19 Farley's tech spec requires that the  
20 applicant submit the PTLR to staff for docking purpose  
21 only when a new fluence period occurs or when it  
22 revises the supplement to PTLR. The applicant will  
23 generate the PT limits for the period of extended  
24 operation in accordance with the NRC approved Farley  
25 PTLR.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Moving on to Section 4.3, Metal Fatigue.  
2 You may wonder why flywheel is listed here as well as  
3 containment tendon pre-stress. This is the way that  
4 the applicant --

5 MR. SIEBER: It's always been there.

6 MS. LIU: Okay. Because I had a staff  
7 member to ask why are they listed here and I want to  
8 prepare the answer to that. Moving on to the next  
9 slide, slide No. 54.

10 MR. LEITCH: Just a minute. Metal  
11 fatigue, charging nozzle.

12 MS. LIU: Are you talking about slide 51?

13 MR. LEITCH: Excuse me?

14 MS. LIU: This is slide No. 51, Dr.  
15 Leitch?

16 DR. WALLIS: No, the next one.

17 MS. LIU: The next one. Okay, 52? Okay.  
18 I'll be going over that.

19 MR. LEITCH: Okay.

20 MS. LIU: Fatigue of ASME Class 1  
21 components. The reactor cooling systems components at  
22 Farley are designed to Class 1 requirements of the  
23 ASME codes. The applicant's evaluation of  
24 environmental effects indicated that two components  
25 may exceed the fatigue cumulative usage factor of 1.0.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 The two components are charging nozzle and RHR safety  
2 injection nozzle to the RCS cold leg.

3 DR. WALLIS: Why is that so big to  
4 fatigue? Is it used that much?

5 DR. CHANG: The applicant's calculation on  
6 the charging nozzle and the RHR SI nozzle is based on  
7 a conservative assumption of FEA equals 15.35 which is  
8 extremely the highest value. When you use a real  
9 value those numbers will come down.

10 DR. SHACK: He's asking why you do  
11 recycling there.

12 DR. WALLIS: Charging nozzle is used quite  
13 a lot, RHR/SI. Does it really cycle that much?

14 DR. CHANG: Charging line based on  
15 Westinghouse prime design has about -- sorry.

16 MS. LIU: John Fair will address this  
17 question for the members.

18 MR. FAIR: Yes, I'm John Fair, the  
19 reviewer in this area. The charging line and safety  
20 injection line are subject to fairly significant  
21 thermal shocks and that's why you have high usage  
22 there.

23 DR. WALLIS: Do you use that safety  
24 injection line?

25 MR. FAIR: Not a lot but it does get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fairly high thermal shocks on it so the design values  
2 are fairly high.

3 DR. BONACA: But isn't the charging nozzle  
4 the one that already had a crack in the past?

5 MR. SIEBER: Yep.

6 DR. BONACA: I think that's the one,  
7 right?

8 MR. MACFARLANE: The Farley line that  
9 initiated the bulletin was a safety injection nozzle  
10 that is normally isolated and it was caused by a  
11 leaking isolation valve.

12 DR. BONACA: So it's not the same nozzle?

13 MR. MACFARLANE: Correct.

14 DR. BONACA: I thought it was the  
15 charging. All right. Do you have full separation of  
16 safety injection and charging pumps so they are not  
17 interchangeable?

18 MR. MACFARLANE: Could you repeat the  
19 question again?

20 DR. BONACA: Do you have full separation,  
21 distinction between the safety injection pumps and the  
22 charging pumps?

23 MR. MACFARLANE: No, it's a dual use  
24 system. The charging pumps are the high-head safety  
25 injection pumps but the lines where they actually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 inject into the RCS for safety injection versus where  
2 they would inject during normal charging are  
3 different.

4 DR. BONACA: They are different. Okay.

5 DR. WALLIS: Charging is makeup? Is it  
6 the same thing?

7 MR. MACFARLANE: Correct. We normally run  
8 an in-flow and an out-flow for chemistry control and  
9 inventory control.

10 DR. WALLIS: But you do have some  
11 regularly but you don't use safety injection  
12 hopefully.

13 MR. SIEBER: You use the safety injection  
14 pump.

15 DR. WALLIS: What kind of corrective  
16 action are they going to take?

17 MS. LIU: The applicant's corrective  
18 action include one or more of these four options. The  
19 first being a further refinement of the fatigue  
20 analysis would --

21 DR. WALLIS: Sharpen the pencils.

22 MS. LIU: Correct. Or repair the affected  
23 locations or replacement of the affected locations and  
24 management of the fatigue effects through the use of  
25 an NRC inspection program. These are very typical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 actions proposed by the other applicants such as Ft.  
2 Calhoun and Summer.

3 MR. LEITCH: The thing that surprises me  
4 is this charging nozzle apparently appears to be from  
5 these calculations way, way unacceptable at 60 years.  
6 We say that prior to entering a period of extended  
7 operation we'll decide what to do with this. How do  
8 we know it's okay today?

9 MR. FAIR: Well, what is unacceptable at  
10 60 years is the usage factor with the environmental  
11 factor factored into it. We did an evaluation back --  
12 I think we presented it back in about 1995 based on a  
13 combination of risk evaluation plus an evaluation of  
14 sample plants that the risk for 40 years operation  
15 wasn't great enough to require anybody to back-fit for  
16 40 years operation. For the additional 20 years we  
17 thought it was worthwhile to reevaluate these  
18 locations to make sure they are good for 60 years.  
19 But it was a combination of evaluation and  
20 conservatisms in the analysis and a risk assessment of  
21 the consequences of fatigue failure at those  
22 locations.

23 MR. LEITCH: I guess if you did these same  
24 calculations for --

25 DR. SHACK: Today.

1 MR. LEITCH: -- today, what kind of a  
2 number would you get?

3 MR. FAIR: One of the things that when  
4 they take the conservatisms out of the analysis, I  
5 think these type of nozzles if they go to the full  
6 limit of doing a finite element analysis, they  
7 probably will show that they are well below 1. That  
8 has been the experience with other utilities of doing  
9 the detailed analysis. They just didn't want to do it  
10 at this point in time and that's one of their options  
11 prior to the period of extended operation.

12 DR. SHACK: And your judgment is that if  
13 they did the detailed one that would be okay so you're  
14 not going to really get too worried about it?

15 MR. FAIR: Yeah, I think each time we find  
16 out that for these particular nozzles they do them  
17 using piping analysis rules which use very  
18 conservative stress intensification factors. When  
19 they go to a full-blown finite element analysis, it  
20 takes a lot of conservatism out of those stresses at  
21 those locations. If you look at the way the fatigue  
22 curve goes, if you reduce the stresses by a factor of  
23 2, you reduce the fatigue usage by much, much greater  
24 than that.

25 MR. LEITCH: I'm just surprised. This

1 particular issue here is not my field but, I mean, I'm  
2 scanning these numbers here and expecting to see  
3 something considerably less than 1.

4 MR. FAIR: Yes.

5 MR. LEITCH: Instead I see something like  
6 12. I mean, hopefully there's a lot of conservatism  
7 there.

8 MR. FAIR: That's not unusual. A lot of  
9 these high-usage locations have fatigue usage factors  
10 close to one for the design basis. When you put an  
11 environmental factor on top of that, then you get  
12 those really high numbers.

13 DR. BONACA: That raises -- I mean, this  
14 is -- I've been thinking about the same issues here  
15 and I know some applicants are showing now interest in  
16 renewing the license beyond 60 years. I'm asking  
17 myself about the issue of fatigue. I mean, these  
18 components simply have a life that is limited. One of  
19 the options is sharpening the pencil and qualifying  
20 the equipment beyond a certain point. How far can you  
21 do that? I'm trying to understand this issue of  
22 margin. How much margin is really there in  
23 components?

24 DR. SHACK: Well, after you put in the  
25 environmental effect and you do the finite element

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 analysis, you get a number that is probably as far as  
2 you can go.

3 MR. MEDOFF: May I make a clarification  
4 here, though? For Part 54 and TLAA's it doesn't say  
5 that your TLAA has to remain valid but if it doesn't  
6 remain valid you have to propose an Aging Management  
7 Program. Even if you don't make the -- if your TLAA  
8 is no longer valid or remains bounding, you can still  
9 manage through an AMP. Even if they don't meet their  
10 CUF for, let's say, an 80-year program, they could  
11 still propose an AMP to address the --

12 DR. BONACA: I was simply raising a  
13 question regarding the margin. We can certainly  
14 sharpen the pencil and propose an AMP, etc., but you  
15 are effectively aging the equipment at some point  
16 whatever margin is in them for whatever aging effects,  
17 in this case it's fatigue, it will be certainly  
18 reduced. The low point is reduced below the level of  
19 confidence or comfort that you should be concerned  
20 about.

21 DR. CHANG: If I may, another proof is  
22 normally you do stress-based fatigue monitoring on the  
23 most critical locations. On Farley the location  
24 selected for stress-based fatigue monitoring program  
25 is the surge line and lower head of the pressurizer so

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 obviously the charging nozzles, SI nozzles, are not  
2 the most critical location. Just because they did a  
3 conservative one-time calculation to get by for 40  
4 years, no. That's why the usage factor is high. In  
5 reality the usage factor is not high. Need not to be  
6 high.

7 DR. WALLIS: What kind of environmental  
8 effects applies to this huge CUF?

9 DR. SHACK: Water.

10 MR. FAIR: Yes, reactor water and oxygen  
11 level and the reactor water.

12 DR. WALLIS: It's the oxygen that does it?

13 MR. FAIR: Well, there's the argument  
14 about that in the ASME code but according to Dr.  
15 Shack's report at this point, it's related to the  
16 oxygen level.

17 DR. SHACK: It depends on whether you have  
18 carbon steel or stainless steel.

19 DR. WALLIS: This is stainless steel.

20 DR. SHACK: Stainless steel, low oxygen  
21 water turns out to be quite damaging. We still don't  
22 understand exactly why. We keep doing the tests. You  
23 keep running them and you keep getting the same  
24 answer.

25 DR. CHANG: But as a first step if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 calculate a reasonable FEN it's not going to be 15.35.  
2 Right away you drop your usage factor way down.

3 DR. WALLIS: I have no idea how much you  
4 have to fudge it to bring it down from 15 to 1 but it  
5 just sounds like --

6 DR. SHACK: Well, as John says, the stress  
7 goes so nonlinerally that I don't know that the 15 --  
8 you know, that the FEN probably isn't all that  
9 unreasonable but you get so much back from the stress  
10 analysis.

11 DR. WALLIS: You know so little about what  
12 the oxygen is doing so you have the factor of safety.

13 DR. BONACA: All right.

14 DR. WALLIS: I guess we have to trust Dr.  
15 Shack.

16 MR. SIEBER: I do.

17 MR. FAIR: Yes. I'm trusting him so far.

18 MS. LIU: Okay. Moving on to slide No.  
19 53, fatigue of reactor coolant pump flywheel. The  
20 applicant's fatigue crack growth analysis assume the  
21 occurrence of 6,000 reactor coolant pump start/stop  
22 cycle through the expiration of PEO, six years, with  
23 allowable crack growth of .08 inches. Farley's  
24 fatigue analysis for ASA classified components assume  
25 200 plant start-up and trip cycles through six years

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of operation.

2 Based on these assumptions it would take  
3 over 30 reactor coolant pump start/stop cycles per  
4 plant shutdown to exceed the allowable crack growth of  
5 .08 inches. This is beyond the normal number of  
6 reactor coolant pumps start/stop cycles that would be  
7 expected during any plant shutdown. Therefore, the  
8 staff concludes that Farley reactor coolant pump  
9 flywheels have sufficient margin against fracture for  
10 PEO.

11 On to fatigue of SME non-Class 1  
12 components. SME Class 2 and 3 and ANC standards  
13 require that a stress reduction factor be applied to  
14 the allowable thermal bending stress range if the  
15 number of full-range cycles exceeds 7,000. Most  
16 piping systems within the scope of license renewal are  
17 bounded by 7,000 cycles. Sampling was designed for  
18 22,000 cycles.

19 DR. WALLIS: What does sampling mean here?

20 MR. SIEBER: Sampling system.

21 DR. WALLIS: What does that mean?

22 MR. SIEBER: It's the piping system where  
23 you get reactor cooling through a bunch of cells that  
24 tells you what the chemistry is.

25 DR. WALLIS: So you're saying the sampling

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 system is okay?

2 MR. SIEBER: They take a sample of --

3 DR. WALLIS: I'm trying to get the logic,  
4 get the connection between the 7,000 and 22,000.

5 DR. SHACK: Well, they just designed the  
6 sampling system to take a lot more --

7 DR. WALLIS: That's just to say the  
8 sampling system is okay. How about the other  
9 components? Is it only the sampling system that's  
10 okay?

11 MS. LIU: John, would you like to  
12 elaborate on that?

13 DR. WALLIS: I'm not sure what the logic  
14 is. That's all.

15 MR. FAIR: I think he had the answer  
16 correctly. The sampling system was designed for a lot  
17 more cycles than the 7,000 so it's okay.

18 DR. WALLIS: So it's okay. So this answer  
19 only applies to the sampling system.

20 DR. SHACK: No, the other systems are  
21 bounded by the 7,000 cycles which is sort of the  
22 standard criteria for the 3011.

23 DR. WALLIS: How many cycles are you going  
24 to get in this how many years? How many cycles is it  
25 going to be connected to?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. FAIR: Let's take -- for these non-  
2 Class 1 systems the criteria is looking at the full  
3 bending of the piping system like the start-up and  
4 shutdown. For most systems they don't cycle them that  
5 often so 7,000 is a very bounding number.

6 DR. WALLIS: How long will they cycle them  
7 during the period of license renewal? What is the  
8 total of cycles we're talking about? Is it 2,000?

9 MR. FAIR: Oh, it's probably on most  
10 systems on the order of hundreds or less. I'll defer  
11 to --

12 DR. WALLIS: All are different. That's  
13 all I need to know. Some sort of comparison.

14 MS. LIU: Thank you, John. Finally, on  
15 the number of thermal cycles for emergency diesel  
16 generator air start system that may see 7,000 during  
17 the operation. However, the applicant indicated that  
18 the equivalent number of full temperature cycles will  
19 be less than 7,000.

20 DR. WALLIS: Is that because they are  
21 required to keep testing it and so on?

22 MR. FAIR: Well, on this particular one  
23 the number of times this thing as cycled is going to  
24 be more than 7,000 but the applicant actually  
25 monitored the temperature swings during the cycling

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for this particular line and found that they were much  
2 less than the design for full charging so that when  
3 they used the code criteria for calculating the  
4 equivalent number of full-range cycles it comes out  
5 less than 7,000 so it's okay.

6 MR. SIEBER: What part of the air-start  
7 system is the critical part from a fatigue standpoint?

8 MR. FAIR: I believe it was straight  
9 downstream of the compressor. Maybe you could help.

10 MR. SIEBER: You mean the piping system?

11 MR. MACFARLANE: The discharge line out of  
12 a compressor which gets really hot during a full  
13 charge of the cumulator tank.

14 MR. SIEBER: Okay.

15 MR. MACFARLANE: And then typically the  
16 reason we get these partial cycles is we do -- you  
17 know, you get some leakage out of these things and  
18 they'll do small makeups into this cumulator so the  
19 compressor doesn't run very long. It's a very short  
20 cycle and you don't get the heat that you do with a  
21 full charge and that's when you get to this equivalent  
22 cycle determination. Like you said, we did do testing  
23 on it to actually quantify what that was.

24 MR. SIEBER: Thank you.

25 MS. LIU: Moving on to containment tendon

1 pre-stress. This was related to an REI that the staff  
2 requested the applicant to provide, minimum required  
3 pre-stress enforced for tendon. The applicant's  
4 trending analysis provided actual force for tendon and  
5 a trend line. The values are based on interpretation  
6 from the trend line curve.

7 As you can see from this table, the trend  
8 line values are provided for four years and six years  
9 and both of those values are above the minimum  
10 required value.

11 DR. WALLIS: How accurately do you know  
12 these tension?

13 MS. LIU: I would like to ask Hans Ashar  
14 to elaborate on that, please.

15 MR. ASHAR: I didn't hear the question.

16 DR. WALLIS: Presumably there are many  
17 tendons.

18 MR. ASHAR: Yes, there are.

19 DR. WALLIS: And there's a variation in  
20 this tension. They don't all have the same tension.  
21 I am surprised to see numbers here, five significant  
22 figures.

23 MR. ASHAR: Yes. Well, it is calculated  
24 that way. I'll tell you what happens is at each  
25 tendon inspection there are seven or eight tendons

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 inspected for liftoff testing. That means they  
2 measured the stressing points at those times. They  
3 are done every five-year interval so they get a number  
4 of readings which are shown in the ASE if you look at  
5 the Safety Relation Report on page number --

6 DR. WALLIS: The average is okay because  
7 you are only interested in the total --

8 MR. ASHAR: No. It is not averaging  
9 really. What is being done here is they are measuring  
10 stress points at various times. What they did was  
11 they did the regression analysis showing the trend  
12 line as to what can happen in the future through  
13 regression analysis.

14 DR. WALLIS: My question is the minimum  
15 required for a tendon and you've got some sort of  
16 average tension on the tendon or stress in the tendon.  
17 I presume there is a variation from tendon to tendon  
18 so some tendons come below the minimum?

19 MR. ASHAR: Oh, absolutely. That's what  
20 I'm trying to -- if you have a Safety Relation Report  
21 with you, I can point out to you what is exactly done  
22 there.

23 DR. WALLIS: Section of the variation and  
24 the stress between tendons from tendon to tendon. We  
25 don't need great complexity here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ASHAR: I will show you the readings.  
2 On Safety Relation Report whole charge is given for  
3 the readings for which this trend line has been --  
4 these are the readings from the trend line, not from  
5 individual tendons.

6 DR. WALLIS: Suppose you have a trend line  
7 and you're extrapolating to 1198 on five at 60 years.  
8 Is that the average stress in the tendon? Are some of  
9 them below 1,000 or something? I don't understand how  
10 much spread there is from tendon to tendon and whether  
11 it matters or not.

12 MR. ASHAR: That's what I'm trying to show  
13 you. If you have the ASE I can show you very well  
14 what the schedule is. These are the schedules shown  
15 on the chart which is in the Safety Relation Report.

16 DR. WALLIS: I don't need that. I just  
17 need to know if your criterion is just an average  
18 tension or if you're taking account of the various --

19 MR. ASHAR: Oh, yes. You're quite right.  
20 I think what happens here is the minimum required  
21 stress is based on the required internal pressure.

22 DR. WALLIS: Does that have to be in all  
23 tendons or is it the average minimum?

24 MR. ASHAR: It has to be the average  
25 minimum.

1 DR. WALLIS: Average?

2 MR. ASHAR: That's correct.

3 DR. WALLIS: That's the question I started  
4 with.

5 MR. ASHAR: The reason is because it's not  
6 based on --

7 DR. WALLIS: Obviously there's a scatter  
8 here.

9 MR. ASHAR: Yes. Right.

10 DR. WALLIS: That's a pretty ambitious  
11 trend line for that data.

12 MR. ASHAR: Yes.

13 DR. SHACK: We won't calculate R-squared.

14 DR. WALLIS: Oh, dear. This must be a  
15 materials problem.

16 DR. SHACK: I put it on a log-log plot and  
17 it looks better.

18 DR. WALLIS: Of course, you've got the  
19 black numbers so I can't see them on a blue  
20 background. What is your criterion for success?  
21 Everything above the red line. Is that it?

22 MR. ASHAR: That's correct.

23 DR. WALLIS: So that looks a little more  
24 hopeful. Okay. But there's obviously no trend  
25 whatsoever in the data after the first one.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ASHAR: Well, that's the reason you  
2 need the regression analysis.

3 DR. WALLIS: Even so. Well, okay.

4 MS. LIU: Thank you, Hans. Going back  
5 to --

6 DR. WALLIS: Is this standard procedure?  
7 Is this just regulatory space you're talking about?  
8 This is something that is standard throughout industry  
9 when they deal with this kind of stuff?

10 MS. LIU: Yes.

11 MR. ASHAR: Do you want me to respond to  
12 your question, sir?

13 DR. KUO: Go ahead.

14 DR. WALLIS: Is this what they do with  
15 bridges and things like that or buildings?

16 MR. ASHAR: No. I think in bridges  
17 because there are separate girders there, what they  
18 are doing normally the AASHTO requirement to measure  
19 the stressing and 10-year interval or something. Just  
20 look at that part of the tendons. Here we have a  
21 multiple number of tendons, 200 tendons in vertical  
22 direction.

23 DR. WALLIS: You take a sample?

24 MR. ASHAR: Yeah, we take a sample, sir.  
25 Correct.

1 DR. WALLIS: Well, okay. Maybe if I were  
2 curious I would have to look at all the details and I  
3 don't think I've got time.

4 MS. LIU: Going back to slide No. 55, this  
5 is on Section 4.4, environmental qualification of  
6 electrical equipment. The EQ programs consist of the  
7 GALL program and the effects of aging on the intended  
8 functions will be adequately managed for the period of  
9 extended operation from the applicant's continued  
10 implementation of the EQ program. Again, the staff  
11 concluded that the applicant's EQ program is adequate  
12 to manage electrical equipment.

13 Section 4.5, this is where we have other  
14 plant specific TLAAs that includes ultimate heat sink  
15 silting, leak-before-break analysis, and RHR relief  
16 valve capacity verification --

17 DR. WALLIS: I'm curious about silting.  
18 The bottom of the pump silts up but does the top level  
19 stay constant?

20 MS. LIU: SNC, would you like to address  
21 that?

22 MR. MACFARLANE: Essentially it does.

23 DR. WALLIS: Is there water coming in to  
24 keep the level up always?

25 MR. MACFARLANE: Maybe I misunderstood

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 your question. The confines of the pond stays  
2 essentially constant. It is an earthen structure.

3 DR. WALLIS: Water comes from a river or  
4 something --

5 MR. MACFARLANE: The water level --

6 DR. WALLIS: -- until it dries up.

7 MR. MACFARLANE: Oh, that's true. We keep  
8 a makeup to the pool. We do have tech spec limits on  
9 what the pond level is and we maintain it actually a  
10 given level. When they do this test that's one of the  
11 things they do is they regulate that pond level to get  
12 it up to a standard point so that when they do the  
13 test it's consistent from test to test and then they  
14 measure the silting looking at poind depths. A  
15 sounding survey is essentially what they're doing.

16 DR. SHACK: Have you had to dredge this  
17 thing before?

18 MR. MACFARLANE: No. Actually, our  
19 testing results show that we do not have a significant  
20 silting problem. It just happens we have a  
21 calculation that went out and used a 40-year number to  
22 look at whether or not it would be a problem and that  
23 made it fall into a TLAA space.

24 DR. WALLIS: A big silting is when you get  
25 a flood or something presumably and there are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 particulates in the water.

2 MR. MACFARLANE: In the case of the pond  
3 we get outflow of the pond in that situation and the  
4 pond would actually fill up potentially and we would  
5 have it going out of the spillway the other way.

6 MS. LIU: Slide No. 57, ultimate heat sink  
7 silting. 1325 acre-feet for service water pond is  
8 used as the ultimate heat sink in the FSAR. The  
9 average measured pond volume is 1418.5 acre-feet.  
10 This is taken from 12 sets of data over a 22-year  
11 period. That data was taken from 1981 to 2003.

12 With the 2003 data the increase with time  
13 is .054 acre-feet per year with a predicted 60-year  
14 end-of-life ultimate heat sink volume of 1421 acre-  
15 feet. Again, this is above the 1325 acre-feet used in  
16 the FSAR.

17 DR. WALLIS: This looks like the easiest  
18 technical analysis of all.

19 MS. LIU: Yes.

20 DR. WALLIS: Understandable at a pretty  
21 early stage in one's mathematical career.

22 MS. LIU: The staff performed an  
23 independent regression analysis of the data furnished  
24 by the applicant and found SSE statements concerning  
25 the regression analysis to be correct that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 ultimate heat-sink pond volume during the period of  
2 extended operation will remain above 1325 acre-feet  
3 used in the UHS analysis.

4 I want to point out that the minimum  
5 recorded ultimate heat-sink pond volume is 1403 acre-  
6 feet. This was based on a 1984 surveillance data.  
7 The staff agrees with the applicant's conclusion that  
8 existing required pond volume remains conservative for  
9 the renewal term and assures adequate ultimate heat  
10 sink volume to safely shutdown and maintain long-term  
11 cooling. Next one is on --

12 DR. WALLIS: This isn't a pond that  
13 freezes, is it?

14 MS. LIU: Probably not. It's down south  
15 and pretty warm over there.

16 Moving on to leak-before-break analysis.  
17 The applicant's leak-before-break analysis has been  
18 redemonstrated and continues to be valid during the  
19 period of extended operation. The staff determined  
20 that the applicant's reanalysis appropriately  
21 evaluated impacts of aging degradation on the  
22 perimeters and acceptance criteria for the analysis  
23 and demonstrated that the analysis was adequately  
24 projected through the expiration of the period of  
25 extended operation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1                   Finally, on RHR relief valve capacity  
2 verification calculations. This is addressed in  
3 commitment No. 15 in Appendix A to the SER. It states  
4 that SNC will update the RHR relief valve flow  
5 capacity analysis that utilizes P-T curves as an input  
6 to include the calculated 54 effective full power  
7 limit curves prior to the period of extended  
8 operation.

9                   DR. SHACK: Just before -- I keep coming  
10 back to my leak-before-break question. Every license  
11 renewal for a PWR is going to come up. We go through  
12 this analysis but you are really not quite consistent  
13 with the staff branch position on leak-before-break  
14 because you have now got an active degradation  
15 mechanism postulated in here. I suppose we could give  
16 them credit for one mitigating action because they are  
17 adding zinc but you're going to have to come up  
18 with --

19                  DR. WALLIS: -- is that what it does?

20                  DR. SHACK: -- a position on leak-before-  
21 break. Well, it prevents cracking. At least that's  
22 part of the theory.

23                  MR. MEDOFF: What's your question?

24                  DR. SHACK: Just how do you credit them  
25 for leak-before-break when they don't meet the branch

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 position on what your need for leak-before-break.

2 MR. MEDOFF: I'm not the expert in this.  
3 My understanding is that the materials in Chemical  
4 Engineering Branch of NRR is looking into the impact  
5 of stress corrosion cracking on the assumptions made  
6 for leak-before-break analysis and how it's going to  
7 impact previous approvals granted for pressurized  
8 water reactors in the United States. My understanding  
9 is Matt Mitchell is the senior engineer that is  
10 responsible for that review and I can get more  
11 information on that if you need it.

12 DR. SHACK: I'm actually comfortable with  
13 the analysis. I think the cracking is not going to be  
14 that extensive. It's not going to grow that fast.  
15 Boric acid is a great leak detection system if nothing  
16 else.

17 MR. MEDOFF: My understanding is that is  
18 definitely being looked into right now and being  
19 discussed with the industry.

20 MS. LIU: And, finally, in summary we are  
21 seeing the conclusion that we mentioned earlier. The  
22 staff found that Farley license renewal application  
23 has met the requirements of 10 C.F.R. Part 54 in terms  
24 of scoping and screening, AMPs and AMRs, and TLAAs.

25 DR. WALLIS: Did you put up your 60 slides

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with no typos? That's a pretty good job.

2 MS. LIU: Thank you, Dr. Wallis. That  
3 concludes staff's presentation on the Farley draft  
4 SER.

5 DR. BONACA: Thank you. I would like to  
6 go around the table and see if there are any comments.  
7 Clearly this is the draft SER. I don't see many  
8 changes coming because they are open items and I  
9 thought that both the application and the SERs were  
10 high quality. I would like to go around the table  
11 maybe and start with you, Jack.

12 MR. SIEBER: I agree with your  
13 conclusions. This is the best one I've seen so far.

14 DR. SHACK: Yeah, I'll just put in a  
15 pitch. Whether you had to twist their arm or  
16 something, they did a very nice job on the fatigue  
17 program. I thought that was very nice, the fatigue  
18 monitoring program. And the discussion in the SER of  
19 the fatigue monitoring and the leak-before-break and  
20 the various reasons I thought was very good. As I  
21 mentioned before, I thought the whole organization of  
22 the SER was a very good one.

23 DR. BONACA: Graham.

24 MR. LEITCH: I have no further comments.  
25 I had a number of questions and I was satisfied with

1 the answers. I think the application was easy to  
2 follow and understandable. I also liked the audit and  
3 review report. I thought it was very well done.

4 DR. BONACA: Rich.

5 DR. DENNING: Best one I've seen so far.

6 DR. WALLIS: Does it meet your quality  
7 standards?

8 DR. BONACA: Graham.

9 DR. WALLIS: Well, I really liked the on-  
10 site audits record of that. That really helps me a  
11 lot. That really adds a lot to just checking off  
12 everything as according to GALL, but when you actually  
13 go there and talk to the people and dig in, I really  
14 appreciate that.

15 DR. BONACA: Vic.

16 DR. RANSOM: The only questions I had were  
17 answered during the presentation. It appeared good to  
18 me.

19 DR. BONACA: I agree with the fact that I  
20 mentioned before, the Farley application was a quality  
21 work and so was the SER. The presentation was very  
22 effective. I think, you know, looking at the plant  
23 itself there are a lot of initiatives there to  
24 maintain it in good condition from the placement of  
25 the heads, although there are no indication yet to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 other initiatives they have to maintain it.

2 Statements of the inspector that the plant  
3 looks better today than it looked eight to 10 years  
4 ago is also significant. I'm pretty encouraged by  
5 this application. I thank both of you and you for the  
6 If there are no further comments --

7 DR. SHACK: Oh, could I ask what the CDF  
8 is?

9 DR. DENNING: Today you mean?

10 MR. SIEBER: It's a three-loop  
11 Westinghouse plant.

12 DR. SHACK: Nobody knows?

13 MS. LIU: We can get back to you on that  
14 if you would like.

15 DR. SHACK: I would be interested. Add  
16 that to the list of things that really aren't part of  
17 the license renewal but we always like to know.

18 DR. WALLIS: This is a subcommittee so  
19 when you finish give us the CDF.

20 MS. LIU: Okay. Thank you.

21 DR. BONACA: Okay. Did you get the  
22 answer? No. Not yet.

23 MS. LIU: He's going to get back to us.

24 DR. WALLIS: You don't know what your CDF  
25 is? It must be a very important thing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. BONACA: With that commitment for some  
2 information there, I think I will adjourn this  
3 subcommittee meeting. Thank you very much.

4 (Whereupon, at 5:30 p.m. the meeting was  
5 adjourned.)  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE


This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards  
Plant License Renewal  
Subcommittee

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.



---

Rebecca Davis  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

# **Farley Nuclear Plant License Renewal Presentation to ACRS Subcommittee**

**Jan Fridrichsen**  
November 3, 2004

---



Nov 3, 2004

1



## **Introduction**

- Application and Background
- Description and Features of FNP
- Operating History
- Scoping Discussion
- Application of GALL
- Commitment Process
- Industry Issues

Nov 3, 2004

2



## **Application Background**


- Application submitted Sep 12, 2003
- Original license expiration:
  - Unit 1 - Jun 25, 2017
  - Unit 2 – Mar 31, 2021
- New Process
  - Consistent with GALL Audits
- Approximately 168 questions including RAIs, Supplemental and Followup

Nov 3, 2004

3

## **Description of FNP**

- Three-loop,  
Westinghouse PWR
- Bechtel/Southern  
Company Services-  
Architect/Engineers
- Initial Ops: Unit 1  
1977, Unit 2 1981
- Electrical capacity:  
910 megawatts/unit



Nov 3, 2004

4

## Plant Performance – Five Years



<u>Farley Unit 1</u>	1999	2000	2001	2002	2003
Capacity Factor (%)	97.4	71.5*	87.6	99.0	90.8
Outage Duration (days)	-	82.5*	41.2	-	35.4
Radiation Exposure (dual unit figures) (Rem)	95.2	179.9*	160.3*	48.2	55.5
<u>Farley Unit 2</u>	1999	2000	2001	2002	2003
Capacity Factor (%)	71.7	100.0	78.2*	87.6	100.4
Outage Duration (days)	60.3	-	74.3*	44.9	-

\*Steam Generator Replacement


Nov 3, 2004

5

## NRC Performance Indicators



- Initiating Events
- Mitigating Systems
- Barriers
- Emergency Preparedness
- Occupational and Public Radiation Safety
- Physical Protection



Nov 3, 2004

6

## **Features of FNP**

- Pre-stressed/post-tensioned dry Containment Building
- Safety-related Cooling Water Pond
- Six offsite power sources
- Five Emergency Diesel Generators
- Forced-draft Cooling Towers
- 18 Month Fuel Cycles

Nov 3, 2004

7

## **Operating History**

- Upflow Modification-1983 (U1)
  - Baffle jetting caused fuel failures
- Cracked tendon anchor head 1985 (U2)
  - Hydrogen induced stress cracking
- IEB 88-08 Pipe Crack U1-Dec 1988
  - Thermal cycling caused by valve leakage
- Zinc Addition project-1994 (U2), 1999 (U1)
  - Dose reduction benefit is evident
  - Reduce stress corrosion cracking susceptibility

Nov 3, 2004

8

## **Operating History (cont.)**

---

- Upgraded: 1998 Unit 1, 1998 Unit 2
  - Increased capacity by 123 MWt/unit
- SGs replaced in 2000 (U1)/2001 (U2)
  - Model 54F (Alloy 690 tubing, SS cruciform support plates, full depth roll)
- RV Head Replacement (Oct '04/'05)
  - Alloy 690 penetrations without thermal sleeves

Nov 3, 2004

9

## **Long Term Operation Focus**

---

- SG replacement
- RV Head replacement
- Cooling Tower replacement
- Dry Cask Storage installation
- Baffle Former Bolt replacement

Nov 3, 2004

10

## **FNP Scoping Methodology**

- Consistent with past applicants

Nov 3, 2004

11

## **GALL Comparison**

- SNC maximized the use of GALL
- Some material/environment/program combinations not addressed in GALL
- Plant-specific programs used as needed (or directed by GALL)

Nov 3, 2004

12

## **Key GALL Exceptions**

- Reactor Vessel Surveillance Program
  - One surveillance capsule (in each unit) will remain in the reactor vessel until approximately an 80-year fluence exposure. (GALL AMP XI.M31 specifies all remaining capsules are to be removed at a 60-year fluence exposure.)

Nov 3, 2004

13

## **Key GALL Exceptions (cont.)**

- Reactor Vessel Internals Program
  - Consistent with previously NRC-approved programs
  - Participation in industry initiatives to evaluate RV internals aging mechanisms and develop inspection guidance,
  - SNC will submit inspection plan for review and approval at least 24 months prior to period of extended operation.

Nov 3, 2004

14

## Key GALL Exceptions (cont.)



- Non-EQ Cables Used in Instrumentation Circuits
  - Consistent with previous NRC-approved programs
  - Program based on alternate XI.E2 program

Nov 3, 2004

15

## Key GALL Exceptions (cont.)



- Water Chemistry Control Program - Closed Cycle Cooling Water
  - Credit EPRI monitoring guidelines (e.g., inspections) in lieu of GALL performance testing for pumps and heat exchangers

Nov 3, 2004

16

## Minor GALL Exceptions



- Exceptions/clarifications where a GALL Program was utilized were primarily:
  - Use of different or later versions of codes and standards
  - Expansion of a program's scope beyond that described in GALL
  - Use of later NRC guidance

Nov 3, 2004

17

## Commitment Tracking




- Commitment
  - Commitments made through the LRA, RAI and audit/inspection process
  - Tracked with onsite Commitment Tracking System
  - Region II to perform commitment inspection
  - Approximately 130 commitments made to date

Nov 3, 2004

18



## Commitment Tracking System



Nov 3, 2004

19

## Industry Issues



- Bottom Mounted Instrumentation Inspection results (IEB 2003-02)
  - Inspections performed: U1 2003/2004, U2 2004
  - No degradation evident
- VC Summer Inspections (MRP 2003-039)
  - Inspections performed: U1-2004, U2-2004
  - Visual no degradation evident

Nov 3, 2004

20


## **Closing Remarks**

---

- Staff process was thorough and rigorous
- Consistent with GALL process added depth and clarity

Nov 3, 2004

21



# Joseph M. Farley Nuclear Plant Units 1 and 2 License Renewal Draft Safety Evaluation Report

Staff Presentation to the ACRS Subcommittee  
Tilda Liu, Project Manager  
Office of Nuclear Reactor Regulation  
November 3, 2004



# Agenda

- Overview and Highlights
- Review Process
- SER Section 2, Scoping and Screening
- License Renewal Inspections
- SER Section 3, AMPs and AMRs
- SER Section 4, TLAA
- Conclusion



# Overview

- First LRA to use newly revised NEI format
  - Table 1
  - Table 2
  - Standard Notes for tables
- First pilot license renewal review to fully implement consistency with GALL audits for AMP and AMR (new review process)



# Staff's Conclusion

- FNP LRA has met the requirements of 10 CFR Part 54
  - Scoping and Screening
  - AMPs and AMRs
  - TLAA



# Highlights of Review

- Draft SER issued on October 15, 2004
- No Open or Confirmatory Items
- Efficiencies gained from the new review process
  - Reduction in number of staff's Requests for Additional Information (RAIs)
  - Onsite audits provided direct and more effective interactions between the staff and the applicant, resulted in minimum formal correspondence



# RAI Related Statistics

- 163 RAIs issued via 17 letters
  - 62 on scoping and screening
  - 15 on AMPs
  - 70 on AMRs (including 3 from Audit Team)
  - 16 on TLAAs
- Number of RAIs for other LRAs
  - Summer (280), Robinson (360), and Ginna (224)
- 2 meetings and 56 conference calls
- Applicant also provide supplemental information to the LRA, in addition to RAI responses





# Highlights of Review (continued)

- 3 license conditions
  - FSAR update following the issuance of renewed licenses
  - Commitments completed in accordance with schedule
  - Reactor Vessel Surveillance Program
    - Continue meeting ASTM E 185-82 standards
    - NRC staff review and approval are required for any changes to:
      - Capsule withdrawal schedule
      - Capsule storage requirements



# Highlights of Review (continued)

- Brought into scope and subjected to AMR
  - Additional 10 CFR 54.4 (a)(2) components
    - 8 systems from Auxiliary Systems
    - 3 of which resulted AMR information revised
- 1 AMP added after LRA submittal
  - Plant-Specific AMP: Periodic Surveillance and Preventive Maintenance Activities Program




# NRC Review Process

- Scoping and Screening Methodology Audit
- Consistency with GALL Audits
- Table top [in-house] safety review
- Regional inspections
  - Scoping and Screening Inspection
  - AMP Inspection
  - Third (Optional) Inspection




# NRC Review Process (continued)

- AMP GALL Audit
  - November 3 – 7, 2003
- Scoping and Screening Methodology Audit
  - November 17 – 21, 2003
- AMR GALL Audit
  - December 15 – 19, 2003
- AMP/AMR Audit Exit Meeting
  - February 14 – 16, 2004
- Regional Scoping and Screening Inspection
  - May 10 – 14, 2004
- Regional AMP Inspection
  - September 20 – 24, 2004, and September 27 – October 1, 2004
- Regional Third (Optional) Inspection
  - March 1, 2005



## Summary for Section 2, Scoping and Screening

- The applicant's scoping methodology meets the requirements of 10 CFR 54.4
- Scoping and screening results included all SSCs within the scope of license renewal and subject to AMR as required by 10 CFR 54.21 (a)(1)



# Applicant's Revised Scoping Methodology Pertaining to 10 CFR 54.4 (a)(2)

- Initial mechanical scoping criteria for spray interaction for low-energy lines
  - Assumed a spray interaction of 20 ft radius
  - Limited valid targets to only electrical SSCs
- Revised mechanical scoping criteria for spray interaction for low energy lines
  - All fluid-bearing NSR SSCs, provided the NSR components are located in the same space as the SR SSCs
  - Sprays and leaks on mechanical, structure, and electrical SR SSCs, with no limitations on the duration of the leaks/sprays



## Section 2: Structures and Components Subject to Aging Management Review

- Section 2.1, Scoping and Screening Methodology
  - On-site audit November 17 - 21, 2003
  - Staff audit and review concluded that the applicant's methodology satisfies the rule
  - RAI
    - NSR criteria pursuant to 10 CFR 54.4 (a)(2)



## Section 2: Structures and Components Subject to Aging Management Review

- Section 2.2 , Plant Level Scoping Results
  - Staff identified SSCs that met 10 CFR 54.4(a)(2) criterion and additional components were brought into scope for 8 auxiliary systems
- Section 2.3, Scoping and Screening Results – Mechanical Systems
  - Reactor Vessel, Internals, and Reactor Coolant Systems
  - Engineered Safety Feature Systems
  - Auxiliary Systems
  - Steam and Power Conversion Systems





## Section 2: Structures and Components Subject to Aging Management Review

- Section 2.4, Scoping and Screening Results – Containments, Structures, and Component Supports
  - PWR Concrete Containment, Auxiliary Building, Diesel Generator Building, Turbine Building, Other Structures and Supports
- Section 2.5, Scoping and Screening Results – Electrical and Instrumentation and Control (I&C) Systems
  - 10 electrical and I&C commodity groups subject to AMR



# Scoping and Screening Summary

- The applicant's scoping methodology meets the requirements of 10 CFR 54.4
- Scoping and screening results included all SSCs within the scope of license renewal and subject to AMR as required by 10 CFR 54.21 (a)(1)



# License Renewal Inspections

- Scoping and Screening Inspection
- Aging Management Inspection
- Third (Optional) Inspection
- Commitment Tracking
- Plant Reactor Oversight Process (ROP)



# Scoping and Screening Inspection

- Objective: To determine whether the applicant has included all appropriate SSCs in the scope of license renewal as required by the Rule
- Conducted May 10 – 14, 2004
- Concluded that the applicant's scoping and screening process was successful in identifying those SSCs requiring AMR



# Aging Management Program Inspection

- Objective: To evaluate that existing AMPs are managing current age related degradation
- Conducted September 20 - 24, and September 27 - October 1, 2004
- Material condition of plant was being adequately maintained
- Documentation was detailed and comprehensive





# Third (Optional) Inspection

- Objective: To verify that the applicant has loaded future commitments into its commitment tracking system
- Scheduled for March 1, 2005




# Farley, Unit 1, 3Q/2004 Performance Summary






# Farley, Unit 2, 3Q/2004 Performance Summary







## Section 3: Aging Management Review Results

- Summary: FNP LRA met 10 CFR 54 for AMPs and AMRs
  - 3.0.3, Aging Management Programs
  - 3.1, Reactor Vessel, Internals, and Reactor Coolant System
  - 3.2, Engineered Safety Features Systems
  - 3.3, Auxiliary Systems
  - 3.4, Steam and Power Conversion Systems
  - 3.5, Containments, Structures and Component Supports
  - 3.6, Electrical Components




# GALL Review and Audits

- First pilot to fully utilize consistency with GALL audits for AMPs and AMRs
- Conducted on-site at SNC headquarters
- Staff review process described in SER Section 3.0.2
- GALL audit criteria
  - Consistency with GALL
  - No associated emerging issues or ISGs under development
  - Past precedents not used for FNP review



# GALL Review and Audits (continued)

- Consisted of NRC staff and contractors
- Site-specific Audit Plan
- Aging Management Program Audit (Nov. 3-7, 2003)
  - Consistent with GALL, including with exceptions and enhancements
  - SER Section 3.0.3
- Aging Management Review Audit (Dec 15-19, 2003, and Feb. 14-16, 2004)
  - AMR line items that are consistent with GALL
  - Extensive in-house review prior to going on-site
  - SER Sections 3.1 to 3.6



# Aging Management Programs (AMPs)

- Total 22 AMPs
  - 9 common AMPs
  - 13 component/structural group-specific AMPs
- Comprised of 8 existing, 5 enhanced, and 9 new AMPs
- GALL Consistency
  - Consistent with GALL: 8 (new AMPs: 2)
  - Consistent with GALL, with enhancements: 5
  - Consistent with GALL, with exceptions: 5 (new AMPs: 3)
  - Not consistent with GALL: 4 (new AMPs: 4)



# Examples of AMPs with GALL Deviations

- Fatigue Monitoring Program (consistent)
- One-Time Inspection Program
- Non-EQ Cables in Instrumentation Circuits Program



# Fatigue Monitoring Program

- New program will be consistent with GALL
- Specific components include:
  - PZR subcomponents
  - RPV shell and head
  - RPV inlet and outlet nozzles
  - RCL
  - Charging nozzles
  - SI nozzles
  - Class 1 piping  $\geq$  1 inch
  - Other Class 1 components
- FNP is currently using cycle counting method but will be modified to use fatigue monitoring software



# Fatigue Monitoring Program (continued)

- Stress based on-line fatigue monitoring will be conducted for the surgeline and lower region of the pressurizer
- Evaluated effects of environmental impact on fatigue comparable to NUREG/CR-6260 locations
- Operating Experience: FNP Unit 2 piping to loop B cold leg



# One-Time Inspection (OTI) Program

- New and plant-specific AMP
- Addressed by Commitment No. 10
- OTI program selects and inspects representative locations based on combinations of applicable materials/environment/aging effects
- OTI will be used for:
  - An aging effect that is not expected to occur
  - Validate the effectiveness of other credited AMPs
  - Aging is expected to progress very slowly





# One-Time Inspection Program (continued)

- Specific components included in sample population:
  - Pressurizer CASS spray head
  - RCS small bore butt-welded piping
  - RCP thermal barrier CCW nozzle
  - Components exposed to environments of selective leaching
  - CVCS letdown and charging/SI pump mini-flow orifices
  - External surface of service water piping in EDG building
  - TDAFWP lube oil coolers (fouling of the tubes)
  - Condensate Storage Tank
  - Fuel Oil Storage Tanks and EDG Day Tanks




# Non-EQ Cables Program

- A new program that will be consistent with GALL with an exception
- Exception: Non-EQ cables used in circuits with sensitive, high voltage, low-level signals are tested in accordance with the alternate XI.E2 program developed by the License Renewal Electrical Working Group (Commitment No. 12)
- Changes implemented by the applicant through the audit:
  - AMP revised to test all cables
  - AMP master document revised to include connectors



# Reactor Vessel Surveillance Program

- Existing AMP, consistent with GALL with one exception
- Future action is addressed by Commitment No. 18
  - FNP plans to remove all surveillance capsules prior to entering PEO
  - The applicant committed that for each unit, alternative dosimetry will be installed to monitor neutron fluence
- License condition
  - Continue meeting ASTM E 185-82 standards
  - Require NRC staff review and approval for any changes to capsule withdrawal schedule and storage requirements



# NiCrFe Component Assessment Program

- New and plant-specific AMP
- The program scope will include:
  - Nickel-based alloy RCS pressure boundary components
- FNP has committed via Commitment No. 11 to:
  - continue participating in industry initiatives
  - add implemented rankings and inspections consistent with latest EPRI-MRP recommendations
  - submit an inspection plan for NRC review and approval at least 24 months prior to period of extended operation (PEO)




## Section 3.1, Reactor Vessel, Internals, and Reactor Coolant System

- Reactor Vessel, Internals, and Reactor Coolant System include:
  - Reactor Vessel
  - Reactor Vessel Internals
  - Reactor Coolant System and Connected Lines (includes Reactor Coolant Pumps and Pressurizer)
  - Steam Generators
- Staff concluded that aging effects associated with reactor systems will be adequately managed by the associated AMPs during PEO



## Examples: AMR 3.1 RV, Internals, and RCS

- Loss of fracture toughness due to thermal aging
  - GALL: either enhanced volumetric examination or flaw tolerance evaluation be performed
- Leak before break (LBB) analyses cannot be taken as a substitute for the flaw tolerance evaluation
- The applicant committed to revise the LRA to be consistent with GALL



## Examples: AMR 3.1 RV, Internals, and RCS (continued)

- Under crack initiation and growth due to cyclic loading or SCC
  - The staff approved FNP's RI-ISI program in March 2004
  - RI-ISI will be used for selection of small-bore Class 1, butt weld locations for the one-time volumetric examination, but will not be used to eliminate volumetric OTI
  - The applicant identified 2"x3" drain connection on normal letdown line for UT



## Section 3.2, Engineered Safety Features Systems


- ESF Systems include:
  - Containment Spray System, Containment Isolation System, and Emergency Core Cooling System
- Aging Management Programs for ESF Systems
  - Water Chemistry Control Program
  - One-Time Inspection Program
  - External Surfaces Monitoring Program
  - Borated Water Leakage Assessment and Evaluation Program
- Staff concluded that aging effects associated with ESF systems will be adequately managed by associated AMPs for PEO





## Section 3.3, Auxiliary Systems

- 23 plant-specific systems
  - 11 AMPs that manage aging effects related to auxiliary system components
- Staff concluded that aging effects associated with auxiliary systems will be adequately managed by associated AMPs during PEO




## Section 3.4, Steam and Power Conversion Systems

- Steam and Power Conversion Systems (SPCS) include:
  - Main Steam System, Feedwater System, Steam Generator Blowdown System, Auxiliary Feedwater System, and Auxiliary Steam and Condensate Recovery System
- Aging Management Programs for SPCS
  - Water Chemistry Control Program
  - One-Time Inspection Program
  - Flow Accelerated Corrosion Program
  - Borated Water Leakage Assessment and Evaluation Program
  - External Surfaces Monitoring Program
  - Service Water Program
  - Periodic Surveillance and Preventive Maintenance Activities Program
- Staff concluded that aging effects associated with steam and power conversion systems will be adequately managed by the associated AMPs for PEO



## Section 3.5, Containments, Structures and Component Supports

- Containments, Structures and Component Supports include:
  - PWR Concrete Containment, Auxiliary Building, Diesel Generator Building, Turbine Building, Utility/Piping Tunnels, Water Control Structures, Steel Tank Structures, Yard Structures, and Component Supports
- Aging Management Programs for Containment Systems
  - Inservice Inspection Program
  - Water Chemistry Control Program
  - Structural Monitoring Program
  - Fire Protection Program
  - Borated Water Leakage Assessment and Evaluation Program
  - Service Water Pond Dam Inspection Program
- Staff concluded that aging effects associated with containments, structures, and component supports will be adequately managed by the associated AMPs for PEO



# Aging Management of In-Scope Inaccessible Concrete

	Aggressive Limit	FNP
pH	<5.5	6.7 – 7.1
Chlorides	>500 ppm	2.0 – 3.7 ppm
Sulfates	>1500 ppm	5.3 – 6.4 ppm

- Below grade environment is non-aggressive
- No history of aging degradation or failure of concrete components exposed to a below grade environment
- Phosphate ( $\text{PO}_4$ ) level is 0.03 ppm, sampled from Service Water Pond
- Phosphate level is below detectable limit in groundwater sample near the main power block structure



## Section 3.6, Electrical Components

- 10 component types subject to AMR
  - AMPs that will be used to manage aging effects
    - Non-EQ Cables Program
    - External Surfaces Monitoring Program
    - Buried Piping and Tank Inspection Program
  - Staff concluded that aging effects associated with electrical components will be adequately managed for PEO



## Section 4: Time-Limited Aging Analyses (TLAAs)

- Summary: TLAAs met the requirements of 10 CFR Part 54
  - 4.1, Identification of TLAAs
  - 4.2, Reactor Vessel Neutron Embrittlement
  - 4.3, Metal Fatigue
  - 4.4, Environmental Qualification of Electrical Equipment
  - 4.5, Other Plant Specific TLAAs



## Section 4.2, Reactor Vessel Neutron Embrittlement

- Five analyses affected by neutron irradiation embrittlement
  - Neutron Fluence
  - Upper-Shelf Energy
  - Pressurized Thermal Shock
  - Adjusted Reference Temperature
  - Pressure-Temperature (P-T) Limits



# Neutron Fluence

- Conforms with RG 1.190, "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence," March 2001





# Reactor Vessel Upper Shelf Energy (USE)

Reactor Vessel USE	Acceptance Criteria (ft-lb)	FNP Unit 1 Staff Calculated Value (ft-lb)	FNP Unit 2 Staff Calculated Value (ft-lb)
Limiting Beltline Materials	$\geq 50$	53.1	57.9

- Based on  $\frac{1}{4}T$  neutron fluence values at the end of extended period of operation (i.e., 54 EFPYs)
- Applicant calculated USE values were 52.8 ft-lb for Unit 1, and 58 ft-lb for Unit 2
- Meets USE requirements of 10 CFR Part 50, Appendix G, for PEO



# Pressurized Thermal Shock

Limiting Beltline Materials	$RT_{PTS}$ Criterion (°F)	Staff Calculated $RT_{PTS}$ (°F)
Lower Shell Plate B6919-1 (Unit 1)	$\leq 270$	195
Intermediate Shell Plate B7212-1 (Unit 2)	$\leq 270$	208.8

- Applicant calculated  $RT_{PTS}$  were 191 °F for Unit 1, and 208 °F for Unit 2
- Based on fluence values for the clad-to-base metal locations of the RVs
- Used latest reported surveillance capsule data for Units 1 and 2
- Meets requirements of 10 CFR 50.61 for PEO



# Adjusted Reference Temperature (ART)

ART	FNP Unit 1 Staff Calculated $RT_{NDT}$ (°F)	FNP Unit 1 Applicant Calculated $RT_{NDT}$ (°F)	FNP Unit 2 Staff Calculated $RT_{NDT}$ (°F)	FNP Unit 2 Applicant Calculated $RT_{NDT}$ (°F)
1/4T	185.1	182	195.8	195
3/4T	161.2	159	162.9	163

- Most limiting materials and locations: Unit 1 - Lower Shell Plate B6919-1; Unit 2 - Intermediate Shell Plate B7212-1
- FNP calculation of the 1/4T and 3/4T ART conforms with recommended guidelines in RG 1.99, rev. 2, and is acceptable



# Pressurizer-Temperature (P-T) Limits

- FNP 54-EFPY P-T limits for the PEO is based on an NRC-approved Pressure Temperature Limits Report (PTLR) process
- The applicant will generate P-T limits for the PEO in accordance with NRC-approved FNP PTLR



## Section 4.3, Metal Fatigue

- Fatigue of ASME Class 1 Components
- Fatigue of Reactor Coolant Pump Flywheel
- Fatigue of ASME Non-Class 1 Components
- Containment Tendon Pre-Stress




# Metal Fatigue (continued)

- Fatigue of ASME Class 1 Components
  - Evaluation of environmental effects indicated that two components may exceed the fatigue cumulative usage factor (CUF) of 1.0
    - Charging nozzle
    - RHR/SI nozzle to the RCS cold leg
  - The applicant committed to take corrective actions before the PEO (Commitment No. 14) via one or more of the four options it proposed



# Metal Fatigue (continued)

- Fatigue of Reactor Coolant Pump Flywheel
  - Based on bounding analysis of 6000 start/stop cycles, and .08 inches of allowable crack growth
  - FNP RCP flywheels have sufficient margin against fracture for PEO
- Fatigue of ASME Non-Class 1 Components
  - Based on ASME Class 2 and 3, and ANSI B31.1
  - Most piping systems bounded by 7000 thermal cycles, sampling system designed for 22000 cycles, and this number of cycles would not be exceeded
  - Analyses of these systems remain valid for the PEO
  - Evaluation of EDG air start system found that the equivalent number of full-temperature cycles will be less than 7000 cycles



# Containment Tendon Pre-Stress

- Applicant provided trending analysis
- Pre-stress forces projected for 40 and 60 years of operation

Tendon Type	Trend Line Value At 40 Years Kip/Tendon	Trend Line Value At 60 years Kip/Tendon	Minimum Required Value Kip/Tendon
Vertical	1215.5	1198.5	1157.7
Hoop	1156.0	1130.5	1021.7
Dome	1122.0	1088.0	1079.5





## Section 4.4, Environmental Qualification (EQ) of Electrical Equipment

- Applicant's EQ Program consistent with GALL AMP, X.E1, "Environmental Qualification of Electrical Components"
- The staff concluded that applicant's continued implementation of EQ Program is adequate to manage electrical equipment



## Section 4.5, Other Plant Specific TLAAs

- Ultimate Heat Sink Silting
- Leak-Before-Break (LBB) Analysis
- RHR Relief Valve Capacity Verification Calculations



# Ultimate Heat Sink (UHS) Siltling

- 1325 acre-feet for service water pond as the UHS was used in FSAR
- Average measured pond volume is 1418.5 acre-feet (12 sets of data over 22 years)
- Minimum recorded UHS pond volume is 1403 acre-feet (1984 surveillance data)
- Staff performed an independent regression analysis



# Leak-Before-Break (LBB) Analysis

- Applicant reanalyzed the LBB analysis and projected the analysis through the expiration of the PEO.
- Applicant's reanalysis included evaluation of the impacts of pertinent aging degradation mechanisms on the crack growth and crack size acceptance criteria for the analysis.
- Staff concluded that the applicant's TLAA for LBB met the criterion of 10 CFR 54.21(c)(1)(ii) and was acceptable.



# RHR Relief Valve Capacity Verification Calculations

- Applicant's future action is to update the analysis to include calculated 54 EFPY P-T limit curves before PEO (addressed in Commitment No. 15)



# Conclusion

- FNP LRA has met the requirements of 10 CFR Part 54
  - Scoping and Screening
  - AMPs and AMRs
  - TLAA