



Entergy

Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 501 858 5000

OCAN110403

November 15, 2004

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Revision to General Design Criterion 57 Exemption Request
Arkansas Nuclear One, Units 1 & 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51, NPF-6

Dear Sir or Madam:


By letter dated October 30, 2003, (OCAN100302), Entergy Operations, Inc. (Entergy) requested exemptions from the requirements of General Design Criteria (GDC) 57 of 10CFR50 Appendix A for Arkansas Nuclear One (ANO), Units 1 and 2. Specifically, Entergy requested an exemption from the requirements of GDC 57 to operate at power with the manual isolation valves for the ANO-1 and ANO-2 Emergency Feedwater System steam traps and the ANO-2 atmospheric dump valve (ADV) drain steam trap in the open position.

The purpose of this letter is to include the ANO-1 ADV drain steam trap in the previously referenced exemption request. As documented in the previous submittal, operating with steam trap isolation valves upstream of the main steam isolation valves open does not affect the consequences of any of the accidents analyzed in the Safety Analysis Reports of either ANO unit.

If you have any questions or require additional information, please contact Richard Scheide at 479-858-4618.

There are no commitments contained in this letter.

Sincerely,



Dale E. James
Director, Nuclear Safety Assurance (Acting)

DEJ/rhs

A001

cc: Dr. Bruce S. Mallett
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Mr. Drew Holland
Mail Stop 0-7 D1
Washington, DC 20555-0001

U. S. Nuclear Regulatory Commission
Attn: Mr. Thomas Alexion
Mail Stop 0-7 D1
Washington, DC 20555-0001