1. SRN Number: MGFE-SRN- 330 100 9/20/04					
2. Project Title: Repository Design and Thermal- Mechanical Effects Code Development–PCSAProject No. 20.06002.01.103					
3. SRN Title: PCSA Tool Version 3.0.0					
4. Originator/Requestor: George Adams Date:	: Sep. 17, 2004				
5. Summary of Actions					
□ Release of new software □ Change of access	s software				
☑ Release of modified software: □ Software F	Retirement				
☑ Enhancements made					
Corrections made					
6. Validation Status					
☑ Validated					
Limited Validation					
L Not validated Explain:					
7. Demons Arthurized Access					
7. Persons Authorized Access	<u> </u>				
Name Read Only/Read-Write Addi	tion/Change/Delete				
CNWRA Staff Read / Execute Addi NBC Staff Addi	tion				
NRC StallRead / ExecuteAddiNorm EisenbergRead / ExecuteAddi	tion				
o. Element Manager Approval: 9-17-2004					

SOFTWARE SUMMARY FORM

01. Summary Date: September 17, 2004	02. Summary prepared by (Na George Adams, (210) 522-49	03. Summary Action: REPLACEMENT		
04. Software Date: September 17, 2004	05. Short Title: PCSA Tool Version 3.0.0			
06. Software Title: Preclosure Safety Analysis T	ool Version 3.0.0		07. Internal Software ID: none	
08. Software Type:	09. Processing Mode:	10. Application Area		
□ Automated Data System	☑ Interactive	a. General:	Auxiliant Analyses	
Computer Program	□ Batch	□ Total System PA	Other	
□ Subroutine/Module	□ Combination	Jmer		
11. Submitting Organization CNWRA/SwRI 6220 Culebra Road San Antonio, TX 78228	and Address:	12. Technical Contact(s) and Phone: George Adams, (210) 522-4957		
13. Software Application:The software is used to perform preclosure safety analysis. It is an interactive program in which the user enters data that is stored in a database. The software retrieves, stores, and displays information from the database.				
14. Computer Platform IBM compatible PC	15. Computer Operating System: Windows XP	16. Programming Language(s): Visual Basic 6.0	17. Number of Source Program Statements: Greater than 5,000	
18. Computer Memory Requirements: not known	19. Tape Drives: N/A 20. Disk Units: N/A		21. Graphics: No special graphics required	
22. Other Operational Requirements No other special operational requirements				
23. Software Availability: ☑ Available □ Limited	□ In-House ONLY	24. Documentation Availabili ☑ Available □ Preliminat	ty: ry □In-House ONLY	
25. George Adams Software Developer: 17,2004 Date: Date: Date: 17,2004				

CNWRA Form TOP-4-1 (05/98)

CENTER FOR NUCLEAR WASTE REGULATORY ANALYSES QA VERIFICATION REPORT				
-> DEVELOPE	D OR ACQUIRED TO BE MODIFIED SOF	TWARE 🗲	•	1
Software Title/Name: Version: Demonstration workstation: Operating System: Developer:	PCSA Tool 3.0.0 PC Windows XP G. adams			
Software Requirements Descriptio	n (SRD) [TOP-018, Section 5.3]			
SRD Version: SRD Approval Date:	SRD-PCSA Tool 3.0.0 December 9,2003	······································		
SRD and any changes thereto review	ed in accordance with QAP-002 requirements?			
		Yes: 🗖	No: 🗶	N/A: 🗖
Is a Software Change Report(s) (SC configured version of software?	R) used for minor modifications (i.e., acquired	code), prot	olems or ch	anges to a
Comments: 431-438, 506-514, 531, 537, 539-541 Yes: № No: N/A: D				
Software Development Plan (SDP)	[TOP-018, Section 5.4]			
SDP Version: SDP (EM) Approval Date:	PCSA Tool 3.0.0 6/3/2004			
The SDP addresses applicable sectio	ns of TOP-018, Appendix B, SDP Template?			
		Yes: 🗗	No: 🗖	N/A: 🗖
Is the waiver (if used) in accordance	with specified guidelines?			
Comments:		Yes: 🗖	No: 🗖	N/A: 🗶
Design and Development [TOP-018, Section 5.5.1 - 5.5.4]				
Is code development in accordance with the conventions (i.e., coding conventions) described in the SDP/SCR?				
Module(s) Reviewed:		Yes: 🗶	No: 🗖	N/A: 🗖
Comments:				

. -

CENTER FOR NUCLEAR WASTE REGULATORY ANALYSES QA VERIFICATION REPORT FOP				
→ DEVELOPED OR ACQUIRED TO BE MODIFIED SO	FTWARE ←			
Is code internally documented to allow a user to understand the function(s) being p execution of individual routines?	performed and	l to follow t	he flow of	
	Yes:	No: 🗖	N/A: 🗖	
Module(s) Reviewed:				
Comments:				
Is development of the code and informal module/subroutine-level testing docume SCR?	ented in scien	tific notebo	ook and/or	
SCR's and/or Scientific Notebook(s) Reviewed:	Yes: 🕱	No: 🗖	N/A: 🗖	
Comments: Dientific Notebook @ 14 and applicable	SCK's.			
Software designed so that individual runs are uniquely identified by date, time, na	me of softwar	e and versi	on?	
Date and Time Displayed:	Yes: 🗖	No: 🗖	N/A: 🙀	
Name/Version Displayed:				
Comments: Interactive rather than batch.				
Medium and Header Documentation [TOP-018, Section 5.5.6]				
A program title block of main program contains: Program Title, Customer Name, Cu Contact(s), Customer Phone Number, Associated Documentation, Software Develo	stomer Officor	e/Division,	Customer	
		ie i tumber,	Date, and	
Disclaimer Notice?	Yes: 🗶	No: 🗖	Date, and N/A: □	
Disclaimer Notice? Comments:	Yes: 🗶	No: 🗖	Date, and N/A: □	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer	Yes: 🗶	No: 🗖	Date, and N/A: □ , Revision	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)?	Yes: 🗶 rence, Revisio Yes: 🗶	No: Don Number, No: D	Date, and N/A: □ , Revision N/A: □	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)? Module(s) Reviewed:	Yes: 🗶 rence, Revisio Yes: 🗶	No: D n Number, No: D	Date, and N/A: , Revision N/A:	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)? Module(s) Reviewed: Comments:	Yes: 🗶 rence, Revisio Yes: 🗶	No: Don Number, No: D	Date, and N/A: , Revision N/A:	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)? Module(s) Reviewed: Comments: The physical labeling of software medium (tapes, disks, etc.) contains: Program N Revision, File type (ASCII, OBJ, EXE), Recording Date, and Operating System(s)	Yes: 🗶	No: on Number, No: /Name/Title	Date, and N/A: , Revision N/A: e, Module	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)? Module(s) Reviewed: Comments: The physical labeling of software medium (tapes, disks, etc.) contains: Program N Revision, File type (ASCII, OBJ, EXE), Recording Date, and Operating System(s) Comments:	Yes: 🗶	No: on Number, No: /Name/Title No:	Date, and N/A: □ , Revision N/A: □ e, Module N/A: □	
Disclaimer Notice? Comments: Source code module headers contain: Program Name, Client Name, Contract refer History, and Reference to SRD/SCR requirement(s)? Module(s) Reviewed: Comments: The physical labeling of software medium (tapes, disks, etc.) contains: Program N Revision, File type (ASCII, OBJ, EXE), Recording Date, and Operating System(s) Comments:	Yes: 🗶	No: on Number, No: /Name/Title No:	Date, and N/A: □ , Revision N/A: □ e, Module N/A: □	

, "

....

CENTER FOR NUCLEAR WASTE REGULATORY ANALYSES QA VERIFICATION REPORT FOR →DEVELOPED OR ACQUIRED TO BE MODIFIED SOFTWARE ←				
Are code reviews (if implemented) documented in a scientific notebook or in ano understand the code review process and results?	ther format	that allows	others to	
Documented in Scientific Notebook No.:	Yes: 🗖	No:	N/A: 🛛	
Comments:				
Acceptance and Installation Testing [TOP-018, Section 5.6]				
Does acceptance testing demonstrate whether or not requirements in the SRD and/o	r SCR(s) ha	we been ful	filled?	
ger all SCLs testing performed and reviewed	Yes: 🗶	No: 🗖	N/A: 🗖	
Has acceptance testing been conducted for each intended computer platform and op	erating syst	em?		
Computer Platforms: PC Operating Systems: Windows XP	Yes: 🗶	No: 🗖	N/A: 🗖	
Location of Acceptance Test Results: SCR 5 + Dcientific Notelook 635 F				
Comments:				
Has installation testing been conducted for each intended computer platform and op	erating syst	em?		
Computer Platforms: Operating Systems: Windows X f	Yes: 🔏	No: 🗖	N/A: 🗖	
Location of Acceptance Test Results: Dee above				
Comments:				
User Documentation [TOP-018, Section 5.5.7]				
Is there a Users' Manual for the software and is it up-to-date?	Yes: 🗖	No:	N/A: 🗖	
User's Manual Version and Date: <u>MCSA Joel Vá</u> .O Comments: Reference E-mail to G. adam from R. 8/2/2004 resording Users Manual	Влин V 2.0	1		

Page 3 of 5

(04/01)

, `•

.>

CENTER FOR NUCLEAR WASTE REGULATORY ANALYSES QA VERIFICATION REPORT FOR DEVELOPED OF ACQUIRED TO BE MODIFIED SOFTWARE &				
- DEVELOPED OK ACQUIKED IO BE MODIFIED SOF	TWAKE			
Are there basic instructions for the <i>installation</i> and <i>use</i> of the software?	6			
Location of Instructions: User manual V2.0	Yes: 🗖	No: 🗖	N/A: 🗖	
Comments:				
Configuration Control [TOP-018, Section 5.7, 5.9.3]				
Is the Software Summary Form (Form TOP-4-1) completed and signed?	Yes:	No: 🗖	N/A: 🗖	
Date of Approval:///////				
Is the list of files attached to the Software Summary Form complete and accurate?		No. 🗂	N7/A · 🗂	
Comments: On CD	1 es. 🖵	110.	іч/А. Б	
Is the source code available or, is the executable code available in the case of (acqu	ired/comme	ercial codes)?	
Location of Source Code:CD	Yes:	No: 🗖	N/A: 🛛	
Comments:			-	
Have all the script/make files and executable files been submitted to the Software C	ustodian?			
Location of script/make files: <u>CD - PCSA V3.</u> 0.0 in QA R.e.	Yes: X	No: 🗖	N/A: 🗆	
Comments:				
Coffigure Delager (TOD-018 Section 5 0)				
			· , ,	
does the version number of the software match the documentation?	(N), Form 1	OP-6 been	issued and	
	Yes:	No: 🗖	N/A: 🗖	
SRN Number: 330	Ň			
Comments:				
Software Validation [TOP-018. Section 5.10]				

(04/01)

. ••

CENTER FOR NUCLEAR WASTE REGULATORY ANALYSES QA VERIFICATION REPORT FOR →DEVELOPED OR ACQUIRED TO BE MODIFIED SOFTWARE ←
Has a Software Validation Test Plan (SVTP) been prepared for the range of application of the software?
Yes: X No: N/A: Version and Date of SVTP: 3.0.0 10/6/03 Test Report 3.0.0 9/15/04
Date Reviewed and Approved via QAP-002: 10/6/03
Comments:
Has a Software Validation Test Report (SVTR) been prepared that documents the results of the validation cases, interpretation of the results, and determination if the software has been validated?
Version and Date of SVTR: Ruision 0 9/15/04 Yes: No: NA: D
Date Reviewed and Approved via QAP-002: 9/15/2064
Comments:
Additional Comments:
Bine 1 (1) al 9/20/04 Software Developer/Date Software Custodian/Date 9/20/04

, **`**

SOFTWARE VALIDATION TEST REPORT SUMMARY FOR PCSA TOOL VERSION 3.0.0

Center for Nuclear Waste Regulatory Analyses Southwest Research Institute San Antonio, Texas

Prepared by

George Adams Troy Maxwell

Asadul H. Chowdhury Manager, Mining, Geotechnical, and Facility Engineering

9-15-04

Date

CONTENTS

Section	ר P.	age
1.0	INTRODUCTION 1.1 Purpose 1.2 Background	. 1 . 1 . 1
2.0	SCOPE OF THE VALIDATION	. 1
3.0	REFERENCES	. 2
4.0	SOFTWARE VALIDATION TEST REPORTS	. 2
5.0	NOTES	. 5

1.0 INTRODUCTION

1.1 Purpose

The Preclosure Safety Analysis (PCSA) Tool has been developed for use by U.S. Nuclear Regulatory Commission (NRC) and Center for Nuclear Waste Regulatory Analyses (CNWRA) staff to conduct a systematic independent analysis and review of the U.S. Department of Energy (DOE) preclosure safety analysis for a proposed repository at Yucca Mountain, Nevada. As part of a license application for construction authorization and a subsequent license amendment to receive and possess waste at the proposed repository, the DOE must conduct a preclosure safety analysis for the period until permanent closure. The PCSA Tool will be used to identify areas of vulnerability in the DOE safety analysis, to assess the DOE calculation of radiological consequences to workers and the public, and to evaluate the identification of structures, systems, and components important to safety.

This Software Validation Test Report (SVTR) Summary was prepared to document validation testing of PCSA Tool Version 3.0.0. It is intended to supplement the previously reviewed and approved Software Validation Test Plan (SVTP) by providing documentation for the individual validation tests performed. Individual validation tests are documented on the attached SVTRs.

1.2 Background

The PCSA Tool is structured around a preclosure safety analysis review methodology, which is based on both the requirements and objectives of 10 CFR Part 63 and the guidance provided in Yucca Mountain Review Plan (NRC, 2003). The structures, modules, and data flow within the PCSA Tool are described in Chapter 2 of the PCSA Tool Version 2.0 User Guide.

Validation testing was performed on PCSA Tool Version 3.0.0 using the SVTP as a reference. Section 6 of the SVTP describes the individual validation tests required. During validation testing, SVTRs were completed to document how individual tests were conducted, to identify the results obtained, and to indicate whether the test was passed. In addition, these SVTRs refer to the appropriate sections of the SVTP that were used while conducting the test. Section 6.14 of the SVTP describes testing for functionality added to the PCSA Tool which was not present at the time the SVTP was written. The SVTRs for this additional functionality document the testing by describing the procedure used and describing the results obtained.

2.0 SCOPE OF THE VALIDATION

PCSA Tool Version 3.0.0 is projected to be used for reviewing the preclosure safety analysis in a potential license application for the proposed repository at Yucca Mountain. Hence, PCSA Tool Version 3.0.0 is the subject of this validation test, and this validation testing is a complete validation for PCSA Tool Version 3.0.0.

A large part of the PCSA Tool's functionality involves the manipulation of data to include: (i) the display of data on the screen and in the form of reports, (ii) the storage and retrieval of data to and from a database, and (iii) the supply and retrieval of data to and from standalone code modules. Therefore, much of the validation testing focused on this data manipulation.

In addition to data manipulation, the PCSA Tool is used to invoke standalone code modules. In some cases data is sent to and retrieved from the standalone code modules in addition to invoking them (e.g., RSAC), and in other cases, the standalone code modules are invoked without being supplied with data (e.g., SAPHIRE). Whenever a standalone code module was part of a validation test, it was identified in the Test Environment Setup, Software section of the SVTR.

The following software was not developed as part of the PCSA Tool but will be released with PCSA Tool Version 3.0.0: (i) RSAC Version 6.2, (ii) MELCOR Version 1.8.5, and (iii) SAPHIRE Version 6.80. RSAC Version 6.2 and MELCOR Version 1.8.5 have been validated; however, SAPHIRE Version 6.80 validation has not been completed. SAPHIRE Version 6.80 validation is projected for September 2004.

3.0 REFERENCES

Adams, G., T. Maxwell, B. Dasgupta, and R. Benke. "Software Validation Test Plan for PCSA Tool Version 3.0." San Antonio, Texas: CNWRA. September 2003.

Adams, G., T. Maxwell, R. Benke. "Software Validation Test Report for RSAC Version 6.2." San Antonio, Texas: CNWRA. January 2004.

Benke, R. "Analytical and Numerical Solutions of the Expected Number of Occurrences for Combinations of Event Sequences due to Variability." San Antonio, Texas: CNWRA. December 2003.

Benke, R. "Software Validation Test Plan for MELCOR Version 1.8.5." San Antonio, Texas: CNWRA. October 2001.

Dasgupta, B., R. Benke, B. Sagar, R. Janetzke, and A. Chowdhury. "PCSA Tool Development Progress Report II." San Antonio, Texas: CNWRA. September 2002.

Dasgupta, B., R. Benke, T. Maxwell, and N. Eisenberg. "PCSA Tool Version 2.0 User Guide." San Antonio, Texas: CNWRA. June 2003.

Dasgupta, B., R. Benke, G. Adams. "Software Requirements Description for the PCSA Tool Version 3.0 (Revision 04)." San Antonio, Texas: CNWRA. July 2002.

Dasgupta, B. "Software Validation Test Report for SAPHIRE Version 6.80." San Antonio, Texas: CNWRA. September 2004 (projected date).

4.0 SOFTWARE VALIDATION TEST REPORTS

All validation testing is documented on individual SVTRs which are included with this summary. The following table is provided to link the test case from the SVTP with its associated SVTR and supporting files. SVTRs and supporting files are included on the attached CD.

Test Case	SVTR ID	Associated Files
Section 6.1 Project Tree	1-1	SVTRs\SVTR_1\SVTR_1-1.wpd SVTRs\SVTR_1\1-1.pdf
Section 6.2 External Events	2-1	SVTRs\SVTR_2\SVTR_2-1.wpd SVTRs\SVTR_2\2-1.pdf SVTRs\SVTR_2\2-2.pdf
Section 6.3.1 System—System Description	3-1	SVTRs\SVTR_3\SVTR_3-1.wpd SVTRs\SVTR_3\3_1_1.pdf SVTRs\SVTR_3\3_1_2.pdf SVTRs\SVTR_3\3_1_3.pdf SVTRs\SVTR_3\3_1_4.pdf SVTRs\SVTR_3\3_1_5.pdf SVTRs\SVTR_3\3_1_6.pdf SVTRs\SVTR_3\3_1_6.pdf SVTRs\SVTR_3\3_1_7.pdf SVTRs\SVTR_3\3_1_8.pdf SVTRs\SVTR_3\3_1_9.pdf
Section 6.3.2 System—Structures, Systems, and Components (SSCs)	3-2	SVTRs\SVTR_3\SVTR_3-2.wpd SVTRs\SVTR_3\3_2_1.pdf SVTRs\SVTR_3\3_2_2.pdf
Section 6.4.1 Internal Events—FMEA	4-1	SVTRs\SVTR_4\SVTR_4-1.wpd SVTRs\SVTR_4\4_1.pdf
Section 6.4.2 Internal Events—What If	4-2	SVTRs\SVTR_4\SVTR_4-2.wpd SVTRs\SVTR_4\4_2.pdf
Section 6.4.3 Internal Events—Energy Method	4-3	SVTRs\SVTR_4\SVTR_4-3.wpd SVTRs\SVTR_4\4_3.pdf
Section 6.4.4 Internal Events—HRA	4-4	SVTRs\SVTR_4\SVTR_4-4.wpd SVTRs\SVTR_4\4_4.pdf
Section 6.4.5 Internal Events—Severe Events (All)	4-5	SVTRs\SVTR_4\SVTR_4-5.wpd SVTRs\SVTR_4\4_5.pdf
Section 6.5.1 Frequency Analysis—Initiating Event	5-1	SVTRs\SVTR_5\SVTR_5-1.wpd SVTRs\SVTR_5-51.pdf
Section 6.5.2 Frequency Analysis—Event Tree	5-2	SVTRs\SVTR_5\SVTR_5-2.wpd SVTRs\SVTR_5\5-2-1.pdf SVTRs\SVTR_5\5-2-2.pdf
Section 6.5.3 Frequency Analysis—Fault Tree	5-3	SVTRs\SVTR_5\SVTR_5-3.wpd SVTRs\SVTR_5\5-3-1.pdf SVTRs\SVTR_5\5-3-2.pdf
Section 6.5.4 Frequency Analysis—Event Sequence	5-4	SVTRs\SVTR_5\SVTR_5-4.wpd SVTRs\SVTR_5\5-4.pdf

Test Case	SVTR ID	Associated Files
Section 6.6 SAPHIRE	6-1	SVTRs\SVTR_6\SVTR_6-1.wpd
Section 6.7.1 Consequence Analysis—Consequence Worker Dose	7-1-1	SVTRs\SVTR_7\SVTR_7-1-1.wpd SVTRs\SVTR_7\WorkerDose.xls SVTRs\SVTR_7\WorkerDosefromPoo IRelease2min.xls
Section 6.7.2.1.1 Consequence Analysis—RSAC Execution Standard Input-Deterministic	7-2-1	SVTRs\SVTR_7\SVTR_7-2-1.wpd SVTRs\SVTR_7\7-2-1A_Rsac6.out SVTRs\SVTR_7\7-2-1B_Rsac6.out SVTRs\SVTR_7\7-2-1C_Rsac6.out SVTRs\SVTR_7\7-2-1D_Rsac6.out SVTRs\SVTR_7\7-2-1-Aout.pdf SVTRs\SVTR_7\7-2-1-Bout.pdf SVTRs\SVTR_7\7-2-1-Cout.pdf SVTRs\SVTR_7\7-2-1-Dout.pdf SVTRs\SVTR_7\7-2-1-Ain.pdf SVTRs\SVTR_7\7-2-1-Bin.pdf SVTRs\SVTR_7\7-2-1-Cin.pdf SVTRs\SVTR_7\7-2-1-Din.pdf
Section 6.7.2.1.2 Consequence Analysis—RSAC Execution Standard Input-Deterministic-User Specified	7-2-2	SVTRs\SVTR_7\SVTR_7-2-2.wpd SVTRs\SVTR_7\7-2-2A_Rsac6.out SVTRs\SVTR_7\7-2-2B_Rsac6.out SVTRs\SVTR_7\7-2-2-Aout.pdf SVTRs\SVTR_7\7-2-2-Bout.pdf SVTRs\SVTR_7\7-2-2-Ain.pdf SVTRs\SVTR_7\7-2-2-Bin.pdf
Section 6.7.2.1.3 Consequence Analysis—RSAC Execution Advanced Input	7-2-3	SVTRs\SVTR_7\SVTR_7-2-3.wpd SVTRs\SVTR_7\7-2-3_RSAC6.OUT
Section 6.7.2.1.4 Consequence Analysis—RSAC Execution Standard Input-Probabilistic-Four Realizations	7-2-4	SVTRs\SVTR_7\SVTR_7-2-4.wpd SVTRs\SVTR_7\7-2-4_lhs.out SVTRs\SVTR_7\7-2-4_Rsac6.out
Section 6.7.2.1.5 Consequence Analysis—RSAC Execution Standard Input-Probabilistic-Ten Realizations	7-2-5	SVTRs\SVTR_7\SVTR_7-2-5.wpd SVTRs\SVTR_7\7-2-5_lhs.out SVTRs\SVTR_7\7-2-5_Rsac6.out SVTRs\SVTR_7\7-2-5.xls SVTRs\SVTR_7\7-2-5A.xls SVTRs\SVTR_7\distribution-7-2.A.xls
Section 6.7.2.2.1 Consequence Analysis—MELCOR Execution-PWR	7-2-6	SVTRs\SVTR_7\SVTR_7-2-6.wpd SVTRs\SVTR_7\7-2-6_8mel.doc
Section 6.7.2.2.2 Consequence Analysis—MELCOR Execution-BWR	7-2-7	SVTRs\SVTR_7\SVTR_7-2-7.wpd SVTRs\SVTR_7\7-2-7_8mel.doc

Test Case	SVTR ID	Associated Files
Section 6.8.1.1 Performance Analysis—Safety Assessment-Current Level Results	8-1	SVTRs\SVTR_8\SVTR_8-1.wpd SVTRs\SVTR_8\8-1_1.pdf SVTRs\SVTR_8\8-1_2.pdf SVTRs\SVTR_8\8-1_3.pdf SVTRs\SVTR_8\8-1_4.pdf SVTRs\SVTR_8\calc_8.xls (tab 8-1)
Section 6.8.1.2 Performance Analysis—Safety Assessment- Compliance Assessment	8-2	SVTRs\SVTR_8\SVTR_8-2.wpd SVTRs\SVTR_8\8-2_1.pdf SVTRs\SVTR_8\8-2_2.pdf SVTRs\SVTR_8\8-2_3.pdf SVTRs\SVTR_8\calc_8.xls (tab 8-2a, 8-2b)
Section 6.8.1.3 Performance Analysis—Safety Assessment- Structures, Systems, and Components Important to Safety (SSCIS)	8-3	SVTRs\SVTR_8\SVTR_8-3.wpd SVTRs\SVTR_8\8-3_1.pdf SVTRs\SVTR_8\8-3_2.pdf SVTRs\SVTR_8\calc_8.xls (tab 8-3)
Section 6.8.2 Performance Analysis—Risk Assessment	8-4	SVTRs\SVTR_8\SVTR_8-4.wpd SVTRs\SVTR_8\8-4_1.pdf SVTRs\SVTR_8\8-4_2.pdf SVTRs\SVTR_8\calc_8.xls (tab 8-4)
Section 6.9 Software Reliability	9-1	SVTRs\SVTR_9\SVTR_9-1.wpd SVTRs\SVTR_9\9-1.pdf
Section 6.10.1 Failure Rate—View Taxonomy	10-1	SVTRs\SVTR_10\SVTR_10-1.wpd
Section 6.10.2 Failure Rate—Search Database	10-2	SVTRs\SVTR_10\SVTR_10-2.wpd
Section 6.10.3 Failure Rate—Failure calculator	10-3	SVTRs\SVTR_10\SVTR_10-3.wpd
Section 6.10.4 Failure Rate—Human Error Probability (HEP) Generator	10-4	SVTRs\SVTR_10\SVTR_10-4.wpd
Section 6.11 Checklists	11-1	SVTRs\SVTR_11\SVTR_11-1.wpd
Section 6.12 Regulations	12-1	SVTRs\SVTR_12\SVTR_12-1.wpd
Section 6.13 Help	13-1	SVTRs\SVTR_13\SVTR_13-1.wpd
Section 6.14 Additional Functionality—Worker Dry Form	14-1	SVTRs\SVTR_14-1\SVTR_14-1.wpd SVTRs\SVTR_14-1\14-1.xls

Test Case	SVTR ID	Associated Files
Section 6.14 Additional Functionality—Worker Downwind Dose	14-2	SVTRs\SVTR_14-2\SVTR_14-2.wpd SVTRs\SVTR_14-2\14-2.xls
Section 6.14 Additional Functionality—Display Images	14-3	SVTRs\SVTR_14-3\SVTR_14-3.wpd
Section 6.14 Additional Functionality—Highlight Doses and Dose Rates Above Limits (Performance Assessment)	14-4	SVTRs\SVTR_14-4\SVTR_14-4.wpd SVTRs\SVTR_14-4\14-4_1.pdf SVTRs\SVTR_14-4\14-4_2.pdf SVTRs\SVTR_14-4\14-4_3.pdf
Section 6.1.4 Additional Functionality Saving the System Log and Database	14-5	SVTRs\SVTR_14-5\SVTR.14-5.wpd

5.0 NOTES

At the time that the SVTP was written, some functionality was not present in the PCSA Tool, and it wasn't at that time possible to determine the scope of the changes that were yet to be made to the software. Therefore, the individual SVTRs identify when procedures were modified from the SVTP or changes in input data were required from that listed in the SVTP.

The SVTP calls for validation testing on a Windows NT 4.0/Windows XP machine. Instead, due to availability, one validation tester performed some of the validation tests on a Windows 2000 machine and a second validation tester performed the remaining tests on a Windows XP machine. The individual SVTRs identify the operating system used for the test. Software validation was not performed on a Windows NT 4.0 machine.

Validation testing started with Version 3.0 BetaN of the PCSA Tool and continued with subsequent versions (BetaP, BetaQ, etc.). As errors were found in the PCSA Tool during validation testing or upgrades were performed (e.g., upgrading SAPHIRE to Version 6.80), changes were implemented, tested, and then documented on SCRs. Afterwards, a new version of the software was made available for validation testing.

Software Validation Test Reports (SVTRs)

Software Validation Test Report (SVTR)

2015 S 18

SVTR#: 1-1	Project #: 20.060002.01.103						
Software Name: PCSA Tool		Version: 3.0 (Beta N)					
Test ID: 6.1	Test Series Name: Pro	iect Tree					
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> 	Method						
<u>Test Envir</u>	onment Setup						
Hardware (platform, peripherals): Machine pi	tor, Windows XP						
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	i <u>des or scripts):</u> PCSA To	ool Version 3.0 BetaN					
Input Data (files, database, mode settings): In 6.1.1 of the SVTP for PCSA Tool Version 3.0	nput information in accor	dance with Section					
Assumptions, constraints, and/or scope of ter Assumptions or constraints: none Scope of the test: This test verifies the projec correctly in the database into the proper func	Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: This test verifies the project tree is built correctly and the input is stored correctly in the database into the proper functional areas within the tree structure						
<u>Test Procedure:</u> Tested in accordance with s 3.0 except the Saphire Project Location is no	<u>Test Procedure:</u> Tested in accordance with section 6.1.2 of the SVTP for PCSA Tool Version 3.0 except the Saphire Project Location is no longer entered.						
<u>Test</u>	Results						
The level information and remarks appear correctly on the PCSA Project Tree Report after exiting and re-entering the PCSA Tool.							
Test results are attached.							
Test Evaluation (Pass/Fail): Pass							
<u>Notes:</u> None.							
Tester: George Adams bury hans	Date: July 29, 2004						

PCSA Project Tree Report

Project: valid_1_1

Functional ID	1st Level	2nd Level	3rd Level	4th Level	Remarks
A.1.2.3	Node A	Node A1	Node A2	Node A3	Functional Area A
B.1.2.3	Node B	Node B1	Node B2	Node B3	Functional area B

l

.

Software Validation Test Report (SVTR)

i .

SVTR#: 2-1	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta N)			
Test ID: 6.2	Test Series Name: Exte	ernal Events			
Test □ code inspection ■ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method				
 Test Envir	onment Setup				
<u>Hardware (platform, peripherals):</u> Machine griffon, Windows 2000 Workstation <u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaN installed <u>Input Data (files, database, mode settings):</u> Default PCSA Tool database created at the start of the test. <u>Assumptions, constraints, and/or scope of test:</u> <u>Assumptions or constraints: none</u> Scope of the test: The scope of this test is to verify that the user input is correctly stored in					
the database. <u>Test Procedure:</u> Tested in accordance with s 3.0.	ection 6.2.2 of the SVTP	for PCSA Tool Version			
<u>Test</u>	Results				
The user input appears correctly on the PCSA External Events Report and PCSA External Events Detail Report after exiting and re-entering the PCSA Tool. <u>Test Evaluation (Pass/Fail):</u> Pass					
Notos: Nono					
Tester: Troy Maxwell	Date: August 9, 2004				

PCSA External Events Report

Project: SVTP

Generic List of Events	5-4 H 4 F	Potential exists for event to be	Rate of process high enough to	Consequence of event high enough	Event Frequency	Applicability of the event to the
Aircraft crash	Ext Hazard ID	applicable	affect facility	to affect facility	(per yr)	site
Avalanche	EXHZ AVALANCHE1	N	N			
Coastal erosion					1.00E-07	t <mark>N</mark> el este de tel site en la
Dam failure						
Debris avalanching						
Denudation						
Dissolution						
Eperogenic displacement						
Erosion						
External Event 1	EXHZ_Ex1	Y	Ν	Y	1.00E-03	N
Extreme weather fluctuations						
Extreme wind						
Fire (facility)						
Fire (range)						
Flooding (storm, river diversion)						
Fungus, bacteria, and algae						
Glacial erosion						
Glaciation						
High lake level						
High river stage						
High tide						
Hurricane						
Inadvertent future intrusions (man-made)						
Industrial activity induced accident						
Intentional future intrusions (man-made)						
Landslides						
Lightning						
Loss of on-site power						
Low river level						
Meteorite impact						
Military activity induced accident						
Orogenic Diastrophism						
Pipeline accident						
Rainstorm						
Sandstorm						
Sedimentation						

8/3/2004

~*

9:23:06AM

PCSA Tool, Version 3.0.0, (BetaN) for evaluation only, not for licensing use

Page 1 of 2

PCSA External Events Report

Project: SVTP

Generic List of Events	Ext Hazard ID	Potential exists for event to be applicable	Rate of process high enough to affect facility	Consequence of event high enough to affect facility	Event Frequency (per yr)	Applicability of the event to the site
Seiche					17. Second Angles Loc. 1997 Million	
Seismic activity, earthquake						
Seismic activity, subsurface fault displacement						
Seismic activity, surface fault displacement						
Seismic activity, uplifting (tectonic)						
Static fracturing						
Stream erosion						
Subsidence						
Tornado						
Tsunami						
Undetected geologic features						
Undetected geologic processes						
Undetected past intrusions (man-made)						
Volcanic eruption						
Volcanism, ashfall						
Volcanism, ashflow (extrusive magmatic activity)						
Volcanism, intrusive magmatic activity						
Waves (aquatic)						

.

PCSA External Events Detail Report

Project: SVTP

Generic Event Name	External Event 1
External Hazard ID	EXHZ_Ex1
Definition	External Event 1.1
Required Condition	External Event 1.2
Potential exists for the Y event to be applicable to the site	External Event 1.3
Rate of process high N enough to affect the facility during preclosure	External Event 1.4
Consequence of process Y significantly high to affect the facility during preclosure period	External Event 1.5
Event Frequency (per yr) Justification	1.00E-03 External Event 1.6
Applicability of the Event N to the site	
Additional Discussion	External Event 1.7
DOE References	External Event 1.8
NRC Review Report File Na	External Event 1.txt

Software Validation Test Report (SVTR)

•

,

SVTR#: 3-1	Project #: 20.060002.01.10	3				
Software Name: PCSA Tool		Version: 3.0 (Beta Q)				
Test ID: 6.3.1	Test Series Name: System	- System Description				
□ code inspection ◎ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Fest Method					
<u>Test E</u>	nvironment Setup					
Hardware (platform, peripherals): Machin	e griffon, Windows 2000 Wc	orkstation				
<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaQ installed <u>Input Data (files, database, mode settings):</u> Default PCSA Tool database created at the start of the test. Input data is shown in Attachment 1.						
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database and can be retrieved from the database and displayed						
<u>Test Procedure:</u> Since this form was being developed at the time the SVTP was written, a detailed procedure did not exist in the SVTP. However, the procedure used was to enter information on each tab of the form until all tabs were filled out and verify upon exiting and reentering the PCSA Tool that the information entered was retrieved from the database.						
Test Results						
The user input appears correctly on the individual PCSA System Description Reports after exiting and re-entering the PCSA Tool.						
Test Evaluation (Pass/Fail): Pass						
Notes: The Detailed Operations Sequence form was renamed 'System Description.'						
Tester: Troy Maxwell	Date: August 12, 2004					
0						

Attachment 1

1

Input Data: Detailed Operations Sequence

Data Entry Field	Entry Field Record 1	
Tab: Function		
Function	SysDes_Function_1.1	N/A
Additional Information	SysDes_Function_1.2	N/A
References	SysDes_Function_1.3	N/A
Tab: Operations Sequence		
Detailed Operation Sequence	SysDes_OperationSequenc e_1.1	SysDes_OperationSequenc e_2.1
Duration of Operation	3 Hours	2 Hours
Additional Information	SysDes_OperationSequenc e_1.2	SysDes_OperationSequenc e_2.2
DOE Reports and References	SysDes_OperationSequenc e_1.3	SysDes_OperationSequenc e_2.3
Lift Height	24 meters	N/A
Distance Traveled	3 miles	N/A
Speed of Travel	4.5 mph	N/A
Tab: Waste Characterization		
Description of Waste	SysDes_WasteCharacteriza tion_1.1	SysDes_WasteCharacteriza tion_2.1
Material Type	Mat_Type_1.2	Mat_Type_2.2
Material Container	Mat_Container_1.3	Mat_Container_2.3
Material Amount	Mat_Amount_1.4	Mat_Amount_2.4
Heat Generation Rate	1	2
External Dose Rate	.001	.002
References	SysDes_WasteCharacteriza tion_1.5	SysDes_WasteCharacteriza tion_2.5
Tab: Human Actions		
A) Maintenance and Standby	SysDes_HumanActions_1.1	SysDes_HumanActions_2.1
B) Operational Actions	SysDes_HumanActions_1.2	SysDes_HumanActions_2.2
C) References	SysDes_HumanActions_1.3	N/A

D) Additional Information	SysDes_HumanActions_1.4	N/A
Tab: Shielding		
Additional Information	SysDes_Shielding_1.1	SysDes_Shielding_2.1
Source Geometry	SysDes_Shielding_1.2	SysDes_Shielding_2.2
Worker Location Relative to Sources	SysDes_Shielding_1.3	SysDes_Shielding_2.3
Shield Locations Relative to Sources	SysDes_Shielding_1.4	SysDes_Shielding_2.4
References	SysDes_Shielding_1.5	SysDes_Shielding_2.5
Shield Material	SysDes_Shielding_1.6	SysDes_Shielding_2.6
Shield Composition	SysDes_Shielding_1.7	SysDes_Shielding_2.7
Shield Density	8 kg/m^3	7 kg/m^3
Shield Thickness	9 cm	2 cm
Tab: Software System		
Software System Used	SysDes_SoftwareSystem_1. 1	SysDes_SoftwareSystem_2. 1
References	SysDes_SoftwareSystem_1. 2	N/A
Additional Information	SysDes_SoftwareSystem_1. 3	N/A
Tab: Fire Hazards		
Presence of Combustible Materials	(Yes) SysDes_FireHazards_Yes	(No)
Location and Description of Combustible Material	SysDes_FireHazards_1.1	SysDes_FireHazards_2.1
Additional Information	SysDes_FireHazards_1.2	SysDes_FireHazards_2.2
DOE Reports and References	SysDes_FireHazards_1.3	SysDes_FireHazards_2.3
Function	SysDes_FireHazards_1.4	SysDes_FireHazards_2.4
Tab: General		
There is presence of neutron moderators for criticality	Checked	N/A
Radiation Area Designation	Radiation Area	N/A
Ventilation Flow Rate	3	N/A

, ·

Tab: Assumptions		
Assumptions	SysDes_Assumptions_1.1	SysDes_Assumptions_2.1
Additional Information	SysDes_Assumptions_1.2	SysDes_Assumptions_2.2

, .

PCSA System Description (Function Report)

Project: SVTP	Description:	Node A Node A1	
Functional ID: A.1.2.3		Node A2 Node A3	
Function	Additional Information	F	References
SysDes_Function_1.1	SysDes_Function_1.2	S	SysDes_Function_1.3

8/3/2004

9:27:23AM

Project:	SVTP			Description:	Node A		
					Node A1		
Functional	ID: A 1 2 3				Node A2		
					Node A3		
Item No	Detailed Operations Sequence	Duration of Operation	Lift Height	Distance Traveled	Speed of Travel	Additional Information	DOE Reports and
0001.00	SysDes_OperationSequen	3 hours	24 m	3 miles	4.5 mph	SysDes_OperationSequen	SysDes_Operatio
0002.00	SysDes_OperationSequen ce_2.1	2 hours				ce_1.2 SysDes_OperationSequen ce_2.2	nSequence_1.3 SysDes_Operatio nSequence_2.3

PCSA System Description (Operation Sequence Report)

8/3/2004

9:28:24AM

PCSA System Description (Waste Characterization Report)

Project: SVTP	Description:	Node A
•		Node A1
Eventional ID: A 1.2.2		Node A2
Functional 1D: A.1.2.3		Node A3

Item No	Material Type Material Container Material Amount	Heat Generation Rate (W) Ext. Dose Rate (mrem/hr)	Description of Waste	References
0001.00	Mat_Type_1.2	1	SysDes_WasteCharacterization_1.1	SysDes_WasteCharacterization_1.5
	Mat_Container_1.3	.001		
0002.00	Mat_Amount_1.4 Mat_Type_2.2	2 2	SysDes_WasteCharacterization_2.1	SysDes_WasteCharacterization_2.5
	Mat_Container_2.3	.002		
	Mat_Amount_2.4			

PCSA System Description (Human Actions Report)

Project: SVTP			Description:	Node A Node A1
Functional ID: A.1.2.3				Node A2 Node A3
Maintenance & Standby	Item No	Data		
· · · · · · · · · · · · · · · · · · ·	0001.00 0002.00	SysDes_HumanActions_1.1 SysDes_HumanActions_1.2		
Operational	0001.00 0002.00	SysDes_HumanActions_2.1 SysDes_HumanActions_2.2		

References:

SysDes_HumanActions_1.3

Additional Information SysDes_HumanActions_1.4

8/3/2004

Project: SVTP		Description:	Node A Node A1
Functional ID: A.1.2.3			Node A2 Node A3
Item No	0001.00		
Source Geometry	SysDes_Shielding_1.2		
Worker Location	SysDes_Shielding_1.3		
Shield Locations Relative to Sources	SysDes_Shielding_1.4		
Shield Material	SysDes_Shielding_1.6		
Shield Composition	SysDes_Shielding_1.7		
Shield Density	8 kg/m^3		
Shield Thickness	9 cm		
Additional Information	SysDes_Shielding_1.1		
References	SysDes_Shielding_1.5		

PCSA System Description (Shielding Report)

Project: SVTP		Description:	Node A Node A1
Functional ID: A.1.2.3			Node A2 Node A3
Item No	0002.00		
Source Geometry	SysDes_Shielding_2.2		
Worker Location	SysDes_Shielding_2.3		
Shield Locations Relative to Sources	SysDes_Shielding_2.4		
Shield Material	SysDes_Shielding_2.6		
Shield Composition	SysDes_Shielding_2.7		
Shield Density	7 kg/m^3		
Shield Thickness	2 cm		
Additional Information	SysDes_Shielding_2.1		
References	SysDes_Shielding_2.5		

PCSA System Description (Shielding Report)

PCSA System Description (Software System Report)

Project: SVTP	Description:	Node A Node A1
Functional ID: A.1.2.3		Node A2 Node A3

Item No	Software System Used
0001.00	SysDes_SoftwareSystem_1.1
0002.00	SysDes_SoftwareSystem_2.1

References:

SysDes_SoftwareSystem_1.2

Additional Information

SysDes_SoftwareSystem_1.3

Proiect: SVTP			Description:	Node A	
···· ·			-	Node A1	
Eurotional ID: A 1 2 2			٦	Node A2	
runctional ID: A.1.2.5			٩	Node A3	
Item No	Combustible Material	Location and Description of the Combustible Material	Function	Additional Information	DOE Reports and References
0001.00	SysDes_FireHazards_Yes	SysDes_FireHazards_1.1	SysDes_FireHaz ards 1.4	SysDes_FireHazards_1.2	SysDes_FireHazards_1.3
0002.00		SysDes_FireHazards_2.1	SysDes_FireHaz ards_2.4	SysDes_FireHazards_2.2	SysDes_FireHazards_2.3

PCSA System Description (Fire Hazards Report)

8/3/2004

9:30:46AM

PCSA System Description (General Report)

Project: SVTP	Description:	Node A
		Node A1
Functional ID: A 1 2 2		Node A2
		Node A3
There is presence of neutron True		

moderators for criticality Ventilation flow rate (m^3/sec) Radiation area designation

Radiation Area

3

8/3/2004

٠

~

; ,

PCSA System Description (Assumptions Report)

Project: SVTP		Description:	Node A	
			Node A1	
Functional ID: A.1.2.3			Node A2	
			Node A3	
Item No	Assumptions		Additional Information	
0001.00	SysDes_Assumptions_1.1		SysDes_Assumptions_1.2	
0002.00	SysDes_Assumptions_2.1		SysDes_Assumptions_2.2	

8/3/2004

ŝ

• • • • •
-

Œ

ر •د

SVTR#: 3-2	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta V)			
Test ID: 6.3.2	Test Series Name: Sys Systems, and Compon	tem - Structures, ents (SSCs)			
Test	Method				
 hand calculation spreadsheet graphical 					
comparison with external code					
<u>Test Envir</u>	onment Setup				
<u>Hardware (platform, peripherals):</u> Machine gr	riffon, Windows 2000 Wo	orkstation			
Software (OS, compiler, libraries, auxiliary co	odes or scripts): PCSA To	ool Version 3.0 BetaV			
Input Data (files, database, mode settings): I of the test. Input data is shown in Attachmer	Default PCSA Tool databant 1.	ase created at the start			
Assumptions, constraints, and/or scope of te	<u>st:</u>				
Scope of the test: The scope of this test is to the database and can be retrieved from the c	verify that the user input latabase and displayed.	is correctly stored in			
<u>Test Procedure:</u> Since this form was being developed at the time the SVTP was written, a detailed procedure did not exist in the SVTP. However, the procedure used was to enter information on each tab of the form until all tabs were filled out and verify upon exiting and reentering the PCSA Tool that the information entered was retrieved from the database					
Test	Results				
The user input appears correctly on the PCSA Structures, Systems, and Components Report as well as the Design Bases and Design Criteria Report after exiting and re-entering the PCSA Tool.					
Test Evaluation (Pass/Fail): Pass					
Notes: None					
Tester: Troy Maxwell	Date: September 13, 20	004			

Attachment 1:

а — - - - - - а

_

Data Entry Field	Record 1	Becord 2
Tab: General		
SSC ID	SSC_1.1	SSC_2.1
SSC Description	SSC_1.2	SSC_2.2
System	SSC_1.3	SSC_2.3
Mode of Operaton	Manual	Manual
Subsystem	SSC_1.4	SSC_2.4
DOE Determination	(No)	(Yes)
Staff Determination	(No)	(Yes)
Functions	N/A	Criticality Control
Additional Information	SSC_1.5	SSC_2.5
Tab: Design Bases and Desig	n Criteria	
Design Bases	SSC_1.6	N/A
Design Criteria	SSC_1.7	N/A
Design Review Comment	SSC_1.8	N/A
Additional Information	SSC_1.9	N/A
Functions	Backup Power	N/A
Hazards	Hazards_1.10	N/A
Initiating Events	InitiatingEvents_1.11	N/A
Event Tree	EventTree_1.12	N/A

Input Data: Structures, Systems, and Components (SSCs)

Project: SVTP			Description:	Node A Node A1	
Functional ID: A.1.2	2.3			Node A2 Node A3	
Item Number:	0001.0)			
SSC ID:	SSC_1	L			
SSC Description:	SSC_1	2			
Mode of Operation:	Manual				
System:	SSC_1	3			
Subsystem:	SSC_1	1			
Important to Safety DOE Determination:	N	Staff Determination: N			
Additional Informatio	n: SSC_1	5			
Item No 0001.00	Design Bases SSC_1.6	Design Criteria SSC_1.7		Design Review Comment SSC_1.8	Additional Information SSC_1.9

PCSA Structures, Systems, and Components Report

9/13/2004

PCSA Design Bases and Design Criteria Report

Project: SVTP		Description:	Node A Node A1		
Functional ID: A.1.2.3			Node A2		
				Node A3	
SSC ID: SSC_1.1					
Item No	Design Bases	Design Criteria		Design Review Comment	Additional Information
0001.00	SSC_1.6	SSC_1.7		SSC_1.8	SSC_1.9
Functions, Hazards, Initiating Events, Event Tree Subsequent Events event tree EventTree 1.12					
function	Backup Power				
hazard	Hazards_1.10				
initiating event	InitiatingEvents_1.11				

9/13/2004

Project: SVTP			I	Description:	Node A Node A1				
Functional ID: A.1.2	2.3				Node A2 Node A3				
Item Number:	0002.00					<u></u>	 	- /	
SSC ID:	SSC_2.1								
SSC Description:	SSC_2.2								
Mode of Operation:	Manual								
System:	SSC_2.3								
Subsystem:	SSC_2.4								
Important to Safety DOE Determination:	Y	Staff Determination:	Y						
Additional Informatio	n: SSC_2.5								
Functions:	Criticality Control								

PCSA Structures, Systems, and Components Report

9/13/2004

.

1:42:25PM

SVTR#: 4-1	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta Q)			
Test ID: 6.4.1	Test Series Name: Int.	Events - FMEA			
Test	Method				
<u> </u>					
<u>spreadsheet</u>					
□ graphical □ comparison with external code					
Test Envir	<u>onment Setup</u>				
Hardware (platform, peripherals): Machine griffon, Windows 2000 Workstation					
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed					
Input Data (files, database, mode settings): I of the test. Additional input is shown in Attac	Default PCSA Tool datab hment 1.	ase created at the start			
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: The scope of this test is to the database, and that severe events are co	<u>st:</u> verify that the user inpur rectly distinguished from	t is stored correctly in non-severe events.			
<u>Test Procedure:</u> Tested in accordance with section 6.4.1.2 of the SVTP for PCSA Tool Version 3.0. No data was entered for "DOE Safeguards and Controls" since it does not exist for version 3.0. Data was entered into "Preventative and Mitigative Features" which did not exist when the SVTP was written. An "Effect on other Functional Areas" checkbox was also added for version 3.0, and data was entered similar to the "Severe Events" checkbox. The extra data entered is located in the FMEA Additional Input Table found in Attachment 1.					
Test	<u>Results</u>				
The user input appears correctly on the PCS PCSA Tool. The severe events are correctly	A FMEA Report after exi	ting and re-entering the severe events.			
Test Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: Troy Maxwell	Date: August 12, 2004				

, V ...

Attachment 1

. •

3

FMEA Additional Input Table

Data Entry Field	Record 1	Record 2
Preventative and Mitigative Features	FMEA_1.5	FMEA_2.5
Effect on other Functional Areas	(Yes) FMEA_1.8	(No) FMEA_2.8

PCSA FMEA Report

Project: SVTP	Description:	Node A
		Node A1
		Node A2
runctional ID: A.1.2.3		Node A3
Identification	Dreven	tive and

a) Item No				Mitigative		Effect on other	Additional	
b) Component	Failure N	Iode Cause of Failu	re Effect of Failu	re Features	Severe Events	Functional Areas	Information	
a) 0001.00	FMEA_1.2	FMEA_1.3	FMEA_1.4	FMEA_1.5	Y	Y	FMEA_1.6	
b) FMEA_1.1					FMEA_1.7	FMEA_1.8		
a) 0002.00	FMEA_2.2	FMEA_2.3	FMEA_2.4	FMEA_2.5	N	N	FMEA_2.6	
b) FMEA_2.1					FMEA_2.7	FMEA_2.8		

SVTR#: 4-2	Project #: 20.060002.0 ⁻	1.103				
Software Name: PCSA Tool		Version: 3.0 (Beta R)				
Test ID: 6.4.2	Test Series Name: Int.	Events - What If				
□ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code						
Hardware (platform, peripherals): Machine griffon, Windows 2000 Workstation						
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaR installed						
Input Data (files, database, mode settings): Dof the test. Additional input is shown in Attac	Default PCSA Tool databa hment 1.	ase created at the start				
Assumptions, constraints, and/or scope of tes Assumptions or constraints: none Scope of the test: The scope of this test is to the database, and that severe events are cor	<u>st:</u> verify that the user input rectly distinguished from	is stored correctly in non-severe events				
<u>Test Procedure:</u> Tested in accordance with section 6.4.2.2 of the SVTP for PCSA Tool Version 3.0. No data was entered for "DOE Safeguards" since it does not exist for version 3.0, therefore data was entered into "Preventative and Mitigative Features" which did not exist when the SVTP was written. A "Effect on other Functional Areas" checkbox was also added for version 3.0, and data was entered similar to the "Severe Events" checkbox. The extra data entered is located in the What If Additional Input Table found in Attachment 1						
<u>Test</u>	Results					
The user input appears correctly on the PCS the PCSA Tool. The severe events are corre	A What If Report after ex ctly distinguished from n	iting and re-entering on-severe events.				
Test Evaluation (Pass/Fail): Pass						
Notes: None.	Notes: None.					
Tester: Troy Maxwell	Date: August 17, 2004					

Attachment 1

•

.

What If Additional Input Table

Data Entry Field	Record 1	Record 2
Preventative and Mitigative Features	WhatIf_1.4	WhatIf_2.4
Effect of other Functional Areas	(No) WhatIf_1.7	(Yes) WhatIf_2.7

PCSA 'What If' Analysis Report

Project: SVTP	Description:	Node A		
•		Node A1		
Functional ID: A 1 2 2		Node A2		
runctional 1D: A.1.2.5		Node A3		

Identification:

Item No			Preventive and		Effect on Other	
What If	Causes	Consequences	Mitigative Features	Severe Events	Fuctional Areas	Additional Info
0001.00	WhatIf_1.2	WhatIf_1.3	WhatIf_1.4	N	N	WhatIf_1.5
WhatIf_1.1				WhatIf_1.6	WhatIf_1.7	
0002.00	WhatIf_2.2	WhatIf_2.3	WhatIf_2.4		a di se y teli ter sono Sandaritetti	WhatIf_2.5
WhatIf_2.1				WhatIf_2.6	WhatIf_2.7	

8/17/2004

.

\$

,

SVTR#: 4-3	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta N)			
Test ID: 6.4.3	Test Series Name: Int. Events - Energy Method				
Test	Method				
 □ code inspection △ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 					
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	orkstation			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed					
Input Data (files, database, mode settings): Input Data (files, database, mode settings): In of the test. Additional input is shown in Attac	Default PCSA Tool datab	ase created at the start			
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none. Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database, and that severe events are correctly distinguished from non-severe events					
<u>Test Procedure:</u> Tested in accordance with section 6.4.3.2 of the SVTP for PCSA Tool Version 3.0. Data was entered into "Preventative and Mitigative Features" which did not exist when the SVTP was written. An "Effect on other Functional Areas" checkbox was also added for version 3.0, and data was entered similar to the "Severe Events" checkbox. The extra data entered is located in the Energy Method Additional Input Table found in Attachment 1.					
<u>Test</u>	Results				
The user input appears correctly on the PCSA Energy Analysis Report after exiting and re- entering the PCSA Tool. The severe events are correctly distinguished from non-severe events.					
Test Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: Troy Maxwell	Date: August 2, 2004				

Attachment 1

2 V

Energy Method Additional Input Table

Data Entry Field	Record 1	Record 2
Preventative and Mitigative Features	EnergyAnal_1.3	EnergyAnal_2.3
Effect of other Functional Areas	(Yes) EnergyAnal_1.6	(No) EnergyAnal_2.6

PCSA Energy Method Report

Project: SVTP			Description:	Node A		
			•	Node A1		
Eurotional ID: A 1 2 2				Node A2		
Functional ID: A.1.2.5				Node A3		
	Identification:		Preventive and			
	a) Item No		Mitigative		Effect on other	
EventCategory	b) Event Name	Cause of Event	Features	Severe Events	Functional Areas	Additional Information
Collision/Crushing	a) 0001.00	EnergyAnal_1.2	EnergyAnal_1.3	Y	Y	EnergyAnal_1.4
	b) EnergyAnal_1.1			EnergyAnal_1.5	EnergyAnal_1.6	
Explosion/Implosion	a) 0001.00	EnergyAnal_2.2	EnergyAnal_2.3	N	N	EnergyAnal_2.4
	b) EnergyAnal_2.1			EnergyAnal_2.5	EnergyAnal_2.6	

• • • • •

SVTR#: 4-4	Project #: 20.060002.01.103					
Software Name: PCSA Tool		Version: 3.0 (Beta N)				
Test ID: 6.4.4	Test Series Name: Int.	Events - HRA				
□ code inspection ⊠ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code						
<u>Test Envir</u>	onment Setup					
Hardware (platform, peripherals): Machine g	iffon, Windows 2000 Wo	orkstation Version				
Software (OS, compiler, libraries, auxiliary co installed	o <u>des or scripts):</u> PCSA To	ool Version 3.0 BetaN				
Input Data (files, database, mode settings): Input Data (files, database, mode settings): In of the test. Additional input is shown in Attac	Default PCSA Tool datab hment 1.	ase created at the start				
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: The scope of this test is to the database, and that severe events are cor	<u>Assumptions, constraints, and/or scope of test:</u> Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database, and that severe events are correctly distinguished from non-severe events					
<u>Test Procedure:</u> Tested in accordance with section 6.4.4.2 of the SVTP for PCSA Tool Version 3.0. No data was entered for "DOE Safeguards and Controls" since it does not exist for version 3.0. Data was entered into "Preventative and Mitigative Features" which did not exist when the SVTP was written. An "Effect on other Functional Areas" checkbox was also added for version 3.0, and data was entered similar to the "Severe Events" checkbox. The extra data entered is located in the HRA Additional Input Table found in Attachment 1.						
Test Results						
The user input appears correctly on the PCSA What If Report after exiting and re-entering the PCSA Tool. The severe events are correctly distinguished from non-severe events.						
Test Evaluation (Pass/Fail): Pass						
Notes: None.						
Tester: Troy Maxwell	Date: August 9, 2004					

Attachment 1:

. .

>

Data Entry FieldRecord 1Record 2Preventative and Mitigative
FeaturesHRA_1.6HRA_2.6Effect of other Functional
Areas(No) HRA_1.9(Yes) HRA_2.9

HRA Additional Input Table

PCSA HRA Report

Project: SVTP				Description:	Node A Node A1			
Functional ID: A.1.	.2.3				Node A2			
Identification:					Node A3			
a) Item No b) Category _c) Human Action	Human Failure Event	Performance Shaping Factors	Recovery Action	Effect of Failure	Preventive and Mitigative Features	Severe Events	Effect on other Functional Areas	Additional Information
a) 0001.00	HRA_1.2	HRA_1.3	HRA_1.4	HRA_1.5	HRA_1.6	N	N	HRA_1.7
b) A						HRA_1.8	HRA_1.9	
c) HRA_1.1								
a) 0002.00	HRA_2.2	HRA_2.3	HRA_2.4	HRA_2.5	HRA_2.6	r	un Y illion commenciales de la	HRA_2.7
b) C2						HRA_2.8	HRA_2.9	
c) HRA_2.1								

.

t . *

SVTR#: 4-5	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta N)			
Test ID: 6.4.5	Test Series Name: Int.	Events - Severe Events			
Test <u>□ code inspection</u> <u>◎ output inspection</u> <u>□ hand calculation</u> <u>□ spreadsheet</u> <u>□ graphical</u>	Method				
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	orkstation Version			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed					
Input Data (files, database, mode settings): I of the test. Additional input is shown in Attac	Default PCSA Tool datab hment 1.	ase created at the start			
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: The scope of this test is to are displayed correctly.	<u>Assumptions, constraints, and/or scope of test:</u> Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the severe events previously entered are displayed correctly				
<u>Test Procedure:</u> Tested in accordance with section 6.4.5.2 of the SVTP for PCSA Tool Version 3.0. In addition, remarks were entered for the FMEA, What If, Energy Method, and HRA severe event forms. The extra data entered is located in the Severe Events Additional Input Table found in Attachment 1.					
<u>Test</u>	Results				
The severe events are correctly displayed from previous entries in the FMEA, What If, Energy Method, and HRA Reports.					
Test Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: Troy Maxwell	Date: August 9, 2004				

Attachment 1:

.

,

Severe Events Additional Input Table

Severe Events Additional input Table				
Form	Remarks			
Severe Events List for 'FMEA'	FMEA_1.8			
Severe Events List for 'What If'	WhatIf_2.7			
Severe Events List for 'Energy Method'	EnergyAnal_1.6			
HRA Severe Events	HRA_2.9			

PCSA Severe Events Report

Project: SVTP		Description:	Node A Node A1 Node A2	
Functional ID: A.1.2.5			Node A3	
Type / Item No	Description			Remarks
ENRG_0001.00	Ev.Cat. Collision/Crushing: EnergyAnal_1.1 EnergyAnal_1.2			EnergyAnal_1.6
FMEA_0001.00	FMEA_1.1 FMEA_1.2			FMEA_1.8
HRA0002.00	Cat. C2: HRA_2.1 HRA_2.2			HRA_2.9
What_0002.00	WhatIf_2.1 WhatIf_2.2			WhatIf_2.7

e. 5

-

SVTR#: 5-1	Project #: 20.060002.0	1.103				
Software Name: PCSA Tool		Version: 3.0 (Beta Q)				
Test ID: 6.5.1	Test Series Name: Free Event	q. Analysis - Initiating				
Test	Method					
 □ code inspection ⊠ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 						
<u>Test Envir</u>	onment Setup					
Hardware (platform, peripherals): Machine gr	riffon, Windows 2000 Wo	orkstation				
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed						
Input Data (files, database, mode settings): Dof the test.	Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.					
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database, and the event is correctly labeled as "likely", "unlikely", or "not included".						
<u>Test Procedure:</u> Tested in accordance with section 6.5.1.2 of the SVTP for PCSA Tool Version 3.0.						
Test	Results					
The user input appears correctly on the PCSA Initiating Event Report after exiting and re- entering the PCSA Tool. The events are correctly labeled as "likely", "unlikely", or "not included".						
Test Evaluation (Pass/Fail): Pass	Test Evaluation (Pass/Fail): Pass					
Notes: Manual Data was checked in place of DOE Event. EXHZ_Ex1 was selected for Hazard ID.						
Tester: Troy Maxwell	Date: August 9, 2004					

PCSA Initiating Event Report

Project: SVTP	Description:	Node A	
		Node A1	
Functional ID: A.1.2.3		Node A2	
		Node A3	

Identification

Item							Time Periods
Event				Include for			Proclosuro
Hazard	Man.	Description	Frequency	Sequence Analysis	Additional Info	Managarta in ta	Preciosure
0001.00	Y	InitEvent_1.3	1.10E-02	Y	InitEvent 1.7	Y	Operational
InitEvent_1.1			InitEvent_1.5	InitEvent_1.6		InitEvent 1.4	100
EXHZ_Ex1				_		Intevent_1.4	100
0002.00	N	InitEvent_2.3	1.10E-06	N	InitEvent_2.7	Niger - Andre State	100
InitEvent_2.1			InitEvent_2.5	InitEvent_2.6			100
EXHZ_Ex1				양 그 가슴 가			100
0003.00	N	InitEvent_3.3	1.10E-06	N	InitEvent_3.7	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	100
InitEvent_3.1			InitEvent_3.5	InitEvent_3.6	<u>–</u>	InitEvent 3.4	100
EXHZ_Ex1				_		incevent_5.4	100

1

;

r**a**

SVTR#: 5-2	Project #: 20.060002.0	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta U)			
Test ID: 6.5.2	Test Series Name: Free	q. Analysis - Event Tree			
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> 	Method				
<u>Test Envir</u>	onment Setup	<u> </u>			
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	orkstation			
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	<u>odes or scripts):</u> PCSA To	ool Version 3.0 BetaU			
Input Data (files, database, mode settings): D	Default PCSA Tool databa	ase created at the start			
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database.					
<u>Test Procedure:</u> Tested in accordance with section 6.5.2.2 of the SVTP for PCSA Tool Version 3.0.					
<u>Test</u>	Results				
The user input appears correctly on the PCSA Event Tree Report after exiting and re- entering the PCSA Tool. Event_Tree 1.4 is not shown in the Crystal Report for Record 1 since 'Manual Data' is selected for 'InitEvent_1.1'.					
Test Evaluation (Pass/Fail): Pass					
<u>Notes:</u> Data entry field 'Material at Risk' was added for version 3.0. The input data for this field is located in Attachment 1.					
Tester: Troy Maxwell					
- 0					

Attachment 1:

i 1

Input Data: Event Tree						
Data Entry Field	Record 1	Record 2				
Material at Risk	Event Tree_1.9	Event Tree_2.9				
Safety System or SSC	-	SSC_1.1				

with Dotos Friend T .

PCSA Event Tree Report

Project: SVTP				Description:	Node A			
_					Node A1			
Functional ID: A.1.	2.3				Node A3			
Scenario a) Item No. b) ID c) Incl for P/A	Initiating Event a) ID b) Frequency	Item No	Subsequent Event	Safety Sy or SSC	stem	Probability	Uncertainty	Linking
a) 0001.00	a) InitEvent_1.1						Chesteancy	cinking
b) Event Tree_1.1	b) 1.10E-02							
c) N								
	Saphire Data Path:							
	Material at Risk: Event Tree_1.9							
	Event Scenario: Event Tree_1.2							
	Additional Information: Event Tree_1.3							
a) 0002.00	a) InitEvent_2.1	0001.00	Sub_2.5	SSC_1.1		1.00E-02	Y	F
b) Event Tree_2.1	b) 1.10E-06		Subsequent_2.6				Subsequent 2.7	Subsequent 2.8
c) Y								
	Saphire Data Path: Event Tree_2.4 Material at Risk: Event Tree_2.9							
	Event Scenario: Event Tree_2.2							
	Additional Information: Event Tree_2.3							

•

PCSA Event Tree Report

Project: SV	ТР			Description:	Node A			
					Node A1			
Functional ID:	A.1.2.3				Node A2			
					Node A3			
Scenario ID:	Event Tree_2.1	Initiating Event ID:	InitEvent_2.1					
Item No	Subsequent Event	Safety Sy	stem or SSC	Probab	ility	Uncertainty	Linking	
0001.00	Sub_2.5	SSC_1.1		1.00E-0	2	Y	F	

 Subsequent_2.6
 Subsequent_2.7
 Subsequent_2.8

.

• •••

SVTR#: 5-3	Project #: 20.060002.01.103					
Software Name: PCSA Tool		Version: 3.0 (Beta U)				
Test ID: 6.5.3	Test Series Name: Free	q. Analysis - Fault Tree				
Test □ code inspection ■ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method					
<u>Test Envir</u>	onment Setup					
<u>Hardware (platform, peripherals):</u> Machine griffon, Windows 2000 Workstation <u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaU						
Input Data (files, database, mode settings): D of the test.	<u>Input Data (files, database, mode settings):</u> Default PCSA Tool database created at the start of the test.					
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database.						
<u>Test Procedure:</u> Tested in accordance with section 6.5.3.2 of the SVTP for PCSA Tool Version 3.0. In addition, data was entered into the Fault Tree Event Table for Record 1. The additional input data is located in Attachment 1.						
Test Results						
The user input appears correctly on the PCSA Fault Tree Report and Fault Tree Event Report after exiting and re-entering the PCSA Tool.						
Test Evaluation (Pass/Fail): Pass						
Notes: None.						
Tester: Troy Maxwell						
~ /						

Attachment 1:

•

•

Input Data: Fault Tree Event Table						
Data Entry Field	Record 1	Record 2				
Event Name	Fault Tree_1.5	N/A				
Type of Event	Fault Tree_1.6	N/A				
Description	Fault Tree_1.7	N/A				
Probability	0.002	N/A				
Uncertainty	Fault Tree_1.8	N/A				
Additional Info.	Fault Tree_1.9	N/A				

Input Data: Fault Tree Event Table

PCSA Fault Tree Report

_	-			D	escription:	Node A	
Project: SVTP						Node A1	
Functional ID: A.1	1.2.3					Node A2	
						Node A3	
Item No	Top Event Name and Description	P/F	Pt. Estimate	Mean Median	5% 95%	Saphire Data Path	Additional Information
0001.00	Fault Tree_1.1	Р	2.00E-03	3.00E-03	5.00E-03	Fault Tree_1.4	Fault Tree_1.3
Events	Fault Tree_1.2			4.00E-03	6.00E-03		
0002.00	Fault Tree_2.1	F	2.00E-04	3.00E-04	5.00E-04	Fault Tree_2.4	Fault Tree_2.3
Events	Fault Tree_2.2			4.00E-04	6.00E-04		

.

×.

PCSA Fault Tree Event Report

Project: SVTP				Description:	Node A	
					Node A1	
Functional ID: A.1.	2.3				Node A2	
Top Event: Fault Tr	ee_1.1				Node A3	
Item No	Event Name	Type of Event	Probability	Uncertainty	Description	Additional Info
001.00	Fault Tree_1.5	Fault Tree_1.6	2.00E-03	Fault Tree_1.8	Fault Tree_1.7	Fault Tree_1.9

٠

, 1

SVTR#: 5-4	Project #: 20.060002.01.103				
Software Name: PCSA Tool		Version: 3.0 (Beta Q)			
Test ID: 6.5.4	Test Series Name: Free Sequence	q. Analysis - Event			
Test	Method				
 code inspection output inspection hand calculation spreadsheet graphical comparison with external code 					
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	rkstation			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed					
Input Data (files, database, mode settings): D	Default PCSA Tool databa	ase created at the start			
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user input is stored correctly in the database.					
<u>Test Procedure:</u> Tested in accordance with section 6.5.4.2 of the SVTP for PCSA Tool Version 3.0.					
Test Results					
The user input appears correctly on the PCSA Event Sequence Report after exiting and re- entering the PCSA Tool.					
Test Evaluation (Pass/Fail): Pass					
Notes: Public Dose and Worker Dose were selected for Records 1 and 2 respectively.					
Tester: Troy Maxwell	Date: August 2, 2004				

PCSA Event Sequence Report

Project:	SVTP			De	escription: Node	e A		
-					Nod	e A1		
Functional					Node	e A2		
Functionar	ID: A.1.2.5				Node	e A3		
Item No	Ev. Scen. ID	Ev. Seq. ID/ Frequency	Appl./ Category	Description	End State	Additional Info	Expected # Events	Probability of Occurrence
0001.00	Event Tree_1.1	EventSeq_1.1	Р	EventSeq_1.2	EventSeq_1.3	EventSeq_1.4	1	
		1.00E-02	1					
0002.00	Event Tree_2.1	EventSeq_2.1	W	EventSeq_2.2	EventSeq_2.3	EventSeq_2.4		9.52E-02
		1.00E-03	2					

8/10/2004

3:25:52PM

4

å

SVTR#: 6-1	Project #: 20.060002.07	1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta S)			
Test ID: 6.6	Test Series Name: SAF	PHIRE			
Test □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method				
Test Envir	onment Setup				
Hardware (platform, peripherals) [,] Machine pi	tor. Windows XP				
<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaS installed, SAPHIRE Version 6.80 <u>Input Data (files, database, mode settings):</u> Default PCSA Tool database created at the start of the test.					
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: This test verifies that the PCSA Tool can invoke the SAPHIRE module.					
<u>Test Procedure:</u> Tested in accordance with section 6.6.2 of the SVTP for PCSA Tool Version 3.0.					
Test Results					
The SAPHIRE program was invoked and the SAPHIRE window was displayed. The PCSA Tool menu and forms were still available for user access and SAPHIRE was available after the PCSA Tool was closed.					
Notes: None.					
Tester: Troy Maxwell ///////////////////////////////////					
~ /					

<u>ң</u> с. т. т.

Software Name: PCSA Tool Version: 3.0 (Beta N) Test ID: 6.7.1 Test Series Name: Conseq Worker Dose, Worker Internal, Pool Imade calculation Image: Conseq Worker Dose, Worker Internal, Pool Imade calculation Image: Conseq Worker Dose, Worker Internal, Pool Image: Conseq Worker Dose, Worker Internal, Pool Image: Conseq Worker Dose, Worker Internal, Pool Image: Conseq Worker Dose, Worker Dose, Worker Internal, Pool Image: Conseq Worker Dose, Constraints, and/or scope of test: Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. Test Procedure: Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. Image: Within 5% of the calculated values. The dose changes as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose change as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced	SVTR#: 7-1-1	Project #: 20.060002.01.103			
Test ID: 6.7.1 Test Series Name: Conseq Worker Dose, Worker Internal, Pool Image: Consequence of the series of the	Software Name: PCSA Tool		Version: 3.0 (Beta N)		
Test Method Imade calculation Image: spreadsheet Image: graphical Image: comparison with external code Test Environment Setup Hardware (platform, peripherals); Machine griffon, Windows 2000 Workstation Software (OS, compiler, libraries, auxiliary codes or scripts); PCSA Tool Version 3.0 BetaN installed Input Data (files, database, mode settings); Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver, 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDose/monPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail); Pass Notes: None. Test: Troy Maxwell	Test ID: 6.7.1	Test Series Name: Conseq Worker Dose, Worker Internal, Pool			
Test Environment Setup Hardware (platform, peripherals): Machine griffon, Windows 2000 Workstation Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. Test Procedure: Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail): Pass Notes: None. Tester: Troy Maxwell Machine Intel Machine Date: August 9, 2004	Test □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	: Method			
Hardware (platform, peripherals); Machine griffon, Windows 2000 Workstation Software (OS, compiler, libraries, auxiliary codes or scripts); PCSA Tool Version 3.0 BetaN installed Input Data (files, database, mode settings); Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. Test Procedure; Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail): Pass Notes; None. Tester: Troy Maxwell Date: August 9, 2004	Test Envir	onment Setup			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. Test Procedure: Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail): Pass Notes: None. Tester: Troy Maxwell	Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wc	orkstation		
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. <u>Test Procedure:</u> Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. <u>Test Results</u> The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. <u>Test Evaluation (Pass/Fail)</u> : Pass <u>Notes:</u> None. <u>Tester: Troy Maxwell</u>	Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed				
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters. <u>Test Procedure:</u> Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. <u>Test Results</u> The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. <u>Test Evaluation (Pass/Fail)</u> : Pass <u>Notes:</u> None. <u>Tester: Troy Maxwell</u> <u>Madual</u> Date: August 9, 2004	Input Data (files, database, mode settings): D of the test.	Default PCSA Tool datab	ase created at the start		
Test Procedure: Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0. Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail): Pass Notes: None. Tester: Troy Maxwell	Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly and the dose changes for changes in the input parameters.				
Test Results The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. Test Evaluation (Pass/Fail): Pass Notes: None. Tester: Troy Maxwell Mathematical Mathmatred Mathematical Mathematical Mathmatematica	Test Procedure: Tested in accordance with section 6.7.1.2 of the SVTP for PCSA Tool Version 3.0.				
Notes: None. Tester: Troy Maxwell MM Date: August 9, 2004	<u>Test Results</u> The generated values from the Worker Dose Form for Inhalation, Submersion, and Skin agree within 5% of the calculated values. The dose changed as expected when the input parameters were altered. The formulas, from the PCSA Users Manual ver. 2.0, for the Inhalation, Submersion, and Skin were input into an EXCEL spreadsheet included in the Appendix. There are two EXCEL spreadsheets used to validate the calculations: WorkerDosefromPoolRelease2min.xls and WorkerDose.xls. Both spreadsheets produced results within 5% of the PCSA Tool. <u>Test Evaluation (Pass/Fail):</u> Pass				
Tester: Troy Maxwell Tester: Troy Maxwell Date: August 9, 2004	Notes: None.				
	Tester: Troy Maxwell	Date: August 9, 2004			

<u>Appendix</u>

.

Test Results from Table 6.7.1-1, 1st row input

Fuel Assem. Breached Gaseous Release Frac. Inhalation Rate Air Mixing Volume Time Spent	0.	8 0.4 000333 1059.1 2				
Fuel Type		PWR				
Intermed. Results						
	С	i/Assem	Α	ir Conc.	Inha	alation
H3	1.	10E+02	1.	23E+10	4.09	9E+06
Ar39	3	39E-05	3.	79E+03	1.26E+00	
Kr85	1.	06E+03	1.	19E+11	3.95E+07	
1129	1.	95E-02	2	18E+06	7.26E+02	
Pb212(Rn220)	2	74E-02	9.	26E+01	1.02E+03	
Pb214(Rn222)	8	28E-07	9	26E+01	3.0	3E-02
, <u>, , , , , , , , , , , , , , , , , , </u>	_					
Dose Conv. Fact.	In	halation	Su	bmersion	Skin	
H3	1.	73E-11	1	.19E-15	Ν	J/A
Ar39		N/A	5	.54E-14	3.7	5E-11
Kr85		N/A	4	.70E-13	4.6	6E-11
1129	4	69E-08		N/A	N/A	
Rn219		N/A		N/A	N/A	
Pb212(Rn220)	4	56E-08		N/A	N/A	
Pb214(Rn222)	2	11E-09		N/A	N/A	
· · · -	9	46E-08	5	.27E-13	8.41E-11	
Dose Results					••••	
	In	halation	Su	bmersion	Skin	
	8	50E-01	0E-01 4.89E-05			
	-	7.01E-10 4.7		4.7	5E-07	
			1	.86E-01	1.84	E+01
	4.	09E-01				
	5.	58E-01				
	7.	80E-07				
Totals -	1	82E+00	1	86F-01	1.84	IF+01
101410		022100	•			2.0.
Bow 1 Input/Table 6 7 1-	1)	Inhalat	ion	Submer	sion	Skin
PCSA Tool Version 3.0		1.82F-	.00	1.86F-	01	1.85F+01
FXCFI		1 82E+00 1 86E-01 1 84		1 84F±01		
Percent Difference		0.17%	6	0.04%	6	0.30%

,

Test Results from Table 6.7.1-1, 2nd row input

8
0.4
0.000333
1059.1
2
BWR

Intermed. Results

	Ci/Assem	Air Conc.	Inhalation	
H3	4.25E+01	4.75E+09	1.58E+06	
Ar39	1.44E-05 1.61E+03		5.36E-01	
Kr85	3.83E+02 4.28E+10		1.43E+07	
1129	7.61E-03 8.51E+05		2.83E+02	
Pb212(Rn220)	1.16E-02 3.60E+01 4		4.32E+02	
Pb214(Rn222)	3.22E-07 3.60E+01 1.20E		1.20E-02	
Dose Conv. Fact.	Inhalation	Submersion	Skin	
H3	1.73E-11	1.19E-15 N/A		
Ar39	N/A	5.54E-14 3.75E-11		
Kr85	N/A	4.70E-13	4.66E-11	
1129	4.69E-08	N/A	N/A	
Rn219	N/A	N/A	N/A	
Pb212(Rn220)	4.56E-08	N/A	N/A	
Pb214(Rn222)	2.11E-09	N/A	N/A	
	9.46E-08	5.27E-13	8.41E-11	
Dose Results				
	Inhalation	Submersion	Skin	
	3.28E-01	1.89E-05		
		2.98E-10	2.02E-07	
		6.72E-02	6.66E+00	
	1.59E-01			
	2.36E-01			
-	3.04E-07			
Totals	7.24E-01	6.72E-02	6.66E+00	
How 2 Input(I able 6.7.1-	1) Inhalat	ion Submers	sion Skin	
FUSA 1001 Version 3.0) /.24E-	01 6./1E-0	UZ 6.65E+00	
EXCEL	7.24E-	01 6./2E-0	02 6.66E+00	

Percent Difference	0.03%	0.20%	0.21%
Test Results from Table 6.7.1-1, 3rd row input

•

Fuel Assem. Breached	16
Gaseous Release Frac.	0.4
Inhalation Rate	0.000333
Air Mixing Volume	1059.1
Time Spent	2
Fuel Type	PWR

Intermed. Results

1 5

	Ci/Assem	Air Conc.	Inhalation
H3	1.10E+02	2.46E+10	8.19E+06
Ar39	3.39E-05	7.58E+03	2.52E+00
Kr85	1.06E+03	2.37E+11	7.89E+07
l129	1.95E-02	4.36E+06	1.45E+03
Pb212(Rn220)	2.74E-02	1.85E+02	2.04E+03
Pb214(Rn222)	8.28E-07	1.85E+02	6.16E-02
Dose Conv. Fact.	Inhalation	Submersion	Skin
H3	1.73E-11	1.19E-15	N/A
Ar39	N/A	5.54E-14	3.75E-11
Kr85	N/A	4.70E-13	4.66E-11
1129	4.69E-08	N/A	N/A
Rn219	N/A	N/A	N/A
Pb212(Rn220)	4.56E-08	N/A	N/A
Pb214(Rn222)	2.11E-09	N/A	N/A
	9.46E-08	5.27E-13	8.41E-11
Dose Results			
	Inhalation	Submersion	Skin
	1.70E+00	9.78E-05	
		1.40E-09	9.49E-07
		3.72E-01	3.69E+01
	8.17E-01		
	1.12E+00		
	1.56E-06		
Totals	3.63E+00	3.72E-01	3.69E+01
Row 3 Input(Table 6.7.1-	1) Inhalat	tion Submer	sion Skin
PCSA Tool Version 3.0	3.63E-	+00 3.73E-	01 3.69E+01
EXCEL	3.63E-	+00 3.72E-	01 3.69E+01
Percent Difference	0.10	% 0.23 %	<u>6 0.03%</u>

Test Results from Table 6.7.1-1, 4th row input

Fuel Assem. Breached	16
Gaseous Release Frac.	0.2
Inhalation Rate	0.000333
Air Mixing Volume	1059.1
Time Spent	2
Fuel Type	BWR

Intermed. Results

د ن

	Ci/Assem	Air Conc.	Inhalation
H3	4.25E+01	4.75E+09	1.58E+06
Ar39	1.44E-05	1.61E+03	5.36E-01
Kr85	3.83E+02	4.28E+10	1.43E+07
1129	7.61E-03	8.51E+05	2.83E+02
Pb212(Rn220)	1.16E-02	3.60E+01	4.32E+02
Pb214(Rn222)	3.22E-07	3.60E+01	1.20E-02
Dose Conv. Fact.	Inhalation	Submersion	Skin
H3	1.73E-11	1.19E-15	N/A
Ar39	N/A	5.54E-14	3.75E-11
Kr85	N/A	4.70E-13	4.66E-11
1129	4.69E-08	N/A	N/A
Rn219	N/A	N/A	N/A
Pb212(Rn220)	4.56E-08	N/A	N/A
Pb214(Rn222)	2.11E-09	N/A	<u>N/A</u>
-	9.46E-08	5.27E-13	8.41E-11
Dose Results			
	Inhalation	Submersion	Skin
	3.28E-01	1.89E-05	
		2.98E-10	2.02E-07
		6.72E-02	6.66E+00
	1.59E-01		
	2.36E-01		
	3.04E-07		
Totals	7.24E-01	6.72E-02	6.66E+00
Dow 4 Input/Table 6.7.1	1) Inhelet	ion Cubmon	eien Ckin
	i) iiiialai 704⊑		
	/ /.24E* フク/E		
EAUEL	1.245	01 0.72E-	02 0.000+00
Percent Difference	0.039	% 0.20%	6 0.21%

Test Results from Table 6.7.1-1, 5th row input

Fuel Assem. Breached	16
Gaseous Release Frac.	0.2
Inhalation Rate	3.33E-03
Air Mixing Volume	1059.1
Time Spent	2
Fuel Type	PWR

, .

Intermed. Results

	Ci	/Assem	Α	ir Conc.	Inha	alation
H3	1.	10E+02	1.	23E+10	4.09	9E+07
Ar39	3.	39E-05	3.	79E+03	1.26	SE+01
Kr85	1.	06E+03	1.	19E+11	3.95	5E+08
l129	1.	95E-02	2.	18E+06	7.26	8E+03
Pb212(Rn220)	2.	74E-02	9.	26E+01	1.02	2E+04
Pb214(Rn222)	8.	28E-07	9.	26E+01	3.08	3E-01
Dose Conv. Fact.	In	halation	Su	bmersion	s	kin
H3	1.	73E-11	1	.19E-15	Ν	J/A
Ar39		N/A	5	.54E-14	3.75	5E-11
Kr85		N/A	4	.70E-13	4.66	6E-11
1129	4.	69E-08		N/A	٨	I/A
Rn219		N/A		N/A	N/A	
Pb212(Rn220)	4.	56E-08		N/A	Ν	I/A
Pb214(Rn222)	2.	11E-09		N/A	N	I/A
	9.	46E-08	5	.27E-13	8.4	IE-11
Dose Results						
	In	halation	Su	bmersion	S	kin
	8.	50E+00	4	.89E-05		
			7	.01E-10	4.75	5E-07
			1	.86E-01	1.84	E+01
	4.	09E+00				
	5.	58E+00				
_	7.	80E-06				
Totals	1.8	82E+01	1.	.86E-01	1.84	E+01
Row 5 Input(Table 6.7.1-	-1)	Inhalat	ion	Submer	sion	Skin
PCSA Tool Version 3.0)	1.82E+	01	1.86E-0	01	1.85E+01
EXCEL		1.82E+	01	1.86E-0	01	1.84E+01
	_					
Percent Difference		0.17%	6	0.04%	6	0.30%

Test Results from Table 6.7.1-1, 6th row input

Fuel Assem. Breached	16
Gaseous Release Frac.	0.2
Inhalation Rate	3.33E-03
Air Mixing Volume	528.05
Time Spent	2
Fuel Type	BWR

Intermed. Results

۱

.

	Ci/Assem	Air Conc.	Inhalation
H3	4.25E+01	9.53E+09	3.17E+07
Ar39	1.44E-05	3.23E+03	1.08E+01
Kr85	3.83E+02	8.59E+10	2.86E+08
l129	7.61E-03	1.71E+06	5.68E+03
Pb212(Rn220)	1.16E-02	7.22E+01	8.66E+03
Pb214(Rn222)	3.22E-07	7.22E+01	2.40E-01
Dose Conv. Fact.	Inhalation	Submersion	Skin
H3	1.73E-11	1.19E-15	N/A
Ar39	N/A	5.54E-14	3.75E-11
Kr85	N/A	4.70E-13	4.66E-11
1129	4.69E-08	N/A	N/A
Rn219	N/A	N/A	N/A
Pb212(Rn220)	4.56E-08	N/A	N/A
Pb214(Rn222)	2.11E-09	N/A	N/A
•	9.46E-08	5.27E-13	8.41E-11
Dose Results			
	Inhalation	Submersion	Skin
	6.59E+00	3.79E-05	
		5.97E-10	4.04E-07
		1.35E-01	1.34E+01
	3.20E+00		
	4.74E+00		
	6.09E-06		
Totals	1.45E+01	1.35E-01	1.34E+01
How 6 Input(Table 6.7.1-	1) Inhalat	ion Submer	sion Skin
PCSA Tool Version 3.0) 1.45E+	-01 1.34E-	01 1.33E+01
EXCEL	1.45E+	-01 1.35E-	01 1.34E+01
Percent Difference	0.179	0.63%	6 0.50%
		0.00/	0.0070

Test Results from Table 6.7.1-1, 7th row input

Fuel Assem. Breached	16
Gaseous Release Frac.	0.2
Inhalation Rate	3.33E-03
Air Mixing Volume	528.05
Time Spent	4
Fuel Type	PWR

Intermed. Results

×

-

	Ci/Assem	Air Conc.	Inhalation
H3	1.10E+02	2.47E+10	8.21E+07
Ar39	3.39E-05	7.60E+03	2.53E+01
Kr85	1.06E+03	2.38E+11	7.91E+08
1129	1.95E-02	4.37E+06	1.46E+04
Pb212(Rn220)	2.74E-02	1.86E+02	2.05E+04
Pb214(Rn222)	8.28E-07	1.86E+02	6.18E-01
Dose Conv. Fact.	Inhalation	Submersion	Skin
H3	1.73E-11	1.19E-15	N/A
Ar39	N/A	5.54E-14	3.75E-11
Kr85	N/A	4.70E-13	4.66E-11
1129	4.69E-08	N/A	N/A
Rn219	N/A	N/A	N/A
Pb212(Rn220)	4.56E-08	N/A	N/A
Pb214(Rn222)	2.11E-09	N/A	N/A
-	9.46E-08	5.27E-13	8.41E-11
Dose Results			
	Inhalation	Submersion	Skin
	3.41E+01	1.96E-04	
		2.81E-09	1.90E-06
		7.46E-01	7.40E+01
	1.64E+01		
	2 24F±01		
	3 13E-05		
- Totals	7 29E+01	7 46F-01	7 40F+01
101010	,	1102 01	11102101
Row 7 Input(Table 6.7.1-	1) Inhala	tion Submer	sion Skin
PCSA Tool Version 3.0) 7.29E-	+01 7.47E-	01 7.41E+01
EXCEL	7.29E-	+01 7.46E-	01 7.40E+01
Percent Difference	0.03	% 0.08%	6 0.16%

Test Results from Table 6.7.1-1, 8th row input

16
0.2
3.33E-03
528.05
4
BWR

Intermed. Results

•

•

	Ci/Assem	Air Conc.	Inhalation
H3	4.25E+01	9.53E+09	3.17E+07
Ar39	1.44E-05	3.23E+03	1.08E+01
Kr85	3.83E+02	8.59E+10	2.86E+08
1129	7.61E-03	1.71E+06	5.68E+03
Pb212(Rn220)	1.16E-02	7.22E+01	8.66E+03
Pb214(Rn222)	3.22E-07	7.22E+01	2.40E-01
		.	-
Dose Conv. Fact.	Inhalation	Submersion	Skin
H3	1.73E-11	1.19E-15	N/A
Ar39	N/A	5.54E-14	3.75E-11
Kr85	N/A	4.70E-13	4.66E-11
1129	4.69E-08	N/A	N/A
Rn219	N/A	N/A	N/A
Pb212(Rn220)	4.56E-08	N/A	N/A
Pb214(Rn222)	2.11E-09	N/A	N/A
	9.46E-08	5.27E-13	8.41E-11
Dose Results			
	Inhalation	Submersion	Skin
	1.32E+01	7.58E-05	
		1.19E-09	8.09E-07
		2.70E-01	2.67E+01
	6.40E+00		
	0 /0 - 00		
	9.48E+00		
<u> </u>	1.22E-05		
lotals	2.91E+01	2.70E-01	2.67E+01
Pow 8 Input/Table 6.7.1	1) Inholot	ion Suhmor	sion Ckin
PCSA Tool Version 3 () 290F⊥		02 267E⊥00
FYCEI	2.30C+ 2.01E+		$02 2.07 \pm 00$
	2.0164	2.700-	

Deveent Difference	0 1 70/	0 1 4 9/	0 100/
Percent Difference	U.17%	0.14%	U.12%

, •

.

SVTR#: 7-2-1	Project #: 20.060002.0	1.103						
Software Name: PCSA Tool		Version: 3.0 (Beta P)						
Test ID: 6.7.2.1.1	Test Series Name: Cor Deterministic	iseq RSAC,						
Test Method								
 □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 								
Test Environment Setup								
Hardware (platform, peripherals): Machine griffon, Windows 2000 Workstation								
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaP installed, pcsa_prob, RSAC Version 6.2								
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.								
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the Boiling Water Reactor (BWR) and Pressurized Water Reactor (PWR) values is calculated correctly.								
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.7.2.1.1.2 of the	SVTP for PCSA Tool						
Test	Results							
The RSAC input agrees with the information contained on the PCSA Tool input form. The output doses displayed by the PCSA Tool agree with the output generated by the standalone RSAC module. The TEDE displayed by the PCSA Tool may differ from that displayed in the rsac output file. For these cases, hand calculations were used to verify that the TEDE from the RSAC output file and the PCSA Tool calculated TEDE values are within 5%. Extracted output data may be seen in the appendix. Crystal Report input values were verified by RSAC6.out input values.								
Test Evaluation (Pass/Fail): Pass								
<u>Notes:</u> The "Inoperative" option was located "Hepa, Bldg. Discharge, Others" for Test Cas	under "Release Fraction se D.	by Group" and not						
Tester: Troy Maxwell	Date: August 9, 2004							

<u>Appendix</u>

288 () () () () () () () () () (HSAC OU	pul and	
Summery Results		Ingestional		Giound	Surface		Totals . Pak
				the second			南北全主的
Pathway	Mean Dose per Event Sequence (rem)	Minimum	5th 👘	50th	95h	Maximum	Number
INHALATION	2.22E-06	2.22E-06	2.22E-06	2.22E-06	2.22E-06	2.22E-06	0
INGESTION	2.51E-05	2.51E-05	2.51E-05	2.51E-05	2.51E-05	2.51E-05	0
GROUND SURFACE	7.64E-08	7.64E-08	7.64E-08	7.64E-08	7.64E-08	7.64E-08	0
SUBMERSION	1.56E-07	1.56E-07	1.56E-07	1.56E-07	1.56E-07	1.56E-07	0
TEDE	2.76E-05	2.76E-05	2.76E-05	2.76E-05	2.76E-05	2.76E-05	0

Data extracted from 7-2-1A_Rsac6.out:

•

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIRIMMERS	S TOTAL
22380 U-238	1.29E-14	3.86E-18	1.37E-20	-	1.29E-14
902340 Th-234	3.23E-18	3.50E-18	2.07E-19	-	6.94E-18
922340 U-234	6.40E-14	1.91E-17	8.29E-20	-	6.40E-14
902300 Th-230	1.68E-22	1.19E-23	3.66E-23	-	2.16E-22
862220 Rn-222		0.00E+	- 00	0.00)E+00
842180 Po-218		6.40E-	18 -	6.40	DE-18
822140 Pb-214	1.25E-12	5.94E-14	1.76E-13	-	1.49E-12
832140 Bi-214	6.55E-13	1.50E-15	1.02E-12	-	1.68E-12
822100 Pb-210	2.12E-15	1.28E-16	9.77E-20	-	2.24E-15
832100 Bi-210	4.91E-20	1.14E-19	1.88E-19	-	3.51E-19
952430 Am-243	7.12E-12	7.58E-14	1.98E-16	-	7.20E-12
932390 Np-239	4.06E-17	1.53E-17	5.61E-18	-	6.15E-17
942390 Pu-239	5.76E-11	4.04E-13	1.12E-17	-	5.80E-11
922350 U-235	5.85E-16	1.77E-19	1.61E-19	-	5.85E-16
902310 Th-231	3.99E-21	8.69E-22	2.01E-20	-	2.50E-20
862190 Rn-219	-	-	0.00E+00	-	0.00E+00
822110 Pb-211	1.23E-14	0.00E+00	1.62E-18	-	1.23E-14
832110 Bi-211	-	-	1.56E-18	-	1.56E-18
852110 At-211	6.74E-17	1.58E-18	6.47E-20	-	6.90E-17
832070 Bi-207	8.06E-24	5.80E-24	2.53E-21	-	2.54E-21
812070 TI-207		1.94E-2	20 -	1.94	4E-20
SUBTOTALS	2.22E-06	2.51E-05	7.64E-08	-	2.74E-05

FINITE MODEL CLOUD GAMMA 1.56E-07

TOTAL **2.76E-05**

RSAC	Public	Ana	vsis:	'Test	Case	в.
110.102			,			

.

Summary Results	inhelation -	Ingenion		Grand	Surface 9		Totals 1
				和過度力			
Pathway -	Mean Dose per Event Sequence (rem)	Minimum	5th 10.0	50th 1	95h	Maximum	Number
INHALATION	5.72E-06	5.72E-06	5.72E-06	5.72E-06	5.72E-06	5.72E-06	0
INGESTION	6.44E-05	6.44E-05	6.44E-05	6.44E-05	6.44E-05	6.44E-05	0
GROUND SURFACE	1.81E-07	1.81E-07	1.81E-07	1.81E-07	1.81E-07	1.81E-07	0
SUBMERSION	4.33E-07	4.33E-07	4.33E-07	4.33E-07	4.33E-07	4.33E-07	0
TEDE	7.07E-05	7.07E-05	7.07E-05	7.07E-05	7.07E-05	7.07E-05	0

Data extracted from 7-2-1B_Rsac6.out:

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIR IM	IERS TOTAL
922380 U-238	3.09E-14	9.27E-18	8.48E-20	-	3.09E-14
902340 Th-234	7.76E-18	4.91E-19	1.28E-18	-	9.53E-18
922340 U-234	1.68E-13	5.03E-17	2.18E-19	-	1.68E-13
902300 Th-230	4.42E-22	3.14E-23	2.29E-22	-	7.03E-22
862220 Rn-222		0.00E+	- 00		0.00E+00
842180 Po-218		1.64E-1	7 -		1.64E-17
822140 Pb-214	3.22E-12	1.52E-13	4.53E-13	-	3.82E-12
832140 Bi-214	1.68E-12	3.86E-15	2.62E-12	-	4.31E-12
842140 Po-214		3.02E-2	- 20		3.02E-20
822100 Pb-210	5.43E-15	3.30E-16	2.51E-19	-	5.76E-15
832100 Bi-210	1.26E-19	2.93E-19	4.83E-19	-	9.02E-19
952430 Am-243	1.48E-11	1.57E-13	4.10E-16	-	1.50E-11
932390 Np-239	8.43E-17	3.18E-17	1.16E-17	-	1.28E-16
942390 Pu-239	1.53E-10	1.07E-12	2.98E-17	-	1.54E-10
922350 U-235	1.47E-15	4.45E-19	4.04E-19	-	1.47E-15
902310 Th-231	1.00E-20	2.22E-21	5.05E-20	-	6.28E-20
912310 Pa-231	0.00E+00	0.00E+00			0.00E+00
862190 Rn-219		0.00E+	- 00		0.00E+00
822110 Pb-211	2.64E-14	0.00E+00	3.49E-18	-	2.64E-14
832110 Bi-211		3.35E-1	18 -		3.35E-18
852110 At-211	1.45E-16	3.39E-18	1.39E-19	-	1.48E-16
832070 Bi-207	1.73E-23	1.25E-23	5.44E-21	-	5.47E-21
812070 TI-207		4.17E-2	20 -		4.17E-20
SUBTOTALS	5.72E-06	6.44E-05	1.81E-07	-	7.03E-05

FINITE MODEL CLOUD GAMMA 4.33E-07

TOTAL 7.08E-05 *

5.72E-06 + 6.44E-05 + 1.81E-07 + 4.33E-07 = 7.07E-05

* Percent Diff. ((7.08E-05 - 7.07E-05) / 7.08E-05)100 = 0.09%

	RSAC Input str. 1 and 4 and 4 and 4 and			t de la	RSAC Ou	put	
Summery Results		- Ingestion		Ground	Surface .		Totals
	一、"是你和我们的人"	1. 1. A.					119
Patrivay Talent - 1 - 1	Moan Dive per Event Sequence (r	em] Mirinum	5th	506428	95th 22.	Maximum	Number
INHALATION	2.22E-06	2.22E-06	2.22E-06	2.22E-06	2.22E-06	2.22E-06	0
INGESTION	2.51E-05	2.51E-05	2.51E-05	2.51E-05	2.51E-05	2.51E-05	0
GROUND SURFACE	6.96E-08	6.96E-08	6.96E-08	6.96E-08	6.96E-08	6.96E-08	0
SUBMERSION	1.56E-07	1.56E-07	1.56E-07	1.56E-07	1.56E-07	1.56E-07	0
TEDE	2.75E-05	2.75E-05	2.75E-05	2.75E-05	2.75E-05	2.75E-05	0

Data extracted from 7-2-1C_Rsac6.out:

.

.

_ _ _ _ _ _ _

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIR IMMERS	TOTAL

842180 Po-218		6.40E-1	18 -	6.40E	5-18
822140 Pb-214	1.25E-12	5.94E-14	1.76E-13	-	1.49E-12
832140 Bi-214	6.55E-13	1.50E-15	1.02E-12	-	1.68E-12
822100 Pb-210	2.12E-15	1.28E-16	9.77E-20	-	2.24E-15
832100 Bi-210	4.91E-20	1.14E-19	1.88E-19	-	3.51E-19
862190 Rn-219		0.00E+	- 00	0.00E	E+00
822110 Pb-211	1.23E-14	0.00E+00	1.62E-18	-	1.23E-14
832110 Bi-211		1.56E-1	- 18	1.56E	E-18
852110 At-211	6.74E-17	1.58E-18	6.47E-20	-	6.90E-17
832070 Bi-207	8.06E-24	5.80E-24	2.53E-21	-	2.54E-21
812070 TI-207		1.94E-2	- 20	1. 9 4E	-20
SUBTOTALS	2.22E-06	2.51E-05 6.90	6E-08	-	2.74E-05

FINITE MODEL CLOUD GAMMA 1.56E-07

TOTAL 2.75E-05

	a HSAL INDUCTION STATES AND A STATE				FISAC Ou	put issi	
Summary Reputs	We with the second weeks of the second	24 Ingention	RE ÌN	Giand	Suitace (* S		. Tolats
	建立这些新闻的资源 。						
Palmey states i	Mean Doke per Event Sequence In	m): Minimum	5th 2 1	50h 250	90h 40h	Meximum	Number
INHALATION	1.01E-04	1.01E-04	1.01E-04	1.01E-04	1.01E-04	1.01E-04	0
INGESTION	2.69E-04	2.69E-04	2.69E-04	2.69E-04	2.69E-04	2.69E-04	0
GROUND SURFACE	3.45E-05	3.45E-05	3.45E-05	3.45E-05	3.45E-05	3.45E-05	0
SUBMERSION	1.77E-06	1.77E-06	1.77E-06	1.77E-06	1.77E-06	1.77E-06	0
TEDE	4.06E-04	4.06E-04	4.06E-04	4.06E-04	4.06E-04	4.06E-04	0

Data extracted from 7-2-1D_Rsac6.out:

.

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIR IMMER	S TOTAL
942420 Pu-242	1.24F-08	5 01E-12	4 59E-15		1 24F-08
942380 Pu-238	2.44E-05	1.70E-07	1.19E-11	-	2.46F-05
922380 U-238	4.12E-10	1.24E-13	1.13E-15	-	4.13E-10
902340 Th-234	1.04E-13	6.55E-15	1.71E-14	-	1.27E-13
912340 Pa-234	2.91E-19	2.07E-18	7.56E-15	-	7.56E-15
912341 Pa-234m		3.90E	-20 -	3.90	E-20
922340 U-234	2.25E-09	6.73E-13	2.92E-15	-	2.25E-09
902300 Th-230	2.96E-18	4.19E-19	3.06E-18	-	6.44E-18
862220 Rn-222		0.00E	+00 -	0.00	E+00
842180 Po-218		6.62E	-17 -	6.62	E-17
822140 Pb-214	8.23E-12	3.43E-14	1.82E-12	-	1.01E-11
832140 Bi-214	2.50E-12	1.56E-14	1.05E-11	-	1.31E-11
842140 Po-214		1.22E	-19 -	1.22	E-19
822100 Pb-210	3.35E-15	3.09E-16	2.51E-19	-	3.65E-15
832100 Bi-210	3.45E-20	2.66E-19	1.63E-18	-	1.93E-18
952430 Am-243	1.98E-07	2.11E-09	5.49E-12	-	2.00E-07
932390 Np-239	1.13E-12	4.26E-13	1.56E-13	-	1.71E-12
942390 Pu-239	2.04E-06	1.43E-08	3.99E-13	-	2.06E-06
922350 U-235	1.97E-11	5.95E-15	5.41E-15	-	1.97E-11
902310 Th-231	1.38E-16	2.98E-17	6.77E-16	-	8.45E-16
912310 Pa-231	1.69E-19	1.77E-19		3.46	E-19
862190 Rn-219		0.00E	+00 -	0.00	E+00
822110 Pb-211	1.90E-13	0.00E+00	2.52E-17	-	1.91E-13
832110 Bi-211		2.41E	-17 -	2.41	E-17
852110 At-211	3.64E-16	8.53E-18	3.50E-19	-	3.73E-16
832070 Bi-207	1.89E-23	3.04E-23	1.33E-20	-	1.33E-20
812070 TI-207		2.90E	-19 -	2.90	E-19
SUBTOTALS	 1 01E-04	 2 60E-04	 3 45E-05		4.04E-04
CODICIALO	1.01L-0 4	2.032-04	0.402-00	-	4.046-04

FINITE MODEL CLOUD GAMMA 1.77E-06

TOTAL **4.06E-04**

4

.

SVTR#: 7-2-2	Project #: 20.060002.0	1.103							
Software Name: PCSA Tool		Version: 3.0 (Beta P)							
Test ID: 6.7.2.1.2	Test Series Name: Con Deterministic, User Spe	iseq RSAC, ecified							
Test	Test Method								
 □ code inspection ◎ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 									
Test Environment Setup									
Hardware (platform, peripherals): Machine griffon, Windows 2000 Workstation									
<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaP installed, pcsa_prob, RSAC Version 6.2									
of the test.									
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data generated from the User Specified input values is calculated correctly.									
Test Procedure: Tested in accordance with s Version 3.0.	ection 6.7.2.1.2.2 of the	SVTP for PCSA Tool							
Test	Results								
The RSAC input agrees with the information contained on the PCSA Tool input form. The output doses displayed by the PCSA Tool agree with the output generated by the standalone RSAC module. The TEDE displayed by the PCSA Tool may differ from that displayed in the rsac output file. For these cases, hand calculations were used to verify that the TEDE from the RSAC output file and the PCSA Tool calculated TEDE values are within 5%. Extracted output data may be seen in the appendix. Crystal Report input values were verified by RSAC6.out input values.									
Test Evaluation (Pass/Fail): Pass									
<u>Notes:</u> Setting the HEPA Filtration to "Inoper Group" and not under "Hepa, Bldg. Discharg	ative" was provided unde e, Others" for Test Case	er "Release Fraction by B User.							
Tester: Troy Maxwell	Date: August 6, 2004								

Appendix:

_ _ _ _ . _

	FISACION AND A CARD		限。即		HEAL UN	DUI CONTRACTOR	
Summary Rebuilts	Thislation	incestori :		Giound	Sulace		Totals 2
9 1			Sh	C. C.	956 4 3	Marrowani	No. 1
INHALATION	3.10E-11	3.10E-11	3.10E-11	3.10E-11	3.10E-11	3.10E-11	0
INGESTION	2.09E-13	2.09E-13	2.09E-13	2.09E-13	2.09E-13	2.09E-13	0
GROUND SURFACE	1.06E-17	1.06E-17	1.06E-17	1.06E-17	1.06E-17	1.06E-17	0
SUBMERSION	5.16E-21	5.16E-21	5.16E-21	5.16E-21	5.16E-21	5.16E-21	0
TEDE	3.12E-11	3.12E-11	3.12E-11	3.12E-11	3.12E-11	3.12E-11	0

Data extracted from 7-2-2A_Rsac6.out:

r .

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIR IMMERS	TOTAL
				********	****
922340 U-234	4.15E-12	2.11E-14	5.35E-18	-	4.17E-12
902300 Th-230	1.09E-20	7.73E-22	5.61E-27	-	1.17E-20
942390 Pu-239	2.69E-11	1.88E-13	5.25E-18	-	2.71E-11
922350 U-235	8.80E-25	9.87E-26	0.00E+00	-	9.79E-25
SUBTOTALS	3.10E-11	2.09E-13	1.06E-17	-	3.12E-11

FINITE MODEL CLOUD GAMMA 5.16E-21

TOTAL **3.12E-11**

RSAC Public Analysis: 'TestCaseB_User'

.

Summery Results	Inheletori (1997)	Ingetion		Ground	Surfaces (2)		Totale .
	a State Production of States						
Pathway	Mean Dote per Event Sequence (re	m) Minimum .	516	50th 21.0	9500	Maxman	Number
INHALATION	1.48E-08	1.48E-08	1.48E-08	1.48E-08	1.48E-08	1.48E-08	0
INGESTION	4.99E-09	4.99E-09	4.99E-09	4.99E-09	4.99E-09	4.99E-09	0
GROUND SURFACE	3.40E-08	3.40E-08	3.40E-08	3.40E-08	3.40E-08	3.40E-08	0
SUBMERSION	4.28E-11	4.28E-11	4.28E-11	4.28E-11	4.28E-11	4.28E-11	0
TEDE	5.38E-08	5.38E-08	5.38E-08	5.38E-08	5.38E-08	5.38E-08	0

Data extracted from 7-2-2B_Rsac6.out:

NUCLIDE	INHALATION	INGESTION	GROUND SUR	AIR IMMERS	TOTAL
270600 Co- 60	1.48E-08	4.99E-09	3.40E-08	-	5.37E-08
922340 U-234	2.07E-12	1.05E-14	2.67E-18	-	2.08E-12
902300 Th-230	5.45E-21	3.86E-22	2.80E-27	-	5.83E-21
SUBTOTALS	1.48E-08	4.99E-09	3.40E-08	-	5.37E-08
		FINITE		GAMMA 4.	28E-11
		TOTAL	5.37E-08 *		

1.48E-08 + 4.99E-09 + 3.40E-08 + 4.28E-11 = 5.38E-08

* Percent Diff. ((5.37E-08 - 5.38E-08) / 5.38E-07)100 = 0.25%

71

۰,

Æ

15

SVTR#: 7-2-3	SVTR#: 7-2-3 Project #: 20.060002.01.103				
Software Name: PCSA Tool		Version: 3.0 (Beta P)			
Test ID: 6.7.2.1.3	Test Series Name: Cor Advanced Input	nseq RSAC,			
Test <u>□ code inspection</u> <u>∞ output inspection</u> <u>□ hand calculation</u> <u>□ spreadsheet</u> <u>□ graphical</u> <u>□ comparison with external code</u>	Method				
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	orkstation			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaP installed, RSAC Version 6.2					
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.					
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the information generated by the RSAC standalone module and placed in the rsac6.out file is the information the user entered as input in rsac6 in					
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.7.2.1.3.2 of the	SVTP for PCSA Tool			
Test	Results				
The information generated from the RSAC standalone module correctly displayed the test input in the rsac6.out file. Data extracted from 7-2-3_RSAC6.out are shown in the appendix.					
Test Evaluation (Pass/Fail): Pass	Test Evaluation (Pass/Fail): Pass				
Notes: None.					
Tester: Troy Maxwell	Date: August 6, 2004				
	50 560 11 661				

Appendix:

* Dose Calcs for inhalation, ingestion, ground surface, & submersion # Released Activities (Ci) for PWR, BWR, or User Specified SNF 2000, 1 TH231, 1.20E-12 U234, 2.40E-12 U235, 1.80E-12 2999 # Meteorological data 5000, 0 5001, 3.0, 40.0, 1420.0, 1.29e+03, 0.0, 1 5002, 0.001, 0.01, 0.0, 0.001, 0.001 5101, 11000.0 5201, 1.0, 0.0 5400, 2, 0.0, 0.0 5410, 1, 6, 0 5999 **# INHALATION Dose Calculation** 7000, 1, 1, 1, 0, 1 7001, 3.33e-04, 0.0, 0, 0 7003, 1.0, 3 7999 **# INGESTION Dose Calculation** 7000, 3, 1, 1, 0, 1 7001, 0, 0.0, 1.0, 0 7004, 0, 2, 7.0, 7.0 7051, 23.8, 15.0, 3.7, 4.1, 0.76, 1.0 7052, 0.57, 0.2, 1.0, 0.0021, 7, 7, 1.0 7053, 225.0, 14.0, 1.0, 16.0, 2.0, 20.0 7054, 0.4, 0.43, 14.0, 3.0, 1.23, 4.9 7055, 0.5, 0.33, 0.5, 0.33 7999 # GROUND SURFACE Dose Calculation 7000, 4, 1, 1, 0, 1 7001, 0, 0.0, 1.0, 0.7 7999 # Submersion Dose Calc for a FINITE plume 9000, 0, 0.0 10000

• • *

٠

SVTR#: 7-2-4 Project #: 20.060002.01.103		1.103			
Software Name: PCSA Tool		Version: 3.0 (Beta P)			
Test ID: 6.7.2.1.4	Test Series Name: Cor Probabilistic, Four Real	nseq RSAC, lizations			
Test	Method				
 □ code inspection □ output inspection □ hand calculation ∞ spreadsheet □ graphical □ comparison with external code 					
Test Environment Setup					
Hardware (platform, peripherals): Machine g	riffon, Windows 2000 Wo	orkstation			
<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaP installed, pcsa_lhs, pcsa_lhsinp, pcsa_prob, RSAC Version 6.2					
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.					
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: The scope of this test is to probabilistic run can also be computed from	Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the dose generated from the probabilistic run can also be computed from four deterministic runs.				
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.7.2.1.4.1 of the	SVTP for PCSA Tool			
<u>Test</u>	Results				
A Probabilistic run of four realizations was performed, data was extracted and reentered into four deterministic runs, and the data calculated from the deterministic runs is within 5% of the probabilistic run.					
The percent difference results are shown in A	Attachment 1.				
Test Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: Troy Maxwell	Date: August 6, 2004				

Attachment 1

% Diff.	Prob.	Det. Avg.	Det. 1	Det. 2	Det. 3	Det. 4
0.5%	5.27E-10	5.24E-10	3.32E-11	1.68E-09	3.29E-10	5.43E-11
0.4%	7.11E-11	7.08E-11	4.48E-12	2.27E-10	4.44E-11	7.33E-12
0.1%	3.59E-15	3.59E-15	2.26E-16	1.15E-14	2.25E-15	3.71E-16
0.3%	8.76E-20	8.73E-20	5.51E-21	2.80E-19	5.48E-20	9.04E-21
0.4%	5.98E-10	5.96E-10	3.77E-11	1.91E-09	3.73E-10	6.16E-11

, • · •

.....

SVTR#: 7-2-5	Project #: 20.060002.01.103			
Software Name: PCSA Tool	Version: 3.0 (Beta P - 10 realization scenario, Beta U - 100 realization scenario)			
Test ID: 6.7.2.1.5	Test Series Name: Conseq RSAC, Probabilistic, Ten Realizations			
Test	Method			
code inspection				
D band calculation				
□ hand calculation				
comparison with external code				
Test Envir	onment Setup			
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Workstation			
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaP, Beta U, installed, pcsa_lhs, pcsa_lhsinp, pcsa_prob, RSAC Version 6.2				
Input Data (files, database, mode settings): D of the test.	Default PCSA Tool database created at the start			
Assumptions, constraints, and/or scope of tes	st:			
Assumptions or constraints: none				
Scope of the test: The scope of this test is to the range of values specified for the probabili Fraction by Group and Meteorological Data.	verify that the values from the lhs.out fall within stic parameter input distributions for Release			
<u>Test Procedure:</u> Tested in accordance with s Version 3.0. Performed a subsequent test co	ection 6.7.2.1.5.2 of the SVTP for PCSA Tool omparing 100-realization sample sets to target			
CDFs and used PCSA Tool Version BetaU for	or this test.			
Test	Results			
A Probabilistic run of ten realizations was performed. The values from the lhs.out file fall with the range of the two specified probabilistic input parameters. The output data is shown in attachment 1. The values from lhs.out from the 100-realization test fall along the target CDF plots as shown in attachment 2.				
Test Evaluation (Pass/Fail): Pass				
Notes: None.				
Tester: Troy Maxwell	Date: September 13, 2004			

Attachment 1:

Calculations to verify value is within specified range. The lower LHS data is subtracted from the specified input while the specified input is subtracted from the higher LHS data. Hence all positive values in the two far right columns indicate the LHS output falls within the range of specified user input.

Realization #	Release Fraction	# - 2.0E-6	2.4E-4 - #
1	2.18E-06	1.76E-07	2.38E-04
2	6.65E-06	4.65E-06	2.33E-04
3	1.81E-05	1.61E-05	2.22E-04
4	5.29E-06	3.29E-06	2.35E-04
5	9.02E-06	7.02E-06	2.31E-04
6	3.12E-06	1.12E-06	2.37E-04
7	4.05E-06	2.05E-06	2.36E-04
8	7.76E-05	7.56E-05	1.62E-04
9	2.92E-05	2.72E-05	2.11E-04
10	1.50E-05	1.30E-05	2.25E-04
Realization #	Avg. Wind Vel.	# - 0.978	13.2 - #
Realization #	Avg. Wind Vel. 2.73	# - 0.978 1.75	<u>13.2 - #</u> 10.47
Realization # 1 2	Avg. Wind Vel. 2.73 4.77	# - 0.978 1.75 3.80	13.2 - # 10.47 8.43
Realization # 1 2 3	Avg. Wind Vel. 2.73 4.77 1.53	# - 0.978 1.75 3.80 0.55	13.2 - # 10.47 8.43 11.67
Realization # 1 2 3 4	Avg. Wind Vel. 2.73 4.77 1.53 2.34	# - 0.978 1.75 3.80 0.55 1.36	13.2 - # 10.47 8.43 11.67 10.86
Realization # 1 2 3 4 5	Avg. Wind Vel. 2.73 4.77 1.53 2.34 1.91	# - 0.978 1.75 3.80 0.55 1.36 0.93	13.2 - # 10.47 8.43 11.67 10.86 11.29
Realization # 1 2 3 4 5 6	Avg. Wind Vel. 2.73 4.77 1.53 2.34 1.91 3.81	# - 0.978 1.75 3.80 0.55 1.36 0.93 2.83	13.2 - # 10.47 8.43 11.67 10.86 11.29 9.39
Realization # 1 2 3 4 5 6 7	Avg. Wind Vel. 2.73 4.77 1.53 2.34 1.91 3.81 2.93	# - 0.978 1.75 3.80 0.55 1.36 0.93 2.83 1.95	13.2 - # 10.47 8.43 11.67 10.86 11.29 9.39 10.27
Realization # 1 2 3 4 5 6 7 8	Avg. Wind Vel. 2.73 4.77 1.53 2.34 1.91 3.81 2.93 6.14	# - 0.978 1.75 3.80 0.55 1.36 0.93 2.83 1.95 5.17	13.2 - # 10.47 8.43 11.67 10.86 11.29 9.39 10.27 7.06
Realization # 1 2 3 4 5 6 7 8 9	Avg. Wind Vel. 2.73 4.77 1.53 2.34 1.91 3.81 2.93 6.14 10.99	# - 0.978 1.75 3.80 0.55 1.36 0.93 2.83 1.95 5.17 10.01	13.2 - # 10.47 8.43 11.67 10.86 11.29 9.39 10.27 7.06 2.21

÷

LHS output data:

1	55			
0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
2.04E-05	0.00E+00	2.18E-06	2.73E+00	1.42E+03
2.00E-02	1.00E-02	0.00E+00	6.00E-03	2.30E-02
6.00E+00	3.33E-04	0.00E+00	1.00E+00	0.00E+00
1.00E+00	7.00E+00	7.00E+00	2.38E+01	1.50E+01
3.70E+00	4.10E+00	7.60E-01	1.00E+00	5.70E-01
2.00E-01	1.00E+00	2.10E-03	3.50E+00	3.50E+00
1.00E+00	2.25E+02	1.40E+01	1.00E+00	1.60E+01
2.00E+00	2.00E+01	4.00E-01	4.30E-01	1.40E+01
3.00E+00	1.23E+00	4.90E+00	5.00E-01	3.30E-01
5.00E-01	3.30E-01	0.00E+00	1.00E+00	7.00E-01
2	55			
0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
6.74E-06	0.00E+00	6.65E-06	4.77E+00	1.42E+03
2.00E-02	1.00E-02	0.00E+00	6.00E-03	2.30E-02
6.00E+00	3.33E-04	0.00E+00	1.00E+00	0.00E+00
1.00E+00	7.00E+00	7.00E+00	2.38E+01	1.50E+01
3.70E+00	4.10E+00	7.60E-01	1.00E+00	5.70E-01

2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 55 3 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.15E-05 0.00E+00 1.81E-05 1.53E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 4 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.21E-04 0.00E+00 5.29E-06 2.34E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 5 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.27E-05 0.00E+00 9.02E-06 1.91E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 6 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 7.28E-06 0.00E+00 3.12E-06 3.81E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01

5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 7 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 4.74E-05 0.00E+00 4.05E-06 2.93E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 8 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 3.03E-05 0.00E+00 7.76E-05 6.14E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 9 55 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 4.05E-06 0.00E+00 2.92E-05 1.10E+01 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01 55 10 0.00E+00 0.00E+00 0.00E+00 0.00E+00 0.00E+00 1.57E-05 0.00E+00 1.50E-05 1.78E+00 1.42E+03 2.00E-02 1.00E-02 0.00E+00 6.00E-03 2.30E-02 6.00E+00 3.33E-04 0.00E+00 1.00E+00 0.00E+00 1.00E+00 7.00E+00 7.00E+00 2.38E+01 1.50E+01 3.70E+00 4.10E+00 7.60E-01 1.00E+00 5.70E-01 2.00E-01 1.00E+00 2.10E-03 3.50E+00 3.50E+00 1.00E+00 2.25E+02 1.40E+01 1.00E+00 1.60E+01 2.00E+00 2.00E+01 4.00E-01 4.30E-01 1.40E+01 3.00E+00 1.23E+00 4.90E+00 5.00E-01 3.30E-01 5.00E-01 3.30E-01 0.00E+00 1.00E+00 7.00E-01

Attachment 2:

• •



CDF Plot for Average Wind Velocity



CDF Plot for Release Fraction for Other Particulates and Fuel Fines

. . . .

· . n.

¢

SVTR#: 7-2-6	Project #: 20.060002.01.103			
Software Name: PCSA Tool		Version: 3.0 (Beta N)		
Test ID: 6.7.2.2.1	Test Series Name: Cor	iseq MELCOR, PWR		
Test □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method			
Test Envir	onment Setup			
Hardware (platform, peripherals): Machine GRIFFON, Windows 2000 Professional Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed, MELCOR 1.8.5				
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.				
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: This test verifies the input files to the MELCOR modules contain the parameters identified as input within the PCSA Tool and the output extracted from the MELCOR output file by the PCSA Tool is the actual data from the MELCOR output file.				
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.7.2.2.1.2 of the	SVTP for PCSA Tool		
Test	Results			
Test results are located in the Appendix.				
The data from Table 6.7.2-11 of the SVTP for PCSA Tool Version 3.0 was input into MELCOR. The input file contains the same data entered into the PCSA Tool. The output data from the 8MEL.OUT and MELCOR output is identical to the results from section 6.7.2.2.1.3 of the SVTP for PCSA Tool Version 3.0.				
Test Evaluation (Pass/Fail): Pass				
Notes: None.				
Tester: Troy Maxwell	Date: August 9, 2004			

<u>Appendix</u>

.

		Output	
Screen Output Results			
	MELCOR Results Radionuclide Type	Building Discharg	e Fraction (unitless)
	Vapors and Noble Gases	2.090E-02	
	Particulates	8.907E-04	Close
Output from 8mel.out	RADIOACTIVE RADIONU	ICLIDE FRACTIC	NAL DISTRIBUTION
	CLASS TYPE01 TYPE 1 9.791E-01 2.090E-02	:09	
	2 9.991E-01 8.908E-04 3 9.991E-01 8.930E-04	1 1	
	4 9.791E-01 2.094E-02 5 9.991E-01 8.942E-04	<u>2</u> 4	
	6 9.991E-01 8.907E-04 7 9.834E-01 1.660E-02	1	
	8 9.991E-01 8.906E-04 9 9.991E-01 8.942E-04	1 1	
	10 9.991E-01 8.907E-0	4	
	12 9.991E-01 8.907E-0	4	
	13 0.000E+00 0.000E+(14 0.000E+00 0.000E+(00 00	
	15 0.000E+00 0.000E+(00	
	16 0.000E+00 0.000E+0 17 9.999E-01 6.327E-0	00 5	

uwR *EOR* MELGEN TITLE 'WHB Assembly Cell' ******* * FILES * ******* * 8melg.OUT OUTPUTFILE 8melg.DIA DIAGFILE RESTARTFILE 8mel.RST * initial time step DTTIME 0.1 * default initial dt=1 NCG INPUT ***** * * MATERIAL 4 IS N2 NCG001 N2 4 * MATERIAL 5 IS O2 NCG002 02 5 NCG333 H2 6 * MATERIAL 6 IS H2 CVH/FL INPUT ***** * CONTROL VOLUME INPUT * ****** * CV10100 'ASSEMBLY CELL#1' 2 1 1 * NON-EQL, HORZ, CV id 2 * POOL ALLOWED, NO FOG CV10101 0 $(V10103 \ 268.0 \ (L \times W) = 20 \times 13.4 = 268$ * FLOW AREA (LxW) * POOL/ATM INPUT CV101A0 3 PVOL 1.0130E05 RHUM 0.5 TATM 305.0 * P = 1 ATM, HUMID, T(K) tempenture CV101A1 CV101A3 MLFR.5 0.2 * 0.8 N2, 0.2 O2 MLFR.4 0.8 * bottom (m); vol (m^3) CV101B0 0.0 0.0 CV101B1 0.5 134.0 * CEILING m; VOL m^3 CV10200 'ASSEMBLY CELL#2' 2 1 1 * NON-EQL, HORZ, CV id 2 0 * POOL ALLOWED, NO FOG CV10201 268.0 * FLOW AREA (LxW) CV10203 * POOL/ATM INPUT CV102A0 3 PVOL 1.0130E05 RHUM 0.5 <u>TATM 305.0</u> * P = 1 ATM, HUMID, T(K) MLFR.4 0.8 MLFR.5 0.2 * 0.8 N2, 0.2 O2 CV102A1 MLFR.4 0.8 MLFR.5 0.2 CV102A3 * bottom (m); vol (m^3) CV102B0 0.5 0.0 CV102B1 15.0 3886.0 * CEILING m; VOL m^3 'ASSEMBLY CELL#3' 2 1 1 * NON-EQL, HORZ, CV id CV10300 * POOL ALLOWED, NO FOG 2 0 CV10301

* FLOW AREA (LxW) CV10303 268.0 * POOL/ATM INPUT CV103A0 3 CV103A1 PVOL 1.0130E05 RHUM 0.5 TATM 305.0 * P = 1 ATM, HUMID, T(K) * 0.8 N2, 0.2 O2 CV103A3 MLFR.4 0.8 MLFR.5 0.2 CV103B0 15.0 0.0 * bottom (m); vol (m^3) CV103B1 15.24 64.320000000000 * CEILING m; VOL m^3 * ENVIRONMENT 2 1 9 * ENVIRONMENT CV90000 * NORM POOL/FOG, T-INDEP 0 -1 CV90001 * NO POOL CV900A1 PVOL 1.0130E05 TATM 300.0 TDEW 280.0 * ATM PRESS, T(K), DEW PT(K) MLFR.4 0.8 MLFR.5 0.2 * 0.8 N2, 0.2 O2 CV900A3 * Ground Surface at -5 m -5.0 0.0 CV900B0 * Height m; atm vol m^3 1.0E5 CV900B1 45.0 ***** FLOW PATHS ***** * VOLUMES JUNCT.ELEV FROM TO FROM ΤO 0.5 FL20100 LOW H FLOW 101 102 0.5 * FLOW A, L, OPEN FRACT FL20101 268.0 0.5 1.0 0 * NORMAL VERTICAL FLOW 0 FL20102 * DEFAULT FOR&REV LOSS COEF 1.0 1.0 FL20103 * SEGMENT A, L, HYD.DIAM. 16.0479041916168 FL201S1 268.0 0.5 103 15.0 15.0 FL20200 HIGH H FLOW 102 * FLOW A, L, OPEN FRACT FL20201 268.0 0.5 1.0 * NORMAL VERTICAL FLOW FL20202 0 0 * DEFAULT FOR&REV LOSS COEF FL20203 1.0 1.0 FL202S1 268.0 0.5 * SEGMENT A, L, HYD.DIAM. 16.0479041916168 * VOLUMES JUNCT.ELEV FROM TO FROM TO 102 900 4.0 40.0 FL12500 VENTOUT FL12501 1.0 36.0 1.0 * FLOW A, L, OPEN FRACT fL12502 * NORMAL VERTICAL FLOW 0 0 * DEFAULT FOR&REV LOSS COEF FL12503 1.0 1.0 * FLOW VEL 30000cfm AIR, POOL 7.08 0.0 FL12504 * SEGMENT A, L, HYD.DIAM. 1.0 4.0 1.0 FL125S1 312.7 14.16 5.0 0 * (x5)MAX PHEAD; RATE-MAX,@MAXP FL125P1 FANA ***** * HEAT STRUCTURE INPUT * ***** 0 HS10001000 5 1 HS10001001 'ROOM FLOOR' Ο. HS10001002 0. 0. -1 HS10001100 1 HS10001101 0.25 5 HS10001200 -1 'NEW CONCRETE' HS10001201 4 HS10001300 0

HS10001400 0 HS10001600 0.5 0.5 * see HSCCCCC400 + 500 1 101 EXT HS10001700 268.0 13.4 15.24 * floor area; boundary L; flow perp L HS90001000 5 0 1 'PARKING LOT' HS90001001 HS90001002 Ο. Ο. HS90001100 -1 1 Ο. 5 HS90001101 2. HS90001200 -1 HS90001201 'NEW CONCRETE' 4 HS90001300 0 HS90001400 0 HS90001600 900 0.5 1 EXT 0.5 HS90001700 5000. 50. 100. * floor area; boundry L; flow perp L ***** * THERMAL PROPERTIES FOR NEW CONCRETE * ***** MPMAT10200 'NEW CONCRETE' MPMAT10201 THC * THERMAL CONDUCTIVITY VS. TEMPERATURE 821 MPMAT10202 CPS 822 * SPECIFIC HEAT VS. TEMPERATURE MPMAT10203 RHO 823 * DENSITY VS. TEMPERATURE TF82100 'THC CONCRETE' 2 1.0 0.0 TF82111 273.15 10000.0 1.3 1.3 TF82200 'CPS CONCRETE' 2 1.0 0.0 TF82211 273.15 1200.0 10000.0 1200.0 TF82300 'RHO CONCRETE' 1.0 0.0 2 TF82311 273.15 2340.0 10000.0 2340.0 ***** * DECAY HEAT DEFINITION * ***** DCHDEFCLS0 ALL DCHCLS0170 'U Released from Fuel' DCHCLS0171 FF DCHCLSNORM 'NO' * * _____ * REDEFINE DECAY HEATS ALLOWREPLACE * Update decay heats * Input time(s) & decay heat power(W/kg) for each element * Decay heat output was normalized by the entire RN class mass * and the element fractions were all set to one. ÷ Element\/ \/ Fraction of Class Mass 'CO' 1.0 DCHNEM0100 DCHNEM0101 0.0 1.4400E-01 DCHNEM0102 200000.0 1.4400E-01 'KR' 1.0 DCHNEM0200 DCHNEM0201 0.0 4.5300E-01

DCHNEM0202	200	0000.0) 4	.530	00E-0	1
DCHNEM0300	'SR'	1.0				
DCHNEM0301		0.0) 9	.400	JOE01	
DCHNEM0302	200	0000.0) 9	.400	JOEOI	
DCHNEM0400	'Y'	1.0	~ 4	27	20001	
DCHNEM0401		0.0		.3/(JUEUI	
DCHNEM0402	200	0000.0) 4	.370	JOEOI	
DCHNEM0500	'SB'	1.0	~ 4	07/		1
DCHNEM0501		0.0		.27	DOE-0	1
DCHNEM0502	200	1000.0	0 4	.27	00E-0	Т
DCHNEM0600	'CS'	1.0	<u> </u>	FC	00001	
DCHNEM0601	200		0 2	.50	00501	
DCHNEM0602		1 0	0 2	. 500	00601	
DCHNEM0700	BA	1.0	n 9	10	00501	
DCHNEM0701	200		0 9 0 9	40	00501	
DCHNEM0702	15111	1 0	0)	. 10	00101	
DCHNEM0900	ĿО	1.0	0 4	37	00E01	
DCHNEM0901	200		0 4	37	00E01	
DCHNEM0902	1 DII	1 0		• 57	00001	
DCHNEM1000	FO	1.0	0 8	10	00E-0	1
DCHNEM1001	200	0.000	0 0 0 8	10	00E-0	1
DCHNEM11002	1 AM	1 0	0 0	• 10	001 0	-
DCHNEM1100	11-1	1.0	0 4	37	00E01	
DCHNEM1101	200	0000.	0 4	.37	00E01	
DCHNEM1200	'CM'	1.0	-			
DCHNEM1201	011	 0.	0 4	.37	00E01	
DCHNEM1202	20	0000.	0 4	.37	00E01	
DCHNEM3500	1991	1.0	-			
DCHNEM3501		0.	0 8	.78	00E-0	1
DCHNEM3502	20	0000.	0 8	.78	00E-0	1
*						
* Zero defaul	t de	cay h	eats			
DCHNEM0800	'PM'	0.0				
DCHNEM0801		0.0	0.0			
DCHNEM1300	'XE'	0.0				
DCHNEM1301		0.0	0.0			
DCHNEM1400	'RB'	0.0				
DCHNEM1401		0.0	0.0			
DCHNEM1500	'I'	0.0				
DCHNEM1501		0.0	0.0)		
DCHNEM1600	'BR'	0.0	~ ~			
DCHNEM1601		0.0	0.0)		
DCHNEM1700	'TE'	0.0				
DCHNEM1701		0.0	0.0)		
DCHNEM1800	'SE'	0.0				
DCHNEM1801		0.0	0.0)		
DCHNEM1900	'RU'	0.0	0.0			
DCHNEM1901		0.0	0.0)		
DCHNEM2000	'RH'	0.0	0.0	`		
DCHNEM2001	1001	0.0	0.0	,		
DCHNEM2100	. PD.	0.0	0 0	`		
DCHNEM2101	11/01	0.0	0.0	,		
DCHNEM2200	'MO'	0.0	0 0	`		
DCHNEM2201	1001	0.0	0.0	,		
DCHNEM2300	10	0.0				
DOUNDMO 201		0 0	0 0	<u>۱</u>		

```
DCHNEM2400
             'NB' 0.0
DCHNEM2401
                  0.0
                       0.0
             'CE' 0.0
DCHNEM2500
DCHNEM2501
                  0.0
                       0.0
             'ZR' 0.0
DCHNEM2600
DCHNEM2601
                  0.0
                       0.0
DCHNEM2700
             'NP' 0.0
DCHNEM2701
                  0.0
                       0.0
             'LA' 0.0
DCHNEM2800
DCHNEM2801
                  0.0
                       0.0
             'PR' 0.0
DCHNEM2900
DCHNEM2901
                  0.0
                       0.0
DCHNEM3000
             'ND' 0.0
DCHNEM3001
                  0.0
                       0.0
DCHNEM3100
             'U'
                 0.0
DCHNEM3101
                  0.0
                       0.0
DCHNEM3200
             'AS' 0.0
DCHNEM3201
                  0.0
                       0.0
DCHNEM3300
             'SN' 0.0
DCHNEM3301
                  0.0
                       0.0
             'AG' 0.0
DCHNEM3400
DCHNEM3401
                  0.0
                       0.0
******
* RADIONUCLIDE INPUT *
******
        ACTIVATE RN1 PACKAGE
RN1000
        0
*
       NUMSEC NUMCOMP NUMCLS H20# B203# #AERO-S #VAP-S CSI# CHEM#
RN1001
                                            12
                                                     2
         20
                 17
                          17
                                14
                                     13
                                                          16
                                                                6
RNCC001 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17
* AEROSOL MIN AND MAX DIAMETERS; AEROSOL NOMINAL DENSITY
*
          DMIN
                   DMAX
                         NOM.DENSITY(kg/m^3)
RN1100 1.0000E-08
                   1.0000E-02
                                    1000.0
* PARTICLE SIZE DISTRIBUTION
* _____
* See p. 57-58 of "Commerical SNF Accident Release Fractions" (1999)
* ANL-WHS-SE-000002 REV 00
* MMD = Mass Median Diameter
* GSD = Geometric Standard Deviation
* Burst Rupture> MMD=150 mircometers, GSD=3.8 (Lorenz et al. 1980)
* Impact Rupture> MMD= 18 mm, GSD=8.18 (Mecham et al. 1981)
* Crud Distrib => MMD= 9.7E-6 m, GSD=1.87 (Sandoval et al. 1991)
            2=gas,vapor
                                     2=LOGNORMAL
*
       CV PHS CLS RFRAC MRATE
                                 TAB DIST
RNVS010 102 2
               1 1.0
                         1.4100E00 555
                                             * Noble Gas, Xe
                                          2 * Alkali Metals, Cs released spent

18 * MMD(m) GSD

2 * Alkaline Earths, Ba nuclear fuel
BNAS020 102 2
                2 1.0
                          3.5500E-05 555
                            2.1000E-02 8.18 * MMD(m) GSD
RNAS021
RNAS030 102 2
               3 1.0
                          3.9000E-05 555
                            2.1000E-02 8.18 * MMD(m) GSD
RNAS031
RNVS040 102 2
               4 1.0
                         1.6400E-02 555
                                            * Halogens, I
RNAS050 102 2 5 1.0
                         5.8100E00 555 2 * Chalcogens
```

RNAS051 2.1000E-02 8.18 * MMD(m) GSD RNAS060 102 2 6 1.0 1.0900E-04 555 2 * Planitoids 2.1000E-02 8.18 * MMD(m) GSD RNAS061 RNAS070 102 2 7 1.0 2.3500E-04 555 2 * Early Trans Metals RNAS071 9.7000E-06 1.87 * Co CRUD values, MMD(m) GSD RNAS080 102 2 8 1.0 2.3400E-04 555 2 * Tetravalents RNAS081 2.1000E-02 8.18 * MMD(m) GSD RNAS090 102 2 9 1.0 1.1100E-05 555 2 * Trivalents RNAS091 2.1000E-02 8.18 * MMD(m) GSD RNAS100 102 2 10 1.0 8.0400E-04 555 2 * Uranium RNAS101 2.1000E-02 8.18 * MMD(m) GSD RNAS110 102 2 11 1.0 2.4600E-07 555 2 * More Volatile RNAS111 2.1000E-02 8.18 * MMD(m) GSD RNAS120 102 2 12 1.0 3.7300E-06 555 2 * Less Volatile RNAS121 2.1000E-02 8.18 * MMD(m) GSD RNAS130 102 2 11 1.0 4.8400E-07 555 2 * B, Si, P RNAS131 2.1000E-02 8.18 * MMD(m) GSD 6.1800E02 555 2 * Large SNF particles of U RNAS140 101 2 17 1.0 RNAS141 5.0000E-02 0.1 * Forced large sizes, MMD(m) GSD * aerosol TF linearly decreasing from 2.0 kg/s to zero in 1 s \/ Enter # of Assemblies BELOW TENAME NTEPAR TESCAL TEADCN # Fuel Assemblies Breached TF55500 AERO-S 2 6.0 0.0 TF55510 0.0 2.0 * TIME(s) RATE(kg/s) TF55511 1.0 0.0 * TIME(s) RATE(kg/s) * AEROSOL COEFFICIENTS RNACOEF 1 *CALCULATE THE COEFFICIENTS * ADD AEROSOL DEPOSITION SURFACES RNDS001 10001 RHS FLOOR *ROOM FLOOR CV101 RNDS002 90001 RHS FLOOR *PARKING LOT CV900 * FLOW THROUGH AREAS FOR DEPOSITION CV out CV-in Elev Area RNSET001 102 101 0.5 268.0 RNSET002 103 102 15.0 268.0 . * End of MELGEN Input *EOR* MELCOR ****** MELCOR INPUT ***** * 'WHB Assembly Cell' TITLE ******* * FILES * ******* RESTARTFILE 8mel.RST

OUTPUTFILE 8mel.OUT PLOTFILE 8mel.PTF DIAGFILE 8mel.DIA MESSAGEFILE 8mel.MES * CRTOUT * DTSUMMARY * CPULIM 100000.0 CPULEFT 20.0 * 0 RESTART * * TIME DTMAX DTMIN DTEDT DTPLT DTRST 0.0 0.1 0.0001 TIME1 9000 9000 9000 0.1 TIME2 10.0 0.0001 9000 9000 9000 TIME3 100.0 0.1 0.0001 9000 9000 9000 TIME4 1000.0 0.1 0.0001 9000 9000 9000 TIME5 10000.0 0.1 0.0001 9000 9000 9000 * TEND 9000 * elapsed time = 2.5 h •

. . . .

...

SVTR#: 7-2-7	Project #: 20.060002.01.103					
Software Name: PCSA Tool		Version: 3.0 (Beta N)				
Test ID: 6.7.2.2.2	Test Series Name: Con	iseq MELCOR, BWR				
Test code inspection output inspection hand calculation spreadsheet graphical comparison with external code	Method					
Test Environment Setup						
<u>Hardware (platform, peripherals):</u> Machine GRIFFON, Windows 2000 Professional <u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaN installed, MELCOR 1.8.5						
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.						
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: This test verifies the input files to the MELCOR modules contain the parameters identified as input within the PCSA Tool and the output extracted from the MELCOR output file by the PCSA Tool is the actual data from the MELCOR output file.						
<u>Test Procedure:</u> Tested in accordance with section 6.7.2.2.2.2 of the SVTP for PCSA Tool Version 3.0.						
Test Results						
Test results are located in the Appendix.						
The data from Table 6.7.2-13 of the SVTP for PCSA Tool Version 3.0 was input into MELCOR. The input file contains the same data entered into the PCSA Tool. The output data from the 8MEL.OUT and MELCOR output is identical to the results from section 6.7.2.2.1.3 of the SVTP for PCSA Tool Version 3.0.						
Test Evaluation (Pass/Fail): Pass						
Notes: None. Tester: Troy Maxwell						
~ 1						

<u>Appendix</u>

		Output				
Screen Output Results						
	MELCOR Results					
	Radionuclide Type	Building Discharg	e Fraction (unitless)			
	Vapors and Noble Gases	3.057E-02				
	Co-60 Crud	2.052E-02				
	Particulates	7.708E-04	Close			
Output from 8mel.out	RADIOACTIVE RADIONU	CLIDE FRACTI	IONAL DISTRIBUTION			
	CLASS TYPE01 TYPE()9				
	2 9.992E-01 7.753E-04					
	3 9.992E-01 7.750E-04					
	4 9.694E-01 3.057E-02					
	5 9.992E-01 7.707E-04					
	6 9.992E-01 7.750E-04					
ſ	7 9.795E-01 2.052E-02					
	8 9.992E-01 7.733E-04					
	9 9.992E-017.708E-04	1				
	11 9 992E-01 7 707E-04					
	12 9.992E-01 7.743E-04					
	13 0.000E+00 0.000E+0	0				
	14 0.000E+00 0.000E+0	0				
	15 0.000E+00 0.000E+0	0				
	16 0.000E+00 0.000E+0	0				
	17 9.999E-01 9.695E-05	I.				

BWR

```
*
      *EOR* MELGEN
            'WHB Assembly Cell'
      TITLE
      *******
      * FILES *
      *******
      OUTPUTFILE
              8melg.OUT
      DIAGFILE
              8melq.DIA
      RESTARTFILE 8mel.RST
      * initial time step
              * default initial dt=1
      DTTIME 0.1
      NCG INPUT
      NCG001
            N2
                4
                                  * MATERIAL 4 IS N2
      NCG002
            02
                5
                                  * MATERIAL 5 IS 02
      NCG333
           H2
                6
                                  * MATERIAL 6 IS H2
      CVH/FL INPUT
      ******
      * CONTROL VOLUME INPUT *
      *******
 rocan ath
            'ASSEMBLY CELL#1' 2
                         1 1
                                 * NON-EQL, HORZ, CV id
      CV10100
                                 * POOL ALLOWED, NO FOG
      CV10101
            2 0
    V_{CV10103} = \frac{268.0}{2} (L \times W) = 10 \times 26.8 = 268
                                  * FLOW AREA (LxW)
            3
                                  * POOL/ATM INPUT
      CV101A0
    CV101A1 PVOL 1.0130E05 RHUM 0.5 TATM 297.0 * P = 1 ATM, HUMID, T(K)
terperature CV101A3
                                  * 0.8 N2, 0.2 O2
            MLFR.4 0.8 MLFR.5 0.2
            0.0
                                  * bottom (m); vol (m^3)
                  0.0
      CV101B1 0.5
                134.0
                                 * CEILING m; VOL m^3
      CV10200
           'ASSEMBLY CELL#2' 2
                           1
                              1 .
                                 * NON-EQL, HORZ, CV id
      CV10201
           2
                  0
                                  * POOL ALLOWED, NO FOG
      CV10203 268.0
                                  * FLOW AREA (LxW)
                                  * POOL/ATM INPUT
      CV102A0
           3
           PVOL 1.0130E05 RHUM 0.5 TATM 297.0 * P = 1 ATM, HUMID, T(K)
      CV102A1
                                * 0.8 N2, 0.2 O2
      CV102A3
           MLFR.4 0.8 MLFR.5
                            0.2
                               * bottom (m); vol (m^3)
      CV102B0 0.5 0.0
      CV102B1 15.0 3886.0
                                  * CEILING m; VOL m^3
      CV10300 'ASSEMBLY CELL#3' 2 1
                              1
                                 * NON-EQL, HORZ, CV id
                                  * POOL ALLOWED, NO FOG
      CV10301
            2 0
```

indust
* FLOW AREA (LxW) CV10303 268.0 * POOL/ATM INPUT CV103A0 3 CV103A1 PVOL 1.0130E05 RHUM 0.5 TATM 297.0 * P = 1 ATM, HUMID, T(K) * 0.8 N2, 0.2 O2 MLFR.4 0.8 MLFR.5 0.2 CV103A3 * bottom (m); vol (m^3) CV103B0 15.0 0.0 CV103B1 15.24 64.320000000001 * CEILING m; VOL m^3 * CV90000 ENVIRONMENT 2 1 9 * ENVIRONMENT * NORM POOL/FOG, T-INDEP 0 -1 CV90001 * NO POOL CV900A1 PVOL 1.0130E05 TATM 300.0 TDEW 280.0 * ATM PRESS,T(K),DEW PT(K) CV900A3 MLFR.4 0.8 MLFR.5 0.2 * 0.8 N2, 0.2 O2 * Ground Surface at -5 m -5.0 0.0 CV900B0 * Height m; atm vol m^3 45.0 1.0E5 CV900B1 ***** * FLOW PATHS ***** VOLUMES JUNCT.ELEV FROM TO FROM TO 101 102 0.5 0.5 FL20100 LOW H FLOW * FLOW A, L, OPEN FRACT FL20101 268.0 0.5 1.0 0 * NORMAL VERTICAL FLOW 0 FL20102 1.0 1.0 * DEFAULT FOR&REV LOSS COEF FL20103 FL201S1 268.0 0.5 14.5652173913043 * SEGMENT A, L, HYD.DIAM. FL20200 HIGH H FLOW 102 103 15.0 15.0 FL20201 268.0 0.5 1.0 * FLOW A, L, OPEN FRACT * NORMAL VERTICAL FLOW 0 FL20202 0 * DEFAULT FOR&REV LOSS COEF 1.0 FL20203 1.0 * SEGMENT A, L, HYD.DIAM. FL202S1 268.0 0.5 14.5652173913043 JUNCT.ELEV VOLUMES FROM TO FROM TO 900 40.0 FL12500 VENTOUT 102 4.0 FL12501 1.0 36.0 1.0 * FLOW A, L, OPEN FRACT flownate FL12502 0 0 * NORMAL VERTICAL FLOW FL12503 1.0 1.0 * DEFAULT FOR&REV LOSS COEF 21.16 0.0 * FLOW VEL 30000cfm AIR, POOL FL12504 1.0 4.0 1.0 * SEGMENT A, L, HYD.DIAM. FL125S1 FL125P1 FANA 312.7 14.16 5.0 0 * (x5)MAX PHEAD; RATE-MAX,@MAXP ***** * HEAT STRUCTURE INPUT * ******* 0 5 HS10001000 1 HS10001001 'ROOM FLOOR' Ο. HS10001002 Ο. 0. HS10001100 -1 1 0.25 HS10001101 5 HS10001200 -1 'NEW CONCRETE' 4 HS10001201 HS10001300 0

HS10001400 0 HS10001600 1 101 EXT 0.5 0.5 * see HSCCCCC400 + 500 HS10001700 268.0 26.8 15.24 * floor area; boundary L; flow perp L 5 0 HS90001000 1 HS90001001 'PARKING LOT' HS90001002 Ο. Ο. HS90001100 -1 1 0. HS90001101 2. 5 HS90001200 -1 'NEW CONCRETE' HS90001201 4 HS90001300 0 HS90001400 0 HS90001600 1 900 EXT 0.5 0.5 HS90001700 5000. 50. 100. * floor area; boundry L; flow perp L ********************************* * THERMAL PROPERTIES FOR NEW CONCRETE * ***** MPMAT10200 'NEW CONCRETE' * THERMAL CONDUCTIVITY VS. TEMPERATURE MPMAT10201 THC 821 MPMAT10202 CPS 822 * SPECIFIC HEAT VS. TEMPERATURE MPMAT10203 RHO 823 * DENSITY VS. TEMPERATURE TF82100 'THC CONCRETE' 2 1.0 0.0 273.15 TF82111 1.3 10000.0 1.3 TF82200 'CPS CONCRETE' 2 1.0 0.0 TF82211 273.15 1200.0 10000.0 1200.0 * 2 1.0 'RHO CONCRETE' TF82300 0.0 TF82311 10000.0 2340.0 273.15 2340.0 ***** * DECAY HEAT DEFINITION * ***** DCHDEFCLS0 ALL DCHCLS0170 'U Released from Fuel' DCHCLS0171 FF DCHCLSNORM 'NO' * REDEFINE DECAY HEATS ALLOWREPLACE * Update decay heats * Input time(s) & decay heat power(W/kg) for each element * Decay heat output was normalized by the entire RN class mass * and the element fractions were all set to one. * Element\/ \/ Fraction of Class Mass DCHNEM0100 'CO' 1.0 DCHNEM0101 0.0 1.0300E01 200000.0 1.0300E01 DCHNEM0102 'KR' 1.0 DCHNEM0200 0.0 4.3400E-01 DCHNEM0201

•

DCUNEM0202	200			A 3400F-01
DCHNEM0202		1 0		4.34000-01
DCHNEMUSUU	SK	1.0		0 0700001
DCHNEM0301		0.0		9.2700E01
DCHNEM0302	200	000.0		9.2700E01
DCHNEM0400	'Y'	1.0		
DCHNEM0401		0.0		4.1100E01
DCHNEM0402	200	000.0		4.1100E01
DCHNEM0500	'SB'	1.0		
DCHNEM0501		0.0		4.3200E-01
DCHNEM0502	200	000.0		4.3200E-01
DCHNEM0600	'CS'	1.0		
DCHNEM0601		0.0		2.4700E01
DCHNEM0602	200	000.0		2.4700E01
DCHNEM0700	'BA'	1 0		
DCHNEM0701	DA	1.0 0		9 2700501
DCHNEM0701	200			0.2700E01
DCHNEMU/02	200	1 0		9.2700201
DCHNEM0900	.ΕΟ.	1.0		4 1100001
DCHNEM0901		0.0		4.1100E01
DCHNEM0902	200	000.0		4.1100E01
DCHNEM1000	'PU'	1.0		
DCHNEM1001		0.0		4.1600E-01
DCHNEM1002	200	000.0		4.1600E-01
DCHNEM1100	'AM'	1.0		
DCHNEM1101		0.0		4.1100E01
DCHNEM1102	200	000.0		4.1100E01
DCHNEM1200	'CM'	1.0		
DCHNEM1201		0.0		4.1100E01
DCHNEM1202	200	0000.0		4.1100E01
DCHNEM3500	יקקי יקקי	1.0		
DCHNEM3501		- 0 0	I	7.1100E-01
DCHNEM3502	200			7 1100E-01
*	200			
* Zama dafaul	+ doo	how ho	- +	G
^ Zero deraur			al	5
DCHNEMU8UU	· PM ·	0.0	~	0
DCHNEM0801		0.0	0.	0
DCHNEMI300	'XE'	0.0		
DCHNEM1301			-	-
DCHNEM1400		0.0	Ο.	0
	'RB'	0.0	0.	0
DCHNEM1401	'RB'	0.0 0.0 0.0	o. o.	0
DCHNEM1401 DCHNEM1500	'RB' 'I'	0.0 0.0 0.0 0.0	0. 0.	0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501	'RB' 'I'	0.0 0.0 0.0 0.0 0.0	0. 0.	0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600	'RB' 'I' 'BR'	0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0.	0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601	'RB' 'I' 'BR'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0.	0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700	'RB' 'I' 'BR' 'TE'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0.	0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701	'RB' 'I' 'BR' 'TE'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0. 0.	0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800	'RB' 'I' 'BR' 'TE' 'SE'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0.	0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801	'RB' 'I' 'BR' 'TE' 'SE'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 0. 0. 0. 0. 	0 0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900	'RB' 'I' 'BR' 'TE' 'SE'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0. 0.	0 0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901	'RB' 'I' 'BR' 'TE' 'SE' 'RU'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 0. 0. 0. 0. 0. 	
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM1901	'RB' 'I' 'BR' 'TE' 'SE' 'RU'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	0. 0. 0. 0. 0.	0 0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RH'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 0. 0. 0. 0. 0. 0. 	
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RH'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 o. o. o. o. o. o. o. 	0 0 0 0 0 0 0
DCHNEM1401 DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001 DCHNEM2100	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RH' 'PD'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 o. o. o. o. o. o. 	0 0 0 0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001 DCHNEM2100 DCHNEM2101	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RH' 'PD'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 0. 0. 0. 0. 0. 0. 0. 0. 	0 0 0 0 0 0 0
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001 DCHNEM2101 DCHNEM2101 DCHNEM2200	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RU' 'RH' 'PD'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 o. o. o. o. o. o. o. 	
DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1800 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001 DCHNEM2101 DCHNEM2101 DCHNEM2200 DCHNEM2201	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RU' 'RH' 'PD' 'MO'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 o. o. o. o. o. o. o. o. o. 	0 0 0 0 0 0 0 0 0 0 0 0 0 0
DCHNEM1401 DCHNEM1401 DCHNEM1500 DCHNEM1501 DCHNEM1600 DCHNEM1601 DCHNEM1700 DCHNEM1701 DCHNEM1801 DCHNEM1801 DCHNEM1900 DCHNEM1901 DCHNEM2000 DCHNEM2001 DCHNEM2101 DCHNEM2101 DCHNEM2201 DCHNEM2201 DCHNEM2300	'RB' 'I' 'BR' 'TE' 'SE' 'RU' 'RU' 'RH' 'PD' 'MO'	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	 0. 0. 0. 0. 0. 0. 0. 0. 	0 0 0 0 0 0 0 0 0 0 0 0 0 0

٠

.

```
'NB' 0.0
DCHNEM2400
DCHNEM2401
                 0.0
                      0.0
            'CE' 0.0
DCHNEM2500
DCHNEM2501
                 0.0
                      0.0
            'ZR' 0.0
DCHNEM2600
DCHNEM2601
                 0.0
                      0.0
            'NP' 0.0
DCHNEM2700
DCHNEM2701
                 0.0
                      0.0
DCHNEM2800
            'LA' 0.0
DCHNEM2801
                 0.0
                      0.0
            'PR' 0.0
DCHNEM2900
DCHNEM2901
                 0.0
                      0.0
DCHNEM3000
            'ND' 0.0
DCHNEM3001
                 0.0
                      0.0
DCHNEM3100
            'U'
                0.0
DCHNEM3101
                 0.0
                      0.0
            'AS' 0.0
DCHNEM3200
DCHNEM3201
                 0.0
                      0.0
DCHNEM3300
            'SN' 0.0
                 0.0
DCHNEM3301
                      0.0
            'AG' 0.0
DCHNEM3400
DCHNEM3401
                 0.0
                     0.0
*****
* RADIONUCLIDE INPUT *
******
*
        ACTIVATE RN1 PACKAGE
RN1000
        0
       NUMSEC NUMCOMP NUMCLS H20# B203# #AERO-S #VAP-S CSI# CHEM#
*
RN1001
         20
                 17
                         17
                              14
                                   13
                                         12
                                                  2
                                                       16
                                                              6
RNCC001 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17
*
* AEROSOL MIN AND MAX DIAMETERS; AEROSOL NOMINAL DENSITY
*
         DMIN DMAX NOM.DENSITY(kg/m^3)
RN1100 1.0000E-08 1.0000E-02
                                  1000.0
* PARTICLE SIZE DISTRIBUTION
* _____
* See p. 57-58 of "Commerical SNF Accident Release Fractions" (1999)
* ANL-WHS-SE-000002 REV 00
* MMD = Mass Median Diameter
* GSD = Geometric Standard Deviation
* Burst Rupture> MMD=150 mircometers, GSD=3.8 (Lorenz et al. 1980)
* Impact Rupture> MMD= 18 mm, GSD=8.18 (Mecham et al. 1981)
* Crud Distrib => MMD= 9.7E-6 m, GSD=1.87 (Sandoval et al. 1991)
           2=gas,vapor
                                   2=LOGNORMAL
*
       CV PHS CLS RFRAC MRATE
                               TAB DIST
RNVS010 102 2 1 1.0
                         5.3000E-01 555
                                            * Noble Gas, Xe
RNAS020 102 2
                2 1.0
                         1.3900E-05 555
                                          2 * Alkali Metals, Cs
                           1.8000E-02 8.18 * MMD(m) GSD
RNAS021
                                          2 * Alkaline Earths, Ba
RNAS030 102 2
              3 1.0
                         1.4800E-05 555
RNAS031
                           1.8000E-02 8.18 * MMD(m) GSD
                         6.4100E-03 555
                                        * Halogens, I
RNVS040 102 2
              4 1.0
RNAS050 102 2
                5 1.0
                         2.4100E00 555 2 * Chalcogens
```

RNAS051 1.8000E-02 8.18 * MMD(m) GSD RNAS060 102 2 6 1.0 5.8700E-05 555 2 * Planitoids RNAS061 1.8000E-02 8.18 * MMD(m) GSD released RNAS070 102 2 7 1.0 1.3000E-03 555 2 * Early Trans Metals RNAS071 7.3000E-06 1.87 * Co CRUD values, MMD(m) GSD crud RNAS080 102 2 8 1.0 1.9300E-04 555 2 * Tetravalents RNAS081 1.8000E-02 8.18 * MMD(m) GSD RNAS090 102 2 9 1.0 4.8900E-06 555 2 * Trivalents RNAS091 1.8000E-02 8.18 * MMD(m) GSD RNAS100 102 2 10 1.0 3.3400E-04 555 2 * Uranium RNAS101 1.8000E-02 8.18 * MMD(m) GSD RNAS110 102 2 11 1.0 1.0300E-07 555 2 * More Volatile 1.8000E-02 8.18 * MMD(m) GSD RNAS111 RNAS120 102 2 12 1.0 3.1200E-06 555 2 * Less Volatile RNAS121 1.8000E-02 8.18 * MMD(m) GSD RNAS130 102 2 11 1.0 1.7400E-07 555 2 * B, Si, P RNAS131 1.8000E-02 8.18 * MMD(m) GSD RNAS140 101 2 17 1.0 3.0600E02 555 2 * Large SNF particles of U RNAS141 5.0000E-02 0.1 * Forced large sizes, MMD(m) GSD * aerosol TF linearly decreasing from 2.0 kg/s to zero in 1 s \/ Enter # of Assemblies BELOW * TFNAME NTFPAR TFSCAL TFADCN # Fuel Assemblies Breached TF55500 AERO-S 2 10.0 0.0 * TIME(s) RATE(kg/s)
* TIME(s) RATE(kg/s) TF55510 0.0 2.0 TF55511 1.0 0.0 * AEROSOL COEFFICIENTS RNACOEF 1 *CALCULATE THE COEFFICIENTS * ADD AEROSOL DEPOSITION SURFACES RNDS001 10001 RHS FLOOR *ROOM FLOOR CV101 RNDS002 90001 RHS FLOOR *PARKING LOT CV900 * FLOW THROUGH AREAS FOR DEPOSITION CV out CV-in Elev Area RNSET001 102 101 0.5 268.0 RNSET002 103 102 15.0 268.0 . * End of MELGEN Input *EOR* MELCOR ****** MELCOR INPUT ***** * 'WHB Assembly Cell' TITLE * ***** * FILES * ******* * RESTARTFILE 8mel.RST

. •

OUTPUTFILE 8mel.OUT PLOTFILE 8mel.PTF DIAGFILE 8mel.DIA MESSAGEFILE 8mel.MES * CRTOUT * DTSUMMARY * CPULIM 100000.0 CPULEFT 20.0 * RESTART 0 * * TIME DTMAX DTMIN DTEDT DTPLT DTRST TIME1 0.0 0.1 0.0001 9000 9000 9000 TIME2 10.0 0.1 0.0001 9000 9000 9000 TIME3 100.0 0.1 0.0001 9000 9000 9000 TIME4 1000.0 0.1 9000 9000 9000 0.0001 TIME5 10000.0 0.1 0.0001 9000 9000 9000 * TEND 9000 * elapsed time = 2.5 h.

. •

, **Y**

e

SVTR#: 8-1	Project #: 20.060002.01.103				
Software Name: PCSA Tool		Version: 3.0 (Beta N)			
Test ID: 6.8.1.2	Test Series Name: Safe Compliance Assessme	ety Assessment - nt			
Test	Method				
□ code inspection ⊠ output inspection □ hand calculation ⊠ spreadsheet □ graphical □ comparison with external code					
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine pi	tor, Windows XP				
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed					
Input Data (files, database, mode settings): I 6.8.1 of the SVTP for PCSA Tool Version 3.0	nput information in accor	dance with Section			
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: This test verifies that even category 1, category 2, and BCFL event sequence can be correctly filtered based on category.	<u>st:</u> t sequences can be corr uences. It also verifies tl	ectly categorized as nat event sequences			
<u>Test Procedure:</u> Tested in accordance with s Version 3.0; however in Table 6.8.1-1 BWR a Only public event sequences were evaluated	ection 6.8.1.1.2 of the S and PWR default determ	VTP for PCSA Tool inistic doses were used.			
<u>Test Results</u> Test results from spreadsheet calc_8.xls are attached. Event sequences were correctly categorized and filtered into category 1, category 2, and BCFL event sequences and therefore this test passed.					
Test Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: George Adams Migne Locus	Date: July 30, 2004				

Description of Test Results

For an event sequence to be classified as a category 1 event sequence, its expected number of occurrences (defined as the product of its frequency and the operational period) must be greater than or equal to 1. Otherwise, if its probability (defined as 1-exp(-1*frequency*operational period)) is greater than or equal to 0.0001 then it is a category 2 event sequence and below 0.0001 it is a BCFL event sequence. The table below shows that that the first nine event sequences were identified as category 1 event sequences, the tenth was identified as a category 2 event sequence, and the last one was identified as a BCFL event sequence. The attached Performance Assessment Reports show the event sequences were correctly categorized by the PCSA Tool.

Event Sequence	Frequency	Expected Number of Events	(Category 1	category2	BCFL
1	0.05		2.5	у	n	n
2	0.1		5	ÿ	n	n
3	0.25	1	2.5	У	n	n
4	0.05		2.5	У	n	n
5	0.1		5	У	n	n
6	0.25	1	2.5	У	n	n
7	0.05	2	2.5	У	n	n
8	0.1		5	У	n	n
9	0.25	1	2.5	У	n	n
10	0.001	0	.05	n	У	n
11	0.0000001	0.0000	005	n	n	У

Operation Period 50

The attached Performance Assessment Reports also show that the event sequences can be correctly filtered into Category 1, 2, and BCFL event sequences.

Project: valid_8-1

Description: Node A Level 1

Functional ID: A.1

Item Number	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat.	Description	Man	Dose, Pt. Estimate Path	Dose, Mean Path	Additional Info
0001.00	evsc001	evseq1	5.00E-02	1		N			
0002.00	evsc001	evseq2	1.00E-01	1		N			
0003.00	evsc001	evseq3	2.50E-01	1		N			
0004.00	evsc001	evseq4	5.00E-02	1		N National			
0005.00	evsc001	evseq5	1.00E-01	1		N			
0006.00	evsc001	evseq6	2.50E-01	1		N.			
0007.00	evsc001	evseq7	5.00E-02	1 1		N			
0008.00	evsc001	evseq8	1.00E-01	1		Ň			
0009.00	evsc001	evseq9	2.50E-01	1		N			
0010.00	evsc001	evseq10	1.00E-03	2		Ň			
0011.00	evsc001	evseq11	1.00E-07	BCFL		N			

3:14:35PM

.

Project: valid_8-1

Description: Node A Level 1

Functional ID: A.1

Item Number 0001.00	Event Scenario Identifier evsc001	Event Sequence Identifier evseq1	Event Sequence Frequency 5.00E-02	Cat.	Description	ManN	Dose, Pt. Estimate Path	Dose, Mean Path	Additional Info
0002.00	evsc001 evsc001	evseq2 evseq3	1.00E-01 2.50E-01	1110 - 1 Historia 111 - Calles 1					
0004.00 0005.00	evsc001 evsc001	evseq4 evseq5	5.00E-02 1.00E-01	1		na Harataria Tanataria Harataria Harataria Harataria Harataria N			
0006.00	evsc001 evsc001	evseq6 evseq7	2.50E-01 5.00E-02	t t angtang ter		N Medical profession N			
0008.00	evsc001 evsc001	evseq8 evseq9	1.00E-01 2.50E-01	1 1		na seconda de la constante de			

Doses: rem

3:15:48PM

-

Project: va	alid_8-1			Description:	Node A Level 1		
Functional ID	: A.1						
	Event	Event	Event			• • • • • • • • • • • • • • • • • • •	

Item	Scenario	Sequence	Sequence				Dose, Pt. Estimate	Dose, Mean	
Number	Identifier	Identifier	Frequency	Cat.	Description	Man	Path	Path	Additional Info
0010.00	evsc001	evseq10	1.00E-03	2		N			

Doses: rem

3:16:54PM

7/30/2004

.

Project: valid_8-1 Description: Node A Level 1 Functional ID: A.1 Event Event Event Item Scenario Sequence Sequence Dose, Pt. Estimate Dose, Mean Number Path Identifier Identifier Frequency Description Path Cat. Man Additional Info 0011.00 evsc001 1.00E-07 BCFL evseq11 Ν

7/30/2004

SVTR#: 8-2	Project #: 20.060002.01.103				
Software Name: PCSA Tool		Version: 3.0 (Beta Q)			
Test ID: 6.8.1.2	Test Series Name: Safe Compliance Assessme	ety Assessment - nt			
Test	Method				
 □ code inspection ◎ output inspection □ hand calculation ◎ spreadsheet □ graphical □ comparison with external code 					
<u>Test Envir</u>	onment Setup				
Hardware (platform, peripherals): Machine pitor, Windows XP Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed Input Data (files, database, mode settings): Input information in accordance with Section 6.8.1 of the SVTP for PCSA Tool Version 3.0 Also used input information from "Analytical and Numerical Solutions of the Expected Number of Occurrences for Combinations of Event Sequences Due to Variability" by R. R. Benke, 2003.					
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: This test verifies that the frequency weighted sum and total dose is being calculated correctly for category 1 event sequences. In addition, using the data from Benke, 2003, it verifies that the expected number of combinations calculated from three event sequences agrees with the expected number in Benke, 2003					
<u>Test Procedure:</u> Tested in accordance with section 6.8.1.2.2 of the SVTP for PCSA Tool Version 3.0 except for the combinations of event sequences, the data in Benke, 2003 was used to verify the expected number of combinations calculated. In addition, for this analysis only public results were analyzed both deterministic and probabilistic for frequency-weighted sum calculations with a normal operation dose of 1×10^{-5} rem/vr for the probabilistic case.					
<u>Test Results</u> Test results from spreadsheet calc_8.xls are attached. The frequency * dose values and the frequency weighted dose values agree with spreadsheet calculations. The expected number of combinations agree to within 5% of Benke, 2003 values. Therefore this test was passed.					
Lest Evaluation (Pass/Fail): Pass					
Notes: None.					
Tester: George Adams Klow, Many	Date: August 10, 2004				

Description of Test Results

۴

For the nine category 1 event sequences, the hand calculated frequency-weighted values and total dose are shown below for deterministic calculations. These values agree with those shown on the attached Performance Assessment Report.

Event Sequence		frequency	dose		frequency * dose	percent contribution
•	1	0.05		2.76E-05	1.38E-06	2.52%
	2	0.1		7.07E-05	7.07E-06	12.93%
	3	0.25		2.76E-05	6.90E-06	12.62%
	4	0.05		7.07E-05	3.54E-06	6.47%
	5	0.1		2.76E-05	2.76E-06	5.05%
	6	0.25		7.07E-05	1.77E-05	32.33%
	7	0.05		2.76E-05	1.38E-06	2.52%
	8	0.1		7.07E-05	7.07E-06	12.93%
	9	0.25		2.76E-05	6.90E-06	12.62%
					5.47E-05	

For the nine category 1 event sequences, the hand calculated frequency-weighted values and total dose are shown below for probabilistic calculations. These values agree with those shown on the attached Performance Assessment Report.

Probabilistic Res	ult	S			
Event Sequence		frequency dose		frequency * dose	percent contribution
-	1	0.05	4.94E-06	2.47E-07	2.52%
	2	0.1	1.27E-05	1.27E-06	12.95%
	3	0.25	4.94E-06	1.24E-06	12.59%
	4	0.05	1.27E-05	6.35E-07	6.47%
	5	0.1	4.94E-06	4.94E-07	5.04%
	6	0.25	1.27E-05	3.18E-06	32.37%
	7	0.05	4.94E-06	2.47E-07	2.52%
	8	0.1	1.27E-05	1.27E-06	12.95%
	9	0.25	4.94E-06	1.24E-06	12.59%
				9.81E-06	6

For the three event sequences in Benke, 2003, the analytical expected number of combinations was compared to the PCSA Tool generated expected number of combinations and is shown below.

Combination	Analytical Expected Number	PCSA Tool Result	PCSA Tool Result * 30 years	Percent Difference
E[A]	3	0.1	3	0.00%
E[B]	6	0.2	6	0.00%
E[C]	9	0.3	9	0.00%
E[2A]	0.14	4.68E-03	0.1404	0.29%
E[2B]	0.527	1.76E-02	0.528	0.19%
E[2C]	1.12	3.72E-02	1.116	-0.36%
E[A,B]	0.52	1.73E-02	0.519	-0.19%
E[A,C]	0.745	2.48E-02	0.744	-0.13%
E[B,C]	1.43	4.75E-02	1.425	-0.35%
E[3A]	0.0046	1.55E-04	0.00465	1.09%
E[3B]	0.034	1.15E-03	0.0345	1.47%

E[3C]	0.108	3.60E-03	0.108	0.00%
E[A,B,C]	0.134	4.47E-03	0.1341	0.07%
E[2A,B]	0.025	8.48E-04	0.02544	1.76%
E[2A,C]	0.036	1.21E-03	0.0363	0.83%
E[2B,A]	0.05	1.66E-03	0.0498	-0.40%
E[2B,C]	0.136	4.53E-03	0.1359	-0.07%
E[2C,A]	0.105	3.49E-03	0.1047	-0.29%
E[2C,B]	0.2	6.66E-03	0.1998	-0.10%

۲

The expected number of combinations agree to within 5% with the analytical results in Benke, 2003. In addition, on the attached Safety Assessment Combinations Report, the doses from combinations agree with hand calculated doses found by summing contributing event sequence doses within any combination. Also, the maximum combination dose is correctly selected.

Project: svtr_8

Doses:	rem	
Freque	ncv:	1/vr

~

Functional ID	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat.	Description	Man	Dose, Pt. Estimate freq. * dose % contribution	Additional Information
A.1	1	6	2.50E-01	1		N	7.07E-05	
							1.77E-05	
A 1							32.33	
A.1	1	. 8 .	1.00E-01	1		N	7.07E-05	
							7.07E-06	
Δ 1	1	3	1 005 01				12.93	
~··	1	2	1.002-01	1		N	7.07E-05	
							7.07E-06	
A.1	1	9	2 50E-01	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1			12.93	
	-		2.JUL UI	n an Hinne an Anna an Anna an Anna an Anna an Anna Anna Anna Anna		de off N er _{solede} ter	2./0E=U5	
							6.90E-06	
A.1	1	3	2.50E-01	- 11 (11) 1		NI NI	12.62 and 2	
				•			2.702-05	
							6.90E-06	
A.1	1	'4	5.00E-02	ĩ		N	7.07F-05	
						and a state	3 54E-06	
							06.47	
A.1	1	5	1.00E-01	1		N	2.76E-05	
							2.76E-06	
							05.05	
A.1	1	7	5.00E-02	1		Ν	2.76E-05	
							1.38E-06	
							02.52	
A.1	1	1	5.00E-02	1		N	2.76E-05	
							1.38E-06	
							02.52	

Total Frequency Weighted Dose (rem/yr) 5.47E-05

Normal Operation Dose (rem/yr) 0.00000

Total Dose (rem/yr) 5.47E-05

Project: svtr_8

Public: Category 1

•

.

Doses: rem Frequency: 1/yr

Functional ID	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat.	Description	Man	Dose, Mean freq. * dose % contribution	Additional Information
A.1	1	6	2.50E-01	1		N	1.27E-05	
							3.18E-06	
							32.37	
A.1	1	8	1.00E-01	1		No. No.	1.27E-05	
					가슴다는 것은 가슴을 가려왔다. 백국 가슴감가 가슴을 가슴다 가슴을 통해 사람		1.27E-06	
							12.95	
A.1	1	2	1.00E-01	1		i v	1.275-06	
							12 95	
A 1	1	9	2.50E-01	1		N.	4.94E-06	
A.1							1.24E-06	
				a point			12.59	
A.1	1	3	2.50E-01	1	an 1968an an a	N	4.94E-06	
							1.24E-06	
						and the second second	12.59	no contrato de terrete de la contrato de la contrat
A.1	1	4	5.00E-02	1		N	1.2/E-05	
							6.35E-07	
		-	1 005 01	4		AGE AGE AND	4.94E-06	
A.1	1	5	1.002-01	1			4.94E-07	
							05.04	
A.1	1	7	5.00E-02	1		N	4.94E-06	
							2.47E-07	
							02.52	
A.1	1	1	5.00E-02	1		N	4.94E-06	
							2.47E-07	
							02.52	
						Total Frequency	Weighted Dose (rem	o/yr) 9.81E-06
						Norma	l Operation Dose (rem	n/yr) 1.00E-05

Total Dose (rem/yr) 1.98E-05

3:45:28PM

Project: svtr_8

Expected Number Cutoff: 1.00E-06

		Expected Number of Occurrences	Dose from	
<u>Item</u>	 Combination Type	per year	Combination (rem)	Combination
1	E[X]	2.00E-01	7.07E-05	В.1-В
2	E[X]	3.00E-01	2.76E-05	B.1-C
3	E[X]	1.00E-01	2.76E-05	B.1-A
4	E[2X]	1.76E-02	1.41E-04	B.1-B B.1-B
5	E[2X]	3.72E-02	5.52E-05	B.1-C B.1-C
6	E[2X]	4.68E-03	5.52E-05	B.1-A B.1-A
7	E[X,Y]	4.75E-02	9.83E-05	B.1-B B.1-C
8	E[X,Y]	1.73E-02	9.83E-05	B.1-B B.1-A
9	E[X,Y]	2.48E-02	5.52E-05	B.1-C B.1-A
10	E[3X]	1.15E-03	2.12E-04	B.1-B B.1-B B.1-B
11	E[3X]	3.60E-03	8.28E-05	B.1-C B.1-C B.1-C
12	E[3X]	1.55E-04	8.28E-05	B.1-A B.1-A B.1-A
13	E[X,Y,Z]	4.47E-03	1.26E-04	B.1-B B.1-C B.1-A
14	E[2X,Y]	4.53E-03	1.69E-04	B.1-B B.1-B B.1-C
15	E[2X,Y]	1.66E-03	1.69E-04	B.1-B B.1-B B.1-A
16	E[2X,Y]	6.66E-03	1.26E-04	B.1-C B.1-C B.1-B
17	E[2X,Y]	3.49E-03	8.28E-05	B.1-C B.1-C B.1-A
18	E[2X,Y]	8.48E-04	1.26E-04	B.1-A B.1-A B.1-B
19	E[2X,Y]	1.21E-03	8.28E-05	B.1-A B.1-A B.1-C

Maximum Combination Dose to Public (from 2.12E-04

column 4 above) in rem*:

Normal Operation Dose to Public (rem): 0.00E+00

Aggregate Public TEDE (rem): 2.12E-04

*This is the maximum annual dose to a member of the public from those combinations of event sequences expected to occur at least once before permanent closure (when the cutoff value is set equal to the reciprocal of the preclosure period).

,

٠

SVTR#: 8-3	Project #: 20.060002.01.103						
Software Name: PCSA Tool		Version: 3.0 (Beta Q)					
Test ID: 6.8.1.3	Test Series Name: Safety Assessment - Structures, Systems, and Components Important to Safety						
Test	Method						
 code inspection output inspection hand calculation spreadsheet graphical comparison with external code 							
<u>Test Envir</u>	onment Setup						
Hardware (platform, peripherals): Machine pi	tor, Windows XP						
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed							
Input Data (files, database, mode settings): In 6.8.1 and 6.8.1.3.1of the SVTP for PCSA Too entered a normal operation dose of 1.0x10 ⁻⁵ of of 1.5e-5 rem/yr.	nput information in accord of Version 3.0. For the pr rem/yr and a Maximum D	dance with Section robabilistic case, ose from SSC Failure					
Assumptions, constraints, and/or scope of ter Assumptions or constraints: none Scope of the test: This test verifies that the fr calculated correctly for category 1 event sequ	<u>st:</u> equency weighted sum a Jences.	Ind total dose is being					
<u>Test Procedure:</u> Tested in accordance with s Version 3.0. For this analysis, only public res probabilistic for frequency-weighted sum and	<u>Test Procedure:</u> Tested in accordance with section 6.8.1.3.2 of the SVTP for PCSA Tool Version 3.0. For this analysis, only public results were analyzed both deterministic and probabilistic for frequency-weighted sum and total dose calculations.						
<u>Test Results</u> Test results from spreadsheet calc_8.xls are attached. Spreadsheet calculations agree with reported values and therefore this test passed.							
Test Evaluation (Pass/Fail): Pass							
Notes: None.							
Tester: George Adams Description Date: August 10, 2004							

Description of Test Results

4

For the nine category 1 event sequences (with event sequence 4 excluded), the spreadsheet calculated frequency-weighted values and total dose are shown below for deterministic calculations. These values agree with those shown on the attached Performance Assessment Report for the deterministic analysis.

Deterministic Res	sul	ts						
Event Sequence		frequency	dose		frequency *	dose	percent contrib	ution
	1	0.015		1.50E-04	2.2	5E-06		0.25%
	2	0.051		1.70E-02	8.6	7E-04		95.07%
	3	0.25		2.76E-05	6.9	0E-06		0.76%
4 (not included)		0.05		7.07E-05	3.5	4E-06		0.39%
	5	0.1		2.76E-05	2.7	6E-06		0.30%
	6	0.25		7.07E-05	1.7	7E-05		1.94%
	7	0.05		2.76E-05	1.3	8E-06		0.15%
	8	0.1		7.07E-05	7.0	7E-06		0.78%
	9	0.25		2.76E-05	6.9	0E-06		0.76%
					9.1	2E-04		

For the nine category 1 event sequences (with event sequence 4 excluded), the hand calculated frequency-weighted values and total dose are shown below for probabilistic calculations. These values agree with those shown on the attached Performance Assessment Report for the probabilistic analysis.

Probabilistic Resu	ults						
Event Sequence	frequ	ency	dose		frequency * dose	percent contribu	ution
	1	0.015		3.70E-03	5.55E-05		85.46%
	2	0.051		3.50E-05	1.79E-06		2.75%
	3	0.25		4.94E-06	1.24E-06		1.90%
4 (not included)	0.015	;		1.27E-05	1.91E-07		0.29%
	5	0.1		4.94E-06	4.94E-07		0.76%
	6	0.25		1.27E-05	3.18E-06		4.89%
	7	0.05		4.94E-06	2.47E-07		0.38%
	8	0.1		1.27E-05	1.27E-06		1.96%
	9	0.25		4.94E-06	1.24E-06		1.90%
					6.49E-05		
normal dose					1.00E-05		
max dose due to	SSC Fa	ilure			1.50E-05		
total					8.99E-05		

Project: svtr_8	3						Doses: re Frequenc	m y: 1/yr
Category 1 Dose An	alysis	Base				SSC Takeaway Analysis		
Scenario: Point Estima	ite	Frequenc	y Weighted Sum:	5.47E-05		Frequency Weighted Sum:	9.12E-04	
Normal Operation	0.005.00	Total Dos	e	5.47E-05		Maximum Dose from SSC:	0.00E+00	
Dose:	0.00E+00					Total Dose:	9.12E-04	
Functional ID	Event Scen. ID	Event Seq. ID	Event Seq. Frequency	Cate- gory	Description		Dose, PtEst Dose, Mean	Incl f/SA <u>Calc</u>
A.1	1	1	1.50E-02	1			1.50E-04 3.70E-03	Ŷ
	1	2	5.10E-02	1			1,70F=02 3.50E-05	Y
	1	3	2.50E-01	n series and ser			2.76E-05 4.94E-06	Y
	1	4	1.50E-02				7.07E-05 1.27E-05	N
	1	5	1.00E-01	1			2.76E-05 4.94E-06	Y
		6	2.50E-01	1			7.07E-05 1.27E-05	Ŷ
	1	7	5.00E-02	1			2.76E-05 4.94E-06	Y

Project: svtr_8	ect: svtr_8								
Category 1 Dose A	nalysis	Base	a control of the log is the second	A STREET, STRE	SSC Takeaway Analysis	SSC Takeaway Analysis			
Scenario: Point Estim	ate	Frequency Weighted Sum:		5.47E-05		Frequency Weighted Sum:	9.12E-04	Andreas and Alberta Relation of Society	
Normal Operation	0.00E+00	Total Dose	Total Dose:		A PROPERTY OF THE PROPERTY OF	Maximum Dose from SSC:	0.00E+00	and a second second Second second s Second second s	
Dose:						Total Dose:	9.12E-04	inden of the second	
Functional ID	Event Scen. ID	Event Sea. ID	Event Seq. Frequency	Cate- gory	Description		Dose, PtEst	Incl f/SA	
A.1	1	8	1.00E-01	1			7.07E-05	<u> </u>	
							1.27E-05		
					An American Constanting of States of				
	1	9	2.50E-01	1 1			2.76E-05	Y	
							4.94E-06		

Project: svtr_8	3						Doses: r Frequen	em cy: 1/yr
Category 1 Dose Ar	alysis	Base			Martin Martine at Actual Company and Antonia	SSC Takeaway Analysis		
Scenario: Probabilisti	c, Mean	Frequency	Weighted Sum:	9.81E-06		Frequency Weighted Sum:	6.49E-05	Congen Constantion
Normal Operation	1.005-05	Total Dose		1.98E-05		Maximum Dose from SSC:	1.50E-05	
Dose:	1.002-03	and the formation of the second s	Manager of the second	and the state of t		Total Dose:	8.99E-05	
				SUBDROAD COLOR	Station of Constanting			And Bill Initial Constantion
From etching a large			Event Seq.	Cate-			Dose, PtEst	Incl f/SA
A.1	1	Event Seq. ID	Frequency 1.50E-02	gory1	Description		Dose, Mean 1 50F-04	<u>Calc</u>
							3.70E-03	·
	t contractor a table	2	5.10E-02	1			M70E-02-888-85-25	i e cur d y segun
						en neversión en neversión en neversión en polynolitics com	3.50E-05	
	1	3	2.50E-01	and the second s			2 765-05	
				-			4.94E-06	
	1	4	1.50E-02	alayan (Manada)			7 076-05	N
					erenden alle en	A STATE OF A	1.27E-05	
	1	5	1 00E-01	a and the second bio		in the second	2 JEE OF	
	-	5	1.002-01	1			2.76E-05 4.94E-06	Ŷ
							4.942-00	
	1	6	2.50E-01				7.07E-05	Nagada Y a Char
							1.27E-05	
	1	7	5.00E-02	1			2.76E-05	Y
							4.94E-06	•

8/10/2004 4:05:45PM PCSA Tool, Version 3.0.0, (BetaQ) for evaluation only, not for licensing use

.

Project: svtr_	8						Doses: re Frequence	em :y: 1/yr
Category 1 Dose A	nalysis	Base	Same and the second second	State State		SSC Takeaway Analysis	initia anti-	Contraction of the
Scenario: Probabilisti	ic, Mean	Frequency	Weighted Sum:	9.81E-06		Frequency Weighted Sum:	6.49E-05	
Normal Operation	1.00E-05	DOE-05		1.98E-05		Maximum Dose from SSC:	1.50E-05	
Dose.						Total Dose:	8.99E-05	allen engennen er
Functional ID	Event Scen. ID	Event Seg. ID	Event Seq. Frequency	Cate- gory	Description	an kan kan ang kang kang kang kang kang	Dose, PtEst	Incl f/SA
A.1		8	1.00E-01		Mon Posci Public		7.07E-05	<u> </u>
						a destruction destruction destruction destruction destruction destruction destruction destruction destruction d	1.27E-05	
	1	9	2.50E-01	1 1			2.76E-05	riejin element Y
							4.94E-06	

<u>.</u>

SVTR#: 8-4	Project #: 20.060002.01.103						
Software Name: PCSA Tool		Version: 3.0 (Beta N)					
Test ID: 6.8.2.1	Test Series Name: Risł Scenario Risk	< Assessment - Event					
Test Method							
 □ code inspection □ output inspection □ hand calculation ∞ spreadsheet □ graphical □ comparison with external code 							
<u>Test Envir</u>	onment Setup						
Hardware (platform, peripherals): Machine pitor, Windows XP							
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed, pcsa_ietccdf, pcsa_totrisk							
Input Data (files, database, mode settings): Input information in accordance with Section 6.8.2.1.1of the SVTP for PCSA Tool Version 3.0.							
Assumptions, constraints, and/or scope of ter Assumptions or constraints: none Scope of the test: This test verifies the calcul and total risk. These calculations are being p FORTRAN standalone modules: pcsa_ietccd	<u>st:</u> ations being performed f performed within the PCS f and pcsa_totrisk.	or event scenario risk SA Tool itself and the					
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.8.2.1.2 of the S	VTP for PCSA Tool					
Test Results							
Test results from spreadsheet calc_8.xls are attached. Calculated consequences and risks agreed with spreadsheet calculations to within 5% and therefore this test passed.							
Test Evaluation (Pass/Fail): Pass							
Notes: None.							
Tester: George Adams blong Money	Date: August 2, 2004						

Description of Test Results

6

Event Scenario Calculations:

Performed event scenario calculations within the PCSA Tool for the Functional ID A.1. For Functional ID A.1, the following summarizes the deterministic dose calculations.

Deterministic Event Sequence	frequency	coefficient	dose	coefficient * dose
1	0.025	2.512520833	2.76E-05	6.92E-05
2	0.3	30.15025	2.76E-05	8.31E-04
				9.00E-04

The value calculated within the PCSA Tool was 8.999e-4 which compares to within 5% with spreadsheet calculations. The actual percentage difference is -0.01%.

Performed event scenario calculations within the PCSA Tool for the for the probabilistic case as well. The following summarizes the probabilistic dose calculations.

coefficient * dose	cumulative probability	/ index	Percentile
6.48454E-04	0.1	10	100%
3.28932E-04	0.2	9	90%
2.06242E-04	0.3	8	80%
1.64160E-04	0.4	7	70%
1.12667E-04	0.5	6	60%
4.64886E-05	0.6	5	50%
4.59493E-05	0.7	4	40%
4.48927E-05	0.8	3	30%
1.73170E-05	0.9	2	20%
1.71924E-05	1	1	10%
1.63229E-04			

The values within the PCSA Tool compare as follows:

- 1) Mean: 1.632e-4, percentage difference = -0.02%
- 2) Minimum: 1.719e-5, percentage difference = -0.01%
- 3) 5%: 1.719e-5, percentage difference = -0.01%
- 4) 50%: 4.649e-5, percentage difference = 0.003%
- 5) 95%: 6.485e-4, percentage difference = 0.01%
- 6) Maximum: 6.485e-4 = 0.01%

All of these values are within 5% of the spreadsheet calculations. Note the 5 percentile level is taken at the lowest (i.e., 10 percentile level) since only 10 realizations were performed for this test. The 95 percentile level is taken at the highest (i.e., 100% level) for the same reason.

Total Risk Calculations:

mean

Performed total risk calculations within the PCSA Tool for the Functional ID A.1. For Functional ID A.1, the following summarizes the deterministic dose calculations for each of 8 possible combinations.

Scenario(1,2,3)	Calculated	Report	Percentage	Calculated	Report	Percentage
	Combined	Combined	Difference	Consequence	Consequence	Difference
	Probability	Probability				

nnn	9.512294E-01	9.51E-01	-0.0031%	0	0	0%
nny	1.921611E-02	1.92E-02	-0.0318%	4.17E-05	4.17E-05	-0.0045%
nyn	1.921611E-02	1.92E-02	-0.0318%	1.39E-05	1.39E-05	0.0236%
nyy	3.881912E-04	3.88E-04	-0.0235%	5.57E-05	5.57E-05	0.0025%
ynn	9.560015E-03	9.56E-03	-0.0002%	9.00E-04	9.00E-04	-0.0049%
yny	1.931251E-04	1.93E-04	-0.0130%	9.42E-04	9.42E-04	0.0015%
yyn	1.931251E-04	1.93E-04	-0.0130%	9.14E-04	9.14E-04	0.0043%
ууу	3.901386E-06	3.90E-06	-0.0099%	9.56E-04	9.56E-04	-0.0003%
Scenario(1,2,3	3) Calculate	d Risk	Report Risk	Percer	ntage	
				Differe	nce	
nnn	0.000000	E+00	0.0	0E+00	0%	
nny	8.021167	E-07	8.	02E-07	0.00%	
nyn	2.674252	E-07	2.0	67E-07	-0.01%	
nyy	2.160618	E-08	2.	16E-08	-0.03%	
ynn	8.603478	E-06	8.0	60E-06	-0.01%	
vny	1.818632	E-07	1.	82E-07	-0.03%	
vvn	1.764894	E-07	1.1	77E-07	0.01%	
ŴŶ	3.728175	E-09	3.	73E-09	0.00%	

The probability, consequence, and risk values within the PCSA Tool are shown on the attached Deterministic Risk Report and agree with the deterministic dose calculations shown above to within 5%.

For Functional ID A.1, the following summarizes the probabilistic dose calculations for just one of the combinations. The combination was chosen arbitrarily as one for event sequence 1 and event sequence 2 occurring but not event sequence 3.

Combined Probability	/ Consequence for Scenario 1 and Scenario 2 but not Scenario 3	Risk for Scenario 1 and 2 occuring and not scenario 3 equivalent to risk 4 below
0.000193125	5 1.75E-05	3.37165E-09
	1.76E-05	3.39608E-09
	4.56E-05	8.80404E-09
	4.67E-05	9.01126E-09
	4.72E-05	9.11702E-09
	1.14E-04	2.20955E-08
	1.67E-04	3.21939E-08
	2.09E-04	4.04466E-08
	3.34E-04	6.45078E-08
	6.58E-04	1.27170E-07
mean	1.66E-04	3.20E-08

ı

The probability, consequence and risk values within the PcSA Tool are shown on the attached Probabilistic Risk Report and are compared as follows:

1) Mean Consequence: 1.658e-4, percentage difference = -0.12%

2) Probability: 1.931e-4, percentage difference = -0.01%

3) Mean Risk: 3.201e-8, percentage difference = 0.03%

The values shown on the Probabilistic Risk Report agree with the spreadsheet calculations to

within 5%.

•

PCSA Risk Report

Project: valid_8-4

Type of Run: Deterministic

٤.

		Risk	
Probability	Consequence (rem)	(rem in time period)	Contribution (%)
9.512E-01	0.000E+00	0.000E+00	0.00E+00
9.560E-03	8.999E-04	8.603E-06	8.55E+01
1.921E-02	1.392E-05	2.674E-07	2.66E+00
1.921E-02	4.174E-05	8.021E-07	7.97E+00
1.931E-04	9.139E-04	1.765E-07	1.75E+00
1.931E-04	9.417E-04	1.818E-07	1.81E+00
3.881E-04	5.566E-05	2.160E-08	2.15E-01
3.901E-06	9.556E-04	3.728E-09	3.71E-02
		1.006E-05	
	Probability 9.512E-01 9.560E-03 1.921E-02 1.921E-02 1.931E-04 1.931E-04 3.881E-04 3.901E-06	Probability Consequence (rem) 9.512E-01 0.000E+00 9.560E-03 8.999E-04 1.921E-02 1.392E-05 1.921E-02 4.174E-05 1.931E-04 9.139E-04 1.931E-04 9.417E-04 3.881E-04 5.566E-05 3.901E-06 9.556E-04	Probability Consequence (rem) (rem in time period) 9.512E-01 0.000E+00 0.000E+00 9.560E-03 8.999E-04 8.603E-06 1.921E-02 1.392E-05 2.674E-07 1.921E-02 4.174E-05 8.021E-07 1.931E-04 9.139E-04 1.765E-07 1.931E-04 9.417E-04 1.818E-07 3.881E-04 5.566E-05 2.160E-08 3.901E-06 9.556E-04 3.728E-09 1.006E-05 1.006E-05

PCSA Risk Report

Project: valid_8-4

Type of Run: Probabilistic

.

		Mean Consequenc	Mean Risk	
Outcome State	Probability	(rem)	(rem in time period)	Contribution (%)
	9.512E-01	0.000E+00	0.000E+00	0.00E+00
- +	9.560E-03	1.632E-04	1.560E-06	8.55E+01
- + -	1.921E-02	2.524E-06	4.850E-08	2.66E+00
	1.921E-02	7.571E-06	1.455E-07	7.98E+00
+ + -	1.931E-04	1.658E-04	3.201E-08	1.75E+00
+-+	1.931E-04	1.708E-04	3.298E-08	1.81E+00
- + +	3.881E-04	1.010E-05	3.918E-09	2.15E-01
+++	3.901E-06	1.733E-04	6.761E-10	3.71E-02
Total Risk			1.824E-06	

• . . •

_

SVTR#: 9-1	Project #: 20.060002.0*	1.103	
Software Name: PCSA Tool		Version: 3.0 (Beta Q)	
Test ID: 6.9	Test Series Name: SW Systems	Reliability - Software	
Test	Method		
code inspection			
□ hand calculation			
<u>□ spreadsheet</u>			
□ grapnical □ comparison with external code			
Test Envir	onment Setup		
Hardware (platform, peripherals): Machine gi	iffon, Windows 2000 Pro	fessional	
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaQ installed			
Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test.			
Assumptions, constraints, and/or scope of te	<u>st:</u>		
Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data entered into the Software Systems form is displayed correctly after exiting and reentering the PCSA Tool			
Test Procedure: Tested in accordance with s	ection 6.9.2 of the SV/TP	for PCSA Tool Version	
3.0.			
<u>Test</u>	Results		
The information entered into the Software Systems form is correctly displayed after exiting the PCSA Tool and reentering.			
Test Evaluation (Pass/Fail): Pass	Test Evaluation (Pass/Fail): Pass		
Notes: None			
	Date: August 10, 2004		

PCSA Software Systems Report

Project: SVTP System ID Software-1 System name Software_1 Company Software_2 Functional areas where this system is used Software_3 Any extant failure data on the software system Software_4 Characteristics of the software development process **Characteristics (especially Maturity Level) of the software** development organization Software_6 Analysis of the requirements specification for the software Identification and evaluation of the software standards Software_7 used in developing and applying the software, if any Software_8 Determination of the degree to which the software has been previously used and corrected or the degree to which software components (subsystems and reused software) might be employed Other Software 9 Software_10 Functions performed by this system the state of the state of the Hardware components controlled Software_11 Sensors and other input devices (including keyboard, etc.) Software_12

8/10/2004

3:47:43PM

PCSA Tool, Version 3.0.0, (BetaQ) for evaluation only, not for licensing use

PCSA Software Systems Report

Project: SVTP



8/10/2004

3:47:43PM

I.E.

-1

.

SVTR#: 10-1	Project #: 20.060002.0	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta R)
Test ID: 6.10.1	Test Series Name: Fail	ure Rate
Test □ code inspection ◎ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method	
<u>Test Envir</u>	onment Setup	
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Pro	fessional
Software (OS, compiler, libraries, auxiliary co	odes or scripts): PCSA To	ool Version 3.0 BetaR
Input Data (files, database, mode settings): D	Default PCSA Tool datab	ase created at the start
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data retrieved from the View Taxonomy is displayed correctly and the information corresponds to that listed in the reference.		
<u>Test Procedure</u> : The reference that corresponds to the Letter ID 'C' was removed from the PCSA Tool. Therefore, this test was conducted using the "Electrical Equipment/Generator", with the letter ID 'Q'.		
<u>Test</u>	Results	
The search results for "Electrical Equipment/Generator" were displayed in the 'Search Results for:' form correctly as was the corresponding reference for Letter ID 'Q'. The information corresponds to that listed in the reference.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 18, 2004	

SVTR#: 10-2	Project #: 20.060002.01	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta R)
Test ID: 6.10.2	Test Series Name: Fail	ure Rate
Test □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method	
 Test Envir	onment Setup	
Hardware (platform, peripherals): Machine qu	riffon, Windows 2000 Pro	ofessional
<u>Software (Diatrorm, peripherals):</u> Machine griffon, Windows 2000 Professional Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaR installed		
Input Data (files, database, mode settings): I of the test.	Default PCSA Tool datab	ase created at the start
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the data retrieved from the Failure Rate Data Search is displayed correctly and that the information corresponds to that listed in the reference.		
<u>Test Procedure:</u> The reference corresponding to the number id of 3 was removed from the database. The Test Procedure was conducted by entering 'Pumps' into the 'Failure Rate Data Search' window and inputting 'R' for the letter ID.		
Tes	t Results	
The search results for 'Pumps' were displayed in the 'Search Results for:' form correctly as was the corresponding reference for Letter ID 'R'. The information corresponds to that listed in the reference.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 18, 2004	

٠

بو.

Software Name: PCSA Tool		
	Version: 3.0 (Beta N)	
Test ID: 6.10.3	Test Series Name: Failure Rate	
Test □ code inspection □ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	Method	
Test Enviro	onment Setup	
Hardware (platform, peripherals): Machine gri	ffon, Windows 2000 Professional	
Software (OS, compiler, libraries, auxiliary codes or scripts): PCSA Tool Version 3.0 BetaN installed Input Data (files, database, mode settings): Default PCSA Tool database created at the start of the test. Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the Frequency of Failure per year is		
<u>Test Procedure:</u> Tested in accordance with section 6.10.3.2 of the SVTP for PCSA Tool Version 3.0.		
Test	Results	
The "Frequency of Failure per year" is calculated as the product of the failure rate and the number of hours or demands placed on the component. The product is correctly calculated as shown in the equations in Appendix A.		
I est Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 3, 2004	
Appendix A

Frequency Calculation		
Enter the failure rate (per hour or demand) of the desired component:	.002	
Enter the number of hours or demands to be placed on the component per year:	75	
Frequency of failure per year:	0.15	
, Reset	Close	

Figure 1 Screen capture of Frequency of failure per year calculation.

Equation 1: A * B = C

A = 0.002 B = 75

.

.

0.002 * 75 = 0.15

C = 0.15

-

≜ ⁴

-

5

SVTR#: 10-4	TR#: 10-4 Project #: 20.060002.01.103	
Software Name: PCSA Tool Version: 3.0 (B		Version: 3.0 (Beta N)
Test ID: 6.10.4	Test Series Name: Fail	ure Rate
Test □ code inspection ◎ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code	: Method	
<u>Test Envir</u>	onment Setup	
Hardware (platform, peripherals): Machine gi	riffon, Windows 2000 Pro	ofessional
Software (OS, compiler, libraries, auxiliary co installed	odes or scripts): PCSA To	ool Version 3.0 BetaN
Input Data (files, database, mode settings): I of the test.	Default PCSA Tool datab	ase created at the start
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: The scope of this test is to tester through a series of options and produc	<u>st:</u> verify that the module is sing an output representii	capable of guiding the ng the user input.
<u>Test Procedure:</u> Tested in accordance with section 6.10.4.2 of the SVTP for PCSA Tool Version 3.0.		
<u>Test</u>	Results	
The Human Error Probability Generator correctly guided the user through the series of options and produced an output that correctly represented the input. The output is shown in Appendix A.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 3, 2004	

Appendix A

Record of User Actions for HEP Generation

Abnormal Event? No HEP_A1

....

Primary Operational Actions? Yes HEP_A2

Type of Error? Omissions HEP_A3

Written Materials? No HEP_A4

Administrative or Recall Error? Administrative HEP_A5

Is the human action pursuing: a general standard procedure? HEP_A6

Which of the following types of activities is performed? Implement scheduled shiftly checking or inspection HEP_A7

Table 20-6, Choice: Initiate a scheduled shiftly checking or inpection function* HEP = 0.001, EF = 3 From Table, selected by answers to questions

Apply Performance Shaping Factor? No HEP_A8

Final HEP = 0.001EF = 3End of record

SVTR#: 11-1	Project #: 20.060002.0	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta N)
Test ID: 6.11	Test Series Name: Che	ecklist
Test code inspection output inspection hand calculation spreadsheet graphical	Method	
comparison with external code		
<u>Test Envir</u>	onment Setup	
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Pro	ofessional
Software (OS, compiler, libraries, auxiliary co installed	des or scripts): PCSA To	ool Version 3.0 BetaN
Input Data (files, database, mode settings): Dof the test.	Default PCSA Tool datab	ase created at the start
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user is able to retrieve the Component Failure Mode Checklist and search for a specific component.		
<u>Test Procedure:</u> Tested in accordance with section 6.11.2 of the SVTP for PCSA Tool Version 3.0.		
<u>Test</u>	Results	
The Component Mode Failure Checklist successfully displayed the components shown in section 6.11.1 of the SVTP for PCSA Tool Version 3.0 and produced all components pertaining to the user input.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 3, 2004	
	25.007 / 109401 0, 2004	

SVTR#: 12-1	Project #: 20.060002.0	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta N)
Test ID: 6.12	Test Series Name: Reg	js.
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> 	Method	
<u>Test Envir</u>	onment Setup	
<u>Hardware (platform, peripherals):</u> Machine griffon, Windows 2000 Professional <u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaN installed		
Input Data (files, database, mode settings): I of the test.		ase created at the start
<u>Assumptions, constraints, and/or scope of test:</u> Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user is able to view the regulations and navigate through the links within the screen.		
<u>Test Procedure:</u> Tested in accordance with section 6.12.2 of the SVTP for PCSA Tool Version 3.0.		
Tes	t Results	
Regulations 10CFR20 and 10CFR63 were viewed. The links within each regulation functioned properly.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 3, 2004	

.

SVTR#: 13-1	Project #: 20.060002.0*	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta Q)
Test ID: 6.13	Test Series Name: Help)
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> 	Method	
<u>Test Envir</u>	onment Setup	
<u>Hardware (platform, peripherals):</u> Machine griffon, Windows 2000 Professional <u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0 BetaQ installed <u>Input Data (files, database, mode settings):</u> Default PCSA Tool database created at the start		
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: The scope of this test is to verify that the user is able to view the information contained on the About and Disclaimer window.		
<u>Test Procedure:</u> Tested in accordance with s Version 3.0.	ection 6.13.2 of the SVT	P for PCSA Tool
Test	Results	
The About window and Disclaimer window were viewed and contained information appropriate to the development of the PCSA Tool software.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.		
Tester: Troy Maxwell	Date: August 10, 2004	

. .

£.

SVTR#: 14-1	Project #: 20.060002.0	1.103
Software Name: PCSA Tool		Version: 3.0 (Beta P)
Test ID: 6.14	Test Series Name: Wo	rker Dry Form
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> (RADTRAD) 	Method code and Mathematica	results)
<u>Test Envir</u>	onment Setup	
Hardware (platform, peripherals): Machine pi	tor, Windows XP	
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	odes or scripts): PCSA To	ool Version 3.0.0 BetaP
Input Data (files, database, mode settings): I available on startup	Default PCSA Tool datab	ase, pcsademo
Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: Verify the worker dose calculations against independent calculations performed by software RADTRAD and performed in Mathematica as documented in Scientific Notebook 658.		
<u>Test Procedure:</u> The test procedure is identified on Attachme	nt 1	
Test	<u>Results</u>	
Test Results from spreadsheet 14-1.xls are shown on Attachment 2. PCSA Tool generated values agreed to within 5% with Mathematica generated and computer code RADTRAD generated values and therefore this test passed.		
Test Evaluation (Pass/Fail): Pass		
Notes: None.	I	
Tester: George Adams blog blog	Date: August 6, 2004	

Attachment 1

Test Procedure:

1) Open the worker dry form following the menu sequence: Conseq->Worker Dose->Worker Internal->Dry.

2) Under 'Fuel' on the 'Internal Worker Dose' tab, select BWR, PWR, or User Specified.

3) If User Specified fuel is selected, enter inventories for radionuclides under the 'Source Term tab.

4) Modify Group Release Fractions on the 'Release Fraction by Group' tab as required.5) On the 'Internal Worker Dose' tab, press the 'Calculate Doses' button to calculate the inhalation, submersion, and total dose to the worker.

6) Verify calculated doses against spreadsheet calculated doses.

Attachment 2

Under User Specified input, Total Effective Dose Equivalent (TEDE) values were generated for various radionuclides at arbitrary exposure durations and compared to values documented in Scientific Notebook 658. Two scenarios (abbreviated Scn in the table) were also analyzed: scenario 1 uses a 2,400 %/day ventilation rate of the worker room and scenario 2 uses a 0%/day ventilation rate of the worker room. The PCSA Tool generated values were compared to Mathematica and computer code RADTRAD generated values.

Radio- nuclide	Scn.	Exposure Duration	PCSA Tool TEDE	Mathematica TEDE	Percentage Difference Mathematica	RADTRAD TEDE	Percentage Difference RADTRAD
Kr85, 424Ci	1	3.401	1.3468E-04	1.3468E-04	-0.0014%	1.3464E- 04	0.0297%
		6.401	2.95E-04	2.95E-04	0.0008%	2.95E-04	0.0169%
Am241, 0.0167Ci	2	8	4.78E+02	4.78E+02	0.0010%	4.78E+02	0.0021%
Y90, 0.237Ci	2	2.501	1.26E-02	1.26E-02	-0.0012%	1.26E-02	-0.0636%

As shown in the table, PCSA Tool generated TEDE values agreed to within 5% with both Mathematica and RADTRAD generated values.

Scientific Notebook 658 8 05/28/200-1 Julgram Companyori between "Methematice" and PADTRAD calentations for 4 radionuclides. · Radiomuclides: 85Kr, 205r, 907, and 241 Am. • In the next pages, the results of dose calculations performed with RADIRAD are compared to the ones obtained with "Mathematics" (see "Mathematics" -5th ed., Stephen Wolfran,). • RADTRAD output is labeled Trine (m)/Thyroid (new/ TEDE(new); MT stands for Mathematice - Thyrord and MIEDE for Methematice - TEDE, . On page 17, equation (8) is used to calculate the dose at the limit (Qoi/Vo) -> (Qui/V1) for 241 Am, Scenario #1.

Scenario description:
Scenario #1: Ro1=20%/d, R12=2400%/d
Scenario #2: Ro1=20%/d, R12=0.0%/d

· Compartment volumes: V1=V0=1.8×10⁵ff³(1.e. 5097.032387 m³)

05/28/2009

0.401	3.9492521×10 ⁻⁶
0.701	1.1007055×10 ⁻⁵
1.001	2.0561344×10^{-5}
1.301	3.1954262×10 ⁻⁵
1.601	4.4698482×10^{-5}
1.901	5.8433014×10^{-5}
2.201	7.2890454×10^{-5}
2.501	8.7872736×10 ⁻⁵
2.801	1.0323315×10^{-4}
3.101	1.1886305×10 ⁻⁴
3.401	1.3468195×10^{-4}
3.701	1.5063029×10 ⁻⁴
4.001	1.6666393×10^{-4}
4.301	1.8275023×10^{-4}
4.601	1.9886503×10^{-4}
4.901	2.1499044×10^{-4}
5.201	2.3111325×10^{-4}
5.501	2.472237×10^{-4}
5.801	2.6331458×10^{-4}
6.101	2.7938057×10^{-4}
6.401	2.9541777×10^{-4}
6.701	3.114233×10^{-4}
7.001	3.2739506×10 ⁻⁴
7.301	3.4333152×10 ⁻⁴
7.601	3.5923158×10^{-4}
7.901	3.7509444×10^{-4}
8.	3.8032091×10 ⁻⁴
8.001	3.8037368×10 ⁻⁴

(Kr-8!	5)
Scenario	#1

hagran MTEDE = (Inhalation Which Body Bose) + (Arin submersion while body dose); Dore Criffers for inhalation (V/Rg) are from FOR NO. 11.
Dore Criffers for an ontonerrow
(Sv/s/Bg/m³), are from FOR No. 12 WR1 Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 0.0000E+00 6.8967E-13 0.000 0.0000E+00 3.5432E-12 0.001 0.0000E+00 3.7327E-11 0.401 0.0000E+00 3.9365E-06 0.701 0.0000E+00 1.0987E-05 1.001 0.0000E+00 2.0536E-05 √ 1.301 0.0000E+00 3.1925E-05 1.601 0.0000E+00 4.4666E-05 1.901 0.0000E+00 5.8398E-05 2.201 0.0000E+00 7.2853E-05V 2.501 0.0000E+00 8.7834E-05 2.801 0.0000E+00 1.0319E-04 3.101 0.0000E+00 1.1882E-04 V 3.401 0.0000E+00 1.3464E-04 3.701 0.0000E+00 1.5059E-04 4.001 0.0000E+00 1.6662E-04~ 4.301 0.0000E+00 1.8270E-04 4.601 0.0000E+00 1.9882E-04 4.901 0.0000E+00 2.1494E-04 5.201 0.0000E+00 2.3106E-04 V 5.501 0.0000E+00 2.4717E-04 5.801 0.0000E+00 2.6326E-04 6.101 0.0000E+00 2.7933E-04 v 6.401 0.0000E+00 2.9537E-04 6.701 0.0000E+00 3.1137E-04 7.001 0.0000E+00 3.2734E-04

7.301 0.0000E+00 3.4328E-04 7.601 0.0000E+00 3.5918E-04 7.901 0.0000E+00 3.7504E-04 8.000 0.0000E+00 3.8026E-04 V 9

Maran 05/28/2004 MT

MTEDE

					\$
0.401	1.6356298×10^{-5}		0.401	1.2267223	
0 701	4.9942559×10^{-5}		0.701	3.7456919	
1 001	1.0175165×10^{-4}		1.001	7.6313735	
1 201	1.0173105×10^{-4}		1.501	1.2880354×10^{-1}	ja di secondore
1.501	1.7175000×10^{-4}		1.601	1.9489229×10^{4}	
1.601	2.5985659×10^{-4}		1.901	2.7454605×10^{1}	Sametalagiama
1.901	3.660614×10		2.201	3.6773092×10^{1}	
2.201	4.9030/89×10		2.501	4.7441313×10^{1}	fer on a friday and
2.501	6.3255084×10	:	2.801	5.9455897×10^{1}	
2.801	7.9274529×10		3.101	7.2813482×10^{1}	
3.101	9.7084643×10		3.401	8.7510717×10^{1}	and a characterized
3.401	1.1668096×10^{-3}		3.701	1.0354425×10^{2}	
3.701	1.38059×10^{-3}		4.001	1.2091076×10^{2}	parately and the second
4.001	1.6121434×10^{-3}		4.301	1.396069 \times 10 ²	
4.301	1.8614253×10^{-3}		4.601	1.5962935×10^{2}	
4.601	2.1283914×10^{-3}		4.901	1.8097482×10^{2}	
4.901	2.4129976×10^{-3}		5.201	2.0363998×10^{2}	Rise interferences
5.201	2.7151998×10^{-3}		5.501	2.2762156×10^{2}	
5.501	3.0349541×10 ⁻³		5.801	2.5291625×10^{2}	Varian Indanisi di Willia
5.801	3.3722167×10^{-3}		6.101	2.7952078×10^{2}	
6.101	3.7269438×10^{-3}	Time Thyroid TEDE	6.401	3.0743189×10^{2}	
6.401	4.0990919×10^{-3}	(hr) (rem) (rem)	6.701	3.366463×10^{2}	
6.701	4.4886174×10^{-3}	0.000 0.0000E+00 0.0000E+00 0.000 2 5101E-12 1 8826E-07	7.001	3.6716077×10^{2}	
7.001	4.8954769×10^{-3}	0.000 1.2897E-11 9.6727E-07	7.301	3.9897204×10^{2}	
7.301	5.3196273×10^{-3}	0.001 1.3591E-10 1.0193E-05	7.601	4.3207689×10^{2}	500-00-00700 70
7.601	5.7610252×10^{-3}	0.701 4.9964E-05 3.7473E+00	7.901	4.6647207×10^{2}	
7.901	6.2196276×10 ⁻³	1.001 1.0178E-04 7.6336E+00	8.	4.781051×10^{2}	participant and an
8.	6.3747346×10 ⁻³	1.301 1.7178E-04 1.2883E+01 1.601 2.5990E-04 1.9493E+01	8.001	4.7822332×10^{2}	
8.001	6.3763109×10^{-3}	1.901 3.6612E-04 2.7459E+01			and an interaction of the
. .		2.201 4.9037E-04 3.6778E+01			
a taga da pang tagan katala da pang katalan da pang katalan katalan da pang katalan katalan katalan katalan ka	yngen an ber ewit e rynnen yn annen an gener yn	2.801 7.9283E-04 5.9462E+01		n an y na na na ann an Airte an Airte ann an Airte an Air An Airte an A	
		3.101 9.7094E-04 7.2820E+01√			
		3.401 1.1669E-03 8.7518E+01 3.701 1.3807E-03 1.0355E+02			
/		4.001 1.6123E-03 1.2092E+02 V	and an and a state of the stat		
71	h 7A1	4.301 1.8616E-03 1.3962E+02			
(+	qu-011/	4.901 2.4131E-03 1.8099E+02	an gir maasana sy ar charganaan saasan maasan	na menera yana kana dina kalenda kalenda kalenda ata yang kalenda yang kalenda kang kalenda kang kana kana kale	a
		5.201 2.7154E-03 2.0365E+02 ✓			
ana sa		5.501 3.0351E-03 2.2763E+02 5.801 3.3724E-03 2.5293E+02	en general de la compañía de la comp	en selan juni menimus menin te la comparti anteren de States (menoremente en la comparte en la comparte de tradm	a di sebagan
C	anta tt7	6.101 3.7271E-03 2.7953E+02√			
50	vanu Hh.	6.401 4.0993E-03 3.0745E+02	an a tha an an ann an an ann an an an an an an		
		7.001 4.8957E-03 3.6718E+02			
		7.301 5.3198E-03 3.9899E+02	a da a ser a companya da a ser a fina da a ser a s	ng mana ana amin'ny soratra dia Gran I. I mandrina manana amin'ny manana amin' amin' amin' amin' amin' amin' a	a kanana ka na marakan
		7.601 5.7612E-03 4.3209E+02 7.901 6.2199E-03 4.6649E+02			
a and a second second second	nan ana karakan da karakan na mananan karakan kara karakan karakan karakan karakan karakan karakan karakan mana	8.000 6.3747E-03 4.7810E+02√	the galacter and a set of a set of the set of	a an	

10

i í						11
05	128/2004	01			0111-	finden an antikana dia ang ang ang ang ang ang ang ang ang an
		tula	plan	0.401	4.4744739×10^{-2}	
		V		0.701	1.2470924×10^{-1}	Stand in the property of the second state of the second seco
0.401	3.4291552×10^{-5}			1.001	2.3295894×10^{-1}	
0.701	9.5574888×10^{-5}	an managa managan yang dan kanang mang managan dan sama na		1.301	3.6204039×10^{-1}	
1.001	1.7853548×10^{-4}			1.601	5.0643226×10^{-1}	-
1.301	2.7746115×10^{-4}	an ya na waka waka ini malani kata na matangan pana		1.901	6.6204456×10^{-1}	
1.601	3.8812045×10^{-4}			2.201	8.2584765×10^{-1}	
1.901	5.0737888×10^{-4}	n yayan dan di yaran ta ta ta ta ta ku ku an da ku		2.501	9.9559742×10^{-1}	
2,201	6.3291458×10^{-4}			2.801	1.1696317	in the other set of the particular part of the set of t
2 501	7.6300771×10^{-4}	a ja munga unga na kata ta kata		3.101	1.3467195	
2.301	8 9638441 v 10 ⁻⁴			3.701	1.7066451	
3 101	1.0321012×10^{-3}			4.001	1.8883081	
3 401	1.0521012×10^{-3}			4.301	2.070568	per un sub-section and an
3 701	1.2070417×10^{-3}	an fan ar fan de fan		4.601	2.2531509	
3.701	1.3079417×10^{-3}			5.201	2.6185287	
4.001	1.44/1649×10 ~	and an		5.501	2.8010632	
4.501	1.3868436 X 10	n an the second seco		5.801	2.9833761	
4.601	1.7267738×10 ⁻³		MIFNE ->	6.101	3.1654074	
4.901	1.8667944×10^{-5}	-		6.701	3.5284593	
5.201	2.0067927×10^{-5}			7.001	3.7094236	
5.501	2.1466837×10^{-3}			7.301	3.8899883	
5.801	2.286405×10^{-3}			7.601	4.0701407	
6.101	2.4259105×10^{-3}	al na fina ann an		8.	4.2498719	ann an maraigeach air (1993-1994) ann an Stàitean an Stàitean an Stàitean Airean an Stàitean Airean Airean Air
6.401	2.5651661×10^{-3}			8.001	4.3096875	
6.701	2.7041469×10^{-3}					
7.001	2.8428346×10^{-3}		WD 1			
7.301	2.9812161×10 ⁻³	- 1	Time Thyroid TEDE	Endowed and a second		
7.601	3.1192816×10^{-3}		(hr) (rem) (rem)	•		
7.901	3.2570243×10^{-3}	-	0.000 5.9887E-12 7.8142E-0	9		
8.	3.3024076×10^{-3}		0.000 3.0767E-11 4.0146E-0	8		
8.001	3.3028659×10^{-3}		$0.001 \ 3.2413E-10 \ 4.2293E-0$	7		
			0.701 9.5408E-05 1.2449E-0	1,		
		aeroed ar	1.001 1.7833E-04 2.3269E-0	1/		
			1.601 3.8786E-04 5.0612E-0	1		
Tradical sector and processing dependently of a sec		(Serrive)	1.901 5.0711E-04 6.6173E-0	1		
($2.201 \ 6.3264E-04 \ 8.2554E-0$	1~	n (an an a	
	5. 00		2.801 8.9610E-04 1.1694E+0	0		
	Jr-90)		3.101 1.0318E-03 1.3465E+0	0/	an ang sa manang man	
			3.701 1.3077E-03 1.5257E+0	0		
			4.001 1.4469E-03 1.8882E+0	0 //		
C	. 41		$4.301 \ 1.5866E - 03 \ 2.0705E + 0$ $4.601 \ 1.7265E - 03 \ 2.2531E + 0$	0		
Scen	and HI.	1.0.ml	4.901 1.8666E-03 2.4359E+0	0		an a
			5.201 2.0066E-03 2.6186E+0	0 🗸		
	na managa na sa na sa na sa na	1 et 1 at 7 -	5.801 2.2862E-03 2.9836E+0	0	na alta senan mananana al anti an mananana ang kanan kanan na ana ana ana ana ana ana	
And the second sec	· · · ·		6.101 2.4257E-03 3.1657E+0	0 1		
and of particular and start and an and a start and			6.401 2.5650E-03 3.3475E+0 6.701 2 7040E-03 3 5280E-0	0		
			7.001 2.8427E-03 3.7100E+0	0		
	alar ta de San de la desta de la managementa de la desta de la Tendera de la desta de la de		7.301 2.9811E-03 3.8906E+0	0	Chan an Manutan yan ang sa dalayan santan kana ana ana ang sang sang sang sang sang	and a first part of the second standing of the global and an and a stand standing of the second standing of the
			7.901 3.2570E-03 4.0709E+0	0		
		-	8.000 3.3023E-03 4.3099E+0	01	n ya ku wa ku na ku waka na kuku na kuku ku kuku ku kuku na kuku kuku	in and an analysis of the second s

1	2
	lane.

M	
0.401	4.4944522×10^{-6}
0.701	1.3723402×10^{-5}
1.001	2.7959653×10^{-5}
1.301	4.7190681×10 ⁻⁵
1.601	7.1403992×10^{-5}
1.901	1.0058712×10^{-4}
2.201	1.3472764×10^{-4}
2.501	1.7381316×10^{-4}
2.801	2.1783129×10^{-4}
3.101	2.667697×10^{-4}
3.401	3.2061609×10^{-4}
3.701	3.7935818×10^{-4}
4.001	4.4298372×10^{-4}
4.301	5.1148049×10^{-4}
4.601	5.8483632×10^{-4}
4.901	6.6303905×10^{-4}
5.201	7.4607655×10^{-4}
5.501	8.3393674×10^{-4}
5.801	9.2660754×10^{-4}
6.101	1.0240769×10^{-3}
6.401	1.1263329×10^{-3}
6.701	1.2333635×10 ⁻³
7.001	1.3451567×10^{-3}
7.301	1.4617007×10^{-3}
7.601	1.5829835×10^{-3}
7.901	1.7089934×10^{-3}
8.	1.751612×10^{-3}
8.001	1.7520451×10^{-3}

. . -

an ta calantan da sa				n a construction de la construcción de la const	ali ti po ante de ante de ante de	n a fa sheering sandaran a sa sa sa sa
		Kr-	. 85		aga bala ann an consta an An An An An	1991
·			\bigcirc	in and all most includes the	a fad aff fire - growing (1)	alay samagan asalah di ku samah ma
Sc	ena	io #	Z			

Time	Thyroid	TEDE	
(hr)	(rem)	(rem)	
0.000	0.0000E+00	0.0000E+00	na h-sua ar a sigar ann ann an Artain an Artain ann an Artain ann an Artain Artain an Artain An Ann Ann An Ann
0.000	0.0000E+00	6.8972E-13	
0.000	0.0000E+00	3.5437E-12	and man to the stand particular property in the standard particular standard standard standards and standard st
0.001	0.0000E+00	3.7344E-11	
0.401	0.0000E+00	4.4976E-06	
0.701	0.0000E+00	1.3729E-05	an a
1.001	0.0000E+00	2.7967E-05√	
1.301	0.0000E+00	4.7199E-05	
1.601	0.0000E+00	7.1414E-05	A second to a second or second sec
1.901	0.0000E+00	1.0060E-04	
2.201	0.0000E+00	1.3474E-04 ✓	
2.501	0.0000E+00	1.7383E-04	
2.801	0.0000E+00	2.1784E-04	
3.101	0.0000E+00	2.6678E-04 🗸	
3.401	0.0000E+00	3.2063E-04	
3.701	0.0000E+00	3.7937E-04	
4.001	0.0000E+00	4.4300E-04 ∨	 Discussion and a subsection of the second secon second second sec
4.301	0.0000E+00	5.1149E-04	
4.601	0.0000E+00	5.8485E-04	Прамочу чалов, молосили на почата учи ча с раздужива римски почата на рокати програм програма и програма и програма
4.901	0.0000E+00	6.6305E-04	
5.201	0.0000E+00	7.4609E-04	
5.501	0.0000E+00	8.3394E-04	n - Server and a state of the server and the state of the
5.801	0.0000E+00	9.2661E-04	-
6.101	0.0000E+00	1.0241E-03∨	
6.401	0.0000E+00	1.1263E-03	Provinsi ana ana falanda kaong sing na na pana na manana na kaona na manana ang kaona na manana na manana ang kaona na manana na man
6.701	0.0000E+00	1.2334E-03	
7.001	0.0000E+00	1.3452E-03	province and a statement of the
7.301	0.0000E+00	1.4617E-03	
7.601	0.0000E+00	1.5830E-03	
7.901	0.0000E+00	1.7090E-03	an a summing a part of more than a part of the part more subject to be the other of the
8.000	0.0000E+00	1.7515E-03 V	
			+

05/28/2009 Julgrace

a – a naj ku ku ku ku kaj kaj di - a den sekon ku k

•				13
D'	5/28/2009 Jula	Alle .		
			0.401	5.0921819×10^{-2}
	E E	\frown	0.701	1.5548529×10^{-1}
and the second second second	ut t		1.001	3.1678142×10^{-1}
1		(90(B))	1.301	5.3466845×10^{-1}
0.401	3.9025553×10^{-5}	510	1.601	8.0900499×10^{-1}
0.701	1.1916109×10^{-4}		1.901	1.13965
1.001	2.427755×10^{-4}	(cenerio #2	2.201	1.5264628
1.301	4.0976015×10^{-4}		2.801	2.4680307
1.601	6.2000667×10^{-4}		3.101	3.0225062
1.901	8.7340698×10^{-4}		3.401	3.6325901
2.201	1.1698532×10^{-3}		3.701	4.2981437
2.501	1.5092379×10^{-3}	алан жана да армана имиа каки каки каки каки каки каки как	4.301	5.7951056
2.801	1.8914537×10^{-3}		4.601	6.6262377
3.101	2.3163936×10^{-3}		4.901	7.512287
3.401	2.7839508×10^{-3}	$M \mid EDE \longrightarrow$	5.501	9.4485891
3.701	3.294019×10^{-3}	ana ang ang ang ang ang ang ang ang ang	5.801	1.0498568×10^{1}
4.001	3.8464917×10^{-3}		6.101	1.1602918×10^{1}
4.301	4.4412632×10^{-3}		6.401	1.2761502×10^{1}
4.601	5.0782277×10^{-3}		6.701	1.3974186×10^{1}
4.901	5.7572798×10^{-3}		7.001	1.5240833×10^{1}
5.201	6.4783143×10^{-3}	and a stand stand and a stand of some of a construction of a stand stand stand stand stands and and stands stand stands and stand stands and stands	7.301	1.656131×10^{1}
5.501	7.2412264×10^{-3}		7.601	1.7935481×10^{1}
5.801	8.0459113×10 ⁻³	а слад бала мамлана а амалияния нима ни са са са са са са са са самание с ни ни ни ни ни са са са са са са са о С	7.901	1.9363212×10^{1}
6.101	8.8922648×10 ⁻³		8.	1.9846094×10^{1}
6.401	9.7801827×10^{-3}	(a) y substantia and and the set of the s	8.001	1.9851002×10^{1}
6.701	1.0709561×10^{-2}	Time Thyroid TEDE		
7.001	1.1680297×10^{-2}	0.000 0.0000E+00 0.0000E+00		
7.301	1.2692286×10^{-2}	0.000 5.9891E-12 7.8148E-09		n an an the state and an
7.601	1.3745425×10^{-2}	$0.001 \ 3.2427E-10 \ 4.2312E-07$		
7.901	1.4839613×10^{-1}	0.401 3.9055E-05 5.0960E-02	and the second second second second	n na sana ana sa sa sana ang sa sana ang sana ang sa
8.	1.5209685×10^{-2}	$1.001 \ 2.4285E-04 \ 3.1689E-01 \checkmark$		
8.001	1.5213446×10	1.301 4.0986E-04 5.3482E-01		างการการการการการการการที่สารสุดการการการการการการการการการการการการการก
		1.601 6.2013E-04 8.0921E-01 1.901 8.7356E-04 1.1399E+00		
we we and the test of the	2. Sol. 20, a more do real of physical and and an end of the End of a particle of an end of the physical of a first second of the physical	2.201 1.1700E-03 1.5268E+00V		a na marana na kanya na manana manana kanya na na kanya na kanya na mana na mana na manana mana mana
		2.501 1.5095E-03 1.9698E+00 2.801 1.8917E-03 2.4686E+00		
application and a spin of the state of the	n an	3.101 2.3167E-03 3.0232E+00 V		
		3.401 2.7843E-03 3.6335E+00 3.701 3.2944E-03 4.2992E+00		an a
and the second s	na na mana na mangkangkan na mana na pinang di kang di kang mana na akan na mangkan na mangkang na mang ng	4.001 3.8470E-03 5.0203E+00V		
		4.301 4.4418E-03 5.7966E+00 4 601 5 0789E-03 6 6280E+00		а сооружанием станция на соор маластия — сера соона стан. По сооружение с
and the set of the set	n man ananangan kalipan pangan kanangan pangan kanangan pangan pangan pangan kanangan kalipan kananan kanangan	4.901 5.7580E-03 7.5144E+00		
	and the second state of th	5.201 6.4791E-03 8.4556E+00∨ 5.501 7.2421E-03 8.4514E+00		an a
		5.801 8.0469E-03 1.0502E+01		
$\mathrm{PREW}_{\mathrm{pr}} \mathrm{Sola} = 0 \mathrm{Pr}$	a na an an an ann an an ann an an an an	6.101 8.8934E-03 1.1607E+01		and a second and a second s
		6.701 1.0711E-02 1.3979E+01		
Refuglions and a second second second	والمعادية المتعادين المتعادين والمراجع والمراجع والمتعاد المراجع	7.001 1.1682E-02 1.5246E+01		
		7.601 1.3747E-02 1.6567E+01 7.601 1.3747E-02 1.7942E+01		
100 yr 10 yr 10 y 10 y 10 y 10 y	ی دیکھ ایک	7.901 1.4842E-02 1.9371E+01		
		8.000 1.5211E-02 1.9853E+01V		

14

	MT
0.401	1.43722×10^{-5}
0.701	4.0057159×10^{-5}
1.001	7.4827476×10^{-5}
1.301	1.1628908×10^{-4}
1.601	1.6266851×10 ⁻⁴
1.901	2.1265204×10^{-4}
2.201	2.6526654×10^{-4}
2.501	3.1979119×10^{-4}
2.801	3.7569209×10 ⁻⁴
3.101	4.3257383×10^{-4}
3.401	4.9014356×10^{-4}
3.701	5.4818444×10^{-4}
4.001	6.0653592×10^{-4}
4.301	6.6507916×10^{-4}
4.601	7.2372623×10^{-4}
4.901	7.8241205×10^{-4}
5.201	8.4108855×10^{-4}
5.501	8.9972018×10^{-4}
5.801	9.582807×10^{-4}
6.101	1.0167508×10^{-3}
6.401	1.0751162×10^{-3}
6.701	1.1333665×10^{-3}
7.001	1.191494×10^{-3}
7.301	1.2494932×10^{-3}
7.601	1.30736×10^{-3}
7.901	1.3650916×10^{-3}
8.	1.3841129×10^{-3}
8.001	1.384305×10^{-3}



	1
a a construction and a construction and a construction and a construction and and and a construction and a const	0.401
	0.701
	1.001
	1.301
	1.601
սույն է երկը չելի դերեցցել հետու ու հեղջը չու չել են հետոտես հետ չետեցնել վեպրոտը արցերտուստաներությունը, հետոն	1 901
	2.001
анданда алан калан кылдыктан алан алан калан калан калан калар талар калар калан калан калан калан калан калан Калан калан кал	2.201
	2.501
а стадована с уколого си из и из и изила с на селинието на римоте са биванието повена и не дибу 40.44.144.1.144.1	2.801
	3.101
	3,401
	3 701
ана	3.701
	4.001
	4.301
an a	4.601
	4.901
n – a data na ang mangkangkangkangkangkangkangkangkangkangk	5.201
	5.201
	5.501
	5.801
	6.101
	6.401
	6.701
	7.001
	/.001
	7 201
	7.301
Time Thyroid TEDE (hr) (rem) (rem)	7.301 7.601
Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00	7.301 7.601 7.901
Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07	7.301 7.601 7.901 8.
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4356E-05 1.075E+00	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.1619E-04 8.7141E+00	7.301 7.601 7.901 8. 8.001
WKL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01	7.301 7.601 7.901 8. 8.001
WKL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 2.501 3.1966E-04 2.3975E+01	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 \vee 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 \vee 2.501 3.1966E-04 2.3975E+01 2.801 3.7556E-04 2.8167E+01	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 \sqccolor 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 \sqccolor 2.501 3.1966E-04 2.3975E+01 2.801 3.7556E-04 2.8167E+01 3.101 4.3244E-04 3.2433E+01 \sqccolor	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 2.501 3.1966E-04 2.3975E+01 2.801 3.7556E-04 2.8167E+01 3.101 4.3244E-04 3.2433E+01 3.401 4.9001E-04 3.6751E+01	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.2895E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 2.501 3.1966E-04 2.3975E+01 2.801 3.7556E-04 2.8167E+01 3.101 4.3244E-04 3.2433E+01 3.401 4.9001E-04 3.6751E+01 3.701 5.4805E-04 4.1104E+01 4.001 6.0640E-04 4.5480E+01	7.301 7.601 7.901 8. 8.001
WAL Time Thyroid TEDE (hr) (rem) (rem) 0.000 0.0000E+00 0.0000E+00 0.000 2.5100E-12 1.8825E-07 0.000 1.2895E-11 9.6714E-07 0.001 1.2895E-11 9.6714E-07 0.001 1.3585E-10 1.0189E-05 0.401 1.4326E-05 1.0745E+00 0.701 3.9987E-05 2.9990E+00 1.001 7.4739E-05 5.6054E+00 1.301 1.1619E-04 8.7141E+00 1.601 1.6256E-04 1.2192E+01 1.901 2.1253E-04 1.5940E+01 2.201 2.6514E-04 1.9886E+01 2.501 3.1966E-04 2.3975E+01 2.801 3.7556E-04 2.8167E+01 3.101 4.3244E-04 3.2433E+01 3.401 4.9001E-04 3.6751E+01 3.701 5.4805E-04 4.1104E+01 4.001 6.0640E-04 4.9871E+01	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.000 $0.0000E+00$ $0.0000E+00$ 0.000 $2.5100E-12$ $1.8825E-07$ 0.000 $1.2895E-11$ $9.6714E-07$ 0.001 $1.3585E-10$ $1.0189E-05$ 0.401 $1.4326E-05$ $1.0745E+00$ 0.701 $3.9987E-05$ $2.9990E+00$ 1.001 $7.4739E-05$ $5.6054E+00 \lor$ 1.301 $1.1619E-04$ $8.7141E+00$ 1.601 $1.6256E-04$ $1.2192E+01$ 1.901 $2.1253E-04$ $1.5940E+01$ 2.201 $2.6514E-04$ $1.9886E+01\checkmark$ 2.501 $3.1966E-04$ $2.3975E+01$ 2.801 $3.7556E-04$ $2.8167E+01$ 3.101 $4.3244E-04$ $3.2433E+01\checkmark$ 3.401 $4.9001E-04$ $3.6751E+01$ 3.701 $5.4805E-04$ $4.1104E+01$ 4.001 $6.0640E-04$ $4.9871E+01$ 4.301 $6.6494E-04$ $4.9871E+01$	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.000 $0.0000E+00$ $0.0000E+00$ 0.000 $2.5100E-12$ $1.8825E-07$ 0.000 $1.2895E-11$ $9.6714E-07$ 0.001 $1.2895E-11$ $9.6714E-07$ 0.001 $1.3585E-10$ $1.0189E-05$ 0.401 $1.4326E-05$ $1.0745E+00$ 0.701 $3.9987E-05$ $2.9990E+00$ 1.001 $7.4739E-05$ $5.6054E+00 \lor$ 1.301 $1.1619E-04$ $8.7141E+00$ 1.601 $1.6256E-04$ $1.2192E+01$ 1.901 $2.1253E-04$ $1.5940E+01$ 2.201 $2.6514E-04$ $1.9886E+01\checkmark$ 2.501 $3.1966E-04$ $2.3975E+01$ 2.801 $3.7556E-04$ $2.8167E+01$ 3.101 $4.3244E-04$ $3.2433E+01\checkmark$ 3.401 $4.9001E-04$ $3.6751E+01$ 3.701 $5.4805E-04$ $4.1104E+01$ 4.001 $6.6494E-04$ $4.9871E+01$ 4.301 $6.6494E-04$ $4.9871E+01$ 4.601 $7.2359E-04$ $5.4269E+01$ 4.901 $7.8227E-04$ $5.8670E+01$	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.000 $0.0000E+00$ $0.0000E+00$ 0.000 $2.5100E-12$ $1.8825E-07$ 0.000 $1.2895E-11$ $9.6714E-07$ 0.001 $1.3585E-10$ $1.0189E-05$ 0.401 $1.4326E-05$ $1.0745E+00$ 0.701 $3.9987E-05$ $2.9990E+00$ 1.001 $7.4739E-05$ $5.6054E+00 \checkmark$ 1.301 $1.1619E-04$ $8.7141E+00$ 1.601 $1.6256E-04$ $1.2192E+01$ 1.901 $2.1253E-04$ $1.5940E+01$ 2.201 $2.6514E-04$ $1.9886E+01\checkmark$ 2.501 $3.1966E-04$ $2.3975E+01$ 2.801 $3.7556E-04$ $2.8167E+01$ 3.101 $4.3244E-04$ $3.2433E+01\checkmark$ 3.401 $4.9001E-04$ $3.6751E+01$ 3.701 $5.4805E-04$ $4.1104E+01$ 4.001 $6.6494E-04$ $4.9871E+01$ 4.301 $6.6494E-04$ $4.9871E+01$ 4.901 $7.8227E-04$ $5.8670E+01$ 5.201 $8.4095E-04$ $6.3071E+01\checkmark$	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0011.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+00 \checkmark 1.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+01 \checkmark 2.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+01 \checkmark 3.4014.9001E-043.6751E+013.7015.4805E-044.1104E+01 \checkmark 4.3016.6494E-044.9871E+014.6017.2359E-045.4269E+014.9017.8227E-045.8670E+015.2018.4095E-046.3071E+01 \checkmark 5.8019.5814E-047.1861E+01	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0011.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-055.6054E+00 \checkmark 1.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+01 \checkmark 2.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+01 \checkmark 3.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.6494E-044.9871E+014.3016.6494E-045.4269E+014.9017.8227E-045.8670E+015.2018.4095E-046.3071E+01 \checkmark 5.5018.9958E-046.7469E+015.8019.5814E-047.1861E+016.1011.0166E-037.6246E+01 \checkmark	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0001.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+001.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+012.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+013.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.0640E-044.9871E+014.3016.6494E-044.9871E+014.9017.8227E-045.8670E+015.2018.4095E-046.3071E+015.5018.9958E-046.7469E+015.8019.5814E-047.1861E+016.1011.0166E-037.6246E+016.4011.0750E-038.0623E+01	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0011.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+001.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+012.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+013.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.6494E-044.9871E+014.6017.2359E-045.4269E+014.9017.8227E-045.8670E+015.2018.4095E-046.3071E+015.8019.5814E-047.1861E+016.1011.0166E-037.6246E+016.4011.0750E-038.0623E+016.7011.1332E-038.4992E+017.2011.147E-022.025E-04	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0011.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+001.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+012.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+013.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.6494E-044.9871E+014.3016.6494E-044.9871E+014.3015.4805E-046.3071E+015.5018.9958E-046.7469E+015.8019.5814E-047.1861E+016.1011.0166E-037.6246E+016.4011.0750E-038.0623E+016.7011.1332E-038.4992E+017.0011.1914E-038.9352E+017.011.2494E-039.3701E+01	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0001.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+00 \checkmark 1.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+01 \checkmark 2.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+01 \checkmark 3.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.6494E-044.9871E+014.3016.6494E-044.9871E+014.3017.8227E-045.8670E+015.5018.9958E-046.3071E+01 \checkmark 5.5018.9958E-046.7469E+015.8019.5814E-047.1861E+016.4011.0750E-038.0623E+016.4011.0750E-038.0523E+017.0011.1914E-038.9352E+017.3011.2494E-039.3701E+017.6011.3072E-039.8041E+01	7.301 7.601 7.901 8. 8.001
WALTimeThyroidTEDE (hr) (rem) (rem) 0.0000.0000E+000.0000E+000.0002.5100E-121.8825E-070.0001.2895E-119.6714E-070.0011.3585E-101.0189E-050.4011.4326E-051.0745E+000.7013.9987E-052.9990E+001.0017.4739E-055.6054E+00 \checkmark 1.3011.1619E-048.7141E+001.6011.6256E-041.2192E+011.9012.1253E-041.5940E+012.2012.6514E-041.9886E+01 \checkmark 2.5013.1966E-042.3975E+012.8013.7556E-042.8167E+013.1014.3244E-043.2433E+01 \checkmark 3.4014.9001E-043.6751E+013.7015.4805E-044.1104E+014.0016.6494E-044.9871E+014.3016.6494E-044.9871E+014.3016.6494E-044.9871E+015.5018.9958E-046.3071E+01 \checkmark 5.5018.9958E-046.3071E+01 \checkmark 5.5018.9958E-047.469E+015.5018.9958E-047.6246E+01 \checkmark 5.5011.0166E-037.6246E+01 \checkmark 6.4011.0750E-038.0623E+016.7011.1322E-038.4992E+017.3011.2494E-039.3701E+017.3011.2494E-039.3701E+017.9011.3650E-031.0237E+02	7.301 7.601 7.901 8. 8.001

05/28/2004 lulapan MTEDE

.401	1.077915	
.701	3.0042869	
.001	5.6120607	
.301	8.7216813	
.601	1.2200139×10^{1}	and the second sec
.901	1.5948903×10^{1}	
.201	1.989499×10^{1}	
.501	2.3984339×10^{1}	
.801	2.8176907×10^{1}	State of the st
.101	3.2443037×10^{1}	
.401	3.6760767×10^{1}	Republic and a second sec
.701	4.1113833×10^{1}	
.001	4.5490194×10^{1}	percentation in a constant of the second second
.301	4.9880937×10^{1}	
.601	5.4279467×10^{1}	 A state of the sta
.901	5.8680904×10^{1}	
.201	6.3081641×10^{1}	
.501	6.7479013×10^{1}	ge falsens och som star and det första falsen
.801	7.1871053×10^{1}	
.101	7.6256309×10^{1}	$\varphi(h_{1},\mu_{2})=(\mu_{1},\mu_{2})=(\mu_{1},\mu_{2})\mu_{1}h_{1}h_{2}h_{2}h_{3}h_{4}h_{4}h_{4}h_{4}h_{4}h_{4}h_{4}h_{4$
401	8.0633715×10^{1}	
.701	8.5002487×10^{1}	Beckmann and a second
.001	8.9362051×10^{1}	
.301	9.371199×10^{1}	parameter of the construction and down of the P
601	9.8052001×10^{1}	
901	1.0238187×10^{2}	(and the first of the second
	1.0380847×10^{2}	
001	1.0382287×10^{2}	Electric dependent (a comparison of the second s
	n an	anderson a second a second second second second second

				05	12012	a A 1
				04	iej co	
0.401	2.8982821×10^{-4}			un management a strainigt art and and	and and an an all and a strategy and the second	myrene
0.701	8.0612017×10 ^{-*}	PEOPLE AND ADDRESS OF THE PEOPLE				
1.001	1.502808×10 ⁻³				0.401	6.571902 × 10 ⁻⁸
1.301	2.3308967×10^{-3}		(4)		0.701	1.8278907×10^{-7}
1.601	3.254218×10^{-3}	a to provide you provide the provide the second and provide the second and the second and the second and the se	E-28-01/	an an amin'ny service an amin'ny service a	1.001	3.4076417×10^{-7}
1.901	4.2460746×10^{-3}	لألا	(03		1.301	5.2853464×10^{-7}
2.201	5.2867632×10^{-3}	М			1.601	7.3789925×10^{-7}
2.501	6.3617444×10^{-3}	11AA	- M/	->	1.901	9.6280437 $\times 10^{-7}$
2.801	7.4602924×10^{-3}	104			2.201	1 1087822 10-6
3.101	8.574497×10^{-3}				2.501	1.1907022 × 10
3.401	9.6985272×10 ⁻³				2 801	1 6016325 u 10 ⁻⁶
3.701	1.0828087×10^{-2}			Al :	3 101	1.0910335×10
4.001	1.1960015×10^{-2}	ger yn eine wrae farm hanne fy fan yn fyfgyn ffran y	/05-20-		3 401	1.9442812×10 ····
4.301	1.3091984×10^{-2}		en (the		3 701	2.1991569×10 °
4.601	1.4222289×10^{-2}	Banan da ana amin'ny kaodim-paositra dia dia	11111		3.701	2.4552865×10 •
4.901	1.5349679×10 ⁻²	T	-MTEDE HAAA	to a	4.001	2.7119529×10*
5.201	1.6473238×10 ⁻²		and a second		4.301	2.9686289×10^{-6}
5.501	1.7592302×10^{-2}				4.601	3.2249274×10 ⁻⁶
5.801	1.870639×10 ⁻²	ga ana na ang ang ang ang ang ang ang an			4.901	3.4805648×10 ⁻⁶
6.101	1.9815154×10^{-2}				5.201	3.7353337×10 ⁻⁰
6.401	2.0918348×10 ⁻²				5.501	3.9890833×10-
6.701	2.2015801×10^{-2}			-	5.801	4.2417044×10 ⁻⁶
7.001	2.3107394×10 ⁻²	A STORE ST			6.101	4.4931185×10^{-6}
7.301	2.419305×10^{-2}	And the second			6.401	4.7432697×10 ⁻
7.601	2.5272719×10^{-2}				6.701	4.992119×10 ⁻⁰
7.901	2.6346376×10^{-2}	-		-	7.001	5.2396395×10 ⁻ °
8.	2.6699362×10^{-2}		WR1		7.301	5.4858137×10 ⁻
8.001	2.6702924×10^{-2}	_	(hr) (rem) (rem)		7.601	5.7306305×10 ⁻
			0.000 0.0000E+00 0.0000E+00		7.901	5.974084×10 ⁻⁰
		_	0.000 1.1510E - 14 5.0760E - 11 0.000 5.9133E - 14 2.6078E - 10	547-67 6 74	8.	6.0541239×10 ⁻⁶
			0.001 6.2295E-13 2.7473E-09		8.001	6.0549317×10^{-6}
			0.401 6.5547E-08 2.8907E-04 0.701 1.8257E-07 8 0515E-04	ay na ya Bakina na yawa katina	999 Y 299 Y 29	
\sim			1.001 3.4055E-07 1.5019E-03V			
- Art		anna d	1.301 5.2836E-07 2.3301E-03	usus nitre or under parties of	namen an ferdamentaliska en den men en den en den ser en	aller en prochader och av skaleting frähet och anfändet är och annandet en prochader en prochader and
(Ψ-	- J0 /		1.901 9.6277E-07 4.2459E-03			
\mathcal{L}		whereast	2.201 1.1988E-06 5.2870E-03√	and the free of the second		
\sim			2.501 1.442/E-06 6.3625E-03 2.801 1.6919E-06 7.4615E-03			
- MA	man off 1		3.101 1.9447E-06 8.5762E-03			
			3.401 2.1997E-06 9.7008E-03 3.701 2.4559E-06 1 0831E-02	1940 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 - 1976 -		
			4.001 2.7127E-06 1.1963E-02V			
			4.301 2.9695E-06 1.3096E-02			alan (a a sa mana maja kana maja ang mga kang kang kang kang kang kang kang ka
and the second secon	na fer af fere de level - a resolution à allant de resolution en la fagilitation de la fagilitation de la fagil		4.901 3.4817E-06 1.5354E-02			
		un dara (J.M.	5.201 3.7365E-06 1.6479E-02V	المربعة والمحمد المراجع ومحاورة	n a fa su air ann an ann an ann ann an ann an ann an	
		tra traditant m	5.801 4.2431E-06 1.7598E-02 5.801 4.2431E-06 1.8713E-02			
	un muh su baran baran 87 min tamin yang diti un nogani suke dalam muha tamihin suke bara baran baran yang suke		6.101 4.4947E-06 1.9822E-02V	and the second state of the		ny an' an' a na amin' amang ang ang ang ang ang ang ang ang ang
			6.401 4.7449E-06 2.0926E-02			
algamente insperier num bei an hell tel trad	i ku na manana milana ku mana na manana manana manana manana mata ka manana na manana na manana manana mana man		7.001 5.2415E-06 2.3116E-02	the second second second second		
			7.301 5.4878E-06 2.4202E-02			
	un en ante en la companya de la comp		7.901 5.9762E-06 2.6356E-02		andres and an	na presidencia con un constructiva un una constructiva con esta esta de la construcción de la constructiva de s
			8.000 6.0562E-06 2.6709E-02V	/		
				2000 Coll 2010 Statement Statement and	ويدفعهم ويعمره من هن من من معلم والمواد وي معم	

16	
----	--

: .

n ato tank	, 3 10 10 1 10 10 10 10 10 10 10 10 10 10 1	MT	
1	0.401	7 4788114 10-8	
11 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1	0.701	$2,2796615 \times 10^{-7}$	n and a support of the second s
	1.001	A 6324695 × 10 ⁻⁷	
fageter i	1.301	-7 8018041 $\times 10^{-7}$	and a second sec
	1 601	1.177050210-6	
10-14-18	1 901	1.1//9582×10 °	$(1 + 1)^{-1} + (1 + 1)^{-1} = (1 + 1)^{-1} + (1 +$
	2 201	1.0558225×10 °	
	2.201	2.2130569×10 °	1
	2.501	2.8489407×10^{-6}	
	2.801	3.5627586×10^{-6}	
	3.101	4.3537998×10 ⁻⁶	
	3.401	5.2213588×10 ⁻⁶	an ng pang pang pang pang pang pang pang
	3.701	6.1647347×10^{-6}	
	4.001	7.1832317×10^{-6}	11-
	4.301	8.2761587×10^{-6}	M
	4.601	9.4428294×10^{-6}	
	4.901	1.0682562×10^{-5}	a seria antifate il la fictura antifato a serie de anti-ana antifato que
	5.201	1.1994681×10^{-5}	
	5.501	1.3378513×10^{-5}	ang tana ani kanang mijerang mari na kana kana dipina ang kana ang kana ang kana kana kana
,,,,,,	5.801	1.4833391×10 ⁻⁵	
	6.101	1.6358652×10^{-5}	
	6.401	1.7953639×10 ⁻⁵	
	6.701	1.9617698×10^{-5}	age of the photology operation of the first state of the second state of the
	7.001	2.135018×10^{-5}	
-	7.301	2.315044×10^{-5}	
	7.601	2.5017839×10^{-5}	Time Th
~	7.901	2.6951741×10^{-5}	0.000 0.0
	8.	2.7604415×10^{-5}	0.000 1.1
-	8.001	2.7611045×10 ⁻⁵	0.001 6.2

7.901	2.6951741×10^{-5}
8.	2.7604415×10^{-5}
8.001	2.7611045×10^{-5}

....



(1) (1) (1) (1) (1) (1) (1) (1) (1) (1)	a ta pontan a nontr'ante	05/28	8/2009 Julgia	en e
(c) a provinse international contraction of a physical shadded of the basis region over an endowing and provide the second second second second second second second second second second second second second second second second second second second se	, contractory an obtaining it in	nen selas mante e mante esta de la composition de la composition de la composition de la composition de la comp		
		0.401	3.2982392×10^{-4}	j. posocione for a sec
ann an ann an ann an ann ann ann ann an	2 (40) 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	0.701	1.0049151×10^{-3}	
	والمعالية و	1.001	2.0429703×10^{-3}	- -
		1.301	3.4407223×10^{-3}	
- No - Standard and a standard and a standard standard standard standard and standard a standard standar	المعمولات المريوس	1.601	5.1949268×10^{-3}	$\int_{0}^{1} \frac{1}{ x ^{-1}} = - \frac{1}{ x ^{-1}} = - \frac{1}{ x ^{-1}} + \frac{1}{ x$
		1.901	7.3023618×10^{-3}	
	and the set of the	2.201	9.7598275×10^{-3}	processing and an exception
		2.501	1.2564146×10^{-2}	
ana ang ang ang ang ang ang ang ang ang	es es descendentes.	2.801	1.5712163×10^{-2}	i I sense og van Deutster Statesting
		3.101	1.9200743×10^{-2}	
	and a second state of the	3.401	2.3026774×10^{-2}	gen makanan kenelak
•		3.701	2.7187167×10^{-2}	
	a sa nana faring	4.001	3.1678853×10^{-2}	demonstration of the second second
MTEDE>	>	4.301	3.6498783×10^{-2}	
	n mangan dan sama mag	4.601	4.1643931×10^{-2}	pression of the
		4.901	4.7111291×10^{-2}	and the special contraction
		5.201	5.289788×10^{-2}	
	(4) can b ^{ar} before an	5.501	5.9000734×10^{-2}	
		5.801	6.5416908×10^{-2}	
	- Name - Al Statut	6.101	7.2143481×10^{-2}	an marketer and the second
		6.401	7.9177551×10^{-2}	
	una manifest	6.701	8.6516236×10^{-2}	Paper para ana amin'ny fisiana amin'ny fisiana
		7.001	9.4156673×10^{-2}	
WIXT	unu unu anticipation a	7.301	1.0209602×10^{-1}	hannen mariar an an de mediatration
time Thyroid TEDE		7.601	1.1033146×10^{-1}	
0.000 0.0000E+00 0.0000E+00	Course Vision 1979	7.901	1.1886018×10^{-1}	ja mangang kanang mengelakan terter bertakan terter bertakan terter bertakan terter bertakan terter bertakan te
0.000 1.1511E - 14 5.0763E - 11	1	в.	1.2173855×10^{-1}	
0.001 6.2323E-13 2.7485E-09	1	8.001	1.2176779×10^{-1}	
0.401 7.4887E-08 3.3026E-04			an a	والمحافظ والمعارين فروم والمعار
1.001 4.6364E-07 2.0447E-03V	and a she had an an an an an an a			
1.301 7.8079E-07 3.4434E-03	Parameter (1) and a state of the		nne d'a 11. status ar san maja magangka (da 11. status) analisi da makana katika katika katika katika katika ka	anna anna an tao ann airte ann an tao ann an
$1.601 \ 1.1788E-06 \ 5.1987E-03$ 1 901 1 6570E-06 7.3074E-03				
2.201 2.2145E-06 9.7662E-03V		an ang ang ang ang ang ang ang ang ang a	ta awar ning mining ang jalan tanak ang jalakan ning pang pang pang pang pang pang pang pa	والمحافظة فالاستبعاض والمراجع مراجعهم
$2.501 \ 2.8508E-06 \ 1.2572E-02$				
3.101 4.3564E-06 1.9212E-02∨		an a		
3.401 5.2245E-06 2.3040E-02				
4.001 7.1874E-06 3.1697E-02 V		ang niki si kan sa kana sa	an ann an ann an ann an an ann an	a na managana na mangana na mangana na kata kata kata kata kata kata kat
4.301 8.2808E-06 3.6519E-02				
4.601 9.4481E-06 4.166/E-02 4 901 1 0688E-05 4.7137E-02	a character and the set	na anticipation de la contra de	ng pro na ana ang ang ang ang ang ang ang ang	gannaan ann gar dhinnei
5.201 1.2001E-05 5.2927E-02V				
5.501 1.3386E-05 5.9032E-02	n Billion (an Indonesia Containe Containe I an Anna Anna Anna Anna Anna Anna A	na an a		an an an Anna an Anna an An Ang Stario
6.101 1.6367E-05 7.2181E-02∨				
6.401 1.7963E-05 7.9219E-02			 A set of the set of	pantantan karang pantantan
7.001 2.1361E-05 9.4204E-02 V	•			agenta fi entera por 1, etjeritare 1999 etj eren 1
7.301 2.3162E-05 1.0215E-01		noon an	y y y an	
7.601 2.5030E-05 1.1039E-01 7 901 2.6965E-05 1.1892E-01		Reconcernent of the second second second	an a ta matang pang pang pang ang ang ang ang ang ang ang ang ang	an a
8.000 2.7617E-05 1.2179E-01				

1_ 1

05/28/2009 Julanan

ose_Scen_1_EqualQtoV.nb

Dose_Scen_1_EqualQtoV.nb

MT

÷

		_				
		Kontere betretten bezonderze fahrent		0.401	1.2253572	SHERRING
An internet of the second s				0.701	3.7384057	
0.401	1.6338096×10 ⁻⁵	-		1 301	1.28228010^{1}	
0.701	4.9845409×10^{-5}			1.501	1.283389×10	
1.001	1.0146911×10 ⁻⁴			1.001	1.9402749×10^{-1}	
1.301	1.7111853×10^{-4}		MIEDE	>	2.7310011×10^{-1}	
1.601	2.5870332×10^{-4}			2.201	3.6548952×10^{-1}	
1.901	3.6413349×10^{-4}			2.501	4.7112871×10^{-1}	
2.201	4.8731936×10^{-4}	14446.000 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1800 - 1	₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩₩	2.801	5.8995094×10^{-1}	
2.501	6.2817161×10^{-4}			3.101	7.2188972×10^{-1}	
2.801	7.8660125×10^{-4}			3.401	8.6687881×10^{4}	
3.101	9.6251963×10^{-4}			3.701	1.0248522×10^{2}	
3.401	1.1558384×10^{-3}			4.001	1.1957442×10^{2}	
3.701	1.3664696×10^{-3}			4.301	1.3794892×10^{2}	
4.001	1.5943256×10^{-3}			4.601	1.5760221×10^{2}	
4.301	1.8393189×10^{-3}	Product Market State (1) and 1 and 1		4.901	1.7852777×10^{2}	
4.601	2.1013627×10^{-3}			5.201	2.0071914×10^{-1}	
4.901	2.3803703×10^{-3}			5.501	2.2416987 × 10 ⁻	
5.201	2.6762552×10^{-3}			5.801	2.4887352×10^{-1}	
5.501	2.9889315×10^{-3}			6.101	2.7482369×10^{-1}	******
5.801	3.3183135×10^{-3}			6.401	3.02014×10 ⁻	
6.101	3.6643158×10^{-3}		WR1 Time Thyroid TEDE	6.701	3.3043811×10 ²	nangnarangni
6.401	4.0268534×10^{-3}		(hr) (rem) (rem)	7.001	3.6008967×10^{2}	
6.701	4.4058414×10^{-3}		0.000 0.0000E+00 0.0000E+00 0.000 2.5101E-12 1.8826E-07	7.301	3.9096238×10 ²	
7.001	4.8011956×10^{-3}		0.000 1.2897E-11 9.6727E-07	7.601	4.2304997×10 ²	
7.301	5.2128318×10^{-3}	a la contra	0.001 1.3591E-10 1.0193E-05	7.901	4.5634615×10^{-1}	
7.601	5.6406662×10^{-3}		0.701 4.9865E-05 3.7399E+00	8.	4.6759806×10 ⁻	
7.901	6.0846154×10^{-3}		1.001 1.0150E-04 7.6123E+00	8.001	4.6771239×10 ⁻	
8.	6.2346408×10^{-3}		1.301 $1.7116E-04$ $1.2837E+011.601$ $2.5875E-04$ $1.9406E+01$	4		
8.001	6.2361651×10^{-3}		1.901 3.6419E-04 2.7314E+01			
and a second			2.201 4.8738E-04 3.6554E+01 2.501 6.2824E-04 4.7118E+01	: period networks benefities not signal relation for the strength of the strength of the strength of the strength	۲۰۰۰ ۲۰۰۰ ۲۰۰۰ ۲۰۰۰ ۲۰۰۰ ۲۰۰۰ ۲۰۰۰ ۲۰	
	\frown		2.801 7.8668E-04 5.9001E+01			
	·····		3.101 9.6261E-04 7.2195E+01 3 401 1 1559E-03 8 6695E+01			
(A	-241)		3.701 1.3666E-03 1.0249E+02			
LAN			4.001 1.5944E-03 1.1958E+02		ĸĸŦ੶ĸĸŎĸĸŦĸĸĸĸĸŧġĊĸĬŧĸġĊĸġŎĸŎŎĸŎŎŎĸŎŎŎġŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎŎ	
		and for the second	4.601 2.1015E-03 1.5761E+02			
	999 (1994) IS NOT THE REPORT OF THE OTHER PROPERTY OF THE		4.901 2.3805E-03 1.7854E+02			
~	0		5.501 2.9891E-03 2.2418E+02	ana dalah menggali sebagi yakan dan sebuah sebua		
Rol	MIL		5.801 3.3185E-03 2.4889E+02			
· · · · ·	1 (8)	-	6.401 4.0270E-03 3.0203E+02	In studiets which as hypothetical strength to be a series of the balance of the	n próch na meli na lanna stran a star a star a star star a star star a star star	
No	29.01		6.701 4.4060E-03 3.3045E+02			
	A f		7.301 5.2130E-03 3.9098E+02			
· · ·	chern.5		7.601 5.6409E-03 4.2307E+02			
+ 20	- Con Y		7.901 6.0848E-03 4.5636E+02 8.000 6.2347E-03 4.6761E+02			
	the /					

1

-

rs t

SVTR#: 14-2 Project #: 20.060002.01.103						
Software Name: PCSA Tool		Version: 3.0 (Beta P)				
Test ID: 6.14	Test Series Name: Wo	rker Downwind Dose				
Test <u>code inspection</u> <u>output inspection</u> <u>hand calculation</u> <u>spreadsheet</u> <u>graphical</u> <u>comparison with external code</u> 	Method					
Test Envir	onment Setup					
Hardware (platform, peripherals): Machine pi	tor, Windows XP					
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	odes or scripts): PCSA To	ool Version 3.0.0 BetaP				
Input Data (files, database, mode settings): I available on startup	Default PCSA Tool datab	ase, pcsademo				
<u>Assumptions, constraints, and/or scope of test:</u> Assumptions or constraints: none Scope of the test: Verify the worker dose calculations against independent spreadsheet calculations.						
<u>Test Procedure:</u> The test procedure is identified on Attachme	nt 1					
Test Results						
Test Results from spreadsheet 14-2.xls are shown on Attachment 2. PCSA Tool generated values agreed to within 5% with spreadsheet values and therefore this test passed.						
Test Evaluation (Pass/Fail): Pass						
Notes: None.						
Tester: George Adams	Date: August 9, 2004					

Attachment 1

Test Procedure:

4

1) Open the worker downwind dose form.

2) Enter values for the Stack Height, Building Height, Building Width (depending on option), Receptor Distance, Stack Diameter (depending on option), and Flow Rate (depending on option) corresponding to the displacement zone, wake zone, and cavity zone.

3) Compare values displayed by the PCSA Tool to spreadsheet calculated values.

Attachment 2

As shown in the following table, all values generated by the PCSA Tool agreed to within 5% with spreadsheet calculations. Within the PCSA Tool, the cavity, wake, and displacement zones were selected for various receptor distances and results were compared to spreadsheet calculations.

Receptor	Zone	Calculated	PCSA Tool Results	Percentage
Distance		Results		Difference
1	Receptor on building	3.9432E-02	3.9400E-02	-0.0813%
2	Receptor on building	3.9432E-02	3.9400E-02	-0.0813%
20	Receptor on building	1.1166E-02	1.1200E-02	0.3052%
100	Cavity zone off building	1.39E-03	1.3900E-03	-0.2735%
10	Cavity zone off building	1.39E-03	1.3900E-03	-0.2735%
5000	Wake Zone	5.71E-06	5.71E-06	0.0101%
10000	Wake Zone	2.61E-06	2.61E-06	0.0694%
100	Displacement Zone	0.00E+00	0.0000E+00	0.0000%
2000	Displacement Zone	1.87E-09	1.87E-09	0.0000%
20000	Displacement Zone	5.31E-07	5.31E-07	0.0000%

Approach for Implementing Downwind Worker Dose Model

Please consider this approach as DRAFT for discussion.

There are at least three configurations involving the worker, obstacle, and source that may be of interest in preclosure repository safety:

- 1. The source and obstacle are located at the same location; the worker may be collocated or located downwind.
- 2. The source is upstream from the obstacle; the worker is collocated or downwind of the obstacle.
- 3. The source is upstream from the obstacle; the worker and obstacle(s) are collocated.

See Figure 1 for a diagram of these configurations. Case 1 most closely resembles the configurations discussed in IAEA Safety Series 19, where the source and obstacle are collocated.



Figure 1. Three configurations for worker dose.

This may be an important configuration in repository safety analysis. Case 2 considers the situation, that may present for some workers at the repository, where there is one or more buildings intervening between the worker and the source. In this configuration, the downwind building is likely to cause increased mixing of the contaminant plume. For this reason, the doses calculated from this configuration are likely to be bounded by other configurations.¹ Case 3 is directed at considering the storage area, where there may be a large number of obstacles with workers in the space between the obstacles. Because the contaminant plume will flow through this array of objects, mixing with uncontaminated air may be greatly reduced by a channeling effect. This configuration may require a different approach. This initial implementation of downwind worker dose will consider Case 1 only.

To adapt the IAEA approach, we must recognize the following. The IAEA approach was developed to consider chronic (long-term) releases from a facility prior to licensing and operation. The focus of the IAEA analysis is routine releases from a facility and whether such releases induce acceptable concentrations for receptors downwind of the releases. To the contrary, we are concerned with acute, accidental releases. As we proceed, some parts of the IAEA approach may need to be modified to account for this difference. Another assumption based on the intent of the IAEA approach is that the source is on the building which creates the wake; however, the source may be elevated to a height that is substantially greater than the building height. This would be an expected configuration for a facility routinely allowing releasing from a stack.

The IAEA document defines three zones determined by the flow of air over and around the building: (1) displacement zone, (2) wake zone, and (3) cavity zone as shown in Figure 2 (Figure 4 in the IAEA document). The displacement zone is a region some distance downwind from the building, where the concentration is relatively unaffected by the building and its wake. Since the source is considered to be at some elevation, the contaminant plume must travel some distance before it reaches ground level. The displacement zone begins approximately at the point where the contaminant plume first touches down to ground level. This assumes a ground-level receptor,

¹There may be slightly higher concentrations immediately downwind of the building in its cavity zone, because contaminants will be recirculated in a finite volume. However, the obstacle building is likely to be 65 to 100 m downwind of the source building. For a nominal building height of 34m and width between 135m and 150m the cavity zone is likely to extend no more than $2.5xA^{1/2}$, which is approximately equal to 2.5x70.7m = 175m. Thus a receptor in the cavity zone is likely to be 2 to 3 times the distance of the obstacle building from the source building. If a worker is within the cavity zone, his dose will be significantly higher than the dose to a worker at the same distance, but not in the cavity zone. This is because the worker in the cavity zone will experience a concentration close to that ahead of the obstacle (say the 75 m concentration), while the worker in the plume with no obstruction will experience the concentration at up to 175m. At these small distances, such changes will cause significant changes in concentration. However, the dose to a worker between the source and obstacle building will be higher than either of these.



Figure 2. Air flow around a building, showing the three main zones of flow: displacement zone, wake zone and cavity zone.

which is consistent with this worker dose scenario. The cavity zone is immediately leeward of the building. Because contaminants may become trapped in the cavity zone (an attached vortex), the concentration in the cavity zone is strongly affected by the presence of the building. Concentration in the wake zone, which is essentially between the displacement zone and cavity zone, are reduced over what might be expected if no building were present. This is because the building provides additional turbulent mixing which reduces the concentration.

A receptor may be located at ground level and at any distance, x, downwind from the building. This distance, x, will determine in which of these three zones the receptor is located; depending on the zone, a different model is used for estimating concentration. The IAEA approach for determining zones is illustrated in Figure 3 (Figure 5 in the IAEA document). To implement this approach in the PCSA Tool a number of sequential windows will need to be used. At various points in this discussion these windows will be indicated.

WINDOW 1.

The user must specify the building height in meters, H_B , and the source height in meters, H_s . These numbers must be zero or greater.

If $H_s > 2.5 \cdot H_B$ then go to Window 2; if $H_s \le 2.5 \cdot H_B$ then go to Window 3.

WINDOW 2.

The plume does not touch down until after the wake zone. Use the RSAC model with a receptor

elevation equal to zero. The user must specify the distance between the building and the receptor, x, in meters; then proceed with the RSAC calculation. Values for $x \le 2.5 \cdot H_B$ will



Figure 3. Relationship between release height and receptor distance for determination of the type of dispersion model to be used.

probably not yield meaningful results (the receptor is located closer to the building before the location where the plume touches down; after all, this is why releases are elevated). Consider providing a warning if a close distance is chosen or do not allow a calculation for small distances $(x \le 2.5 \cdot H_B)$.

Window 3.

Input the building width or length, W_B , in meters. This could also be whatever length the user desires to characterize the dimension of the building in the direction perpendicular to the direction of the wind. A bigger W_B will produce a bigger cross-wind area, which will increase the size of the cavity zone; i.e., bigger buildings have bigger trapped vortex zones. Calculate:

 $\begin{array}{l} A_B = W_B \cdot H_B \quad (m^2)\\ \text{Input the receptor distance, } x, \text{ in meters. Calculate the quantity:}\\ Q_B = 2.5 \cdot [A_B]^{\frac{1}{2}}\\ \text{If } x \leq Q_B, \text{ then go to Window 4.}\\ \text{If } x > Q_B, \text{ then go to Window 5.} \end{array}$

Window 4.

Is the receptor on the same surface of the building as the release? For example, is the receptor on

the roof with a roof vent releasing radionuclides; or is the receptor at a window on the side of a building that has a vent releasing radionuclides?

If yes, then go to Window 6.

If no, then go to Window 7.

Window 6.

Input the diameter of the vent or stack, D_s , in meters. If $x \le 3 \cdot D_s$, then go to Window 8 If $x > 3 \cdot D_s$, then go to Window 9.

Window 8.

Input the flow rate, V, in m³/s, through the vent emitting radionuclides.

Run RSAC using the standard release (whatever that has been determined to be) at a distance of 100m, **but assume a ground level release** ($H_B=0$). Extract the numerical value of chi/Q, in s/m³, from the RSAC run, as well as the dose from each pathway and organ. Calculate the scaling factor:

 $F_v = 1/{V \cdot [chi/Q]}$

Multiply the dose from each pathway and organ by the scaling factor; the results are the pathway and organ doses for this case (V - vent). Sum the pathway doses to obtain the total dose for this case.

This essentially assumes the receptor has his head in the stack and is breathing undiluted contaminated air as it is released from the vent; he may also get a dose from immersion.

Window 9.

Remember that for this screen the distance from the receptor to source should be:

 $3 \cdot D_s < x \le Q_B$

and the receptor should be on the same side of the building as the release vent.

Run RSAC using the standard release (whatever that has been determined to be) at a distance of 100m, **but assume a ground level release (H_B=0)**. Extract the numerical value of: (1) chi/Q, in s/m³, from the RSAC run, (2) the mean wind speed, U_A, in m/s, as well as (3) the dose from each pathway and organ. Calculate the scaling factor:

 $F_{s} = 30/\{U_{A} \cdot x^{2} \cdot [chi/Q]\}$

Multiply the dose from each pathway and organ by the scaling factor; the results are the pathway and organ doses for this case (S - side). Sum the pathway doses to obtain the total dose for this case.

This essentially assumes the releases from the vent may be recirculated close to the side of the building ; because of zones of stagnation and building wakes, high concentrations, hence doses, may be experienced.

Consider adding a test to assure that the correction factor can be no higher than F_v computed in Window 8.

Window 7.

This receptor is in the cavity zone, but is not on the same side of the building as the vent. Run RSAC using the standard release (whatever that has been determined to be) at a distance of

100m, **but assume a ground level release (H_B=0)**. Extract the numerical value of: (1) chi/Q, in s/m³, from the RSAC run, (2) the mean wind speed, U_A, in m/s, as well as (3) the dose from each pathway and organ. Let $L_B = \min \{W_B, H_B\}$ Calculate the scaling factor:

 $F_{C} = 1/\{U_{A} \cdot \pi \cdot L_{B} \cdot K \cdot [chi/Q]\}$

Where K=1m and is included to make the units consistent. Multiply the dose from each pathway and organ by the scaling factor; the results are the pathway and organ doses for this case (C - cavity). Sum the pathway doses to obtain the total dose for this case.

This essentially assumes the releases from the vent or stack are recirculated in the cavity zone; the quantity of radioactivity released per unit time (Q) is diluted by a flow equal to the product of π m and L_B (the smallest dimension of the building facing the wind) and U_A (the wind speed). Consider adding a test to assure that the correction factor can be no higher than F_v computed in Window 8.

Consider adding a test to assure that the distance from the stack does not exceed the building dimension in that direction.

Window 5.

This receptor is in the wake zone. For this case x must be within certain limits:

 $\frac{2.5 \cdot H_{\rm B}}{2.5 \cdot [A_{\rm B}]^{1/2}} \ge x > Q_{\rm B} = 2.5 \cdot [A_{\rm B}]^{1/2}$

For an ordinary Gaussian plume the concentration at ground level is given by:

C=(Q/U)·[exp-{(h/ σ_z)²}]/[$\pi \sigma_z \sigma_y$];

What we will assume for the wake zone is that the release is at ground level (this increases the concentration), but the vertical dispersion coefficient is increased (this decreases the concentration). Therefore: Run RSAC using the standard release (whatever that has been determined to be) at the distance x, **but assume a ground level release (H_B=0)**. Extract the numerical value of: (1) chi/Q, in s/m³, from the RSAC run, (2) the value of the vertical dispersion coefficient, σ_z , (sigz in the RSAC output), as well as (3) the dose from each pathway and organ. Compute the quantity:

 $\sigma_{zmod} = [(\sigma_z)^2 + (A_B/\pi)]^{1/2}$

Compute the scaling factor:

 $F_w = \sigma_z / \sigma_{zmod}$

Multiply the dose from each pathway and organ by the scaling factor; the results are the pathway and organ doses for this case (W - wake). Sum the pathway doses to obtain the total dose for this case.

.

-



SVTR#: 14-3	Project #: 20.060002.01.103					
Software Name: PCSA Tool		Version: 3.0 (Beta Q)				
Test ID: 6.14	Test Series Name: Dis	olay Images				
Test	Method					
 □ code inspection ☑ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 						
<u>Test Envir</u>	onment Setup					
Hardware (platform, peripherals): Machine pi	tor, Windows XP					
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0.0 BetaQ installed					
Input Data (files, database, mode settings): I available on startup	Default PCSA Tool datab	ase, pcsademo				
Assumptions, constraints, and/or scope of te Assumptions or constraints: none Scope of the test: Verify images can be adde	<u>st:</u> ed, viewed and deleted.					
<u>Test Procedure:</u> From the main menu, images->DOE, open the images form. Verify that one or more images can be viewed. Add a new jpg image to the review section by opening the images->Review form. Delete the image just added and verify it is removed from the screen.						
Test Results						
Verified that the North Portal Plan and Typical Design Drawing Electrical Single Line could be viewed. These images were viewed in Microsoft Photo Editor. Added a jpg image of a screen capture to the images, review screen and subsequently removed it. Since images could be viewed, added, and deleted, this test passed.						
Test Evaluation (Pass/Fail): Pass						
Notes: None.						
Tester: George Adams Jung Mon	Date: August 12, 2004					

SVTR#: 14-4	Project #: 20.060002.01.103						
Software Name: PCSA Tool	Version: 3.0 (Beta R						
Test ID: 6.14	Test Series Name: Highlight Doses and Dose Rates Above Limits (Performance Assessment)						
Test	Method						
 code inspection output inspection hand calculation spreadsheet graphical comparison with external code 							
Test Envir	onment Setup						
Hardware (platform, peripherals): Machine pi	tor, Windows XP						
<u>Software (OS, compiler, libraries, auxiliary codes or scripts):</u> PCSA Tool Version 3.0.0 BetaR installed							
Input Data (files, database, mode settings): A as a minimum category 1 and category 2 eve	new database is create Int sequences for both th	d on startup containing e public and worker.					
Assumptions, constraints, and/or scope of tes Assumptions or constraints: none Scope of the test: Verify doses and dose rate	Assumptions, constraints, and/or scope of test: Assumptions or constraints: none Scope of the test: Verify doses and dose rates are highlighted when above limits						
<u>Test Procedure:</u> For the public and workers, enter doses and in the case of the noninvolved worker, enter dose rates for event sequences. Verify the doses and dose rates are highlighted when above the limits identified in attachment 1.							
Test Results							
Doses and dose rates are highlighted in accordance with attachment 1 and are shown on the attached reports; therefore this test passed.							
Test Evaluation (Pass/Fail): Pass							
Notes: None.							
Tester: George Adams Durg Johns	Date: August 17, 2004						

.

Attachment 1

ę

.

Туре	Category	Limit
Public	1	0.015 rem
Public	2	5 rem
Worker Involved	1	5 rem
Worker Noninvolved	1	100 mrem
Worker Noninvolved	1	2 mrem/hr (dose rate)

PCSA Performance Assessment Report

Project: svtp14-4

							Frequency: 1/yr
Functional ID	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat. Description	Man	Dose, Pt. Estimate freq. * dose % contribution	Additional Information
A.1	1	2	1.00E-01	1	Y	1.51E-03	category 1
A.1	1	1 Jahrson State State State State State State State State State State State	1.00E-01	1		50.17 1.50E-02 1.50E-03 49.83	category 1
				Total	l Frequency Normal (Weighted Dose (rem/yr) Operation Dose (rem/yr)	3.01E-03 0.00000

Total Dose (rem/yr) 3.01E-03

Public: Category 1

Doses: rem

A

PCSA Performance Assessment Report

Involved Worker: Category 1

#

Project: svtp14-4						Internal	Doses: rem Frequency: 1/yr	
Functi ID	onal	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat.	Description	External TEDE freq. * dose % contribution	Additional Information
A.1		1	1	1.00E-01	1		5.00E+00	category 1
							1.00E+00	
							66.62	
A.1		1	2	1.00E-01			2.50E+00	category 1
							2.51E+00	
							STOLE+000 Ha	
							5.01E-01	
							33.38	
							Total Frequency Weighted Dose (rem/yr)	1.50E+00

0.00000 Normal Operation Dose (rem/yr) 1.50E+00

Total Dose (rem/yr)

8/17/2004

PCSA Performance Assessment Report

Noninvolved Worker: Category 1

٠

-

Project: s	vtp14-4			Internal (Facility) External (Facility) TEDE (Facility)	Doses: rem Frequency: 1/yr		
Functional ID	Event Scenario Identifier	Event Sequence Identifier	Event Sequence Frequency	Cat.	Description	freq. * dose % contribution Dose Rate (rem/hr)	Additional Information
A.1	1	2	1.00E-01	1		1.00E-01	category 1
						1.016-049	
						2.01E-02	
						50.12	
			a sole of the	in an a irtean			
A.1	1	1	1.00E-01			1.00E-01	category 1
						2:00E-02	
						49.88 Mart 199, Auto 1997, Alar 1997, Al	
						2.00E-03	
						Total Frequency Weighted Dose (rem/yr)	4.01E-02
						Normal Operation Dose (rem/yr)	0.00000

Total Dose (rem/yr) 4.01E-02

: •

SVTR#: 14-5	Project #: 20.060002.01.103					
Software Name: PCSA Tool		Version: 3.0 (Beta T)				
Test ID: 6.14	Test Series Name: Sav Database	ing the System Log and				
Test	Method					
 □ code inspection ◎ output inspection □ hand calculation □ spreadsheet □ graphical □ comparison with external code 						
Test Envir	onment Setup					
Hardware (platform, peripherals): Machine gr	iffon, Windows 2000 Wo	rkstation				
<u>Software (OS, compiler, libraries, auxiliary co</u> installed	<u>des or scripts):</u> PCSA To	ol Version 3.0.0 BetaT				
Input Data (files, database, mode settings): T on startup	he default PCSA Demo	database is available				
Assumptions, constraints, and/or scope of tes Assumptions or constraints: none Scope of the test: Verifies the System Log is project	<u>st:</u> updated when the user e	exits from the current				
Test Procedure: Tested in accordance with attachment 1						
<u>Test</u>	Results					
The System Log was updated as required in attachment 1 and the database was updated as required in accordance with attachment 1.						
Test Evaluation (Pass/Fail): Pass						
Notes: None.						
Tester: Troy Maxwell	Date: September 3, 200)4				
Attachment 1

. . .

The following table is used to test the System Log and Database update functionality within the PCSA Tool.

Test	Verified	Status
1) Save on exit	Verify a new entry can be placed in the System Log. Verify the database changes were saved.	Pass
2) Intermediate save only and exit	Verify a new entry can be placed in the System Log. Verify only the intermediate changes were saved.	Pass
3) No saves and exit	Verify no new entry is requested for the System Log.	Pass
4) Save and then open or create a new project	Verify a new entry can be placed in the System Log. Verify the database changes were saved.	Pass
5) Intermediate save only and then open or create a new project	Verify a new entry can be placed in the System Log. Verify only the intermediate changes were saved.	Pass
6) No saves and then open or create a new project	Verify no new entry is requested for the System Log.	Pass

Software Change Reports (SCRs)

SOFTWARE CHANGE REPORT (SCR)

- **1**

1. 5	SCR No.	(Software De	eveloper Assigns):	2. Software Title and Version:	3. Project No:
		431		PCSA Tool, Version 3.0.0 (BetaE)	20.06002.01.103
4. /	Affected	Software Mc	odule(s), Description	n of Problem(s): Project Tree Modul	e
	 A) The tree structure needs to remain at the current level after the user specifies a level. Also, there needs to be expand and collapse buttons added so that the entire tree can be seen or only the portion of the tree down to the selected level is seen. B) Multiple people may perform analysis therefore, in order to keep track of the changes different users make, each user needs to have the capability to log their actions. C) Need to add a Crystal Beport 			a level. Also, there be seen or only the e changes different	
5. (Change I	Requested b	y: han -	6. Change Authorized by (Software	e Developer):
Na Da	me: B. Da te: July 1	asgupta, R. B 0, 2003	enke Ræ	Name: B. Dasgupta Mathe Date: July 10, 2003	
7. [Descripti	ion of Chang	e(s) or Problem Re	solution (If changes not implemente	d, please justify):
	A) Add B) Add log C) Crys	led collapse a led logging ca their changes stal Report wa	and expand buttons to apability for which a lo if they saved chango as added showing the	o the Project Tree form. og table was added to the database. A es and previously logged data is preser e Project Tree information	user is required to nt.
8. Al I	mpleme ozano, (nted by: G. Adams, D.	Stead	Date: April 20, 2004	
9.	9. Pass Fail Description of Acceptance Tests:				
1.	Ø		The Project Tree remains at the current level after the user selects a node on the tree.		
2.	Ŋ		Command Buttons expand and collaps	perform their intended function. Note se buttons.	especially the
3.	Ø		Text fields update of	correctly.	
4.	Ø		"Functional Area D level. The information	escriptions" form allows the user to ent tion is stored and can later be retrieved	er information for a land updated.
5.	Ø		"Crystal Report" ca Information.)	ptures the information on the form. (No	ote any missing
6.	 6. ☑ □ 6. ☑ □ When the user saves changes during a session, the log form opens to allow the user to log their changes. 2) When the log form opens, if no entries are currently logged, then an entry is optional; otherwise, an entry is required. 				
Note: Comments on testing are included as Attachment 1.					
10.	10. Tested by: Brandit Winter Date: April 22, 2004				

ATTACHMENT 1

Test	Comments		
1 – Tree remains at	PASSED		
current level after			
node selection			
2 – Command	PASSED		
Buttons Expand and			
Collapse			
3 – Text Fields	PASSED		
update correctly			
4 – Define Levels,	PASSED		
Add Level, Edit	• Define Levels Button allows the user to define the levels of the		
Selection, Delete	Project Tree. The effect of defining these levels can be seen by		
Selection	setting the levels, closing the project tree, opening the "Initiating		
	Event Form" and viewing the selected levels in the upper right text		
	screen.		
	• Clicking on the "Add Level button creates a level number. This is		
	applied to the new level with the "Apply" button.		
	• The "Edit Selection" button is used to label the 1 st through 4 th levels		
	as well as add optional remarks.		
	• When a level is selected and the "Delete Selection" button is		
	clicked, the selected level is removed from both the Project Tree and		
	the Report.		
5 – Show Report	PASSED		
	Note: It is cumbersome to compare the report with the tree because when		
	the report is active, the tree is not, so you cannot scroll to the unseen levels		
	without closing the report. Also, the screen containing the tree is not		
	extendable to allow full view of the tree.		
6 – Log on exit	PASSED		
	Note: The log form opens AFTER the program prompts you to save with a		
	pop-up dialog. Even if you elect not to save, the log form will appear. This		
	is supposed to happen.		
Additional Comments:			
When setting the Proje	ect Tree levels with the "Define Levels" button, it would be useful for this		
information to show up on the Report as a column header instead of "1 st Level", "2 nd Level",			
etc In version Betal	E, the report was upgraded to show the levels defined.		

SOFTWARE CHANGE REPORT (SCR)

1. SC	CR No.	(Software De 432	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta G)	3. Project No: 20.06002.01.103
4. Af	 432 PCSA Tool, Version 3.0.0 (Beta G) 20.06002.01.103 4. Affected Software Module(s), Description of Problem(s): System Description Module A) Need to have a new form (System Description) with several tabs for the user to have available for describing the system to include the following: Description and functions (Function tab) Facility operations and procedures (Operation Sequence tab) Characterization of the waste (Waste Characterization tab) Human actions (Human Actions tab) Description of shielding and worker location (Shielding tab) Software systems used (Software System tab) Fire hazard data (Fire Hazards tab) General information (General tab) Assumptions (Assumptions tab) B) Need to add Crystal Reports for each of the tabs. Need to add the capability for the user to select images from the Shielding tab. Also, the user needs to have the acadebility to add and remove images to and from the database. 				
5. CI Nam	h ange l he: B. D	Requested b	y: /// Benke Fr	6. Change Authorized by (Software Name: B. Dasgupta	e Developer):
7. De	 7. Description of Change(s) or Problem Resolution (If changes not implemented, please justify): A) Added the System Description Form to include the following tabs: Function, Operation Sequence, Waste Characterization, Human Actions, Shielding, Software System, Fire Hazards, General, Assumptions B) Added Crystal Reports showing the information on each of the tabs. C) Within the shielding tab of the System Description form, the user has the capability of viewing images that have been entered into the database. The user can add, view, and remove images 				
8. In M S	pleme illiman	nted by: DoSteard, G.	Adams	Date:	
9. F	Pass	Fail	Description of Te	st	
1	2		Form controls fund	tion correctly.	
2	Ø		Command Buttons	perform their intended function	· · · · · · · · · · · · · · · · · · ·
3	1		Crystal Reports ca Information.)	pture the information on the tabs. (Not	e any missing
4	4 Ø D Images can be selected from the shielding tab and can be added, viewed, and removed from the Images form.				
Note: Additional testing and comments can be found on Attachment 1.					
10. 1	10. Tested by: Brandi L. Winfrey Date: May 10, 2004				
			<u>* * , , /</u>	the second se	

CNWRA Form TOP-5 (05/2000)

• •

\$

SCR 432 Attachment 1

Test 4 - Shielding Tab says to "Double-click on image name…", but in order to get the image to display, the user has to double-click on **Image Type**. Also, to add or remove images, one must go to the drop down menu on the main toolbar outside of the System Description dialog. To see the change implemented, the System Description dialog window must be closed and then reopened. This was corrected in version BetaF.

Action Command	Expected Result & Comment	(P / F)
Function	Opens the Function input window.	Р
Operation Sequence	Opens the Operation Sequence input window.	Р
Waste Characterization	Opens the Waste Characterization input window.	Р
Human Actions	Opens the Human Actions input window.	Р
Shielding	Opens the Shielding input window.	P
Software System	Opens the Software System input window.	Р
Fire Hazards	Opens the Fire Hazards input window.	Р
General	Opens the General input window.	Р
Assumptions	Opens the Assumptions input window.	Р

Results for testing Action commands for Tests 1-3 are shown below.

Action Command	Expected Result & Comment	(P/F)
Add Record	Prompts the user with an "Assumption" input box (I).	Р
Edit Record	Allows the user to alter information in the current window in the selected field.	Р
Copy Record	Copies selected record in the current window, giving it a new item number.	Р
Delete Record	Deletes selected records in the current window.	Р
Show Report	Displays the user input in report format.	Р

Close	Closes the "System Description/Assumptions" window. Closes the entire System Description window, not just the Assumptions window.	Р
Apply	Adds the user input into the System Description, Assumptions window.	Р
Cancel	Closes the "Assumption" input box while not retaining any user input.	Р

Action Command	Expected Result & Comment	(P/F)
Add Record A.	Prompts the user with an "Data" input box (I).	Р
Edit Record A.	Allows the user to alter information in the current window.	Р
Copy Record A.	Copies selected record in the current window, giving it a new item number.	Р
Delete Record A.	Deletes selected records in the current window.	Р
Add Record B.	Prompts the user with an "Data" input box (I).	Р
Edit Record B.	Allows the user to alter information in the current window.	Р
Copy Record B.	Copies selected record in the current window, giving it a new item number.	Р
Delete Record B.	Deletes selected records in the current window.	Р
Edit Record/Update	Allows the user to edit and update References and Additional Information in the "System Description/Human Actions" window.	Р
Show Report	Displays the user input in report format.	Р
Close	Closes the "System Description/Human Actions" window. Closes the entire System Description window, not just the Human Actions window.	Р
ОК	Adds the user input into the System Description/Human Actions window.	Р

Cancel	Closes the "Assumption" input box while not retaining	Р
	any user input.	

ı

Action Command	Expected Result & Comment	(P/F)
Add Record/Update	Allows the user to enter and update data in the "System Description/Waste Characterization" window. Note: if there are multiple records entered, when the Update button is clicked, the record is updated, and the screen jumps to the LAST record. This is NOT an error, but also not standard practice (the record being updated should remain the current record in view). This was corrected in version BetaG.	Р
Edit Record	Allows the user to alter information in the current window.	Р
Scroll Arrows	Scrolls back and forward through available records, one at a time, jump to the first or last record.	Р
Delete Record	Prompts the user with a "Delete Record?" option (I).	Р
Show Report	Displays the user input in report format.	Р
Close	Closes the "System Description/Waste Characterization" window.	Р
Yes	Deletes the selected record. Note: It DOES delete the record, but does NOT delete the text from the screen when there is only one record available. This should be corrected. This was corrected in version BetaG.	Р
No	Closes the "Delete Record?" window and does not delete the selected record.	Р

Action Command	Expected Result & Comment	(P/F)
Add Record/Update	Allows the user to enter and update data in the "System Description/Operation Sequence" window.	Р
Edit Record	Allows the user to alter information in the current window.	Р
Delete Record	Prompts the user with a "Delete Record?" option (I).	Р

Show Report	Displays the user input in report format.	Р
Scroll Arrows	Scrolls back and forward through available records, one at a time, jump to the first or last record.	Р
Close	Closes the "System Description/Operations Sequence" window.	Р
Yes	Deletes the selected record.	Р
No	Closes the "Delete Record?" window and does not delete the selected record.	Р

Action Command	Expected Result & Comment	(P/F)
Edit Record/Update	Allows the user to enter and update data in the "System Description/Operation Sequence" window.	Р
Show Report	Displays the user input in report format.	Р
Close	Closes the "System Description/Function" window.	Р

Action Command	Expected Result & Comment	(P/F)	
Edit/Update	Allows the user to enter and update data in the "System Description/Operation Sequence" window.	Р	
Show Report	Displays the user input in report format.	Р	
Close	Closes the "System Description/General" window.	Р	

Action Command	Expected Result & Comment	(P/F)
Add Record/Update	Allows the user to enter and update data in the "System Description/Operation Sequence" window.	Р
Edit Record	Allows the user to alter information in the current window.	Р
Delete Record	Prompts the user with a "Delete Record?" option (I).	Р
Show Report	Displays the user input in report format.	Р

Close	Closes the "System Description/Fire Hazards" window.	
Yes	Deletes the selected record.	Р
No	Closes the "Delete Record?" window and does not delete the selected record.	Р

Action Command	Expected Result & Comment	(P/F)
Add Record	Prompts the user with a "Data" window (I).	Р
Edit Record	Allows the user to alter information in the current window.	Р
Copy Record	Allows the user to copy the selected record and give it a new Item No.	Р
Delete Record	Deletes the selected record.	Р
Edit/Update	Allows the user to input data in the References and Additional Information text box.	Р
Show Report	Displays the user input in report format.	Р
Close	Closes the "System Description/Software System" window.	Р
ОК	Applies the user input to the System Description/Software System window.	Р
Cancel	Closes the System Description/Software System window not retaining any changes.	Р

Action Command	Expected Result & Comment	(P/F)
Add Record/Update	Allows the user to enter and update data in the "System Description/Shielding" window.	Р
Edit Record	Allows the user to alter information in the current window.	Р

Scroll Arrows	Scrolls back and forward through available records, one at a time, jump to the first or last record.	Р
Delete Record	Prompts the user with a "Delete Record?" option (I).	Р
Show Report	Displays the user input in report format.	
Close	Closes the "System Description/Shielding" window.	Р
Yes	Deletes the selected record.	Р
No	Closes the "Delete Record?" window and does not delete the selected record.	Р

.

SOFTWARE CHANGE REPORT (SCR)

1. SCR No. (Software De	veloper Assigns):	2. Software Title and Version:	3. Project No:
433		PCSA Tool, Version 3.0.0 (BetaB)	20.06002.01.103
4. Affected Software Mo	dule(s), Descriptio	n of Problem(s): Hazard Analysis Mo	odule
 A) Need to add Crystal Reports to the Internal Events forms to include: Failure Modes and Effects Analysis (FMEA), What-If, Human Reliability Analysis (HRA), Energy Method, and Severe Events forms. For FMEA, What-If, HRA, and Energy Method, this includes the form itself, the table associated with the form, and the severe events list. For the Severe Events form there is just one associated Crystal Report. B) Need to add Crystal Reports to the External Events forms to include: Naturally Occurring and Human-Induced Events form and the individual external event edit form. 			
5. Change Requested by	" May	6. Change Authorized by (Softwar	e Developer):
Name: B. Dasgupta, R. B Date: July 10, 2003	enke Re	Name: B. Dasgupta Date: July 10, 2003	
7. Description of Change	e(s) or Problem Re	solution (If changes not implement	ed, please justify):
 A) Added the Crystal Reports to the forms and tables for FMEA, What-If, HRA, and Energy Method. Added Crystal Reports to the severe events list associated with each of these forms. B) Added a Crystal Report to the Severe Events table. C) Added Crystal Reports to the External Events forms. 			
Tool. At the current time, permits, it will be included	there is insufficient under a separate S	information to include Fire Hazard Ana CR.	alysis. If time
8. Implemented by:DaG. AdamsColumnMathematical StructureMathematical Structure		Date: March 8, 2004	
9. Pass Fail	Description of Acceptance Tests:		
1 🗹 🗆	Command Buttons perform their intended function.		
2 🗹 🗆	Text fields update correctly. Note any field length limitations.		
3 🗹 🗆	"Crystal Report" captures the information on the forms. (Note any missing Information.)		
Note: Additional information including in Attachment I.			
10. Tested by: Troy Maxwell Date: April 12, 2004			

CNWRA Form TOP-5 (05/2000)

۰**د**

,

Attachment I

۰ ،

Int. Events/FMEA		
Action Command	Expected Result & Comment	(P/F)
Add Record	Activates the text box to add a record.	Р
Delete Record	Deletes the record currently displayed and prompts the user.	Ρ
Edit Record	Allows the user to modify any data in the form.	Р
Show Report	Displays the information input into the System Description form in report format.	Р
FMEA Table/Form	Toggles between FMEA Form and FMEA Table windows.	Ρ
Close	Closes the window and returns to the main project screen retaining any changes made.	Ρ
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected.	Ρ
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ
Copy Record (FMEA Table only)	Copies information of the entire row into another row. Copy Record is only available in the FMEA Table.	Ρ

Int. Events/What If		
Action Command	Expected Result & Comment	(P/F)
Add Record	Activates the text box to add a record.	Р
Delete Record	Deletes the record currently displayed and prompts the user.	Ρ
Edit Record	Allows the user to modify any data in the form.	Р
Show Report	Displays the information input into the System Description form in report format.	Ρ
What If Table/Form	Toggles between What If Form and What If Table windows.	Р
Close	Closes the window and returns to the main project screen retaining any changes made.	Ρ
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected.	Ρ

Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ
Copy Record (FMEA Table only)	Copies information of the entire row into another row. Copy Record is only available in the What If Table.	Ρ

Int. Events/Energy Method			
Action Command	Expected Result & Comment	(P/F)	
Add Record	Activates the text box to add a record.	Р	
Delete Record	Deletes the record currently displayed and prompts the user.	Р	
Edit Record	Allows the user to modify any data in the form.	Р	
Show Report	Displays the information input into the System Description form in report format.	Р	
FMEA Table/Form	Toggles between Energy Analysis Form and Energy Analysis Table windows.	Р	
Close	Closes the window and returns to the main project screen retaining any changes made.	P	
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected.	Ρ	
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ	
Copy Record (FMEA Table only)	Copies information of the entire row into another row. Copy Record is only available in the Energy Anal. Table.	Р	

Int. Events/Human Reliability Analysis				
Action Command	Expected Result & Comment	(P/F)		
Add Record	Activates the text box to add a record.	Р		
Delete Record	Deletes the record currently displayed and prompts the user.	Р		
Edit Record	Allows the user to modify any data in the form.	Р		
Show Report	Displays the information input into the System Description form in report format.	Р		
HRA Table/Form	Toggles between HRA Form and HRA Table windows.	Р		
Close	Closes the window and returns to the main project screen retaining any changes made.	Р		

Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected.	Ρ
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ
Copy Record (HRA Table only)	Copies information of the entire row into another row. Copy Record is only available in the HRA Table.	Ρ

,

•

SOFTWARE CHANGE REPORT (SCR)

1. SCR No. (Software Develop 434	er Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (BetaE)	3. Project No: 20.06002.01.103		
4. Affected Software Module(s), Descriptio	n of Problem(s): Frequency Analysis	s Module		
 A) Need to upgrade stand B) Categorization of initiat 'Likely,' 'Unlikely,' and ' modified to be strictly c sequences in 10 CFR F C) Need to add a seismic D) Need to add Crystal Residence forms. 	 A) Need to upgrade standalone Saphire software to version 6.77. B) Categorization of initiating events needs to be modified to identify three different categories: 'Likely,' 'Unlikely,' and 'Not Included.' The classification of event sequences needs to be modified to be strictly consistent with the definitions of Category 1 and Category 2 event sequences in 10 CFR Part 63. C) Need to add a seismic fragility form with associated database and report capability. D) Need to add Crystal Reports to the Initiating Event, Event Tree, Fault Tree, and Event 				
5. Change Requested by:	Ay_	6. Change Authorized by (Softwar	re Developer):		
Name: B. Dasgupta, R. Benke Date: July 10, 2003	Tes	Name: B. Dasgupta Date: July 10, 2003			
7. Description of Change(s) of	r Problem Re	esolution (If changes not implement	ted, please justify):		
A) The current version of	he Saphire so	ftware is 6.70. The upgrade to version	n 6.77 was not		
B) Modified the Initiating E Included.' The criteria event will occur with a frequency less than 1.0	 completed due to time constraints. B) Modified the Initiating Event form to classify initiating events as 'Likely', 'Unlikely,' and 'Not Included.' The criteria is as follows: Given the same operational period of 100 years, a likely event will occur with a frequency of 1.00e-2 or greater, an unlikely event will occur with a frequency of 2.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater, and a 'not included' event will occur with a frequency of 1.00e-2 or greater of 1.00e-2 or greater occur with a 'not included' event will occur with				
frequency less than 1.0 C) Modified the Event Sec BCFL. The criteria is a event sequence will oc will occur with a freque will occur with a freque D) A seismic fragility form E) Crystal Reports were a Sequence forms.	 frequency less than 1.00e-2 but at least 1.01e-6, and a not included event will occur with a frequency less than 1.01e-6. C) Modified the Event Sequence form to classify event sequences as category 1, category 2, and BCFL. The criteria is as follows: Given the same operational period of 100 years, a category 1 event sequence will occur with a frequency less that 1.00e-2 but at least 1.01e-6, and a BCFL event sequence will occur with a frequency less than 1.01e-6. D) A seismic fragility form was not added due to time constraints. E) Crystal Reports were added to the Initiating Event, Event Tree, Fault Tree, and Event 				
8. Implemented by:		Date:			
D Stead G. Adams, M. Sillima	n ~	March 30, 2004			
9. Pass Fail Des	cription of Ac	ceptance Tests:			
1 ☑ □ The corre	classification of ectly.	of initiating events and event sequence	es is performed		
2 🗹 🗆 Com	Command Buttons perform their intended function.				
3 🗹 🗆 All fo	All form controls update correctly.				
5 Ø Crystal Reports capture the information on the forms. (Note any missing Information.)					
Note: Additional information included in Attachment I.					
10. Tested by: Troy Maxwell Date: April 21, 2004					

CNWRA Form TOP-5 (05/2000)

1

Attachment I

ι

,

Freq. Analysis/Initiating Event				
Action Command	Expected Result & Comment	(P/F)		
Add Record (Form/Table)	Activates the text box to add a record.	Р		
Delete Record (Form/Table)	Deletes the record currently displayed and prompts the user.	Р		
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ		
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected	Ρ		
Edit Record (Table)	Allows the user to modify any data in the form.	Р		
Show Report (Form/Table)	Displays the information input into the Initiating Event Form in report format.	Ρ		
Init. Table/Form	Toggles between Init. Form and Init. Table windows.	Ρ		
Edit Record (Table)	Allows the user to edit input in the Initiating Event Table.	Ρ		
Copy Record (Table)	Copies information of the entire row into another row. Copy Record is only available in the Initiating Event Table.	Ρ		
Close (Form/Table)	Closes the window and returns to the main project screen retaining any changes made.	Р		

Freq, Analysis/Even	t Tree/Event Scenario	
Action Command	Expected Result & Comment	(P/F)
Add Scenario	Activates the text boxes in the Event Scenario section and allows the user to add a scenario.	Р
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Ρ
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected	Ρ
Delete Scenario	Deletes the scenario currently displayed and prompts the user.	Ρ
Show Report	Displays the information input into the Event Tree Form Form/Event Scenario in report format.	Р

Close	Closes the window and returns to the main project	Ρ
	screen retaining any changes made.	

Freq. Analysis/Event Tree/Subsequent Events			
Action Command	Expected Result & Comment	(P/F)	
Add Record	Allows the user to add a record to the Subsequent Events section of the Event Tree Form.	Р	
Edit Record	Allows the user to edit a record to the Subsequent Events section of the Event Tree Form.	Р	
Copy Record	Allows the user to copy a record to the Subsequent Events section of the Event Tree Form.	P	
Delete Record	Allows the user to delete a record to the Subsequent Events section of the Event Tree Form.	P	
Show Report	Displays the information input into the Event Tree Form Form/Subsequent Events in report format.	Р	
Close	Closes the Event Tree Form.	Р	

Freq. Analysis/Fault	Tree	
Action Command	Expected Result & Comment	(P/F)
Add Record (Form/Table)	Activates the text boxes in the Fault Tree Form and allows the user to add a scenario.	Р
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	Р
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected	Ρ
Delete Record (Form/Table)	Deletes the scenario currently displayed and prompts the user.	Р
Show Report (Form/Table)	Displays the information input into the Fault Tree Form in report format.	Р
Event Table	Displays the Fault Tree Event Table.	Р
Edit Record (Table)	Allows the user to modify any data in the form.	Р
Copy Record (Table)	Allows the user to copy any data in the form.	Р
Close (Table)	Closes the Table window and returns to the Form window.	P
Close (Form)	Closes the window and returns to the main project screen retaining any changes made.	P

Freq. Analysis/Event Sequence			
Action Command	Expected Result & Comment	(P/F)	
Add Record (Form/Table)	Activates the text boxes in the Event Sequence Form and allows the user to add a scenario.	Р	
Update Record	Applies and saves any new information or changes made. Update Record is displayed if Add Record or Edit Record have been selected.	P	
Cancel	Returns the user to the default form display screen without retaining user input. Cancel is displayed if Add Record or Edit Record have been selected	P	
Delete Record (Form/Table)	Deletes the scenario currently displayed and prompts the user.	Р	
Show Report (Form/Table)	Displays the information input into the Event Sequence Form in report format.	P	
Event Seq. Form/Table	Toggles between the Event Sequence Form and Table.	Ρ	
Edit Record (Table)	Allows the user to modify any data in the form.	Р	
Copy Record (Table)	Allows the user to copy any data in the form.	Р	
Close (Table)	Closes the Table window and returns to the Form window.	Р	
Close (Form/Table)	Closes the window and returns to the main project screen retaining any changes made.	Р	

ŧ

ç	SOFTWARE	CHANGE	REPORT	(SCR)
•		OI // HOL		(001)

1. SCR No. (Softwar	re Developer Assigns): 435	2. Software Title and Version: PCSA Tool, Version 3.0.0 (BetaE)	3. Project No: 20.06002.01.103	
4. Affected Softwar	e Module(s), Descriptio	on of Problem(s): Consequence Analysis Module	•	
 A) Need to add graphics. B) Need to upg executes on C) Incorporate This capabil D) Need to give for that dose 5. Change Request	 A) Need to add Crystal Reports for both RSAC input and output. The RSAC output Crystal Reports will include graphics. B) Need to upgrade RSAC to Version 6.2. Version 6.1 will not execute on Windows XP machines. Version 6.1 executes on both Windows NT and Windows XP machines. C) Incorporate MACCS2. The capability will be added to manually enter consequence analysis runs from MACCS2. This capability will extend to packages other than MACCS2. D) Need to give the user the capability to enter Normal Operation Dose and descriptive information for that dose. 5. Change Requested by: Machine 6. Change Authorized by (Software Developer): Machine 1. 			
Date: July 10, 2003	, R. Benke	Name: B. Dasgupta Date: July 10, 2003		
7. Description of Cl	hange(s) or Problem Re	esolution (<i>If changes not implemented, please</i>)	justify):	
 A) Crystal Reportshowing the showing the B) RSAC was unin January, 2 C) Incorporated enter determ D) Added a Northered States 	 A) Crystal Reports were added for both RSAC input and RSAC output. For RSAC output, graphs were added showing the doses by pathway and radionuclide. B) RSAC was upgraded to Version 6.2. The Software Validation Test Report for RSAC Version 6.2 was completed in January, 2004. C) Incorporated a Manual Data entry capability into consequence analysis. The user will have the capability to enter deterministic dose values for consequence analyses they conduct offline. D) Added a Normal Operation Dose form for the public 			
8. Implemented by:		Date:		
9. Stead, G. Adams		April 13, 2004		
9. Pass Fail	Description of Accep	tance Tests:		
1 🗹 🗆	Tabular data can be e	dited. Note especially data type and any size restr	ictions on entered data.	
2 🗹 🗆	Command Buttons per	form their intended function.		
3 🗹 🗆	Text fields update corr	ectly.		
4 🗹 🗆	Consequence results of	can be manually entered. Note any limitations on	entering data manually.	
 RSAC can be invoked and runs to completion. It can be invoked in deterministic and probabilistic mode for BWR, PWR, and User Specified Fuel Types. In addition it can be invoked using the Advanced RSAC Input option. 				
6 🗹 🗆	Crystal Reports capture the information on the input and output forms. (Note any missing information.)			
7 🗹 🗆	7Image: Marcolar baseThe Normal Operation Dose form allows the user to enter the Normal Operation Dose and associated descriptive text.			
Note: Additional information is included in Attachment I.				
10. Tested by: R. Janetzke Date: April 28, 2004				

CNWRA Form TOP-5 (05/2000

t 1

Attachment 1

3

•

The following acceptance test tables are for SCR 435 Version BetaB. GUI Test Worksheet

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq>I	Public Do	ose->RSAC->RSAC	Date:	4-7-2004

Dialogue Window	RSAC: New or Modified Analysis		
Button Sequence	Fuel Selection/; PWR		
Field	Co-60		
Types Accepted (I=integer, R=real, T=text):	IR New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	1.2	
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	Ρ		

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Fuel Selectior	Fuel Selection/; Probabilistic; Deterministic		
Field	Type of Run			
Types Accepted (I=integer, R=real, T=text):	New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):				
Archive File	scr435-1.mdb			
Restorable				
Status (P=pass, F=fail)	F; Error 13			

Dialogue Window	RSAC: New o	r Modified Analysis	
Button Sequence	Release Fraction		
Field	Release Fraction		
Types Accepted (I=integer, R=real, T=text):	IR	New Value	
Range Accepted (N = all	ZP=<1	0.0	

negatives, Z = zero, P = all positives):	
Archive File	scr435-1.mdb
Restorable	yes
Status (P=pass, F=fail)	P

Project: PCSATool(BetaB)	SCR: 435	Tester: Janetzke	
Root Test Box: Conseq>	Public Dose->RSAC->RSAC	Date: 4-7-2004	
Dialogue Window	RSAC: New or Modified Ana	lysis	
Button Sequence	Release Fraction		
Field	Release Fraction		
Types Accepted (I=integer, R=real, T=text):	IR New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP=<1	1.0	
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	Р		

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	nce Release Fraction; Probabilistic; Deterministic	
Field	Release Fraction	

Types Accepted (I=integer, R=real, T=text):		New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):		
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	F; Values are changed to default values rather than those in the project file.	

......

÷ •

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Bldg discharge	
Field	Vapors	
Types Accepted (I=integer, R=real, T=text):	IR New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP=<1	1.0
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	P	

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke	
Root Test Box: Conseq>Public Dose->RSAC->RSAC			Date:	4-7-2004	
		1			

Dialogue Window	RSAC: New or Modified Analysis		
Button Sequence	Bldg. Discharge; Probabilistic		
Field	Number		
Types Accepted (I=integer, R=real, T=text):	1	New Value	

Range Accepted (N = all negatives, Z = zero, P = all positives):	Ρ	2	2
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	Ρ		

, ,

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Release Fraction; Pool; Restore all defaults	
Field	Release in	
Types Accepted (I=integer, R=real, T=text):		New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):		Pool
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	F; Does not restore "Air" as default value.	

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Meterological			
Field	Input value; mixing layer height.			
Types Accepted (I=integer, R=real, T=text):	IR New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP=<3000 3000.0			
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	Ρ			

Project: PCSATool(BetaB)	SCR: 435	Tester:	Janetzke	
Root Test Box: Conseq>Public Dose->RSAC->RSAC			4-7-2004	

,

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Inhalation dos	Inhalation dose		
Field	Input value; ir	Input value; inhalation		
Types Accepted (I=integer, R=real, T=text):	IR New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP 3.0			
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	Р			

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Inhalation dos	Inhalation dose		
Field	Input value; A	ctivity mean		
Types Accepted (I=integer, R=real, T=text):	IR New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):	P>0.1 0.1			
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	Р			

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Ground Surface			
Field	Inpu tvalue; decay time			

Types Accepted (I=integer, R=real, T=text):	IR	New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	10.0
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	Ρ	

,

,

Project: PCSATool(BetaB)	SCR:	435		Tester:	Janetzke
Root Test Box: Conseq>	Public Do	ose->RSAC->	RSAC	Date:	4-7-2004

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Ground Surfa	Ground Surface		
Field	Input value; B	Input value; Building		
Types Accepted (I=integer, R=real, T=text):	IR New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP=<1.0 0.2			
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	Р			

Dialogue Window	RSAC: New or Modified Analysis		
Button Sequence	Submersion		
Field	Input value; decay time		
Types Accepted (I=integer, R=real, T=text):	IR New Value		

Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	10.0	
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	Р		

ъ н

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Ingestion	Ingestion		
Field	Input value; T	Input value; Time crops		
Types Accepted (I=integer, R=real, T=text):	IR New Value			
Range Accepted (N = all negatives, Z = zero, P = all positives):	P>0.04 17.			
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	Ρ			

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->RSAC->RSAC			Date:	4-7-2004

Dialogue Window	RSAC: New or Modified Analysis		
Button Sequence	Fuel Selec	Fuel Selection/; Fuel type	
Field			
Types Accepted (I=integer, R=real, T=text):		New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):		"User Specified"	
Archive File	scr435-1.mdb		

Restorable	yes
Status (P=pass, F=fail)	F; Does not run RSAC when supplied with PWR default values.

•

.

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Restore all defaults; Perform An	
Field		
Types Accepted (I=integer, R=real, T=text):	New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):		
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	P; RSAC runs	

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	PWR; Perform	n An
Field		
Types Accepted (I=integer, R=real, T=text):		New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):		
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	P; RSAC runs.	

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->RSAC->RSAC			Date:	4-7-2004

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Probabilistic; Fuel Selection/; BWR; Bldg D; Perform An	
Field	Number of R	
Types Accepted (I=integer, R=real, T=text):	I New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):	Ρ	2
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	P; RSAC runs.	

è è

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Fuel Selection/; PWR; Bldg; Perform An	
Field	Number of R	
Types Accepted (I=integer, R=real, T=text):	I New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):	Ρ	2
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	P; RSAC runs	

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Fuel Selection/; User SPec; Probabilistic; Perform An	
Field	Co-60	
Types Accepted (I=integer, R=real, T=text):	IR	New Value

Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	6.57
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	F; No RSAC input file created.	
GUI Test Worksheet		
Proiect:	SCR: 435	Tester: Janetzke

· •

•

PCSATool(BetaB)				
Root Test Box: Conseq>l Operation	Public Dose->Normal	Date:	4-7-2004	

Dialogue Window	Public Normal Operation Dose	
Button Sequence		
Field	Normal Operation Dose	
Types Accepted (I=integer, R=real, T=text):	New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):		
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	F; Focus is not on an active field.	

Dialogue Window	Public Normal Operation Dose	
Button Sequence	Edit; Normal Oper	
Field		
Types Accepted (I=integer, R=real, T=text):	IR	New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	10.

Archive File	scr435-1.mdb
Restorable	yes
Status (P=pass, F=fail)	Р

. .

_

Dialogue Window	Public Normal Operation Dose		
Button Sequence	Edit; Description		
Field			
Types Accepted (I=integer, R=real, T=text):	т	New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):		test	
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	Р		

Project: PCSATool(BetaB)	SCR: 435	Tester: Janetzke	
Root Test Box: Conseq>Public Dose->RSAC- >Advanced RSAC Input		Date: 4-8-2004	
Dialogue Window	Deterministic RSAC Run for	Advanced User	
Button Sequence	Edit Exist; Run Adv		
Field			
Types Accepted (I=integer, R=real, T=text):		New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):			
Archive File	scr435-1.mdb		
Restorable			
Status (P=pass, F=fail)	F; RSAC does not run to cor	npletion.	

GUI Test Worksheet

.

.

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq> Public> RSAC -> RSAC- > Perfor		Date:	4-9-2004	

Dialogue Window	RSAC Most Recent Analysis
Button Sequence	RSAC Input; Show Report
Field	All
Archive File	scr435-1.mdb
Comments	All fields in the report have corresponding values on the screen.
Status (P=pass, F=fail)	Ρ

Dialogue Window	RSAC Most Recent Analysis
Button Sequence	RSAC Output; Inhalation; Show Report
Field	All
Archive File	scr435-1.mdb
Comments	Reports do not correspond to the tab selected.
Status (P=pass, F=fail)	F; Could possibly remove the "Show Report" button from these boxes to disable attempts to show data from these tabs.

Project: PCSATool(BetaB)	SCR:	435	Tester:	Janetzke
Root Test Box: Pefrom> Curent Level> Public			Date:	4-9-2004

Dialogue Window	Results Table - Functional ID E.3.3			
Button Sequence	double click on Dose Pt.Est. For manual data ; Apply			
Field	Editing Results Table - Functional ID E.3.3			
Types Accepted (I=integer, R=real, T=text):	IR	New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):	NZP	1.0		
Archive File	scr435-1.mdb			
Restorable	yes			
Status (P=pass, F=fail)	F; Receive Error 76 after editing and selecting 'Apply'.			

The following acceptance test tables are for SCR 435 Version BetaE, and are comprised of the tests that failed for the BetaB version.

Project: PCSATool(BetaE)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->RSAC->RSAC			Date:	4-28-2004

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Fuel Selection/; Probabilistic; Deterministic			
Field	Type of Run			
Types Accepted (I=integer, R=real, T=text):		New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):				
Archive File	scr435-1.mdb			
Restorable				
Status (P=pass, F=fail)	Р			

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Release Fraction; Probabilistic; Deterministic			
Field	Release Fraction			
Types Accepted (I=integer, R=real, T=text):		New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):				
Archive File	scr435-1.mdb			
Restorable				
Status (P=pass, F=fail)	P; Values do not change to default values, but keep those in the project file.			

<u>.</u> •

Dialogue Window	RSAC: New or Modified Analysis			
Button Sequence	Release Fraction; Pool; Restore all defaults			
Field	Release in			
Types Accepted (I=integer, R=real, T=text):		New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):		Pool		
Archive File	scr435-1.mdb			
Restorable				
Status (P=pass, F=fail)	P; Does restore "Air" as default value.			
GUI Test Worksheet				

Project: PCSATool(BetaE)	SCR: 435	Tester:	Janetzke	
Root Test Box: Conseq>Public Dose->RSAC->RSAC		Date:	4-28-2004	

Dialogue Window	RSAC: New or Modified Analysis	
Button Sequence	Fuel Selection/; Fuel type	
Field		
Types Accepted (I=integer, R=real, T=text):	New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):	"User Specified"	
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	P; Does run RSAC when supplied with PWR default values.	

Dialogue Window	RSAC: New or Modified Analysis
Button Sequence	Fuel Selection/; User SPec; Probabilistic; Perform An

Field	Co-60	
Types Accepted (I=integer, R=real, T=text):	IR	New Value
Range Accepted (N = all negatives, Z = zero, P = all positives):	ZP	6.57
Archive File	scr435-1.mdb	
Restorable	yes	
Status (P=pass, F=fail)	P; RSAC input file is created.	

, **4**
GUI Test Worksheet

Project: PCSATool(BetaE)	SCR:	435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->Normal Operation		Date:	4-28-2004	

Dialogue Window	Public Normal Operation Dose	
Button Sequence		
Field	Normal Operation Dose	
Types Accepted (I=integer, R=real, T=text):	New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):		
Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	P; Focus is on an active field.	

GUI Test Worksheet

Project: PCSATool(BetaE)	SCR: 435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->RSAC- >Advanced RSAC Input			4-28-2004

Dialogue Window	Deterministic RSAC Run for Advanced User		
Button Sequence	Edit Exist; Run Adv		
Field			
Types Accepted (I=integer, R=real, T=text):		New Value	
Range Accepted (N = all negatives, Z = zero, P = all positives):			

Archive File	scr435-1.mdb	
Restorable		
Status (P=pass, F=fail)	P; RSAC does run to completion.	

GUI Test Worksheet

4

Project: PCSATool(BetaE)	SCR: 435	Tester:	Janetzke
Root Test Box: Conseq>Public Dose->RSAC- >RSAC-> Perfor		Date:	4-28-2004

Dialogue Window	RSAC Most Recent Analysis
Button Sequence	RSAC Output; Inhalation; Show Report
Field	All
Archive File	scr435-1.mdb
Comments	
Status (P=pass, F=fail)	P; The "Show Report" button from these boxes was removed to disable attempts to show data from these tabs.

GUI Test Worksheet

Project: PCSATool(BetaE)	SCR:	435	Tester:	Janetzke
Root Test Box: Perform>	- Current	Level> Public	Date:	4-28-2004

Dialogue Window	Results Table - Functional ID E.3.3		
Button Sequence	double click o	n Dose Pt.Est. For manual data ; Apply	
Field	Editing Result	ts Table - Functional ID E.3.3	
Types Accepted (I=integer, R=real, T=text):	IR New Value		
Range Accepted (N = all negatives, Z = zero, P = all positives):	NZP	1.0	
Archive File	scr435-1.mdb		
Restorable	yes		
Status (P=pass, F=fail)	P; No error after editing and selecting 'Apply'.		

1.	SCR	No. (Software D	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (BetaE)	3. Project No: 20.06002.01.103
4	Affe	cted Software N	lodule(s). Descriptio	n of Problem(s): Safety Analysis Mo	dule
	 A) Need to add Crystal Reports to the Safety Analysis Module. The Crystal Report needs to display information for Category 1, Category 2, and BCFL event sequences. 				
	B)	Category 1 ever	it sequences that exce	eed 0.015 rem need to be highlighted, a	and Category 2 event
	\sim	sequences that	exceed 5.0 rem need	l to be nighlighted.	t the work conducted
	C)	by B Bonko ar	the calculation for con	urnal article to <i>Risk Analysis</i> : (Benke	B "Analytical and
		Numerical Solu	itions of the Expecte	ed Number of Occurrences for Con	hinations of Event
		Sequences due	to Variability." San Ar	ntonio, TX: Center for Nuclear Waste F	Regulatory analyses.
		2003.} A maxin	num of 3 combination	s will be considered.	
	D)	For compliance	assessment on categ	jory 1 event sequences, the total frequ	ency weighted dose
		will be calculate	d and displayed, and t	he contribution percent of each catego	ry 1 event sequence
<u> </u>		to the total frequ	lency weighted dose	will be displayed.	
5.			by: MATZ	6. Change Authorized by (Softwar	e Developer):
	ite: c	5. Dasyupia, n. i luly 10. 2003	Belike	Date: July 10, 2003	
		ription of Chan	ne(s) or Problem Re	solution (If changes not implement	ed please justify)
.	A)	Crystal Report v	was added to display	event sequences to include Category	1. Category 2. and
	,	BCFL event sec	quences from complia	ince assessment. For category 1 ever	nt sequences,
		doses which ex	ceed 0.015 rem are h	ighlighted on the Crystal Report. For o	category 2 event
1		sequences, dos	es which exceed 5.0	rem are highlighted on the Crystal Rep	port.
	B)	For Category 1	compliance assessme	ent, the calculation for combinations of	l event sequences
ļ	\sim	Was added to a	maximum of 3 compl	nations. A Crystal Report was added	for combinations.
1	0)	dose is calculat	ed and displayed alon	a with the event sequence percent co	ntribution to the
		total frequency	weighted dose. Singl	e category 1 event sequences that exc	ceed 0.015 rem are
	highlighted. In addition category 2 event sequences that exceed 5 rem are highlighted.			highlighted.	
8.	8. Implemented by: Date:				
2	April 21, 2004				
′ 9.	Pas	≤ Fail	Description of Ac	ceptance Tests:	
1	Ø		Category 1 event s sequences exceed assessment table	sequences exceeding 0.015 rem and 0 ling 5.0 rem are highlighted on both th and the Crystal Report.	Category 2 event e compliance
	-		The total frequency	y weighted dose is calculated and disp	layed on both the
2	ম	П	category 1 complia	ance assessment form and the Crystal	Report. The event
	ت		sequence percent	contribution to the total frequency weig	phted dose is also
Ļ			calculated and dis		
$\frac{3}{4}$	<u>_</u>	<u>U</u>	Form controls upd	ate correctly.	i
4			Command buttons	perform their intended function.	<u> </u>
5	Crystal Reports capture the information on the form. (Note any missing Information.)				
6	6Image: Market And ComparisonImage: Comparable And ComparisonImage: Comparison And Comparison And ComparisonImage: Comparison And Comparison <thi< td=""></thi<>				
			I in output.		
(N	ote a	ny additional tes	ting and include as ar	n attachment.)	
10	10. Tested by: R. Janetzke Date: April 28, 2004				
<u> </u>	in joneque				
		v	/		

₩ CNWRA Form TOP-5 (05/2000)

_

ų i

ł

The following acceptance test tables are for SCR 436 Version BetaC.

GUI Test Worksheet

Project: PCSATool(BetaC)	SCR:	436	Tester:	Janetzke
Root Test Box: Proj. Tree -:	> E.3.3 -:	> Done -> Perform.	Date:	4-13-2004

Results Window	Results Table Project View Base Case
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 1; Search
Field	Dose PtEst
Archive File	PCSADemo.mdb
Comments	Edit category 1 Dose PtEst manual data to be 0.0150 and 0.0151.
Status (P=pass, F=fail)	P; All category 1 dose fields>0.015 are highlighted in both table and report.

Dialogue Window	Results Table Project View Base Case		
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 2; Search		
Field	Dose PtEst		
Archive File	PCSADemo.mdb		
Comments	Edit category 2 Dose PtEst manual data to be 5.0.		
Status (P=pass, F=fail)	P; Category 2 dose fields = 5.0 are not highlighted in either the table or report.		

Dialogue Window	Results Table Project View Base Case
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 2; Search

Field	Dose PtEst
Archive File	PCSADemo.mdb
Comments	Edit category 2 Dose PtEst manual data to be 5.01.
Status (P=pass, F=fail)	P; Category 2 dose fields > 5.0 are highlighted in both the table and report.

, i

GUI Test Worksheet

(

Project: PCSATool(BetaC)	SCR:	436	Tester:	Janetzke	
Root Test Box: Proj. Tree -:	> E.3.3 -:	> Done -> Perform.	Date:	4-13-2004	

Results Window	Results Table Project View Base Case		
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 1; Search; Show Report		
Field	Dose PtEst		
Archive File	PCSADemo.mdb		
Comments	Dose is calculated and displayed correctly in table and report		
Status (P=pass, F=fail)	F; Some fields disappear under the cursor icon on the report, table is OK.		

Dialogue Window	Results Table Project View Base Case		
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 1; Search; Probabilistic; Show Report		
Field	Dose PtEst		
Archive File	PCSADemo.mdb		
Comments	Characters are missing from the label for "Total Frequency Weighted Dose" on the report for the probabilistic case.		
Status (P=pass, F=fail)	F		

GUI Test Worksheet

, i

Project: PCSATool(BetaC)	SCR:	436	Tester:	Janetzke
Root Test Box: Proj. Tree -> A.1 -> Done -> Perform.		Date:	4-13-2004	

Dialogue Window	Results Table Project View Base Case	
Button Sequence	Proj; Safety; Public; Compliance; 1; Search; set cutoff to 0; Calculate	
Field	Expected Number	
Archive File	scr436.mdb	
Comments	Data from "Analytical and Numerical Solutions of the Expected Number of Occurrences for Combinations of Event Sequences Due to Variability", R. Benke, 2003.	
Status (P=pass, F=fail)	F; Expected Number is a factor 30 less than that in the reference article. Table and Report column headings should be changed to "Expected Number of Occurrences per year".	

The following acceptance test tables are for SCR 436 Version BetaE and are comprised of the tests that failed for the BetaC version.

GUI Test Worksheet

Project: PCSATool(BetaE)	SCR:	436	Tester:	Janetzke
Root Test Box: Proj. Tree -> E.3.3 -> Done -> Perform.		Date:	4-28-2004	

Results Window	Results Table Project View Base Case		
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 1; Search; Show Report		
Field	Dose PtEst		
Archive File	PCSADemo.mdb		
Comments	Dose is calculated and displayed correctly in table and report		
Status (P=pass, F=fail)	P; Some fields disappear under the cursor icon on the report when run on the ALBY machine. This is assumed to be limited to this machine only, since the test ran correctly on two other machines.		

Dialogue Window	Results Table Project View Base Case	
Button Sequence	Current Lev;Public; edit Dose PtEst; Close Perform.; Proj; Safety; Public; Compliance; 1; Search; Probabilistic; Show Report	
Field	Dose PtEst	
Archive File	PCSADemo.mdb	
Comments	Characters are no longer missing from the label for "Total Frequency Weighted Dose" on the report for the probabilistic case.	
Status (P=pass, F=fail)	Р	

(Blank to next page)

,

. ,

1. SCR No. (Software Developer Assigns):		2. Software Title and Version:	3. Project No:		
437	7	PCSA Tool, Version 3.0.0 (BetaG)	20.06002.01.103		
4. Affected Software I	Module(s), Descriptio	n of Problem(s): Risk analysis Modu	lle		
 A) Need to add C the graphical d B) Need to show to 	rystal Reports for both isplay of probabilistic r the percentage contrib	Deterministic and Probabilistic risk as isk results. ution of each event to risk.	sessment to include		
5. Change Requested	by: /32	6. Change Authorized by (Softwar	e Developer):		
Name: B. Dasgupta, F Date: July 10, 2003	R. Benke	Name: B. Dasgupta Date: July 10, 2003			
7. Description of Cha	nge(s) or Problem Re	solution (If changes not implement	ed, please justify):		
 A) Crystal Reports assessment in B) The Risk Asse each event to r 	 A) Crystal Reports were added to display risk assessment output results. Report for probabilistic assessment includes a graphical display of the results. B) The Risk Assessment output results were modified to show the percentage contribution of a probabilistic assessment to risk. 				
8. Implemented by:		Date:			
G. Adams, M. Silliman,	, T. Maxwell	May 7, 2004			
9. Pass Fail	Description of Acce	eptance Tests:			
1 🗹 🗆	The Crystal Reports capture the information on the form. (Note any missing Information.)				
2 🗹 🗆	The percentage contribution of each event to risk is correctly calculated for both deterministic and probabilistic assessment.				
Note: See Attachments 1 and 2 for comments and additional testing.					
10. Tested by: Brandi L. Wintey		Date: May 10, 2004			
CNWRA Form TOP-5 (05/2000)					

i t

TEST 1: Crystal Reports Capture All Info in Report					
Action Command	Expected Result & Comment	(P/F)			
Deterministic Risk	Calculate Deterministic Risk. A window will appear stating that the calculation is in progress, and when complete, the results will display in a table (I).	Ρ			
Probabilistic Risk	Calculate Deterministic Risk. A window will appear stating that the calculation is in progress, and when complete, the results will display as a graph (I) (II).	Ρ			
Double click on "Dose, PtEst"	Opens a window that calculates Event dose using a deterministic scenario calculation (III).	Р			
Double click on "Dose, Mean"	Opens a window that calculates Event dose using a probabilistic scenario calculation (III).	Р			
I. Common Button					
Show Report	Generate a Crystal Report. Expect all column headers to be displayed on report as well as identical reported results. For Probabilistic Report, Additional options are given (IV).	Ρ			
	Note: It would be useful for the report to state that the results are Deterministic or Probabilistic depending on which report is generated. This change was implemented in version BetaG.				
Done	Closes the Crystal Report and returns to the Risk Analysis window.	Р			
II. Probabilistic Bu	ittons				
View Table/Graph	Toggles between viewing the Graph of CCDF Output for Total Risk and the Probabilistic Results Table	Ρ			
III. Scenario Calcu	lation				
Event Dose	Calculates Event Deterministic Dose (if "Dose, PtEst" was double clicked) or the Mean Dose (if "Dose, Mean" was double clicked) and shows the results in the previously empty text box on the same window.	Ρ			

Done	Closes the Event Dose calculation window. If no calculation was performed, an error message will appear stating that the calculation failed. This is expected.		
IV. Do you wish to	see the plot with data?		
Yes	A Crystal Report is generated that contains the CCDF OUTPUT For Total Risk graph as well as the data it was generated from. Note: the wording of this question should be changed to "Would you like to see the data with the plot?" since it is the data which is the optional item. This change was implemented in version BetaG.	Ρ	
No	A Crystal Report is generated that contains ONLY the CCDF OUTPUT For Total Risk graph.	Ρ	

•

TEST 2: % Contribution of Event Risk is Correctly Calculated				
Calculation Type	Expected Result & Comment	(P/F)		
Deterministic	Risk = Probability * Consequence	Р		
	Total Risk = the sum of all risks			
	%Contribution = (Risk/Total Risk) * 100			
	Risk calculations are 1/1000 off, however since % contribution is only considered to 2 significant digits this does not affect % Contribution accuracy. (see Attachment 2 for Excel spreadsheet) This is due to round off error.			
Probabilistic	Risk = Probability * Consequence	Р		
	Total Risk = the sum of all risks			
	%Contribution = (Risk/Total Risk) * 100			
	Risk calculations are 1/1000 off, however since % contribution is only considered to 2 significant digits this does not affect % Contribution accuracy. (see Attachment 2 for Excel spreadsheet) This is due to round off error.			

, ``

Deterministic Results:

.....

Note: ce	lls highlighted	l in have	differences in a	ccuracy.	
Data and F	lesults obtaine	d from PCSATo	ol version 3.0.0	Results Calcu	lated by
(BetaD)				Excel	O
的時間開始				time period)	Contribution
9 27/F-01	0.000E+00	0.000E+00	0.00E+00	0.000E+00	0.00E+00
9.274L-01	2 766E-05	2 236E-07	3.05E-01	2.236E-07	3.05E-01
0.004E-03	1.044E-03	2.200E 07	3.02E-01	2.218E-07	3.02E-01
7.2175-06	8.032E-01	5.877E-06	8.00E+00	5.877E-06	8.00E+00
7.317E-00	0.002E-01	0.000E+00	0.00E+00	0.000E+00	0.00E+00
7.317E-00	2 7945 01	0.0000	3.77E±00	0.0002100	3 77F+00
2 506E 02	20235-04	1.051E-06	1 43E+00	1.051E-06	1.43E+00
3.590E-03	7 505E-04	2 699E-06	3.68E+00	2 699E-06	3.68E+00
3.590E-03	1.303E-04	1 541E-05	2 10F+01	1.541E-05	2.10E+01
3.590E-03	1.669E-03	6.002E-06	8 17F+00	6.002E-06	8.17E+00
3.390E-03	1.0092-03	1.541E-05	2 10F+01	1 541E-05	2 10F+01
3.390E-03	4.204E-05	1.5412-05	6.23E-03	1.0412.00	6.23E-03
3.5962-03	1.273E-06	1 567E-07	2 13E-00	1.567E-07	2.13E-01
0.550L-05	2 6825-04	1.507 2.07	9.34F+00		9.34E+00
2.337E-02	1 1005 02	1 262E-05	1 72E+01	1 262E-05	1 72E+01
1.14/E-02	2 200E 04	1.2022-05	1 37E-02	1.003E-08	1.37E-02
3.135E-05	5.200E-04	2 4405 08	3.325-02	2 440E-08	3 32E-02
3.135E-05	1.702E-04	1 2525 07		1 352E-07	1 84E-01
3.135E-05	4.312E-03	1.3522-07	7.24E-02	1.0020-07	7.24E-02
3.135E-05	1.097E-03	1 2525 07	1.240-02	1 352E-07	1 84E-01
3.135E-05	4.312E-03	1.352E-07	1.04E-01	1.5522-07	1.04E 01
3.135E-05	2.894E-05	0.0005.00	2.045.02	2 2225-00	3.04E-03
3.135E-05	7.124E-05	2.233E-09	9.04E-03	2.200L-03	8 98E-02
2.229E-04	2.958E-04	1 1095 07	0.90E-02	1 1285-07	1.54E-02
1.000E-04	1.128E-03	1.126E-07	0.495.02	1.1200-07	9.485-03
3.145E-06	2.213E-03		9.402-03		5 855-03
1.411E-06	3.045E-03		5.85E-03		1.09E-00
1.395E-05	1.043E-03		1.98E-02		9.605.02
1.395E-05	4.577E-03		8.69E-02		0.09E-02 2.72E.02
1.395E-05	1.961E-03		3.73E-02		3.73E-02
1.395E-05	4.577E-03		8.69E-02		8.69E-02
1.395E-05	2.936E-04		5.58E-03		5.58E-03
1.395E-05	3.359E-04		6.38E-03		6.38E-03
9.915E-05	5.605E-04	5.557E-08	7.57E-02	5.557E-08	7.57E-02
4.449E-05	1.393E-03		8.44E-02		8.44E-02
1.395E-05	5.035E-03		9.56E-02		9.56E-02
1.395E-05	2.419E-03		4.60E-02		4.60E-02
1.395E-05	5.035E-03		9.56E-02		9.56E-02
1.395E-05	7.518E-04		1.43E-02		1.43E-02
1.395E-05	7.941E-04		1.51E-02		1.51E-02
9.915E-05	1.019E-03	1.010E-07	1.38E-01	1.010E-07	1.38E-01
4.449E-05	1.851E-03	8.235E-08	1.12E-01	8.235E-08	3 1.12E-01

1.395E-05	5.953E-03		1.13E-01		1.13E-01
1.395E-05	8.569E-03	1.195E-07	1.63E-01	1.195E-07	1.63E-01
1.395E-05	4.286E-03		8.14E-02		8.14E-02
1.395E-05	4.328E-03	an di kasar	8.22E-02		8.22E-02
9.915E-05	4.553E-03	4.514E-07	6.15E-01	4.514E-07	6.15E-01
4.449E-05	5.385E-03	2.396E-07	3.26E-01	2.396E-07	3.26E-01
1.395E-05	5.953E-03		1.13E-01		1.13E-01
1.395E-05	1.670E-03		3.17E-02		3.17E-02
1.395E-05	1.712E-03	2.388E-08	3.25E-02	2.388E-08	3.25E-02
9.915E-05	1.937E-03	1.921E-07	2.62E-01	1.921E-07	2.62E-01
4.449E-05	2.769E-03	1.232E-07	1.68E-01	1.232E-07	1.68E-01
1.395E-05	4.286E-03		8.14E-02		8.14E-02
1.395E-05	4.328E-03		8.22E-02		8.22E-02
9.915E-05	4.553E-03	4.514E-07	6.15E-01	4.514E-07	6.15E-01
4.449E-05	5.385E-03	2.396E-07	3.26E-01	2.396E-07	3.26E-01
1.395E-05	4.485E-05		8.52E-04		8.52E-04
9.915E-05	2.695E-04	2.672E-08	3.64E-02	2.672E-08	3.64E-02
4.449E-05	1.102E-03		6.68E-02		6.68E-02
9.915E-05	3.118E-04	3.091E-08	4.21E-02	3.091E-08	4.21E-02
4.449E-05	1.144E-03	5.090E-08	6.93E-02	5.090E-08	6.93E-02
3.163E-04	1.369E-03		5.90E-01		5.90E-01
2.757E-06	1.396E-03		5.24E-03		5.24E-03
1.227E-06	1.661E-03		2.77E-03		2.77E-03
1.227E-06	2.119E-03		3.54E-03		3.54E-03
1.227E-06	5.653E-03		9.44E-03		9.44E-03
1.227E-06	3.037E-03	3.726E-09	5.07E-03	3.726E-09	5.07E-03
1.227E-06	5.653E-03		9.44E-03		9.44E-03
1.227E-06	1.370E-03		2.29E-03		2.29E-03
1.227E-06	1.412E-03	Sec. 1. Sec.	2.36E-03	100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100	2.36E-03
Total Risk		7.342E-05			

Probabilistic Results:

r

Note: ce	Note: cells highlighted in the have differences in accuracy.						
				Results Calcula	Results Calculated by Excel		
				Mean Risk (rem in time period)	Contribution (%)		
9.274E-01	0.000E+00	0.000E+00	0.00E+00	0.000E+00	0.00E+00		
8.084E-03	4.957E-06		3.75E-01		3.75E-01		
1.141E-04	3.484E-04	3.975E-08	3.71E-01	3.975E-08	3.72E-01		
7.317E-06	1.439E-01	1.053E-06	9.84E+00	1.053E-06	9.84E+00		
7.317E-06	2.441E-02	1.786E-07	1.67E+00	1.786E-07	1.67E+00		
7.317E-06	2.641E-02	1.932E-07	1.81E+00	1.932E-07	1.81E+00		
3.596E-03	0.000E+00	0.000E+00	0.00E+00	0.000E+00	0.00E+00		
3.596E-03	5.239E-05	1.884E-07	1.76E+00	1.884E-07	1.76E+00		
3.596E-03	2.991E-04	1.076E-06	1.01E+01	1.076E-06	1.01E+01		
3.596E-03	7.674E-04	2.760E-06	2.58E+01	2.760E-06	2.58E+01		
3.596E-03	2.991E-04	1.076E-06	1.01E+01	1.076E-06	1.01E+01		

GUI Test Worksheet

.

•

Project: PCSATool(BetaE)	SCR:	436	Tester:	Janetzke
Root Test Box: Proj. Tree -:	> A.1 ->	Done -> Perform.	Date:	4-28-2004

Dialogue Window	Results Table Project View Base Case
Button Sequence	Proj; Safety; Public; Compliance; 1; Search; set cutoff to 0; Calculate
Field	Expected Number
Archive File	scr436.mdb
Comments	Data from "Analytical and Numerical Solutions of the Expected Number of Occurrences for Combinations of Event Sequences Due to Variability", R. Benke, 2003.
Status (P=pass, F=fail)	P; Table and Report column headings were changed to "Expected Number of Occurrences per year".

3.596E-03 0.000E+00	0.000E+00	0.00E+00	0.000E+00	0.00E+00
3.596E-03 3.042E-06	1.094E-08	1.02E-01	1.094E-08	1.02E-01
2.557E-02 4.028E-05	1.030E-06	9.63E+00	1.030E-06	9.63E+00
1.147E-02 2.156E-04	2.473E-06	2.31E+01	2.473E-06	2.31E+01
3.135E-05 4.957E-06	1.554E-10	1.45E-03	1.554E-10	1.45E-03
3.135E-05 5.734E-05	1.798E-09	1.68E-02	1.798E-09	1.68E-02
3.135E-05 3.040E-04		8.91E-02		8.91E-02
3.135E-05 7.723E-04	2.421E-08	2.26E-01	2.421E-08	2.26E-01
3.135E-05 3.040E-04		8.91E-02		8.91E-02
3.135E-05 4.957E-06	1.554E-10	1.45E-03	1.554E-10	1.45E-03
3.135E-05 7.999E-06	2.508E-10	2.34E-03	2.508E-10	2.34E-03
2.229E-04 4.523E-05	1.008E-08	9.42E-02	1.008E-08	9.42E-02
1.000E-04 2.205E-04	2.205E-08	2.06E-01	2.205E-08	2.06E-01
3.145E-06 3.887E-04	x 1 5 - 1	1.14E-02		1.14E-02
1.411E-06 5.640E-04		7.44E-03		7.44E-03
1.395E-05 5.239E-05		6.83E-03		6.83E-03
1.395E-05 2.991E-04		3.90E-02		3.90E-02
1.395E-05 7.674E-04		1.00E-01		1.00E-01
1.395E-05 2.991E-04		3.90E-02		3.90E-02
1.395E-05.0.000E+00	0.000E+00	0.00E+00	0.000E+00	0.00E+00
1.395E-05 3.042E-06		3.96E-04		3.97E-04
9.915E-05 4.028E-05		3.73E-02		3.73E-02
4.449E-05 2.156E-04		8.96E-02		8.96E-02
1.395E-05 3.515E-04		4.58E-02		4.58E-02
1.395E-05 8.197E-04	1.143E-08	1.07E-01	1.143E-08	1.07E-01
1.395E-05 3.515E-04		4.58E-02		4.58E-02
1.395E-05 5.239E-05		6.83E-03		6.83E-03
1.395E-05 5.543E-05		7.22E-03		7.23E-03
9.915E-05 9.266E-05	9.187E-09	8.59E-02	9,187E-09	8.59E-02
4 449F-05 2 679F-04	1.192E-08	1.11E-01	1,192E-08	1.11E-01
1.395E-05 1.066E-03	1.487E-08	1.39E-01	1.487E-08	1.39E-01
1.395E-05 5.981E-04		7.80E-02		7.80E-02
1.395E-05 2.991E-04		3.90E-02		3.90E-02
1.395E-05 3.021E-04		3.94E-02		3.94E-02
9.915E-05 3.393E-04		3.14E-01		3.14E-01
4 449E-05 5 146E-04		2.14F-01		2 14F-01
1.395E-05 1.066E-03	1.487E-08	1.39E-01	1.487E-08	1.39E-01
1.395E-05 7.674E-04		1.00E-01		1.00E-01
1.395E-05 7.704E-04		1.00E-01		1.00E-01
9.915E-05 8.076E-04		7.48E-01		7.48E-01
4,449E-05, 9,829E-04	4.373E-08	4.09E-01	4.373E-08	4.09E-01
1 395E-05 2 991E-04		3 90E-02		3 90F-02
1 395E-05 3 021E-04		3.94F-02		3.94F-02
9.915E-05 3.393E-04		3.14E-01		3.14F-01
4,449E-05 5 146E-04		2.14F-01		2 14F-01
1 395E-05 3 042E-06		3.96F-04		3 97F-04
9 915E-05 4 028E-05		3.73F-02		3 73F-02
4 449F-05 2 156F-04		8.96F-02		8 96F-02
9 915F-05 4 332F-05	4 2955-09	4 01F-02	4 295F-09	4 01F-02
4.449E-05 2 186E-04		9.09F-02		9 095-02
		0.000 02		

•

3.163E-04 2.558E-04		7.56E-01		7.56E-01
2.757E-06 2.608E-04		6.72E-03		6.72E-03
1.227E-06 2.558E-04		2.93E-03		2.93E-03
1.227E-06 3.082E-04		3.53E-03		3.53E-03
1.227E-06 5.549E-04		6.36E-03		6.36E-03
1.227E-06 1.023E-03	1.255E-09	1.17E-02	1.255E-09	1.17E-02
1.227E-06 5.549E-04		6.36E-03		6.36E-03
1.227E-06 2.558E-04		2.93E-03		2.93E-03
1.227E-06 2.589E-04		2.97E-03		2.97E-03
Total Risk	1.070E-05			

~

1. 5	SCR N	lo. (Software	Developer Assigns):	2. Software Title and Version:	3. Project No:
		43	8	PCSA Tool, Version 3.0.0 (BetaA)	20.06002.01.103
4. <i>I</i> Imp	 4. Affected Software Module(s), Description of Problem(s): Structures, Systems, and Components Important to Safety. A) Add a new form to allow the user to enter Structures, Systems, and Components (SSCs). B) Add the capability to identify SSCs important to safety. C) Add Crystal Beport capability for SSCs 				
5. 0 Nar Dat	Chang me: B te: Ju	je Requested 3. Dasgupta, F Iy 10, 2003	i by: May R. Benke Be	6. Change Authorized by (Softwar Name: B. Dasgupta Date: July 10, 2003	re Developer):
7. [7. Description of Change(s) or Problem Resolution (If changes not implemented, please justify): A) Added an SSC input form under the System menu item to allow the user to specify SSCs and their design bases and criteria. In addition, added linkage on the Design Bases and Design Criteria tab of this form to associate hazards, initiating events, and event tree subsequent events with these design bases and design criteria. B) Added a Crystal Report to the SSC input form to allow the user to display SSCs and their design bases and design criteria. C) Added a View SSCs form to allow the user to enter selection criteria for SSCs and then display the requested SSCs. 				
8.1	mpler	nented by:	A Cillimon	Date:	
Pg	Stean	G. Adams, N	2.S. Icn~	March 16, 2004	
9.	Pass	Fail	Description of Ac	ceptance lests:	
1	V		Command Buttons	perform their intended function.	
2	Ø		Form controls upda	ate correctly.	
3	V		Crystal Reports ca Information.)	pture the information on the form. (No	ote any missing
4	4 Ø □ User has the capability to select SSCs during takeaway analysis.				analysis.
5	5 🗹 🗆 User has the capability to view SSCs and filter those displayed by entering selection criteria.				
No	te: Ac	ditional inform	mation in Attachment 1.		
10.	Teste	ed by: Troy M	Naxwolf MLM	Date: April 6, 2004	

CNWRA Form TOP-5 (05/2000)

ς.

*

۱

System/SSCs/General				
Action Command	Expected Result & Comment	(P/F)		
Add Record	Allows the user to enter information in the current window.	Р		
Delete Record	Deletes the current record.	Р		
Edit Record	Allows the user to edit the current record.	Р		
Show Report	Displays the information in report format.	Р		
Close	Closes the System/SSCs/General window	Р		
Add/Functions	Allows the user to enter information in the functions section of the System/SSCs/General window.	Р		
Edit/Functions	Allows the user to edit the information in the functions section of the System/SSCs/General window.	Р		
Delete/Functions	Deletes the selection in the functions section of the System/SSCs/General window.	Р		

System/SSCs/Desi	gn Basis and Design Criteria	
Action Command	Expected Result & Comment	(P/F)
Add Record	Allows the user to enter information in the current window.	Р
Edit Record	Allows the user to edit the current record.	Р
Copy Record	Allows the user to copy the current record.	Р
Delete Record	Deletes the current record.	Р
Show Report	Displays the information in report format.	Р
Close	Closes the System/SSCs/General window	Р
Add/Functions	Allows the user to enter information in the Functions section of the System/SSCs/General window.	Ρ
Edit/Functions	Allows the user to edit the information in the Functions section of the System/SSCs/General window.	P
Delete/Functions	Deletes the selection in the Functions section of the System/SSCs/General window.	Р
Add/Hazards	Allows the user to enter information in the Hazards section of the System/SSCs/General window.	Р

Edit/Hazards	Allows the user to edit the information in the Hazards section of the System/SSCs/General window.	P
Delete/Hazards	Deletes the selection in the Hazards section of the System/SSCs/General window.	Ρ
Add/Initiating Events	Allows the user to enter information in the Initiating Events section of the System/SSCs/General window.	Ρ
Edit/Initiating Events	Allows the user to edit the information in the Initiating Events section of the System/SSCs/General window.	Р
Delete/Initiating Events	Deletes the selection in the Initiating Events section of the System/SSCs/General window.	Р
Add/Event Tree	Allows the user to enter information in the Event Tree section of the System/SSCs/General window.	Ρ
Edit/Event Tree	Allows the user to edit the information in the Event Tree section of the System/SSCs/General window.	Ρ
Delete/Event Tree	Deletes the selection in the Event Tree section of the System/SSCs/General window.	Р

•

1. S	CR No.	(<i>Software</i> 5	e Developer Assigns): 06	2. Software Title and Version: PCSA Tool, Version 3.0.0 (BetaE)	3. Project No: 20.06002.01.103
4. A frmF	 4. Affected Software Module(s), Description of Problem(s): frmRSAC_Main, frmResultsTable, frmResultsSSCITSTable, mdlYMPModule1 A) Add highlighting of fixed-parameter cells in RSAC Input grids; fix problem when starting tool if database was not saved the last time the tool was run and an RSAC run had been made, the Input and Output data would no longer be 'in sync'. Add code to avoid an error when loading an older saved RSAC run with the 'Release Fraction Source' data missing, and to set the 'Valid Input/Output Pair' flag in database to False if there was an error loading a run. Set default tabs to be shown first whon frmBSAC. Main loads 				
5. C Nan Date	h ange F ne: B. Da e: July 1	Requeste asgupta, 0, 2003	ed by: /34/ R. Benke R3	6. Change Authorized by (Softward Name: B. Dasgupta	e Developer):
7. D Ad pa 'frr 'Cd wh pre So pro Ad	7. Description of Change(s) or Problem Resolution (<i>If changes not implemented, please justify</i>): Added code to highlight RSAC input grid cells with fixed values with grey color. A grid reference parameter was added to 'gChangeGridCellColor', and existing calls in 'frmResultsTable' and 'frmResultsSSCITSTable' were modified to include the grid reference. The subroutine 'CopySavedRSACTable' has been put back into use to load RSAC output data from the database when the form ('frmRSAC_Main') or a saved run is loaded, rather than reading the output files, to prevent the 'input/output out of sync' condition. Added code to warn user that the 'Release Fraction Source' was missing when loading a saved run, rather than generating an error and aborting the load process when partially completed. Added code to set 'Valid Input/Output Pair' to False on error.				
8. lr	nplemer	nted by:	D. Stead	Date: April 21, 2004	
9.	Pass	Fail	Description of Accept	tance Tests:	
1.	Ø		Load the Main RSAC form the main menu. If the inp corresponds to the input of Results' subtab data disp subtab, and the 'RSAC O	n by selecting 'Conseq> Public Dose -> I out and output data are 'in sync' (output dat data), the 'RSAC Output' tab will be shown layed. Click the 'RSAC Input' tab, modify a putput' tab should be disabled.	RSAC -> RSAC from a is valid and , with the 'Summary any data field on any
2.	Ø		Do a deterministic RSAC question. Restart the too Restart the tool, verify tha this test by first doing a p	analysis, exit the PCSA Tool and answer ' I, and do a probabilistic analysis; exit the to at the deterministic data is still shown on th robabilistic run and afterwards a determinis	Yes' to the 'Save?' ool without saving. e output tab. Repeat stic run.
3.	Ø		Verify that all fixed-value grey background color. If appear stating that they c the grids, to the 'MinValue	RSAC input parameters are highlighted in f these values are double-clicked, an error cannot be edited. [These can be identified e' column, which will show 'FIXED' for fixed	their grids with a message should by scrolling right in I-value parameters.]
4.	4. If we have the sequences that exceed 0.015 rem and category 2 event sequences that exceed 5 rem. If necessary, set doses manually to test this feature.				
5.			Verify the 'Load Saved A run, and for each case, th	nalysis' button loads a saved deterministic ne RSAC output tab is shown.	run and probabilistic
6.	6. I Verify that 'Load Saved Analysis' shows an error if a subdirectory is selected that has no 'RSAC_Run.mdb' file in it.				
Not	Note: Comments on testing are included as Attachment 1.				
10.	10. Tested by: Troy Maxwell Date: April 27, 2004				
CNWR	NWRA Form TOP-5 (05/2000 by / Channel Control				

ATTACHMENT 1

• •

Test	Comments
PASSED	Load the Main RSAC form by selecting `Conseq>
	Public Dose -> RSAC -> RSAC from the main menu. If
	the input and output data are `in sync' (output
	data is valid and corresponds to the input data),
	the 'RSAC Output' tab will be shown, with the
	'Summary Results' subtab data displayed. Click the
	'RSAC Input' tab, modify any data field on any
	subtab, and the `RSAC Output' tab should be
	disabled.
PASSED	Do a deterministic RSAC analysis, exit the PCSA
	Tool and answer `Yes' to the `Save?' question.
	Restart the tool, and do a probabilistic analysis;
· · · · · · · · · · · · · · · · · · ·	exit the tool without saving. Restart the tool,
	verify that the deterministic data is still shown
	on the output tab. Repeat this test by first doing
	a probabilistic run and afterwards a deterministic
	run.
PASSED	Verify that all fixed-value RSAC input parameters
	are highlighted in their grids with a grey
	background color. If these values are double-
	clicked, an error message should appear stating
	that they cannot be edited. [These can be
	identified by scrolling right in the grids, to the
	'MinValue' column, which will show 'FIXED' for
	fixed-value parameters.]
PASSED	Verify that cell highlighting (for high doses)
	occurs in the Results Table (Compliance Assessment)
	and Results Table (Takeaway Analysis - Category
	Search) for category 1 event sequences that exceed
	0.015 rem and category 2 event sequences that
	exceed 5 rem. If necessary, set doses manually to
	test this feature.
PASSED	Verity the 'Load Saved Analysis' button loads a
	saved deterministic run and probabilistic run, and
	for each case, the RSAC output tab is shown.
PASSED	Verity that 'Load Saved Analysis' shows an error if
	a subdirectory is selected that has no
	'RSAC_Run.mdb' file in it.

1.	SCR No	. (<i>Software De</i> 507	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta J)	3. Project No: 20.06002.01.103
4. frn md ent frm frm frm En	4. Affected Software Module(s), Description of Problem(s): mdlYMPModule1, frmEditRSACInput, frmEditRSACLHS mdlYMPModule1: Fix a cell highlighting problem in which no highlighting occurs if the column number is 0, in which case the entire row is supposed to be highlighted. frmEditRSACInput, frmEditRSACLHS: Field name text would not wrap to a second line for very long field names. frmFaultTreeEventTable, frmSELTable, frmSSC_Data, frmResultsSSCITSTable, frmWhatIfSELTable, frmHRATable, frmHRA_SELTable, frmEnergyAnalSELTable, frmEnergyAnalysisTable, frmEventSequenceTable.frm: Entire row would not be bighlighted after editing an entry in the grid				
5. Na Da	Change ame: G. ate: Apri	Adams	y: Adam	6. Change Authorized by (Software Name: G. Adams Date: April 5, 2004	e Developer):
7. md frm to a All	 7. Description of Change(s) or Problem Resolution (If changes not implemented, please justify): mdlYMPModule1: Changed code in 'gHighlightGridCellOrRow' to accept column number >= 0. frmEditRSACInput, frmEditRSACLHS: Made GUI property changes, including setting Word Wrap property to True on labels to allow long field names to wrap to a second line. All other listed forms: Changed call to " to set the column number to '0' to indicate that the entire row is to be highlighted. 				
8. D.	Implem Stead	ented by:	100	Date: June 2. 2004	
9.	Pass	Fail	Description of Tes	st	
1	Ø		Verify that an entire a field in the grid. <i>I</i> the field edited sho forms under the ' <i>In</i> form, and grids on	e row is highlighted after editing a cell in After clicking ' <i>Apply</i> ' to update the entry ould be highlighted. This applies to all 't at. Events' and 'Freq. Analysis' menus, t some tabs of the 'System Description' f	n a grid by editing y, the entire line for able' (grid-based) the ' <i>SSC Data</i> ' form.
2	Ø		Verify that on editin requiring word wrat label on the editing in the database is of <i>kg/yr) includes fruit</i> can be found on the label caption, edit t field name visible of should be tested for different editing for	ng text on the RSAC Input form, that lon pping (continuation to a second line in t popup) display the entire field name. Currently 'Stored (other) vegetable cons ts and grains' in the 'RSAC Ingestion Do e 'Ingestion Dose' tab. To verify word w he 'Input Value' for this field; you should on the field name label above the editing or both deterministic and probabilistic ca ms).	ig field names he field name The longest entry <i>sumption rate (wet ose</i> ' table, which wrapping in the d see the entire g text box. This ases (which use
No	Note: Additional testing and comments can be found on Attachment 1.				
10	10. Tested by: Brandi L. Winfrey Date: 6/10/2004				

CNWRA Form TOP-5 (05/2000)

,

٠

System / System Description - In	<i>t. Events</i> menu	
Action Command	Expected Results & Comment	(P/F)
Edit Record / double click	Verify that an entire row is highlighted after editing a cell in a grid by editing a field in the grid (Assumption I).	Р
	Notes:	
	First add an item using the FMEA Form, what if Form,	
	respective Severe Events form to perform editing.	
	2) The only editable field on the Severe Events form is the "Remarks" field.	
	3) When the Remarks field is edited the first 18 characters	
	are visible under the Remark column on the Severe Events	
	4) There is a 3 character minimum entry requirement per	
	response under the Component Description, What If, Event	
	Name, Human Action, Justification, and Explanation fields.	
System / System Description - F	Functed Booutto & Commont	
Action Command	Expected Results & Comment	
Edit Record / double click	grid by editing a field in the grid.	
	Notes:	
	1) First add an Item using the Initiating Event, Event Tree,	
	Fault Tree, and Event Sequence Forms. Then go to the	
	respective Event Sequence Table (Assumption II) to	
	perform editing.	
	adited are 'EvSeq ID' 'P W B' 'EvSeq Freq' 'Description'	
	'End State', and 'Additional Info'	
System / System Description - S	SC Data form	r
Action Command	Expected Results & Comment	(P/F)
Edit Record / double click	Verify that an entire row is highlighted after editing a cell in a grid by editing a field in the grid.	P
	Notes:	
	1) The SSC data form is available under the System	
	dropdown menu under SSCs.	
	2) Under the Design Bases and Design Criteria tab on the	
	SSC Data form, add a record and edit any or all of the	
	editable cells to obtain the desired results.	
System / System Description – S	System Description tabs	L
Action Command	Expected Results & Comment	(P/F)
Edit Record / double click	Verify that an entire row is highlighted after editing a cell in a	Р
	grid by editing a field in the grid	
	Notes:	
	1) Open the System Description tabs under the System	
	dropdown menu. For each of the following tabs, add a	
	record and then edit the record to obtain the desired results:	
	Human Actions, Software System, Assumptions,	

System / System Description – F	RSAC Input Form	
Action Command	Expected Results & Comment	(P/F)
deterministic	Verify that on editing text on the RSAC Input form, that long field names requiring word wrapping (continuation to a second line in the field name label on the editing popup) display the entire field name. The longest entry in the database is currently 'Stored (other) vegetable consumption rate (wet kg/yr) includes fruits and grains' in the 'RSAC Ingestion Dose' table, which can be found on the 'Ingestion Dose' tab. To verify word wrapping in the label caption, edit the 'Input Value' for this field; you should see the entire field name visible on the field name label above the editing text box.	P
	Notes: 1) To find long field names to verify, simply click and drag the right edge of the Input Parameter column to expand the names. Find a few long names, double click on their Input Values to have the Edit RSAC Input dialog open, and verify that the entire Input Parameter Name is visible above the editing text box.	
probabilistic	Verify that on editing text on the RSAC Input form, that long field names requiring word wrapping (continuation to a second line in the field name label on the editing popup) display the entire field name. The longest entry in the database is currently 'Stored (other) vegetable consumption rate (wet kg/yr) includes fruits and grains' in the 'RSAC Ingestion Dose' table, which can be found on the 'Ingestion Dose' tab. To verify word wrapping in the label caption, edit the 'Input Value' for this field; you should see the entire field name visible on the field name label above the editing text box.	Ρ
	Notes: same as for deterministic, above.	
I. Assumption	After eligibles (Appl/) to undete the entry the undeter (0)	
Арріу	implemented and the entire line for the field edited should be highlighted.	Р
Cancel	Update not implemented, line not highlighted. In effect, no changes made.	Ρ
II. Assumption		
Init Event Table	After clicking the 'Init <i>Event Table</i> ' button the Initiating Event Table becomes available for editing.	Ρ
Event Table	After clicking the ' <i>Event Table</i> ' button the Fault Tree Event Table becomes available for editing.	Ρ
Event Seq Table	After clicking the 'Event Seq Table' button the Event Sequence Table becomes available for editing.	Р

. . .

1. SCR No. (Software Developer Assigns):		2. Software Title and Version:	3. Project No:
508		PCSA Tool, Version 3.0.0 (BetaL)	20.06002.01.103
 4. Affected Software Module(s), Description of Problem(s): SSC Important to Safety Module, Project Tree Module, Frequency Analysis Module A) Correct a display error on the current grid in which design bases do not display when no records are available on form frmSSC_ViewAll and allow resizing of the grid. B) Add an intermediate database to allow the log entries to be stored even if the user decides not to save the current working database. C) Update Crystal Reports to use the gSetLevelDescriptions subroutine instead of the in-line code. D) The last column in the risk assessment grid is cutoff. E) Correct an error on the Current Level Results Table and the FMEA Severe Events List in which a 			
5. Change Requested by: Date: G. Adams M. Janu		6. Change Authorized by (<i>Softwa</i> Date: April 5, 2004	re Developer):
 7. Description of Change(s) or Problem Resolution (<i>If changes not implemented, please justify</i>): A) Modified the SSC_ViewAll form grdCurrent to show a column 0 to allow resizing within the grid. Added lblSelection to the form. Also corrected an error, which occurred when the user clicked on the SSC grid to display design bases and there were no rows in the SSC grid. B) An intermediate database was added to allow the user to store log entries. C) Updated frmCrystalEventSequence, frmCrystalFMEA to use subroutine gSetLevelDescriptions. D) Expanded the column width of the last column in the risk assessment grid to display the column heading correctly. E) Corrected the following forms to allow the user to edit a grid entry: the Results Table (frmResultsTable), Results SSCITS Table (frmResultsSSCITSTable) and the FMEA Severe 			
8. Implemented by: G. Adams, T. Maxwell	1	Date: July 19, 2004	
9. Description of Acceptance Tes	ts:	<u> </u>	
	D		
$\begin{array}{c c c c c c c c c c c c c c c c c c c $	Form contr	ols function correctly.	
2 🛛 🗆	Command	and filtering functions work correct	ly to view SSCs.
3 🗹 🗆	Crystal Rep information	ports (Event Sequence and FMEA) and show the current selected lev	capture the el.
4 🗹 🗆	The headir assessmer	ng displays correctly for the last color nt grid.	umn on the risk
5 Interest table, SSCITS table, and FMEA Severe Events List allow the user to edit a grid entry after previously adding on another form.			
(Note any additional testing and include as an attachment.) 10. Tested by: Date: B. Winfrey July 21, 2004			

. -

ATTACHEMNT 1

.

. .

Action Command	Expected Result & Comment	(P/F)
Add/Update Record	Add makes the fields editable so that the user can add an SSC to the database. Update adds the information in the fields to the database as an SSC. Note: Add three SSCs: 1)Mode of Operation = Manual 2)Important to Safety by DOE determination, and 3)Important to Safety by Staff determination Note: This test only passes if the results table, SSCITS table, and FMEA Severe Events List can be correctly edited after an SSC has been added.	Ρ
Edit Record	Allows the user to edit a record after previously adding.	Ρ
Show Report	Crystal Reports captures the information and displays the user input in report format. The report should include a Description in the upper right corner of the current selected Functional Area level.	Р
Cancel	Cancels the action. Does not make any changes to the database.	Ρ

Action Command	Expected Result & Comment	(P/F)
Edit Record	Allows the user to edit a grid entry after previously adding on another form. This button works correctly on all subareas including: FMEA, What If, Energy Method, HRA, and Severe Events (ALL) for tables under both the form and severe events subcategories.	Ρ
Show Report	Crystal Reports captures the information and displays the user input in report format. All subareas under the Int. Events dropdown menu should include the Functional Area Description for the current selected level in the upper right area of the Report. These subareas include: FMEA, What If, Energy Method, HRA, and Severe Events (ALL) under both the form and severe events subcategories.	Ρ

Action Command	Expected Result & Comment	(P/F)
Refresh	Does nothing for this form. Not part of this SCR, but something that was noticed during testing.	N/A
Edit Record	The results table allows the user to edit a grid entry after previously adding on another form.	Р
Show Report	Crystal Reports captures the information and displays the user input in report format. The report should include a Functional Area Description for the current selected level in the upper right area. Both the involved and noninvolved subcategories should be tested.	Ρ

Action Command	Expected Result & Comment	(P/F)
Functional ID	Command and filtering functions work correctly to view SSCs. Displays SSCs for	Р
	the current Functional ID or for all Functional IDs depending on which is selected.	

Mode of Operation	Command and filtering functions work correctly to view SSCs. Displays SSCs based on the mode of operation selected	P
DOE	Command and filtering functions work correctly to view SSCs. If selected, dispays SSCs if they are Important to Safety by DOE determination.	Ρ
Staff	Command and filtering functions work correctly to view SSCs. If selected, dispays SSCs if they are Important to Safety by Staff determination. Note: if they are important to safety by staff determination, they should also be important by DOE determination. If not, the ITS columns for DOE and Staff will both be highlighted in RED.	P
Close	Closes the "View Selected SSCs" window.	Р
	Go to the System/SSCs dropdown menu and delete all SSCs. Now re-open the Perform./Project Results/Display SSCs to open the View Selected SSCs window. With no SSCs entered in the database, all grids should display properly with no data in them.	Ρ

Action	Expected Result & Comment	(P / F)
Use the scroll bar to scroll to the far right end of the table.	The heading displays correctly for the last column "NoneFilesOnly" on the risk assessment grid.	Р

Action	Expected Result & Comment	(P/F)
Close PCSA Tool using the File/Exit command.	Expected result is that the log will be saved, but the changes to the database will not.	Р
	Close and save all changes using the File/Exit command so that an initial log database will be created. Re-open the demo file in PCSA Tool and close it again. This time, do not save the file. PCSA Tool should exit without prompting for a log entry. Now open PCSA Tool and click on save. Make a few changes (such as entering a new SSC) and exit. Click "No" when prompted to save changes. You should then be prompted to save a log entry. Make the entry and verify with MS Access that the entry was saved upon exit.	

1. SCR No. (Software Developer Assigns): 509			Developer Assigns): 509	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta M)	3. Project No: 20.06002.01.103		
4. As	Affected sessmen	l Software I it Module	Module(s), Description of	Problem(s): Consequence Analysis Modu	le, Safety		
Co wo Sat	Consequence Analysis Module: Develop new Worker form labeled "Worker Dry" to distinguish it from the worker dose for the pool. Safety Assessment Module: Add tables showing the involved and noninvolved worker. Include SSC takeaway						
ana	analysis. Add associated Crystal Reports						
				F	<u>ски, , постала,</u>		
5.	Change	Requested	by:	6. Change Authorized by (Software De	veloper):		
Na Da	me: B. te: Apr	Dasgupta il 5, 2004	/3Am	Name: G. Adams J. A. Date: April 5, 2004			
7.	Descrip	tion of Cha	nge(s) or Problem Resolu	tion (If changes not implemented, please j	justify):		
Th	e descri	ption of cha	nges is included on Attachr	nent 1.			
8.	Implem	ented bv:	1	Date:			
B.	Stead (Adams, T	. Maxwell	July 9, 2004			
9.	Pass	Fail	Description of Test	t			
1	Ŋ		Form controls for bo assessment/takeaway	oth the worker dry form and the performance y analysis forms function correctly.	e		
2	Ø		Command Buttons p	perform their intended function			
3	Ŋ		Crystal Reports capt Information.)	ture the information on the forms. (Note an	ıy missing		
4	Ø		Calculated worker d	ry dose values agree with hand/spreadsheet	calculated values.		
5	Ø		The involved worke Report when above	r category 1 doses are highlighted in both t 5 rem. This includes takeaway analysis.	he form and Crystal		
6	6 ☑ □ The noninvolved worker category 1 doses are highlighted in both the form and Crystal Report when above 100 mrem for dose or 2 mrem/hr for dose rate. This includes taken way analysis forms						
No	ote: Add	ditional testi	ng and comments can be fo	ound on Attachment 2.			
10	Tested	l by:	1141	Date:			
Br	andi L.	Winfrey	my wy	July 29, 2004			
CNW	CNWRA Form TOP-5 (05/2000)						

• *

Changes to Worker Dry Form:

The Worker Dry form was developed, based initially on part of the RSAC Main form, and 5 database tables were added to support it. The tables are based on similar RSAC tables, and are named:

'WkrDry_CrudInventory', 'WkrDry_FuelInformation', 'WkrDry_GeneralInput',

'WkrDry_GroupReleaseFractions', and 'WkrDry_RadionuclideInv'.

This form uses 'frmEditRSACInput' to edit parameters displayed in grids. The Dose Conversion Factors (DCFs) were obtained from EPA Federal guidance reports 11 and 12 (EPA 402-R-93-081 and EPA-520/1-88-020). The DCFs obtained were given in Sv/Bq, and were entered into the database table as-is. They are converted to rem/Ci and saved to separate database fields when the form is loaded. The user can see both values in the grid on the 'Source Term' tab, but the original Sv/Bq units are shown in 'grayed' cells. Likewise, the decay constants are computed from the Half Lives, and saved in a separate database field; the Half Lives are also 'grayed'. The Half Life data (with all values given in seconds) was obtained from Los Alamos National Laboratory's internet site at:

http://t2.lanl.gov/data/decayd.html (address current as of 5/27/04).

Changes to Performance Assessment:

Added Involved Worker and Noninvolved Worker Performance assessment forms. The user enters doses directly on the current level results forms. In addition, the user has the capability of performing takeaway analyses from the worker level forms.

Crystal Report Additions:

Added Crystal Reports to the Performance Assessment forms to include Takeaway Analysis and the Worker Dry form.

a (

Action Command	Expected Result & Comment	(P/F)					
Internal Worker Dose							
Units for Rates	Radio buttons will convert Leakage and Ventilation rates to either m ³ /s or %/day. Only one button can be selected at a time.	Р					
Fuel Type	dio buttons will set the fuel type to BWR, PWR, or User Specified. The type puld change to the value selected. Only one value can be selected at a time.						
Restore Point Estimates	This will return all values on the Internal Worker Dose tab to their default values	Р					
to Defaults	and the Calculated Dose table will close.						
Calculate Doses	Calculated worker dry dose values agree with hand/spreadsheet calculated values.						
	 Notes: Under the Internal Worker Dose tab, set the Units for Rates to %/day, Ventilation Rate of the Worker Room to 2400.0, number of decimal places to display to 8, and Fuel type to User Specified. Enter Inventory (column 1) values under the Source Term tab for the following Radionuclides: Note: User Specified fuel type must be selected on the Internal Worker Dose tab in order to edit this table. Double click on the cell under the Inventory (Ci/Assembyl) column to open it for editing. 	Ρ					
Number of Desired	(see Attachment 3). Will always the number of desimal places displayed in the doop calculations table	D					
Places to Display	Minimum is 2 and Maximum is 8	1					
Source Term	1411111111111115 2 allu 141ax11111111 15 0.						
Restore Point Estimates to Defaults	This will return the Inventory (Ci/Assembly) column back to the default values. If User Specified fuel type is selected under the Internal Worker Dose tab, the default value is 0.00e+00 for all radio nuclides. This button is disabled under the PWR and BWR fuel types.	Р					

Release Fraction by		
Restore Point Estimates	This will return the Release Fraction column back to the default values. The	P
to Defaults	default values are the same for all fuel types.	
Restore All Defaults	Will restore all edited values in all three tabs (Internal Worker Dose, Source Term,	P
	and Release Fraction by Group) to their default values.	
View Notes	View dose calculation data sources and references.	P
Show Report	Show Crystal Reports PCSA Conseq. Worker Dry report with the following sub- reports: Output Doses, Rooms, Fuel, Source Term, and Release Fraction by	Р
	Group. Note: If no calculations have been performed, the report will still be generated, showing all input values, but no Output Doses report will be generated.	
Close	Closes the "frmWorkerDry" window. Closes the entire Consequence Analysis Module window.	Р

: i

Action Command	Expected Result & Comment	(P / F)
Takeaway	Opens the Results Table for Project View SSCIS Case (SSC takeaway analysis) for the Public, Involved Worker or Noninvolved Worker. See Project View SSCIS table (below).	Р
Refresh	Refresh table to show all events instead of just the selected events.	Р
Compliance Assessment	Brings up a Category Search dialog that allows the user to display records for categories 1, 2, or BCFL.	
	Category 1: enter a cutoff for expected number of events and click on calculate. This will open an Event Sequences dialog window that selects event sequences within a specified cutoff for expected number of events. Clicking on the "Calculate" button within this window will generate a table of Event Combinations along with the maximum combination dose, normal operation dose, and aggregate TEDE for the listed combinations.	Ρ
	Clicking on the "Done" button in this window will show a Results table with all Category 1 events.	
	For the public scenario this table has with it, two radio buttons to select between displaying deterministic and probabilistic results.	
	The results for Frequency Weighted, Normal Operation, and Total Dose are displayed for the Public, Involved, and Noninvolved Worker.	
Edit Record	Not selectable. The user is not allowed to edit on this form but could do so if they were instead on the Current Level Results form.	Р
Show Report	Crystal Reports capture the information on the forms.	P
Close	Closes the Results Table – Project View Base Case –	Р
	Public/Involved/Noninvolved Worker window. Closes the entire Performance	
	Assessment Module window.	
Results Table - Pro	oject View SSCIS Case - [Public/Involved/Noninvolved Worl	ker]
Action Command	Expected Result & Comment	(P/F)
SSC Select/Update	Allows SSC selection based on SSCs available in the database. Selection can be made based on Functional ID, Mode of Operation, ITS by DOE and ITS by Staff. When the Edit button is selected, the Update button will institute changes made to	P

	the Additional Information.
SSC Edit	Allows editing of Additional Information for the selected SSC.
Refresh	Updates the Results Table after a Category Search is performed. It repopulates the
	table with default data for all of the Categories.
Category Search	Allows the Results Table to list only results for Category 1, Category 2, or BCFL.
	When Category 1 is selected under Public, a dialog window "Category 1 Event
	Sequences" appears that allows either Point Estimate or Probabilistic Mean Dose Type to be calculated.
	Clicking the Calculate button under Annual Dose due to SSC Failure
	causes the calculation to be performed based on the Dose Type selected as well as the value entered in the text box for the Maximum Dose from
	SSC Failure. If the value entered is greater than 1.40e 02, the Total Dose field is
	• If the value entered is greater than 1.496-02, the Total Dose field is highlighted RED for Point Estimate and Mean Probabilistic results in
	both the Category 1 Event Sequences window and the main Project View SSCIS Case window.
	Under the Involved Worker scenario, when the Maximum Dose is 5 rem or
	greater, it is highlighted red in the Category 1 Event Sequence window, the main Project View window, and in the Crystal Report
	Under the Noninvolved Worker when the Maximum Dose greater than 1.00e-01 rem (e.g., 1.01e-01 rem), it is highlighted red in the Event Sequences window, the Project View window, and the Report.
Edit Record	Allows the user to edit the 'Inclf/SA Calc' :EvSeq Freq' and 'Internal' and
Lan Rocora	'External' Doses columns.
	The noninvolved worker category 1 doses are highlighted in both the form and
	Crystal Report when above 100 mrem for dose or 2 mrem/hr for dose rate. This
	includes takeaway analysis forms.
	The involved worker and public category 1 doses are highlighted in both the form
	and Crystal Report when above 5 rem. This includes takeaway analysis.
	When they are highlighted on the form, they ARE highlighted on the Report.
Show Report	Crystal Reports capture the information on the forms.
Close	Closes the Results Table – Project View Base Case –
	Public/Involved/Noninvolved Worker window. Closes the entire Performance

e s

Values from Excel Spreadsheet WorkerDry.xls

PCSA Tool Calculations for individual radionuclides

Time (t)	Ki	r85	Sr	90	Y	90	Am	241
	Submersion	Inhalation	Submersion	Inhalation	Submersion	Inhalation	Submersion	Inhalation
1.001	2.79597E-05	0.00000E+00	9.88926E-10	3.16781E-01	2.47737E-08	2.04295E-03	7.56991E-09	7.63137E+00
2.201	1.34728E-04	0.00000E+00	4.76530E-09	1.52646E+00	1.18351E-07	9.75971E-03	3.64769E-08	3.67731E+01
3.101	2.66770E-04	0.00000E+00	9.43563E-09	3.02251E+00	2.32835E-07	1.92005E-02	7.22271E-08	7.28135E+01
4.001	4.42984E-04	0.00000E+00	1.56684E-08	5.01903E+00	3.84148E-07	3.16785E-02	1.19927E-07	1.20911E+02
5.201	7.46077E-04	0.00000E+00	2.63889E-08	8.45312E+00	6.41457E-07	5.28972E-02	2.02000E-07	2.03640E+02
6.101	1.02408E-03	0.00000E+00	3.62212E-08	1.16029E+01	8.74835E-07	7.21426E-02	2.77270E-07	2.79521E+02
7.001	1.34516E-03	0.00000E+00	4.75787E-08	1.52408E+01	1.14177E-06	9.41555E-02	3.64204E-07	3.67161E+02
8.000	1.75161E-03	0.00000E+00	6.19554E-08	1.98461E+01	1.47624E-06	1.21737E-01	4.74255E-07	4.78105E+02

Hand Calculations for individual Radionuclides

Time (t)	Kr85		Sr90		Y90		Am241	
	Submersion	Inhalation	Submersion	Inhalation	Submersion	Inhalation	Submersion	Inhalation
1.001	2.79597E-05	0.00000E+00	9.88926E-10	3.16781E-01	2.47737E-08	2.04295E-03	7.56991E-09	7.63137E+00
2.201	1.34728E-04	0.00000E+00	4.76530E-09	1.52646E+00	1.18351E-07	9.75971E-03	3.64769E-08	3.67731E+01
3.101	2.66770E-04	0.00000E+00	9.43563E-09	3.02251E+00	2.32835E-07	1.92005E-02	7.22271E-08	7.28135E+01
4.001	4.42984E-04	0.00000E+00	1.56684E-08	5.01903E+00	3.84148E-07	3.16785E-02	1.19937E-07	1.20911E+02
5.201	7.46077E-04	0.00000E+00	2.63889E-08	8.45312E+00	6.41457E-07	5.28971E-02	2.02000E-07	2.03640E+02
6.101	1.02408E-03	0.00000E+00	3.62219E-08	1.16029E+01	8.74826E-07	7.21426E-02	2.77270E-07	2.79521E+02
7.001	1.34516E-03	0.00000E+00	4.75787E-08	1.52408E+01	1.14178E-06	9.41555E-02	3.64204E-07	3.67161E+02
8.000	1.75161E-03	0.00000E+00	6.19554E-08	1.98461E+01	1.47624E-06	1.21737E-01	4.74255E-07	4.78105E+02

Verification against individual calculations

Time (t)	Ime PCSA Tool			Hand Calculations			Percent Difference		
	Submersion	Inhalation	TOTAL	Submersion	Inhalation	TOTAL	Submersi on	Inhalation	Total
1.001	2.79930E-05	7.95020E+00	7.95023E+00	2.79930E-05	7.95020E+00	7.95023E+00	0.000%	0.000%	0.000%
2.201	1.34887E-04	3.83093E+01	3.83094E+01	1.34887E-04	3.83093E+01	3.83094E+01	0.000%	0.000%	0.000%
3.101	2.67084E-04	7.58552E+01	7.58555E+01	2.67084E-04	7.58552E+01	7.58555E+01	0.000%	0.000%	0.000%
4.001	4.43503E-04	1.25961E+02	1.25962E+02	4.43503E-04	1.25962E+02	1.25962E+02	0.000%	0.000%	0.000%
5.201	7.46946E-04	2.12146E+02	2.12147E+02	7.46946E-04	2.12146E+02	2.12147E+02	0.000%	0.000%	0.000%
6.101	1.02527E-03	2.91196E+02	2.91197E+02	1.02527E-03	2.91196E+02	2.91197E+02	0.000%	0.000%	0.000%
7.001	1.34671E-03	3.82496E+02	3.82497E+02	1.34671E-03	3.82496E+02	3.82497E+02	0.000%	0.000%	0.000%
8.000	1.75362E-03	4.98073E+02	4.98075E+02	1.75362E-03	4.98073E+02	4.98075E+02	0.000%	0.000%	0.000%

.

1. SCR No. (Software De 510	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta P)	3. Project No: 20.06002.01.103				
4. Affected Software Module(s), Description of Problem(s): Consequence Analysis Module (RSAC); frmRSAC_Main, frmReadRSAC, frmLaunchRSAC, mdlYMPModule1, MDI_PCSA_Frm1, new form frmRSAC_WkrInput.							
Add Downwind Worker D	ose Model to the PC	SA Tool's RSAC interface.					
a.							
5. Change Requested b Name: G. Adams	y: Y:	6. Change Authorized by (Software Name: G. Adams	e Developer):				
Date: June 17, 2004		Date: June 17, 2004					
7. Description of Chang	e(s) or Problem Re	esolution (<i>If changes not implemente</i>	ed, please justify):				
Added new module frmR according to the recomm frmReadRSAC, frmLaund mode of operation. Added directly, bypassing 'PCSA for worker mode (RSAC values normally returned) bypass Ingestion, Inhalat Doses and dose totals ar Added Crystal Report to Worker Dose calculations	Added new module frmRSAC_WkrInput to 'walk' the user through to the proper calculation mode, according to the recommended flow from Norm Eisenberg. Modified code in frmRSAC_Main, frmReadRSAC, frmLaunchRSAC, mdlYMPModule1, and MDI_PCSA_Frm1 to accommodate the new mode of operation. Added a new batch file, 'RSAC6wkr.bat', in the \Tools directory, to run RSAC directly, bypassing 'PCSAProb.exe', which returns an error message since there is no Ingestion dose for worker mode (RSAC substitutes a single line with "NO DOSE CALCULATED" for the set of dose values normally returned). New subroutines were added to read RSAC's output file directly, and bypass Ingestion, Inhalation, or Ground Surface data segments for which no dose was calculated. Doses and dose totals are saved to the 'WkrRSAC_OUTPUT' table.						
8 Implemented by:		Date:					
De Stead, G. Adams	V	August 5, 2004					
9. Pass Fail	Description of Te	st					
	Manipulate the RS	AC controls in accordance with the step	os identified in				
	Attachment 1, and	verify the operation of the form.					
2 🗹 🗖	Verify that a sampl wake zone, and ca correctly scaled, ar	e ot the doses generated for the displa wity zone are being retrieved from the r nd displayed.	cement zone, sac output file, are				
3 🗹 🗆	Verify that RSAC c and retrieved. Ver	an be run for the Public. Verify that rur ify that rur be changed.	ns can be saved				
Note: Additional testing and comments can be found on Attachment 2.							
10. Tested by: Troy Ma	xwell	Date: August 6, 2004					
2NWRA Form TOP-5 (05/2000)							

£

1) Verify that the "RSAC Worker Dose Options" form is loaded by selecting 'Conseq. -> Worker Dose -> RSAC from the main menu.

2) Enter '100' for Stack Height, and '30' for Building Height. Click 'Next'. Verify a new frame is displayed to enter the Receptor Distance. Then enter '75' for Receptor Distance, and click 'Next'. Verify that an error message box is displayed.

3) Click 'OK' on the error message box, and change the value for Receptor Distance to '1000'. Verify that a new frame is displayed, with "Receptor is in the Displacement Zone".

4) Click 'Next'; verify that the "RSAC Worker Dose Options" form disappears, and the "RSAC: New or Modified Analysis" form appears showing the "RSAC Input" and "Fuel Selection / Assemblies Breached" tabs.

5) Click on the "Meteorological Data" tab, and verify that the value for "Stack release height (m)" is 100.0 (as entered earlier) and that its cell background is 'grayed'. Verfy that the value for "Downwind distance (m)" is 1000.0 (as entered earlier) and that its cell background is 'grayed'. Verify that the cell backgrounds for "Building height" and "Building width" are also 'grayed'.

6) Click 'Perform Analysis'; verify that the form disappears, RSAC runs, and (after a several seconds) the form reappears with the "RSAC Output" tab shown, with the output data.
۱

Verified the Worker Dry form performs the steps indicated on attachment 1. The error message displayed for step 2 is: "The Receptor Distance is less than or equal to 2.5 times the Building Height. This case is invalid." In step 3, after 1000 is entered for the Receptor Distance, the next frame displays, "Receptor is in the Displacement Zone." Verified the meteorological data tab appears as required in step 5. After performing an analysis, the RSAC Output doses are displayed.

On the summary tab, the following values were observed: Inhalation: 9.38e-18 Ground surface: 3.38e-19 Submersion: 2.39e-7 TEDE: 2.39e-7

In the RSAC6 output file, the following values were observed: Inhalation: 9.38e-18 Ground surface: 3.38e-19 Submersion: 2.39e-7 TEDE: 2.39e-7

The results from the file compare to the results displayed on the summary tab.

Performed a series of tests and compared dose results to spreadsheet calculations. The following summarizes the tests and test results:

Displacement Zone	
Building Width (Wb)	150
Building Height (Hb)	34
Stack Height (Hs)	86
Receptor Location (X)	500

Line 5001 under Meteorological Data in RSAC output file includes the 86 m stack height

RSAC Dose	
Inhalation	8.10E-30
Ground Surface	0.00E+00
Air Submersion	3.06E-07
Total	3.06E-07

The PCSA Tool displays the above values under Summary Results

Checked doses from the output file and compared to the PCSA Tool Display

	output	display
H3 inhalation	7.29E-30	7.29E-30
CEDE inhalation	8.10E-30	8.10E-30

Wake Zone	
Building Width (Wb)	150
Building Height (Hb)	34
Stack Height (Hs)	34
Receptor Location (X)	500
Area Building Ab Qb	5100 178.5357

1

.

Since the receptor location is greater than Qb, wake zone Chi/Q 7.34E-04 sigma z 7.92E+00 sigma zmod 41.06185 Fw 1.93E-01

Check of doses displayed by PCSA Tool

TEDE Inhalation Bone Sur Inhalation Pu240	RSAC 3.41E-04 3.06E-04 1.41E-08	Scaled 6.58E-05 5.90E-05 2.72E-09	Display 6.56E-05 5.90E-05 2.72E-09	Percentage Difference -0.24% -0.01% 0.04%
Cavity Zone on Building	in Stack			
Building Width (Wb)		150		
Building Height (Hb)		34		
Stack Height (Hs)		34		
Receptor Location (X)		1		
Diameter of Stack		0.5		
3 * Diameter of Stack		1.5		
Flowrate through vent	[m^3/s]	11.32674		
Area Building Ab		5100		
Qb		178.5357		
Since the receptor loca	ation is great	ter than Qb, wa	ake zone	
Chi/Q	-	1.12E-02		
Fv		7.92E+00		

Check of doses displayed by PCSA Tool

	RSAC	Scaled	Display	Percentage Difference
TEDE	5.15E-03	4.08E-02	4.08E-02	0.05%
Inhalation CEDE	4.98E-03	3.94E-02	3.94E-02	-0.08%
Ground Surface lungs	9.47E-05	7.50E-04	7.50E-04	0.02%
Ground Surface Pb212	1.40E-09	1.11E-08	1.11E-08	0.13%

7.92E+00

Cavity Zone on Building Av	vay from Stack
Building Width (Wb)	150
Building Height (Hb)	34
Stack Height (Hs)	34
Wind Speed (Ua)	3
Receptor Location (X)	50
Diameter of Stack	0.5
3 * Diameter of Stack	1.5
[m^3/s]	11.32674
Area Building Ab	5100
Qb	178.5357
Since the receptor location	n is greater than Qt
Chi/Q	1 12E-02

•

Since the receptor location is greater than Qb, wake zoneChi/Q1.12E-02Fs3.59E-01Fv7.92E+00

Check of doses displayed by PCSA Tool

TEDE Inhalation CEDE Inhalation R Marrow Ground Surface Co60	RSAC 5.15E-03 4.98E-03 4.56E-03 1.52E-05	Scaled 1.85E-03 1.79E-03 1.64E-03 5.45E-06	Display 1.85E-03 1.79E-03 1.64E-03 5.45E-06	Percentage Difference 0.13% 0.19% 0.25% -0.05%
Covity Zono not on Ruilding			0.102.00	0.0070
Building Midth (M/b)	450			
Building Height (Ub)	150			
Stock Height (He)	34			
Mind Speed (Up)	34			
wind Speed (Oa)	3			
Receptor Location (X) Flowrate through vent	50			
[m^3/s]	11.32674			
Area Building Ab	5100			
Qb	178.5357			
Lb	34			
Since the receptor location is	greater than	Qb, wake zone		
Chi/Q	1.12E-02			
Fc	2.80E-01			
Check of doses displayed by	PCSA Tool			
				Percentage

	RSAC	Scaled	Display	Difference
TEDE	5.15E-03	1.44E-03	1.44E-03	-0.10%
Inhalation CEDE	4.98E-03	1.39E-03	1.39E-03	-0.27%

Ground Surface B Surface	4.47E-04	1.25E-04	1.25E-04	-0.09%
Total Pu239	1.29E-07	3.61E-08	3.61E-08	-0.01%

-1

For all of the tests shown above, the calculated (scaled) dose values agreed with the displayed value to within 1 percent and therefore these tests passed.

Also ran tests with RSAC for the public. Verified that RSAC runs could be saved and retrieved. Changed average wind velocity on the meteorological tab and verified that the changed value was in the output file.

· •

¢: •

1.	SCR No.	(<i>Software De</i> 511	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta N)	3. Project No: 20.06002.01.103	
4. pc	Affected sa_totrisk	Software Mo (.f, and sort.f,	odule(s), Descriptio project tree module,	n of Problem(s): pcsa_prob.f, pcsa_ie consequence analysis module	etccdf.f,	
Th ore	e pcsa_p der to rele	rob.f, pcsa_ie ease the PCS	etccdf.f, and pcsa_to A Tool software, the	trisk.f files contain a proprietary sort rou sort routine needs to be redeveloped ir	utine, sortqr. In hternally.	
Re	emove ref	erences to th	e SysDescription tab	le that is no longer in the database.		
5. Na Da	Change ame: G. A ate: July	Requested b Adams bA	y: door	6. Change Authorized by (Software Name: G. Adams) Adam/ Date: July 19, 2004	e Developer):	
7.	Descript	ion of Chang	ge(s) or Problem Re	esolution (If changes not implemente	d, please justify):	
Re pe pla Re an	eplaced si rformed a aced in file emoved re alysis mo	ubroutine sort a quick sort, tl e sort.f and is eferences to t dule.	tqr with subroutine so he sort_index routine used by each of the he SysDescription ta	ort_index developed internally. The sor e performs a sequential sort. Subroutine three other FORTRAN modules.	tqr routine e sort_index was consequence	
8.	Impleme	nted by:		Date:		
G.	Adams	7 P gam		July 19, 2004		
9.	Pass	Fail	Description of Te	st		
1	 Verify the pcsa_prob module generates equivalent output in version BetaN I I I I I I I I I I I I I I I I I I I					
2	Ø		Verify the pcsa_iet of the PCSA Tool v (prior to the change	ccdf module generates equivalent outp when compared to the output generated e).	ut in version BetaN I in version BetaK	
3	3 ☑ □ Verify the pcsa_totrisk module generates equivalent output in version BetaN of the PCSA Tool when compared to the output generated in version BetaK (prior to the change)					
4	4 ☑ □ Verify that a new database can be created and a new project tree established. Verify that an RSAC run can be saved and restored. These two areas of the database formerly referenced the SysDescription table.					
No	Note: Additional testing and comments can be found on Attachment 1.					
	1					
10	. Tested	by: Troy Ma	xwell LML	Date: July 29, 2004		
CNW	RA Form TOP	P-5 (05/2000)				
	/					

pcsa_prob: Verified that the output files generated by module pcsa_prob through a 100-realization test run of the PCSA Tool consequence module were equivalent between version BetaN and BetaK. The following files were checked: allccdf.dat, ccdfcomb.dat, pcsastat.out, and pcsastat.txt. The only difference between version BetaK and BetaN for files allccdf.dat and ccdfcomb.dat was the date/time stamp in the files. The files pcsastat.out and pcsastat.txt differ internally in the realization selected to represent the 50th percentile. This occurs because more than one consequence module realization generated the same value. The values for the 50th percentile are the same between version BetaK and BetaN even though the realization selected differs; therefore, the files are equivalent between version BetaK and BetaN.

pcsa_ietccdf: Verified that the output files generated by module pcsa_ietccdf were equivalent between version BetaN and BetaK. This test was conducted using the pcsademo database which is the same database in version BetaN and BetaK in which a mean dose calculation was performed. The following files were checked: allccdf.dat and pcsastat.txt. The file pcsastat.txt is identical between the two versions. The only difference in file allccdf.dat between the two versions is the date/time stamp in the file. Therefore, the files are equivalent between version BetaK and BetaN.

pcsa_totrisk: Verified that the output files generated by module pcsa_totrisk were equivalent between version BetaN and BetaK. This test was conducted using the pcsademo database which is the same database in version BetaN and BetaK. A probabilistic risk assessment was performed. The following files were checked: pcsastat.txt, totrisk.out, and trallccdf.dat. The pcsastat.txt and totrisk.out files are identical between version BetaK and BetaN. The trallccdf.dat files differ only in the date/time stamp. Therefore, the files are equivalent between version BetaK and BetaN.

A new database, pcsa_test, was created. A new project tree could be created for this database. A deterministic RSAC run could be saved and restored.

<u>ب</u> ب

1. SCR No. (Software De 512	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta P)	3. Project No: 20.06002.01.103			
4. Affected Software Mo	odule(s), Descriptio	on of Problem(s): performance assess	ment module			
The takeaway analysis C Modify the Crystal Repor	rystal Report does n t to show the scenari	ot display the scenario (probabilistic or io.	point estimate).			
If a Crystal Report is exported after a risk assessment is performed, a subsequent risk assessment could not be done because the default drive is changed when the Crystal Report is exported.						
5. Change Requested b Name: G. Adams	y: y:	6. Change Authorized by (Software Name: G. Adams	Developer):			
7. Description of Chang	je(s) or Problem Re	solution (If changes not implemente	d, please justify):			
Added the scenario to the	e performance asses	ssment takeaway analysis Crystal Repo	rt.			
Modified the software to issue a Change Drive (ChDrive) command prior to issuing a Change Directory (ChDir) command. This ensures that the default drive is correct before a directory is changed.						
8. Implemented by: G. Adams		Date: August 4, 2004				
9. Pass Fail	Description of Te	st				
1 🗹 🗆	1 I verify that the Crystal Report for performance assessment takeaway					
2 Ø D Verify that a risk assessment can be performed after exporting a Crystal Report.						
Note: Additional testing and comments can be found on Attachment 1.						
10. Tested by: Troy Max	woth the Man	Date: August 6, 2004				
;NWHA Form TOP-5 (05/2000)						

·

ţ

The performance assessment takeaway analysis Crystal Report correctly displayed the "Point Estimate" scenario for the deterministic assessment and the "Probabilistic, Mean" scenario for the probabilistic assessment.

Verified that a Crystal Report could be exported (saved to a temp directory) and afterwards, a risk assessment could be performed.

1.	SCR No.	(<i>Software De</i> 513	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta Q)	3. Project No: 20.06002.01.103		
4. , fre	4. Affected Software Module(s), Description of Problem(s): performance assessment module, frequency analysis module, software systems, help menu, about screen						
Pe un	rformand der even	e Assessmer t scenarios m	nt Module: Need to in arked to be included	nclude only those event sequences that for performance assessment	are included		
Fre per (P,	equency riods and W, B)	Analysis Mod I uncertainty,	ule: Modify the Initiat Modify the Event Sec	ing Event Crystal Report to correct the quence Crystal Report to add the Applic	font for time ability of the Event		
So an	ftware Sy d descrip	ystems: Add a tion and ensu	Crystal Report for S ire that they are uniq	Software Systems, Correct the form to r jue	equire a system id		
Fo	r the help	o menu, refer	to the User's Guide i	instead of menu help			
Fo	r the Abc	out box, updat	e the contact informa	ation to include Robert Johnson and Ge	eorge Adams		
5. Na Da	Change me: G. /	Requested b Adams 5000 Ist 6, 2004	y: mue	6. Change Authorized by (Software Name: G. Adams b Manu Date: August 6, 2004	• Developer):		
7.	Descript	ion of Chang	je(s) or Problem Re	esolution (If changes not implemente	ed, please justify):		
Mc inc	dified the	e performance nt sequences	e assessment modul for event scenarios	le results tables and associated Crystal marked to be included for performance	Reports to only assessment.		
Up	dated the	e Initiating Ev	ent and Event Seque	ences Crystal Reports.			
Ad de	ded a So scription	oftware Syster and ensure th	ns Crystal Report an nat they are unique.	nd corrected the form to require a system	n id and system		
Th	e help m	enu refers to	the User's Guide and	d the About Box has the new contact int	ormation		
8.	Impleme	nted by:		Date:			
G.	Adams '	Pagens		August 10, 2004			
9.	Pass	Fail	Description of Te	st			
1			Only event sequen performance asses	ices under event scenarios marked for i ssment are included in the results table	nclusion in s.		
2	V		Initiating Event and	d Event Sequences reports have been u	updated.		
3	Ŋ	۵	Software Systems any missing inform are required on the	Crystal report reflects screen information ation. Also unique System IDs and System Software Systems form.	on entered, note stem Descriptions		
4			The help menu refe contact information	ers to the User's Guide and the About E	3ox has the new		
No	te: Addi	tional testing a	and comments can b	be found on Attachment 1.			
10	Tested	by: Troy Ma	xwell	Date: August 10, 2004			
CNWF	RA Form TO	P-5 (05/2000)					

TEST1:

.

Entered the following Event Sequences and verified that the Public and Worker Results Tables displayed the event sequences and calculated the correct combined frequencyweighted sums when different event scenarios were marked to be included for performance assessment.

Functional ID	Event Scenario	Initiating Event	Event	Event
	ID	Frequency	Sequence ID	Sequence
				Frequency
A.1	1	0.01	1	0.2
			2	0.3
B.1	2	0.015	3	0.1
B.1	3	0.015	4	0.4

Initially, all event scenarios are marked to be included for frequency analysis. The following is a comparison between the expected frequency-weighted sums and the actual values for the public, involved worker, and noninvolved worker.

Public						
Event			Dose Pt	Frequency	Dose	Frequency
Sequence		Frequency	Est	* Dose	Mean	* Dose
	1	0.2	2.76E-05	5.52E-06	5.00E-06	1.00E-06
	2	0.3	7.07E-05	2.12E-05	1.28E-05	3.84E-06
	3	0.1	2.76E-05	2.76E-06	5.00E-06	5.00E-07
	4	0.4	7.07E-05	2.83E-05	1.28E-05	5.12E-06
Frequency- Weighted						
Sum				5.78E-05		1.05E-05
PCSA Tool				5.78E-05		1.05E-05

Involved and Non-Involved Worker

Event				Frequency
Sequence		Frequency	TEDE	* Dose
	1	0.2	7.00E-01	1.40E-01
	2	0.3	3.00E-01	9.00E-02
	3	0.1	7.00E-01	7.00E-02
	4	0.4	3.00E-01	1.20E-01
Frequency-				
Weighted				
Sum				4.20E-01
PCSA Tool				4.20E-01

Event Scenario 1 is then marked as no longer included for performance assessment and the following is a comparison between the expected frequency-weighted sums and the actual values for the public, involved worker, and non-involved worker.

Without Eve Public	ent S	Scenario 1				
Event		-		Frequency	Dose	Frequency *
Sequence		Frequency	Dose Pt Est	* Dose	Mean	Dose
	3	0.1	2.76E-05	2.76E-06	5.00E-06	5.00E-07
	4	0.4	7.07E-05	2.83E-05	1.28E-05	5.12E-06
Frequency- Weighted						
Sum				3.10E-05	5.00E-06	5.62E-06
PCSA Tool				3.10E-05	1.28E-05	5.62E-06
Involved and	d N	on-Involved V	Vorker			
Event				Frequency		
Sequence		Frequency	TEDE	* Dose		
•	3	0.1	7.00E-01	7.00E-02		
	4	0.4	3.00E-01	1.20E-01		
Frequency- Weighted						
Sum				1.90E-01		
PCSA Tool				1.90E-01		

The current level results, performance assessment, combinations, and takeaway analysis forms and Crystal Reports no longer show event sequences 1 and 2 when event scenario 1 is no longer marked to be included in performance assessment as required.

TEST2:

The Initiating Event Crystal Report shows the correct fonts for uncertainty and time periods, the Event Sequences Crystal Report shows the Applicability of the Event as required.

TEST3:

The Software Systems Crystal Report reflects the information entered on the screen. No missing information is noted. Also, unique System IDs and System Descriptions (Names) were required.

TEST4:

The help menu refers to the User's Guide even though the User's Guide is not yet included and the About Box has updated contact information for George Adams and Robert Johnson.

1. SCR No. (Software Do 514	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta R)	3. Project No: 20.06002.01.103				
4. Affected Software Module(s), Description of Problem(s): Hazard Analysis Module (WhatIf, Energy Method), Frequency Analysis Module (Fault Tree, Event Tree), Images, Failure Probability, Software Reliability							
 Change the tab order to flow left to right top to bottom on text and memo fields on the Whatlf, Energy Method, Fault Tree, Event Tree and software reliability forms. Add a set of new images to the database. On the failure probability form, do not require the user to enter a letter id. Also remove data associated with deleted references. On the downwind worker dose form, when the worker is on the same surface of the building as the stack, modify the frame captions and notes to indicate this as well as whether the worker is in or near the stack flow. On the system description waste characterization tab and fire hazards tab, modify text fields to have a maximum length of 15 characters. 							
5. Change Requested to Name: G. Adams	y: Dre	6. Change Authorized by (Software Name: G. Adams) And Adams Date: August 11, 2004	• Developer):				
7. Description of Chang	ge(s) or Problem Re	solution (If changes not implemente	d, please justify):				
Modified the tab order or images to the database, removed data associated Added new images to the variable row heights bec. Modified the downwind v building as the stack and Modified the system des	Modified the tab order on the WhatIF, Energy Method, Fault Tree, and Event Tree forms, added images to the database, modified the failure probability form to no longer require a letter id and removed data associated with deleted references. Added new images to the database identified in Attachment 1. Also modified the images grids to allow variable row heights because some of the captions for the images were long. Modified the downwind worker dose form to reflect that the worker is on the same surface of the building as the stack and is in or near the stack flow.						
8. Implemented by:		Date:					
G. Adams BILION	Г	August 16, 2004					
9. Pass Fail	Description of Te	st	uoro roliobility toyt				
1 🗹 🗆	and memo tab ord	er flows left to right and top to bottom.	are reliability text				
2 🗹 🗆	Images can be acc directory. Long im	essed from the database and associat age captions are visible.	ed drawing				
3 🗹 🗆	Failure probability the failure probabil removed reference	form no longer requires a letter id. Also ity database shows that data does not a es.	a check of data in appear for				
4 🗹 🗆	When the worker is on the same surface of the building as the stack, the frame caption and notes reflect this as well as whether the worker is in or near the stack flow.						
5 🗹 🗆	Text fields on the v 15 characters.	vaste characterization and fire hazards	tabs are limited to				
Note: Additional testing	and comments can b	e found on Attachment 2.					
10. Tested by: Troy Ma	xwell GML	Date: August 16, 2004					

CNWRA Form TOP-5 (05/2000)

ŧ

The following images were added for the underground operations:

- 1) u1.jpg, Locomotives and Waste Package Transporter Approaching the North Portal
- 2) u2.jpg, Waste Package Transportation Equipment Traveling Along Main Drift
- 3) u3.jpg, Waste Package Transporter and Its Components
- 4) u4.gif, Access Main Tunnel, Turnout, and Emplacement Drift Layout
- 5) u5.jpg, Locomotive Operations at Emplacement Drift Turnout
- 6) u6.jpg, Waste Package Emplacement Sequence in Drift, #1
- 7) u7.jpg, Waste Package Emplacement Sequence in Drift, #2
- 8) u8.jpg, Waste Package Emplacement Sequence in Drift, #3
- 9) u9.jpg, Docked Transporter with Pallet and Waste Package on Transporter's Open Deck and Emplacement Gantry Approaching the Docking Area for Pickup
- 10) u10.jpg, Bottom/Side Lift Emplacement Gantry End View within Emplacement Drift
- 11) u11.jpg, Bottom/Side Lift Emplacement Gantry Perspective View

TEST1:

On the Whatlf, Energy Method, Fault Tree, and Event Tree forms, verified the tab order for text and memo fields from left to right and top to bottom.

TEST2:

New images were added to the database. Verified the images identified in Attachment 1 could be viewed. Verified the long captions for the images were visible.

TEST3:

Verified the failure probability form no longer requires a letter id. Also opened the probprac.mdb file and within the Probability and Sheet1 table, verified that where references no longer existed, data was also no longer present.

TEST4:

Verified that when the worker is on the same surface of the building as the stack that the frame caption and notes reflect this and they reflect that the worker is in or near the stack flow. When the receptor distance was within 3 * the stack diameter, the worker was in the stack flow; otherwise, the worker was near the stack flow.

TEST5:

Verified that on the Waste Characterization tab that Material Type, Material Container, and Material Amount were limited to 15 characters. Verified on the Fire Hazards tab that presence of combustible material was limited to 15 characters.

4

1. SCR No. (<i>Software De</i> 531	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta S)	3. Project No: 20.06002.01.103				
4. Affected Software Me	4. Affected Software Module(s), Description of Problem(s): SAPHIRE software						
The SAPHIRE standalone software is invoked by the PCSA Tool. SAPHIRE needs to be upgraded from version 6.70 to version 6.80.							
		Γ					
5. Change Requested b Name: G. Adams Date: August 16, 2004	N drown	6. Change Authorized by (Software Name: G. Adams J. North Date: August 16, 2004	e Developer):				
7. Description of Chang	ge(s) or Problem Re	esolution (If changes not implemente	ed, please justify):				
SAPHIRE software was directory was also upgra	upgraded from versic ded to contain the ve	on 6.70 to version 6.80. The SaphirePr ersion 6.80 demo project.	ojects\Demo				
		· · · · · · · · · · · · · · · · · · ·					
G. Adams	\	August 17, 2004					
9. Pass Fail	Description of Te	st					
1 🗹 🗆	The same Event T YMP1, and Ymp1_ BetaR) and version	ree and Fault Tree Graphics are displa ATS1 projects between version 6.70 (F n 6.80 (PCSA Tool Version BetaS).	yed for the Demo, PCSA Tool Version				
Note: Additional testing and comments can be found on Attachment 1							
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing	and comments can b	be found on Attachment 1.					
Note: Additional testing 10. Tested by: Troy Ma	and comments can b	be found on Attachment 1. Date: August 18, 2004					

-

Within SAPHIRE, from the help menu, verified that version 6.80 was being tested in version BetaS and compared to version 6.70 of BetaR.

Verified the following graphics appeared the same between version BetaR and BetaS for projects Demo, YMP1, and Ymp1_ATS1:

<u>Demo:</u> Event Tree – LOSP Fault Tree – CCS Fault Tree – ECS

<u>YMP1:</u> Fault Tree – YOKE-DROP

<u>Ymp1_ATS1:</u> Event Tree – CASK-DROP-CD1

.

1. SCR No. (Software Do 537	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta T)	3. Project No: 20.06002.01.103				
4. Affected Software Module(s), Description of Problem(s): SSC Data form, System Log, System Description, Worker Dry, Normal Operation Dose							
 If no SSC is selected after a subsequent event is entered, then it is not possible to add a new SSC on the SSC Data form. If a new project is opened or created when one is already open, the System Log should be displayed when leaving the current project. When the next project is opened, the System Log should be displayed for this project. On the System Description form, for the Operation Sequence tab, if no records exist for this tab, then the Edit Record button is not visible. In addition for the Function tab and the Human Actions tab, the Edit Record button should instead be labeled 'Edit.' On the worker dry form, if point estimates are restored after doses are calculated or if a different release fraction source is selected, then the doses displayed may not be correct for the input to the input to the input to the selected. 							
5. Change Requested b Name: G. Adams A Date: August 30, 2004	y: d one	6. Change Authorized by (Software Name: G. Adams), Adam) Date: August 30, 2004	Developer):				
7. Description of Chang	je(s) or Problem Re	solution (If changes not implemente	d, please justify):				
 identifiers. 2) When a project is alre System Log/System Log project is subsequently o 3) For the System Descri regardless of whether or the Human Actions tab, o 4) Modified the Worker D defaults and after a releated 	 Corrected the SSC Data form to no longer search for an empty string when comparing SSC identifiers. When a project is already open and the user tries to open a new project or create a new project, the System Log/System Log Entry forms are displayed on leaving the existing project. When the next project is subsequently opened, its System Log is displayed if there are any records to display. For the System Description form, Operation Sequence tab, made the Edit Record button visible regardless of whether or not operation sequence records existed. In addition, for the Function tab and the Human Actions tab, changed the Edit Record button to instead display 'Edit.' Modified the Worker Dry form to clear output doses after the user restores point estimates to defend the addition of the set of the set						
8. Implemented by:		Date:					
G. Adams Juli hans		September 2, 2004					
9. Pass Fail	SSCs may be adde	st ad on the SSC Data form after a subser	uent event has				
1 🗹 🗆	been added and no	SSC is selected for the subsequent ev	/ent.				
2 🗹 🗆	Current project to o appears when the rexist.	ystem Log Entry forms appear when the pen or create a new project. The Systen next project is subsequently opened if a	e user leaves the em Log form iny log entries				
3 🗹 🗆	For the System Description form, Operation Sequence tab, the Edit Record button appears whether or not operation sequence records exist. The Function tab and Human Actions tab display Edit buttons where previously Edit Record buttons appeared.						
4 🗹 🗆	Calculated doses a are restored to defa	re cleared on the Worker Dry form whe aults and a release fraction source is se	n point estimates				
Note: Additional testing a	and comments can b	e jound on Attachment 1.					
10. Tested by: Troy Max	well 5 11	Date: September 3, 2004					
CNWRA Form TOP-5 (05/2000)							

Test 1:

Added a subsequent event to an event scenario within the PCSA Demo database. Did not select an SSC for this subsequent event. Closed the form and opened the SSC Data form. Verified that an SSC could be added on the SSC Data form and afterwards, this new SSC could be selected for the added subsequent event.

Test 2:

Evaluated a series of scenarios to verify the operation of the System Log/System Log Entry forms.

Scenario 1: Verified display of System Log/System Log Entry forms Opened the PCSA Demo database with no log entries. Verified that the PCSA Tool opened without displaying the System Log. Made no changes and chose to create a new database named test1. Chose not to save on exit and verified that on exiting, the System Log/System Log Entry forms were not displayed. Within the new database, built a project tree. Chose to exit, and when prompted, saved changes and exited. Verified that the System Log/System Log Entry forms displayed on exiting and entered a log entry test message.

Scenario 2: Verified that the System Log/System Log Entry is updated when a new database is opened and that the intermediate saves from the existing database are retained.

Opened the test1 database from the previous scenario. Verified that the System Log displayed when the database was opened since log entries were present. Modified the database by adding an initiating event. Saved the changes. Modified the database again by adding an event scenario. Chose to open the PCSA Demo database. When prompted to save the test1 database, chose not to save. Verified that the System Log/System Log Entry form appears. Made a new test entry in the System Log. After the PCSA Demo database opened, chose to open the test1 database. Verified that the System Log displayed with the log entries previously entered. Verified that the initiating event was present but the event scenario was not since only an intermediate save was performed prior to opening the PCSA Demo database. Exited the tool without saving. Verified that no System Log/System Log Entry form appeared.

Scenario 3: Verified that the System Log and other database changes are saved when a new database is opened and the existing database is saved on exit. Opened the test1 database from the previous scenario. Verified the System Log displayed with the log entries from the previous scenario. Modified the database by adding an event scenario. Chose to open the PCSA Demo database. When prompted to save the test1 database, chose to save. Verified that the System Log/System Log Entry form appears. Made a new test entry in the System Log. After the PCSA Demo database opened, chose to open the test1 database. Verified that the System Log displayed with the log entries previously entered. Verified that the event scenario entered and saved was also present. Exited the tool without saving. Verified that no System Log/System Log Entry form appeared.

<u>Test 3:</u>

۰.

Verified on the System Description form, Operation Sequence tab, that the Edit Record button displayed when no operation sequence records were in the database and one record was in the database. Without records, the Edit Record button was disabled and with a record, the Edit Record button was enabled.

Test 4:

Verified on the Worker Dry form that after doses are calculated, if the user chooses to Restore All Defaults or Restore Point Estimates to Defaults from any of the three tabs that the calculated doses are no longer displayed. Also verified that after doses are calculated, if the user selects a release fraction source, the calculated doses are no longer displayed.

1.	SCR No	. (<i>Software D</i> 539	eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta U)	3. Project No: 20.06002.01.103							
4. Cr	Affected ystal Re	I Software M port, and Fau	odule(s), Descriptio It Tree Crystal Report	n of Problem(s): SSC Data Crystal R	eport, Event Tree							
	1) Data 2) The Ev 3) The	for the 'Addi 'Saphire Data ent Tree Crys 'Saphire Data	tional Information' fiel a Path' and 'Include fo stal Report. a Path' field does not	d does not appear on the SSC Data Cr or Performance Assessment' fields do r appear on the Fault Tree Crystal Repor	ystal Report. not appear on the t.							
5. Na Da	5. Change Requested by: Name: G. Adams Date: September 7, 20046. Change Authorized by (Software Developer): Name: G. Adams Date: September 7, 2004											
7.	Descrip	tion of Chan	ae(s) or Problem Re	solution (<i>If changes not implemente</i>	d. please justify):							
	2) Add Tri 3) Add	ed the 'Saphi ed the 'Saphi	re Data Path' field to t	he Fault Tree Crystal Report.								
8.	Implem	ented by:		Date:								
G.	Adams			September 8, 2004								
9.	Pass	Fail	Description of Te	st								
1	N		Verify that data ent Crystal Report.	ered for Additional Information appears	on the SSC Data							
2	V		Verify that data ent Performance Asse	ered for 'Saphire Data Path' and 'Incluc ssment' appear on the Event Tree Crys	le for Ital Report.							
3	V		Verify that data ent Crystal Report.	ered for 'Saphire Data Path' appears of	n the Fault Tree							
No	ote: none)										
10	. Tested	by: Troy Ma	axwell SML	Date: September 9, 2004								

Developer Assigns): 0	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta V)	3. Project No: 20.06002.01.103				
4. Affected Software Module(s), Description of Problem(s): SSC Data Form and Crystal Report						
 The SSC Design Bases and Design Criteria Crystal Report displays "Functions, Hazards, Initiating Events, and Event Tree Subsequent Events" for multiple SSC IDs. It should display this information for only one SSC ID. When editing an SSC, the SSC ID text field should not be enabled when design bases and design criteria exist for an SSC; otherwise, the link between the former SSC ID and design bases and design criteria is broken. The Design Bases and Design Criteria tab should not be enabled when an SSC is being added or edited from the General tab. 						
by: Duy Adam 2004	6. Change Authorized by (Software Name: G. Adams) Mon Date: September 10, 2004	Developer):				
nge(s) or Problem Re	esolution (If changes not implemente	d, please justify):				
 Updated the SSC Design Bases and Design Criteria Crystal Report to match SSC ID when retrieving records from the database for "Functions, Hazards, Initiating Events, and Event Tree Subsequent Events." For the case where an SSC is being edited, modified the SSC Data form to no longer enable the SSC ID text field when design bases and design criteria exist for the SSC. Disabled the Design Bases and Design Criteria tab when an SSC is being added or edited. 						
	Date:	Carlo Serie				
mable	September 10, 2004					
Description of Te	st					
1 ☑ 1 ☑ □ □ Verify that when "Functions, Hazards, Initiating Events, or Event Tree Subsequent Events" are entered for multiple SSCs that the Design Bases and Design Criteria Crystal Report shows only the information that applies to the applicable 200						
Subsequent Events and Design Criteria the applicable SSC	s" are entered for multiple SSCs that the a Crystal Report shows only the informa	Event Tree e Design Bases tion that applies to				
Verify that when F Subsequent Events and Design Criteria the applicable SSC Verify that when an and design criteria Also, verify that if a Subsequent Event SSC, then the SSC	a Crystal Report shows only the informa a Crystal Report shows only the informa b SSC is edited from the General tab an exist for that SSC, the SSC ID text field on SSC is not selected for use within an and no design bases and design criteria C ID may be edited.	Event Tree e Design Bases tion that applies to d design bases l is disabled. Event Tree a exist for that				
Verify that when F Subsequent Events and Design Criteria the applicable SSC Verify that when ar and design criteria Also, verify that if a Subsequent Event SSC, then the SSC Verify that the Desi SSC is being adde	a Crystal Report shows only the informa a Crystal Report shows only the informa b SSC is edited from the General tab an exist for that SSC, the SSC ID text field an SSC is not selected for use within an and no design bases and design criteria b ID may be edited. ign Bases and Design Criteria tab is dis d or edited.	Event Tree e Design Bases tion that applies to d design bases l is disabled. Event Tree a exist for that abled when an				
	Module(s), Description Module(s), Description is, and Event Tree Such if or only one SSC ID. SSC, the SSC ID text exist for an SSC; othe ign criteria is broken. es and Design Criteria the General tab. by: Dual 2004 nge(s) or Problem Ref C Design Bases and D rds from the database vents." ere an SSC is being ed id when design bases sign Bases and Design Description of Te	D PCSA Tool, Version 3.0.0 (Beta V) Module(s), Description of Problem(s): SSC Data Form and n Bases and Design Criteria Crystal Report displays "Function is, and Event Tree Subsequent Events" for multiple SSC IDs. n for only one SSC ID. SSC, the SSC ID text field should not be enabled when desige exist for an SSC; otherwise, the link between the former SSC ign criteria is broken. es and Design Criteria tab should not be enabled when an SS the General tab. by: 6. Change Authorized by (Software Name: G. Adams) by: Date: could be be abled and be be be abled when an SS the General tab. by: Bases and Design Criteria tab should not be enabled when an SS the General tab. by: Bases and Design Criteria C. Adams) by: Date: September 10, 2004 pate: September 10, 2004 Date: September 10, 2004 Date: September 10, 2004 Date: September 10, 2004				

1. SCR No. (<i>Software Developer Assigns</i>): 541			eveloper Assigns):	2. Software Title and Version: PCSA Tool, Version 3.0.0 (Beta W)	3. Project No: 20.06002.01.103		
4. Affected Software Module(s), Description of Problem(s): Risk Assessment (frmRiskAssessment, frmRiskEventSequence, frmRiskResults)							
	 The pcsa_ietccdf code generates an error message for 100-realization scenarios in which one of the pathways is 'None.' This error was shown for event scenario CTS-ES-01 of the PCSA Demo database. 						
	2) The Risk Assessment form does not update the number of realizations in probabilistic risk assessment for event scenarios in which all event sequences have 'None' selected for the consequence path. In addition, for the case of all event sequences of 'None,' the probabilistic risk assessment generates an overflow error.						
5. Na Da	Change me: G. A ite: Sept	Requested b Adams OK ember 13, 20	y: Nor 04	6. Change Authorized by (Software Name: G. Adams 7 Augu Date: September 13, 2004	e Developer):		
7.	Descript	tion of Chang	ge(s) or Problem Re	solution (If changes not implemente	ed, please justify):		
	1) Whe cor	n file lhs.inp is rectly read the	s generated, reforma e number of realizatio	tted the output to the file to allow the FC	ORTRAN code to		
	2) Modi an	ified the risk a event scenari	ssessment form to c o risk calculation.	heck the number of realizations after th	e user performs		
	3) Modi	fied the calcu	lation of percent cont	tribution to check for a zero total risk.			
	8 Implemented by:						
8.	Impleme	ented by:		Date:			
8. G.	Adams	ented by:		Date: September 15, 2004			
8. G. 9.	Adams Pass	ented by: Solarn Fail	Description of Te	Date: September 15, 2004 st			
8. G. 9. 1	Adams Pass	Fail	Description of Ter Verify the test resu BetaW of the PCS	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool.	with Version		
8. G. 9. 1	Impleme Adams Pass Ø	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. GA Demo database for Event Scenario (fror message for the 100-realization sce	with Version CTS-ES-01 no enario.		
8. G. 9. 1 2 3	Impleme Adams Pass ☑ ☑	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which the consequence p obtained.	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario (rror message for the 100-realization sce ditional event sequences are added to the additional event sequences have 'N both that the same risk results obtained	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are		
8. G. 9. 1 2 3 4	Impleme Adams Pass ☑ ☑ ☑ ☑	Fail	Description of Tea Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which the consequence p obtained. Verify the risk asse those scenarios in	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario (fror message for the 100-realization sce dditional event sequences are added to the additional event sequences have 'N both that the same risk results obtained essment form will modify the number of which all event sequences have 'None'	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for selected.		
8. G. 9. 1 2 3 4 5	Impleme Adams Pass ☑ ☑ ☑ ☑ ☑	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which the consequence p obtained. Verify the risk asset those scenarios in Verify that the perc	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario (Gror message for the 100-realization sce dditional event sequences are added to the additional event sequences have 'N bath that the same risk results obtained essment form will modify the number of which all event sequences have 'None' event contributions are zero when the total	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for ' selected. al risk is zero		
8. G. 9. 1 2 3 4 5 No	Impleme Adams Pass Ø Ø Ø te: Test	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which the consequence p obtained. Verify the risk asse those scenarios in Verify that the perc locumented on attack	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario (fror message for the 100-realization sce dditional event sequences are added to the additional event sequences have 'N both that the same risk results obtained essment form will modify the number of which all event sequences have 'None' eent contributions are zero when the tota hment 1.	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for 'selected. al risk is zero		
8. G. 9. 1 2 3 4 5 No	Impleme Adams Pass Ø Ø Ø te: Test	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which is the consequence p obtained. Verify the risk asse those scenarios in Verify that the perc locumented on attack	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario O rror message for the 100-realization sce ditional event sequences are added to the additional event sequences have 'N bath that the same risk results obtained essment form will modify the number of which all event sequences have 'None' tent contributions are zero when the tota hment 1.	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for ' selected. al risk is zero		
8. G. 9. 1 2 3 4 5 No	Impleme Adams Pass Ø Ø Ø te: Test	Fail	Description of Tex Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which is the consequence p obtained. Verify the risk asse those scenarios in Verify that the perc locumented on attack	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario (rror message for the 100-realization sce ditional event sequences are added to the additional event sequences have 'N bath that the same risk results obtained essment form will modify the number of which all event sequences have 'None' tent contributions are zero when the tota hment 1.	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for ' selected. al risk is zero		
8. G. 9. 1 2 3 4 5 No 10	Impleme Adams Pass Ø Ø Ø te: Test	Ented by: Fail I	Description of Tea Verify the test resu BetaW of the PCS Verify that the PCS longer shows an er Verify that when ac base test in which the consequence p obtained. Verify the risk asse those scenarios in Verify that the perc locumented on attack	Date: September 15, 2004 st Its obtained on SVTR 8-4 are obtained A Tool. A Demo database for Event Scenario O rror message for the 100-realization sce ditional event sequences are added to the additional event sequences have 'N bath that the same risk results obtained essment form will modify the number of which all event sequences have 'None' event contributions are zero when the tota hment 1.	with Version CTS-ES-01 no enario. the SVTR 8-4 lone' selected for under test 1 are realizations for 'selected. al risk is zero		

· L

. .

~

,

Test 1: Compared the risk and consequence values from SVTR8-4 to the values generated within version BetaW and verified the results were in agreement. Also generated deterministic and probabilistic reports as an attachment which show agreement to the SVTR8-4 results.

Test 2: Verified that by initially setting the Number of realizations to 1 for the 'None' files event sequence and then recalculating the event scenario risk that the resulting lhs.inp file is formatted to be read by the FORTRAN software by a 4x, 112 format statement. And verified through a DOS window that the FORTRAN software no longer generates an error message indicating that the number of realizations are not in agreement.

Test 3: Verified that with the addition of one event sequence to event scenario 1 in which the consequence paths for deterministic and probabilistic are both designated 'None' that the same results from Test 1 are obtained.

Test 4: Setup the form to have two event scenarios with 'None' selected and a third which set the number of realizations. Verified that when the number of realizations for the third scenario was modified that the risk assessment form updated the number of realizations for the other two as well.

Test 5: Set all event sequences to have 'None' for the deterministic and probabilistic consequence paths. Verified that when the deterministic and probabilistic risk was calculated that the percent contributions were all zero.

PCSA Risk Report

Project: scr541

Type of Run: Deterministic

Outcome State	Probability	Consequence (rem)	Risk (rem in time period)	Contribution (%)
	9.512E-01	0.000E+00	0.000E+00	0.00E+00
+ Sulfa - September - Sulfa - Sulf	9.560E-03	8.999E-04	8.603E-06	8.55E+01
- + -	1.921E-02	1.392E-05	2.674E-07	2.66E+00
- · · · · · · · · · · · · · · · · · · ·	1.921E-02	4.174E-05	8.021E-07	7.97E+00
+ + -	1.931E-04	9.139E-04	1.765E-07	1.75E+00
	1.931E-04	9.417E-04	1.818E-07	1.81E+00
- + +	3.881E-04	5.566E-05	2.160E-08	2.15E-01
+ + +	3.901E-06	9.556E-04	3.728E-09	3.71E-02
Total Risk			1.006E-05	

PCSA Risk Report

Project: scr541

Type of Run: Probabilistic

Outcome State	Probability	Mean Consequenc (rem)	Mean Risk (rem in time period)	Contribution (%)
	 9.512E-01	0.000E+00	0.000E+00	0.00E+00
+	9.560E-03	1.632E-04	1.560E-06	8.55E+01
- + -	1.921E-02	2.524E-06	4.850E-08	2.66E+00
+	1.921E-02	7.571E-06	1.455E-07	7.98E+00
+ + -	1.931E-04	1.658E-04	3.201E-08	1.75E+00
+ - +	1.931E-04	1.708E-04	3.298E-08	1.81E+00
- + +	3.881E-04	1.010E-05	3.918E-09	2.15E-01
+ + +	3.901E-06	1.733E-04	6.761E-10	3.71E-02
Total Risk			1.824E-06	