



Entergy Operations, Inc.
River Bend Station
5485 U. S. Highway 61N
St. Francisville, LA 70775
Fax 225 635 5068

November 15, 2004

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Subject: Monthly Operating Report
River Bend Station - Unit 1
Docket No. 50-458
License No. NPF-47

File No.: G9.5, G4.25

RBG-46363
RBF1-04-0222

Ladies and Gentlemen:

Pursuant to River Bend Station Technical Specification 5.6.4, enclosed is the Monthly Operating Report for October 2004.

Sincerely,

A handwritten signature in cursive script that reads "David N. Lorfing".

David N. Lorfing
Manager – Licensing (acting)

DNL / dhw
enclosure

IT24

Monthly Operating Report
November 15, 2004
RBG-46363
RBF1-04-0222
Page 2 of 2

cc: U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
R-SB-14

INPO Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Mr. Jim Calloway
Public Utility Commission of Texas
1701 N. Congress Ave.
Austin, TX 78711-3326

Mr. Tom Wolff
American Nuclear Insurers
95 Glastonbury Boulevard
Glastonbury, CT 06033

Docket No. 50-458
River Bend Station

Date: November 15, 2004
Completed by: Danny H. Williamson
Title: Sr. Licensing Specialist
Telephone: 225-381-4279

Page 1 of 2

OPERATING STATUS

1. Reporting period: October 2004
2. Maximum dependable capacity (MWe-Net): 966
3. Design electrical rating (MWe-Net): 966

	<u>MONTH</u>	<u>YEAR TO DATE</u>	<u>CUMULATIVE</u>
4. Number of hours reactor was critical	<u>364.7</u>	<u>6910.5</u>	<u>135,037.4</u>
5. Hours generator on line	<u>339.4</u>	<u>6868.2</u>	<u>131,265.7</u>
6. Unit reserve shutdown hours	<u>0</u>	<u>0</u>	<u>0</u>
7. Net electrical energy generated (MWH)	<u>304,074</u>	<u>6,595,564</u>	<u>118,314,173</u>

UNIT SHUTDOWNS

<u>NUMBER</u>	<u>DATE</u>	<u>TYPE</u>	<u>DURATION</u>	<u>SHUTDOWN METHOD</u>	<u>REASON</u>	<u>CAUSE / CORRECTIVE ACTIONS</u>
04-02	041001	F	160.9 hrs	3	A	An automatic reactor scram occurred as a result of a main turbine trip. This event will be reported in Licensee Event Report 050-458/04-02-00, due 11/30/04.
04-03	041021	S	244.7 hrs.	2	C	Refueling outage no. 12

LEGEND:

TYPE:


F - Forced
S - Scheduled

SHUTDOWN METHOD:

1 - Manual
2 - Manual trip / scram
3 - Automatic trip / scram
4 - Continuation
5 - Other (explain)

REASON:

A - Equipment failure (explain)
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator training / License Exam
F - Administrative
G - Operational error (explain)
H - Other (explain)



Danny H. Williamson