



Inter-Office
Correspondence

W3F1-2004-0119

November 17, 2004

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Updated 2004 Survey of Toxic Chemicals and Pipelines in the Vicinity of
Waterford 3
Waterford Steam Electric Station, Unit 3 (Waterford 3)
Docket No. 50-382
License No. NPF-38

Dear Sir or Madam:

In letter W3F1-2004-0065, dated August 3, 2004, Entergy provided Waterford 3's results of the 2004 Survey of Toxic Chemicals and Pipelines in the Vicinity of Waterford 3 in accordance with Technical Specifications 6.9.1.9 and 6.9.1.10. In the letter, it was stated that some of the information for Report A, "Results of the 2004 Survey of Toxic Chemicals Stored, Processed, or Transported in the Vicinity of Waterford 3," and Report B, "Results of the 2004 Survey of Pipelines in the Vicinity of Waterford 3," had not been received by Waterford 3 and that this data, as well as the results of the detailed analyses, would be provided to the NRC in a follow-up submittal to be issued by November 17, 2004.

Attachments 1 and 2 of this letter include the completed set of survey data and the results of analyses for Report A and Report B, respectively. Therefore, the updated reports transmitted with this letter supercede the information provided in the reports sent with letter W3F1-2004-0065 in their entirety. The results of the analyses of toxic chemicals from the 2004 survey indicate that the Waterford 3 control room will remain habitable under 95th percentile meteorological conditions and that no modifications to toxic chemical detection systems will be necessary as a result of 2004 survey findings.

Please note that attachments 1 and 2 contain information that is considered sensitive. Entergy requests that this information be withheld from public disclosure.

AP01

There are no new commitments contained in this submittal.

Should you have questions regarding these reports, please contact Greg Scott at (504) 739-6703.

Sincerely,



R.J. Murillo
Licensing Manager (Acting)

RJM/GCS/cbh

- Attachments: 1. Report A – Updated Results of the 2004 Survey and Analysis of Toxic Chemicals Stored, Processed, or Transported in the Vicinity of Waterford 3
2. Report B – Updated Results of the 2004 Survey of Pipelines in the Vicinity of Waterford 3

cc: Dr. Bruce S. Mallett
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Waterford Steam Electric Station Unit 3
P.O. Box 822
Killona, LA 70066-0751

U. S. Nuclear Regulatory Commission
Attn: Mr. N. Kalyanam
Mail Stop O-07D1
Washington, DC 20555-0001

Wise, Carter, Child & Caraway
ATTN: J. Smith
P.O. Box 651
Jackson, MS 39205

Winston & Strawn
ATTN: N.S. Reynolds
1400 L Street, NW
Washington, DC 20005-3502