

## TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
5	<u>DESIGN FEATURES</u>	5-1
5.1	<u>SITE</u>	5-1
5.2	<u>CONTAINMENT</u>	5-2
5.2.1	REACTOR BUILDING	5-2
5.2.2	REACTOR BUILDING ISOLATION SYSTEM	5-3
5.3	<u>REACTOR</u>	5-4
5.3.1	REACTOR CORE	5-4
5.3.2	REACTOR COOLANT SYSTEM	5-4
5.4	<u>NEW AND SPENT FUEL STORAGE FACILITIES</u>	5-6
5.4.1	NEW FUEL STORAGE	5-6
5.4.2	SPENT FUEL STORAGE	5-6
5.5	<u>AIR INTAKE TUNNEL FIRE PROTECTION SYSTEMS</u>	5-8
6	<u>ADMINISTRATIVE CONTROLS</u>	6-1
6.1	<u>RESPONSIBILITY</u>	6-1
6.2	<u>ORGANIZATION</u>	6-1
6.2.1	CORPORATE	6-1
6.2.2	UNIT STAFF	6-1
6.3	<u>UNIT STAFF QUALIFICATIONS</u>	6-3
6.4	<u>TRAINING</u>	6-3
6.5	<u>REVIEW AND AUDIT</u>	6-3
6.5.1	TECHNICAL REVIEW AND CONTROL	6-4
6.5.2	INDEPENDENT SAFETY REVIEW	6-5
6.5.3	AUDITS	6-7
6.5.4	INDEPENDENT ONSITE SAFETY REVIEW GROUP	6-8
6.6	<u>REPORTABLE EVENT ACTION</u>	6-10
6.7	<u>SAFETY LIMIT VIOLATION</u>	6-10
6.8	<u>PROCEDURES AND PROGRAMS</u>	6-11
6.9	<u>REPORTING REQUIREMENTS</u>	6-12
6.9.1	ROUTINE REPORTS	6-12
6.9.2	DELETED	6-14
6.9.3	ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT	6-17
6.9.4	ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT	6-18
6.9.5	CORE OPERATING LIMITS REPORT	6-19
6.10	<u>RECORD RETENTION</u>	6-20
6.11	<u>RADIATION PROTECTION PROGRAM</u>	6-22
6.12	<u>HIGH RADIATION AREA</u>	6-22
6.13	<u>PROCESS CONTROL PROGRAM</u>	6-23
6.14	<u>OFFSITE DOSE CALCULATION MANUAL (ODCM)</u>	6-24
6.15	<u>DELETED</u>	6-24
6.16	<u>DELETED</u>	6-24
6.17	<u>MAJOR CHANGES TO RADIOACTIVE WASTE TREATMENT SYSTEMS</u>	6-25

6.14 OFFSITE DOSE CALCULATION MANUAL (ODCM)

6.14.1 Licensee initiated changes to the ODCM:

1. Shall be submitted to the NRC in the Annual Radioactive Effluent Release Report for the period in which the changes were made. This submittal shall contain:
  - a. sufficiently detailed information to justify the changes without benefit of additional or supplemental information;
  - b. a determination that the changes did not reduce the accuracy or reliability of dose calculations or setpoint determinations; and
  - c. documentation that the changes have been reviewed and approved pursuant to 6.8.2.
2. Shall become effective upon review and approval by licensee management.

6.15 DELETED

6.16 DELETED