

From: Paul Fillion, R2
To: McKenzie Thomas
Date: 1/15/04 10:17AM
Subject: Open Item at McGuire - Manual Actions

I am working on open item 03-07-03 from the last TFP at McGuire. The report talks about one manual action which is to de-energize a valve in the auxiliary feedwater system for a fire in Fire Area 16/18. The procedure AP-45, Enclosure 22, contains other manual actions for this area. These other manual actions are not identified as time critical actions in the procedure. My question is: Did you walkdown/evaluate all the manual actions associated with fire area 16/18, which is the 2ETA/electrical penetration room, and determine they are doable?

EF-9

Mail Envelope Properties (4006AF27.9C5 : 5 : 51853)

Subject: Open Item at McGuire - Manual Actions
Creation Date: 1/15/04 10:17AM
From: Paul Fillion

Created By: PJF@nrc.gov

Recipients

ATL_PO.ATL_DO
 MXT2 (McKenzie Thomas)

Post Office

ATL_PO.ATL_DO

Route

Files	Size	Date & Time
MESSAGE	996	01/15/04 10:17AM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard