



GARY R. PETERSON  
Vice President  
McGuire Nuclear Station

Duke Power  
MGO1VP / 12700 Hagers Ferry Road  
Huntersville, NC 28078-9340

704 875 5333

704 875 4809 fax

grpeters@duke-energy.com

November 18, 2004

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555-0001

SUBJECT: McGuire Nuclear Station - Units 1 & 2  
Docket Nos. 50-369, 50-370  
Third Ten-Year Interval  
Inservice Testing Program, Revision 27  
Supplemental Information

Reference: Letter from Mr. G.R. Peterson of Duke Power to NRC,  
dated August 12, 2004

Additional information is hereby provided to clarify questions that the NRC Staff had concerning the various relief requests provided in the referenced document. Relief requests 1) MC-GRP-01, 2) MC-SRP-KC-01, 3) MC-SRP-ND-01, and 4) MC-SRV-NS-01 were approved for the Second Ten-Year Interval and were submitted in the referenced document requiring approval for the Third Ten-Year Interval. Section 5.0 contains the new Relief Request, MC-SRP-NS-01, which requests relief from the requirement to perform comprehensive pump tests within 20% of design flow. Relief Request MC-SRV-CA-01 is no longer needed, and may be deleted, since the applicable valve, 1CA42B, is now meeting its quarterly surveillance requirement.

Questions with respect to this matter should be directed to Norman T. Simms of Regulatory Compliance at 704-875-4685.

Very truly yours

G.R. Peterson

A047

U.S. Nuclear Regulatory Commission  
November 18, 2004  
Page 2

xc:

W.D. Travers  
U.S. Nuclear Regulatory Commission, Region II  
Atlanta Federal Center  
61 Forsyth St., SW, Suite 23 T85  
Atlanta, GA 30303

J.J. Shea (Addressee only)  
NRC Project Manager (MNS)  
U.S. Nuclear Regulatory Commission  
One White Flint North, MS 08 H12  
11555 Rockville Pike  
Rockville, MD 20852-2738

J.B. Brady  
NRC Senior Resident Inspector  
McGuire Nuclear Station