

Duke Energy Company Oconee 1, 2, 3  
Entergy Operations, Inc. ANO-1  
Florida Power Corporation Crystal River 3



AmerGen Energy Company, LLC  
FirstEnergy Nuclear Operating Company  
Framatome ANP

TMI-1  
D-B

---

Working Together to Economically Provide Reliable and Safe Electrical Power

November 30, 2004  
NRC:04:068  
OG:04:1855

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555-0001

**Supporting Materials for Review of BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program"**

- Ref.: 1. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Request for Review and Approval of BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:03:1838, NRC:03:091, December 19, 2003.
- Ref.: 2. Letter, James F. Mallay (Framatome ANP) to Document Control Desk (NRC), "Response to RAI on BAW-1543(NP), Revision 4, Supplement 5, 'Supplement to the Master Integrated Reactor Vessel Surveillance Program'," OG:04:1847, NRC:04:030, July 7, 2004.

On behalf of the B&W Owners Group Reactor Vessel Working Group, Framatome ANP requested the NRC's review and approval for referencing in licensing actions the topical report BAW-1543(NP), Revision 4, Supplement 5, "Supplement to the Master Integrated Reactor Vessel Surveillance Program," (Reference 1). Our response to a Request for Additional Information was provided in Reference 2. A supplemental request for clarification of the contents of Table VIII of the report was discussed in a telephone call on November 23, 2004.

Attachment 1 provides a revised Table VIII that clarifies how Oconee Unit 2, Oconee Unit 3 and TMI are meeting the minimum number of capsules to be withdrawn and tested in accordance with ASTM E185-82. This table completely replaces the table submitted in Reference 1.

We will appreciate your timely review.

Very truly yours,

A handwritten signature in black ink, appearing to read "James F. Mallay", is written over a horizontal line.

James F. Mallay, Director  
Regulatory Affairs

cc: D. G. Holland  
B&WOG Reactor Working Vessel Group  
Project 693

---

Framatome ANP B&W Owners Group  
3315 Old Forest Road  
Lynchburg, VA 24501  
Phone: 434-832-2981 Fax: 434-832-4121

D045

Attachment 1

Table VIII. Comparison of the Plant-Specific Surveillance Capsules with ASTM E 185 Requirements

Plant	ASTM E 185-82 5 Capsule Program Requirement				
	1.5 EFPY or Fluence > 5E18 $\Delta RT_{NDT} \approx 50^\circ F$	3 EFPY or Fluence Midway Between First and Third Capsule	6 EFPY or T/4 EOL Fluence	15 EFPY or IS EOL Fluence	EOL or 1-2 Times EOL Fluence (Capsule may be held w/o testing)
Oconee-1	F-I/T	E-I/T	A-I/T	C-I/T	B-I/NT
Oconee-2	C-I/T	A-I/T	TM12-LG1/T	E-I/T	A5/T
Oconee-3	A-I/T	B-I/T	L1/T	D-I/T	CR3-LG2/T
TMI-1	E-I/T	W1/T	CR3-LG1/T	C-I/T	TM12-LG2/T
Crystal River-3	B-I/T	C-I/T	D-I/T	F-I/T	A-I/NT
ANO-1	E-I/T	B-I/T	A-I/T	C-I/T	D-I/NT
Davis-Besse	F-I/T	B-I/T	A-I/T	D-I/T	C-I/NT
Point Beach-1	V-I/T	S-I/T	T-I/T	R-I/T	P-I/NT
Point Beach-2	V-I/T	T-I/T	R-I/T	S-I/T	P-I/NT
Surry-1	T-I/T	W-I/T*	V-I/T	X-I/T	S,U-R
Surry-2	X-I/T	W-I/T*	V-I/T	Y-I/T	S-I/T*;T-R
Turkey Point-3	T-I/T	V-I/T	S-I/T	X-I/T	U,W-R
Turkey Point-4	T-I/T	S-I/T	X-R	V-R	U,W-R

Legend: I/T = Irradiated and tested  
I/NT = Irradiated and not tested  
R = In reactor

\* Only dosimetry evaluated.