

December 3, 2004

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION – REQUEST FOR ADDITIONAL
INFORMATION ON RELIEF REQUEST RI-35, REPAIR OF REACTOR
PRESSURE VESSEL CONTROL ROD DRIVE NOZZLE-TO-CAP WELD
(TAC NO. MC4954)

Dear Mr. Edington:

By letter dated October 25, 2004, Nebraska Public Power District (NPPD) requested the NRC staff to approve a request for relief as an alternative to the existing ASME Boiler and Pressure Vessel Code, Section XI requirements for the repair and examination of Class 1 welds.

The NRC staff has reviewed the information provided in the submittal and determined that the additional information identified in the enclosure is required in order for the NRC staff to complete its review. As agreed upon with Dave VanDerKamp on December 2, 2004, NPPD will respond to the NRC staff's request for additional information within 30 days from the date of this letter.

Sincerely,

/RA/

Michelle C. Honcharik, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

December 3, 2004

Mr. Randall K. Edington
Vice President-Nuclear and CNO
Nebraska Public Power District
P. O. Box 98
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION – REQUEST FOR ADDITIONAL
INFORMATION ON RELIEF REQUEST RI-35, REPAIR OF REACTOR
PRESSURE VESSEL CONTROL ROD DRIVE NOZZLE-TO-CAP WELD
(TAC NO. MC4954)

Dear Mr. Edington:

By letter dated October 25, 2004, Nebraska Public Power District (NPPD) requested the NRC staff to approve a request for relief as an alternative to the existing ASME Boiler and Pressure Vessel Code, Section XI requirements for the repair and examination of Class 1 welds.

The NRC staff has reviewed the information provided in the submittal and determined that the additional information identified in the enclosure is required in order for the NRC staff to complete its review. As agreed upon with Dave VanDerKamp on December 2, 2004, NPPD will respond to the NRC staff's request for additional information within 30 days from the date of this letter.

Sincerely,
/RA/
Michelle C. Honcharik, Project Manager, Section 1
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	PDIV-1 r/f
RidsNrrDlpmLpdiv (HBerkow)	RidsNrrDlpmLpdiv1 (MWebb)
RidsNrrPMMHoncharik	RidsNrrLADJohnson
RidsAcrsAcnwMailCenter	RidsOgcRp
RidsRgn4MailCenter (KKennedy)	RidsNrrDlpmDpr (BPham)
RidsNrrDeDpr (SWall)	GGeorgiev
MHartzman	TChan
KManoly	

ACCESSION NO: ML043380325

*No substantive changes

OFFICE	PDIV-1/PM	PDIV-1/LA	EMEB-B/SC	EMCB-B/SC	PDIV-1/SC
NAME	MHoncharik	DJohnson	KManoly	TChan	MWebb
DATE	12/3/04	12/2/04	11/23/2004*	11/18/2004*	12/3/04

Cooper Nuclear Station

cc:

Mr. William J. Fehrman
President and Chief Executive Officer
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. Clay C. Warren
Vice President of Strategic Programs
Nebraska Public Power District
1414 15th Street
Columbus, NE 68601

Mr. John R. McPhail, General Counsel
Nebraska Public Power District
P. O. Box 499
Columbus, NE 68602-0499

Mr. Paul V. Fleming
Licensing Manager
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

Mr. Michael J. Linder, Director
Nebraska Department of Environmental
Quality
P. O. Box 98922
Lincoln, NE 68509-8922

Chairman
Nemaha County Board of Commissioners
Nemaha County Courthouse
1824 N Street
Auburn, NE 68305

Ms. Cheryl K. Rogers, Program Manager
Nebraska Health & Human Services
System
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P. O. Box 95007
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Director
of Intergovernmental Cooperation
Department of Natural Resources
P.O. Box 176
Jefferson City, MO 65102

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 218
Brownville, NE 68321

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Jerry Uhlmann, Director
State Emergency Management Agency
P. O. Box 116
Jefferson City, MO 65101

Chief, Radiation and Asbestos
Control Section
Kansas Department of Health
and Environment
Bureau of Air and Radiation
1000 SW Jackson
Suite 310
Topeka, KS 66612-1366

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
401 SW 7th Street
Suite D
Des Moines, IA 50309

Mr. Scott Clardy, Director
Section for Environmental Public Health
P.O. Box 570
Jefferson City, MO 65102-0570

Jerry C. Roberts, Director of Nuclear
Safety Assurance
Nebraska Public Power District
P.O. Box 98
Brownville, NE 68321

REQUEST FOR ADDITIONAL INFORMATION

RELIEF REQUEST RI-35, REPAIR OF REACTOR PRESSURE VESSEL

CONTROL ROD DRIVE NOZZLE-TO-CAP WELD

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

DOCKET NO. 50-298

1. The October 25, 2004, submittal states that the welder and welding procedures will be qualified to use the shielded metal arc welding process. However, the deposition of the Alloy 52 requires the use of the gas tungsten arc welding (GTAW) process. Is the licensee planning to use welder and welding procedures qualified to use the GTAW process? If so, explain the difference.
2. Provide a diagram/sketch showing the control rod drive return nozzle-to-cap weld and the proposed weld overlay configuration.
3. Section (g)(2) of Code Case N-504-2 specifies that the evaluation of the repaired weld consider residual stresses produced by the weld overlay with the other applied loads on the system. The effects of water backing on the repair weld shall be considered. Section (g)(3) of Code Case N-504-2 specifies that the welds and components meet the applicable stress limits of the construction code.
 - a. What is the construction code that was used to satisfy the evaluation requirements in Sections (g)(2) and (g)(3) of the Code Case?
 - b. Provide a description of the methodology used to determine residual stresses and shrinkage effects.
 - c. Provide a list and a description of the calculations used for determining the length and thickness of the weld overlay.
 - d. Provide a table comparing the current licensing basis primary and primary-plus-secondary stresses, and the primary and primary-plus-secondary stresses at the location of the highest stress regions resulting from the installation of the weld overlay. Show that the component and the weld meet the applicable stress limits of the Cooper construction code, as required by the Code Case.
 - e. Provide the largest ASME Section III fatigue cumulative usage factor and its location in the region with and without the weld overlay, considering all applicable thermal and mechanical transients.