

From: "EMERSON, Fred" <fae@nei.org>
To: <sdw1@nrc.gov>
Date: Fri, Dec 3, 2004 9:48 AM
Subject: Circuit Failure Research

Sunil,

You requested my views on the value of the work done by NRC to risk-inform circuit failure issue resolution, specifically the guidance on binning potential circuit failure inspection areas. This guidance was based primarily on the EPRI/NEI circuit failure testing performed several years ago (with NRC participation), and the NRC workshop conducted in February 2003 where potential areas for circuit failure inspection focus were binned, or categorized, by likelihood based on these test results.

In my personal opinion, NRC's performance of this binning process was a useful step toward circuit failure issue resolution. It marked the first significant NRC effort to focus on risk-significant circuit failures and de-emphasize those that are less likely. While I didn't agree entirely with the results of the binning process, the process was generally successful in segregating the likelier failures from those that are not likely and placing those results into the inspection guidance.

This result was useful enough to preclude the need for additional research on the Bin 2 items. Additional research is not necessary for several reasons:

1. There is already enough information from the existing test results to address the areas of uncertainty.
2. Additional research will only prolong the resolution of the circuit failure issue by several years, and even then, the result is likely to be that even more research is needed. This seems to run counter to the Commission direction to close out fire protection issues soon.
3. By the time any additional testing is completed, we will have a year or two of circuit inspections completed using both the RIS 2004-03 inspection guidance and the new SDP. I believe these inspections (of Bin 1 failures) will determine that most are not risk significant. If we learn that Bin 1 items are generally risk insignificant, we could conclude that Bin 2 failures are even less significant without any testing at all. It seems to make sense to allow time to learn from the round of inspections that begin in January 2005 before committing to a research program of uncertain value.

These represent my personal views.

Fred Emerson

This electronic message transmission contains information from the Nuclear Energy Institute, Inc. The information is intended solely for the use of the addressee and its use by any other person is not authorized. If you are not the intended recipient, you have received this communication in error, and any review, use, disclosure, copying or distribution of the contents of this communication is strictly prohibited. If you have received this electronic transmission in

error, please notify the sender immediately by telephone or by electronic mail and permanently delete the original message.

CC: "John Hannon (Hannon, John)" <jnh@nrc.gov>, "MARION, Alex" <am@nei.org>

Mail Envelope Properties (41B07C91.C02 : 21 : 44034)

Subject: Circuit Failure Research
Creation Date: Fri, Dec 3, 2004 9:45 AM
From: "EMERSON, Fred" <fae@nei.org>
Created By: fae@nei.org

Recipients

nrc.gov
owf2_po.OWFN_DO
SDW1 (Sunil Weerakkody)

nrc.gov
owf4_po.OWFN_DO
JNH CC (John Hannon)

nei.org
am CC (Alex MARION)

Post Office

owf2_po.OWFN_DO
owf4_po.OWFN_DO

Route

nrc.gov
nrc.gov
nei.org

Files

Files	Size
MESSAGE	2803
TEXT.htm	4639
Mime.822	9763

Size

Date & Time

Friday, December 3, 2004 9:45 AM

Options

Expiration Date:	None
Priority:	Standard
Reply Requested:	No
Return Notification:	None

Concealed Subject:	No
Security:	Standard