



Serial: RNP-RA/04-0149

DEC 07 2004

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

MONTHLY OPERATING REPORT

Ladies and Gentlemen:

In accordance with the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Technical Specifications Section 5.6.4, "Monthly Operating Reports," and HBRSEP, Unit No. 2, Technical Requirements Manual Section 6.2, "Monthly Operating Report," Progress Energy Carolinas, Inc., also known as Carolina Power and Light Company, submits the attached report of operating statistics and shutdown experience for the month of November 2004.

If you have any questions concerning this matter, please contact me at (843) 857-1253.

Sincerely,

A handwritten signature in cursive script that reads 'C. T. Baucom'.

C. T. Baucom
Supervisor – Licensing/Regulatory Programs

CTB/jwv

Attachment

c: NRC Resident Inspector, HBRSEP
Dr. W. D. Travers, NRC, Region II
C. P. Patel, NRC, NRR

Handwritten initials 'JE24' in a cursive script.

MONTHLY OPERATING REPORT

DOCKET NO. 050-0261
UNIT H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP), UNIT NO. 2
DATE 12/2/2004
COMPLETED BY TIM SURMA
TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2004

1. DESIGN ELECTRICAL RATING (NET MWE): 765
2. MAX DEPENDABLE CAPACITY (NET MWE): 710

	<u>THIS</u> <u>MONTH</u>	<u>YR TO</u> <u>DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR CRITICAL	720.0	7104.4	227662.4
4. HOURS GENERATOR ON LINE	720.0	7068.1	224306.3
5. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	23.2
6. NET ELEC. ENERGY GENERATED (MWH)	538888.0	5180814.0	147558172.0

DOCKET NO. 050-0261
 UNIT NAME HBRSEP, UNIT NO. 2
 DATE 12/2/2004
 COMPLETED BY TIM SURMA
 TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2004

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down the Reactor ²	Cause / Corrective Actions / Comments

- ¹ Reason:
- A-Equipment Failure (Explain)
 - B-Maintenance or Test
 - C-Refueling
 - D-Regulatory Restriction
 - E-Operator Training & License Examination
 - F-Administrative
 - G-Operational Error (Explain)
 - H-Other (Explain)

- ² Method:
- 1-Manual
 - 2-Manual Scram
 - 3-Automatic Scram
 - 4-Continuation
 - 5-Other (Explain)

SUMMARY: The unit operated at approximately full power for the entire month. There were no challenges to the pressurizer power operated relief valves or the pressurizer safety valves during the month.



Serial: RNP-RA/04-0149

DEC 07 2004

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

MONTHLY OPERATING REPORT

Ladies and Gentlemen:

In accordance with the H. B. Robinson Steam Electric Plant (HBRSEP), Unit No. 2, Technical Specifications Section 5.6.4, "Monthly Operating Reports," and HBRSEP, Unit No. 2, Technical Requirements Manual Section 6.2, "Monthly Operating Report," Progress Energy Carolinas, Inc., also known as Carolina Power and Light Company, submits the attached report of operating statistics and shutdown experience for the month of November 2004.

If you have any questions concerning this matter, please contact me at (843) 857-1253.

Sincerely,

A handwritten signature in cursive script that reads 'C. T. Baucom'.

C. T. Baucom
Supervisor - Licensing/Regulatory Programs

CTB/jwv

Attachment

c: NRC Resident Inspector, HBRSEP
Dr. W. D. Travers, NRC, Region II
C. P. Patel, NRC, NRR

Progress Energy Carolinas, Inc.
Robinson Nuclear Plant
3581 West Entrance Road
Hartsville, SC 29550

MONTHLY OPERATING REPORT

DOCKET NO. 050-0261
UNIT H. B. ROBINSON STEAM ELECTRIC PLANT (HBRSEP), UNIT NO. 2
DATE 12/2/2004
COMPLETED BY TIM SURMA
TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2004

1. DESIGN ELECTRICAL RATING (NET MWE): 765
2. MAX DEPENDABLE CAPACITY (NET MWE): 710

	<u>THIS</u> <u>MONTH</u>	<u>YR TO</u> <u>DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR CRITICAL	720.0	7104.4	227662.4
4. HOURS GENERATOR ON LINE	720.0	7068.1	224306.3
5. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	23.2
6. NET ELEC. ENERGY GENERATED (MWH)	538888.0	5180814.0	147558172.0

DOCKET NO. 050-0261
 UNIT NAME HBRSEP, UNIT NO. 2
 DATE 12/2/2004
 COMPLETED BY TIM SURMA
 TELEPHONE (843) 857-1086

REPORTING PERIOD: NOVEMBER 2004

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down the Reactor ²	Cause / Corrective Actions / Comments

Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training & License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

Method:

- 1-Manual
- 2-Manual Scram
- 3-Automatic Scram
- 4-Continuation
- 5-Other (Explain)

SUMMARY: The unit operated at approximately full power for the entire month. There were no challenges to the pressurizer power operated relief valves or the pressurizer safety valves during the month.