






Notes: 1. ksf = kips per square foot.  
 2. RC = Resonant Column test.  
 3. TS = Torsional Shear test.

Explanation				
	Selected curve 500- 1000 ft.			
	<i>Old Alluvium</i>			
UTA Test No.	Confining Stress	Sample No.	Sample Depth	
	RC-6	12.96 ksf	B-1-43	165 feet
	TS-6	12.96 ksf	B-1-43	165 feet
	RC-5	10.37 ksf	B-2-16	109 feet
	TS-5	10.37 ksf	B-2-16	109 feet

SERI  
 GRAND GULF NUCLEAR STATION SITE  
 EARLY SITE PERMIT APPLICATION  
 SITE SAFETY ANALYSIS REPORT

DAMPING RATIO CURVES  
 FOR OLD ALLUVIUM

FIGURE 2.5-96

11/19/04 DRAFTREV. 0