Multi-Purpose Canister (MPC) 3.1.1

3.1 SFSC INTEGRITY

- 3.1.1 Multi-Purpose Canister (MPC)
- LCO 3.1.1 The MPC shall be dry and helium filled.
- APPLICABILITY: During TRANSPORT OPERATIONS and STORAGE OPERATIONS.

ACTIONS

	CONDITION	REQUIRED ACTION	COMPLETION TIME
Α.	MPC cavity vacuum drying pressure or demoisturizer exit gas temperature limit not met.	 A.1 Perform an engineering evaluation to determine the quantity of moisture left in the MPC. <u>AND</u> 	7 days
		A.2 Develop and initiate corrective actions necessary to return the MPC to an analyzed condition.	30 days
В.	MPC helium backfill limit not met.	B.1 Perform an engineering evaluation to determine the impact of helium differential.	72 hours
		AND	
		B.2 Develop and initiate corrective actions necessary to return the MPC to an analyzed condition.	14 days

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Actions and associated Completion Times not met.	C.1 Remove all fuel assemblies from the SFSC.	30 days

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.1.1.1	Verify that the MPC cavity has been dried in accordance with the applicable limits in Table 3-1.	Once, prior to TRANSPORT OPERATIONS
SR 3.1.1.2	Verify MPC helium backfill quantity is within the limit specified in Table 3-2 for the applicable MPC model.	Once, prior to TRANSPORT OPERATIONS