

GL 97-02

December 10, 2004
2130-04-20317

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555 - 0001

Oyster Creek Generating Station
Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: Monthly Operating Report - November 2004

Enclosed is the November 2004 Monthly Operating Report for Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02.

If any further information or assistance is needed, please contact David Fawcett at 609-971-4284.

Sincerely,



C. N. Swenson
Vice President, Oyster Creek Generating Station

CNS/DIF
Enclosure

cc: S. J. Collins, Administrator, USNRC Region I
P. S. Tam, USNRC Senior Project Manager, Oyster Creek
R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek
File No. 04002

IE24

OPERATING DATA REPORT

DOCKET NO. 50-219
UNIT NAME Oyster Creek 1
DATE December 07, 2004
COMPLETED BY Roger B. Gayley
TELEPHONE (609) 971-4406

REPORTING PERIOD: November 2004

1. Design Electrical Rating	<u>650.00</u>			
2. Maximum Dependable Capacity (MWe-Net)	<u>619.00</u>			
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>	
3. Number of Hours the Reactor was Critical	<u>261.33</u>	<u>7,298.48</u>	<u>225,735.50</u>	
4. Number of Hours Generator On-line	<u>241.52</u>	<u>7,230.80</u>	<u>221,426.45</u>	
5. Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>918.20</u>	
6. Net Electrical Energy Generated (MWHrs)	<u>122,953.00</u>	<u>4,373,174.00</u>	<u>126,767,927.0</u>	

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
1	11/02/2004	S	478.48	C	1	Planned refueling maintenance outage designated 1R20. The planned duration was 15 days, 10 hours. The actual duration was 19 days, 22 hours, 29 minutes.

SUMMARY: During November, Oyster Creek generated 122,953 net MWh electric, which was 27.6% of its MDC rating. A refueling maintenance outage designated 1R20 was completed during the month. The outage commenced 11/2/04 at 15:00 hours and was completed 11/22/04 at 13:29 hours, a total of 478.49 hour duration. The outage duration extended four days beyond schedule resulting in an unplanned energy loss of 57,003 MWhrs.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)