

DEC 15 2004

LR-N04-0572



U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

**MONTHLY OPERATING REPORT  
SALEM GENERATING STATION UNIT 1  
DOCKET NO. 50-272**

In compliance with Section 6.9, Reporting Requirements for the Salem Unit 1 Technical Specifications, the operating statistics for **November 2004** are being forwarded.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Fricker".

Carl J. Fricker  
Salem Plant Manager

Attachments

C Distribution

IE24

DOCKET NO.: 50-272  
 UNIT: Salem 1  
 DATE: 12/8/04  
 COMPLETED BY: F. Todd  
 TELEPHONE: (856) 339-1316

Reporting Period November 2004

**OPERATING DATA REPORT**

Design Electrical Rating (MWe-Net)  
 Maximum Dependable Capacity (MWe-Net)  
 No. of hours reactor was critical  
 No. of hours generator was on line (service hours)  
 Unit reserve shutdown hours  
 Net Electrical Energy (MWH)

1193		
1159		
Month	Year-to-date	Cumulative
720	6523	157188
720	6373	152325
0	0	0
848451	7177450	156178098

**UNIT SHUTDOWNS**

NO.	DATE	TYPE F=FORCED S=SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTION/ COMMENT

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

DOCKET NO.: 50-272  
UNIT: Salem 1  
DATE: 12/8/04  
COMPLETED BY: R. Ritzman  
TELEPHONE: (856) 339-1445

### Summary Of Monthly Operating Experience

- Salem 1 began the month at approximately 100% power.
- On November 7, power was reduced to approximately 77% due to solar magnetic disturbances. Power was restored to 100% on November 8.
- Salem 1 operated throughout the remainder of the month without experiencing another power change that exceeded 20% of reactor power.
- At the end of the month, Salem 1 completed 63 days of continuous on-line operation.