

From: Leonard Ward
To: rdafluc@entergy.com
Date: 7/8/04 11:54AM
Subject: RELAP5 Vermont Yankee Input Deck

Attached are the initial pages to the Vermont Yankee RELAP5 input decks for the steady state initialization and transient runs.

Hopefully there's enough information to identify the full decks. The email system will not allow transmittal of large files.

Thanks,

Len ward

Dr. Leonard W. Ward, Ph.D.
US Nuclear Regulatory Commission
NRR/DSSA/SRXB
MS O10-B3
Washington, DC 20555-0001
Work (301) 415-2866
Fax (301) 415-3577

CC: Richard Lobel

Mail Envelope Properties (40ED6E34.CC9 : 4 : 37816)

Subject: RELAP5 Vermont Yankee Input Deck
Creation Date: 7/8/04 11:54AM
From: Leonard Ward

Created By: LWW@nrc.gov

Recipients
entergy.com
rdafluc (rdafluc@entergy.com)

nrc.gov
owf2_po.OWFN_DO
RML CC (Richard Lobel)

Post Office

owf2_po.OWFN_DO

Route

entergy.com
nrc.gov

Files	Size	Date & Time
MESSAGE	1356	07/08/04 11:54AM
VYR5LOCAttran.i	10752	07/08/04 11:49AM
VYR5LOCAss.i	49664	07/08/04 11:42AM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard

```
= r5m8gbe6 - vyloca 0.6 ft2 dis. 1lpcs +1lpci
* W.K.Hughey, Entergy to NRC, July 14, 1999
* Vermont Yankee transient
* INEEL developed a RELAP/SCDAP deck from this input wlj
*****
*
*   THIS DECK REPRESENTS THE VY BASE DECK TO BE USED FOR LOCA
ANALYSES *
*   AND IS BASED ON CALCULATION VYC - 937
*
*****
*****
*
*
*   INITIAL CONDITIONS:  NOMINAL FOR 1698.3 MWTH
*
*
*   WATER LEVEL ABOVE TOEF      =   162.34 IN
*
*   DOME PRESSURE                =   1024.0 PSIA
*
*   CORE POWER                   =   1593.13 MWT
*
*   FEEDWATER TEMPERATURE       =   373.13 F
*
*   FEEDWATER FLOW              =   1873 LBM/SEC
*
*   MAINSTEAM FLOW              =   1873 LBM/SEC
*
*   RECIRC PUMP SPEED           =   1670 RPM
*
*   CORE FLOW                   =   13300 LBM/SEC
*
*   COSINE POWER SHAPE AND CONSERVATIVE PEAKING
*
*****
*****
*
*
*   ACCIDENT CONDITIONS ASSUMED:
*
*
*   1.  BREAK IS ASSUMED TO OCCUR 4.0E-6 SECONDS IN DRYWELL
*
*   2.  LOSS OF AUXILIARY POWER OCCURS AT 4.0E-6 SECONDS.
*
*   3.  REACTOR SCRAMS'S AFTER 1.8 SEC DELAY FROM FIRST RPS SIGNAL.
*
*   (EXCEPT HIGH DRYWELL PRESSURE)
*   SCRAM CURVE 67B OF VYNPS TECHS SPECS IS USED *
*   4. FEEDWATER COASTS DOWN TO 0.0 LBM/SEC AT 4.5 SECONDS. *
*   5. MSIV'S CLOSE IN 3.0 SECONDS AFTER ISOLATION SIGNAL PLUS 0.5 *
*   SECOND DELAY. *
*   6. RECIRC PUMPS IN A & B LOOPS COAST DOWN WITH LOSS OF OUTSIDE *
*   POWER(FREEWHEELING) *
*   7. ADS MAY ACTUATE IF APPROPRIATE SIGNALS EXIST. THEREAFTER, ADS *
```

- * CYCLES OPEN/CLOSE AT 12 PSID BETWEEN STEAMLINE AND DRYWELL *
- * WHEN ADS CRITERIA ARE CURRENTLY MET AT ANY TIME. *
- * 8. ECCS OPERABILITY VARIES WITH EVERY CASE. *
- * 9. RCIC SYSTEM IS NOT AVAILABLE (ASSUMPTION). *
- * 10. HPSI SYSTEM IS NOT AVAILABLE (SINGLE FAILURE) *
- * 11. THE RECIRC. DISCHARGE VALVE IN THE BROKEN LOOP DOES NOT CLOSE. *
- * 12. THE RECIRC. DISCHARGE VALVE IN THE INTACT LOOP CLOSSES ON DEMAND. *
- * 13. THE LPCI SYSTEM IN THE BROKEN LOOP FAILS DUE TO BREAK. *
- * 14. THE LPCI IN THE INTACT LOOP INJECTS UPON DEMAND. *
- * 15. CONTAINMENT PRESSURE IS SET AT 14.7 PSIA AND 165.0.DEGF *
- * 16. EM POINT REACTOR KINETICS INITIALLY AT 1698.3 MWTH. *
- * 17. EM CORE HEAT TRANSFER. *
- * 18. PASSIVE HEAT STRUCTURES ARE INCLUDED. *
- * *

*

100 new transnt

101 run

102 british british

*105 4.0 5.0

*109 40 40 4 4 695

110 nitrogen

*

201 4.0e-6 1.0e-6 1.0e-6 00003 4 4 4

202 10.0 1.0e-6 0.002 00003 500 5000 5000

203 400.0 1.0e-6 0.01 00003 100 20000 20000

*

```
= r5m8gstd - vyloca steady-state
* W.K.Hughey, Entergy to NRC, July 14, 1999
* Vermont Yankee transient
*
*****
* THIS DECK REPRESENTS THE VY BASE DECK TO BE USED FOR LOCA ANALYSES
*
* AND IS BASED ON CALCULATION VYC - 937
*
*****
*
* INITIAL CONDITIONS: NOMINAL FOR 1698.3 MWTH
*
*
* WATER LEVEL ABOVE TOEF = 162.34 IN
*
* DOME PRESSURE = 1024.0 PSIA
*
* CORE POWER = 1593.13 MWT
*
* FEEDWATER TEMPERATURE = 373.13 F
*
* FEEDWATER FLOW = 1873 LBM/SEC
*
* MAINSTEAM FLOW = 1873 LBM/SEC
*
* RECIRC PUMP SPEED = 1670 RPM
*
* CORE FLOW = 13300 LBM/SEC
*
* COSINE POWER SHAPE AND CONSERVATIVE PEAKING
*
*****
*
* ACCIDENT CONDITIONS ASSUMED:
*
*
* 1. BREAK IS ASSUMED TO OCCUR 4.0E-6 SECONDS IN DRYWELL
*
* 2. LOSS OF AUXILIARY POWER OCCURS AT 4.0E-6 SECONDS.
*
* 3. REACTOR SCRAMS'S AFTER 1.8 SEC DELAY FROM FIRST RPS SIGNAL.
*
* (EXCEPT HIGH DRYWELL PRESSURE)
* SCRAM CURVE 67B OF VYNPS TECHS SPECS IS USED
*
* 4. FEEDWATER COASTS DOWN TO 0.0 LBM/SEC AT 4.5 SECONDS.
*
* 5. MSIV'S CLOSE IN 3.0 SECONDS AFTER ISOLATION SIGNAL PLUS 0.5
* SECOND DELAY.
*
```

* 6. RECIRC PUMPS IN A & B LOOPS COAST DOWN WITH LOSS OF OUTSIDE
 * POWER(FREEWHEELING)
 *
 * 7. ADS MAY ACTUATE IF APPROPRIATE SIGNALS EXIST. THEREAFTER, ADS
 * CYCLES OPEN/CLOSE AT 12 PSID BETWEEN STEAMLINE AND DRYWELL
 * WHEN ADS CRITERIA ARE CURRENTLY MET AT ANY TIME.
 *
 * 8. ECCS OPERABILITY VARIES WITH EVERY CASE.
 *
 * 9. RCIC SYSTEM IS NOT AVAILABLE (ASSUMPTION).
 *
 * 10. HPSI SYSTEM IS NOT AVAILABLE (SINGLE FAILURE)
 *
 * 11. THE RECIRC. DISCHARGE VALVE IN THE BROKEN LOOP DOES NOT CLOSE.
 *
 * 12. THE RECIRC. DISCHARGE VALVE IN THE INTACT LOOP CLOSSES ON
 DEMAND. *
 * 13. THE LPCI SYSTEM IN THE BROKEN LOOP FAILS DUE TO BREAK.
 *
 * 14. THE LPCI IN THE INTACT LOOP INJECTS UPON DEMAND.
 *
 * 15. CONTAINMENT PRESSURE IS SET AT 14.7 PSIA AND 165.0.DEGF
 *
 * 16. EM POINT REACTOR KINETICS INITIALLY AT 1698.3 MWTH.
 *
 * 17. EM CORE HEAT TRANSFER.
 *
 * 18. PASSIVE HEAT STRUCTURES ARE INCLUDED.

100	new	transnt						
101	run							
102	british	british						
*105	4.0	5.0						
*109	40	40	4	4	695			
110	nitrogen							
*								
201	4.0e-6	1.0e-6	1.0e-6	00003	4	4	4	
202	10.0	1.0e-6	0.002	00003	500	5000	5000	
203	400.0	1.0e-6	0.01	00003	100	20000	20000	
*								
301	rktpow	0						* total core power
302	rkcreac	0						* net reactivity
303	cntrlvar	804						* core average void fraction
304	p	240010000						* rpv pressure
305	p	540010000						* main steamline pressure
310	mflowj	401000000						* feedwater flowrate
311	mflowj	549000000						* turbine inlet flowrate
312	pmpvel	310						* pump speed loop a
313	pmpvel	360						* pump speed loop b
314	mflowj	326010000						* recirc loop a flow rate
315	mflowj	376010000						* recirc loop b flow rate
316	mflowj	343000000						* jetpump bank a flowrate
317	mflowj	393000000						* jetpump bank b flowrate

```

318   cntrlvar 101          * total core+bypass flowrate
*****
319   mflowj 100010000    * bypass inlet flowrate
320   mflowj 120020000    * lobndl inlet flowrate
321   mflowj 140020000    * avbndl inlet flowrate
322   mflowj 160020000    * hibndl inlet flowrate
323   cntrlvar 100         * total core inlet flowrate
324   mflowj 109000000    * bypass outlet flowrate
325   mflowj 129000000    * lobndl outlet flowrate
326   mflowj 149000000    * avbndl outlet flowrate
327   mflowj 169000000    * hibndl outlet flowrate
*****
328   mflowj 541000000    * msiv flowrate
330   mflowj 551000000    * s/rv1 flowrate
331   mflowj 553000000    * s/rv23 flowrate
332   mflowj 555000000    * s/rv4 flowrate
333   mflowj 559000000    * ads flowrate
335   mflowj 802000000    * break j-802 flowrate
*336   mflowj 801000000    * break j-801 flowrate
*****
337   mflowj 701000000    * hpci pump flowrate
338   mflowj 721000000    * lpcs (1) flowrate
*****
353   cntrlvar 901        * net inflow to primary system
354   cntrlvar 903        * primary system mass
*****
355   cntrlvar 003        * anrlvl
359   cntrlvar 012        * awrlvl
363   cntrlvar 676        * bilvlcl
*****
364   sattemp 206010000   * upper plenum sat temp
365   httemp 122100506    * lobndl temp axnode 5
366   httemp 142100306    * avbndl temp axnode 3
367   httemp 142100506    * avbndl temp axnode 5
368   httemp 162100306    * hibndl temp axnode 3
369   httemp 162100406    * hibndl temp axnode 4
370   httemp 162100506    * hibndl temp axnode 5
371   httemp 162100606    * hibndl temp axnode 6
372   httemp 162100706    * hibndl temp axnode 7
373   httemp 163100306    * hirddl temp axnode 3
374   httemp 163100406    * hirddl temp axnode 4
375   httemp 163100506    * hirddl temp axnode 5
376   httemp 163100606    * hirddl temp axnode 6
377   httemp 163100706    * hirddl temp axnode 7
*****
393   cntrlvar 990        * total mass
*****
***          TRIPS          ***
*****
*
*   ACCIDENT INITIATION AND GENERAL TRIPS
*
*   ACCIDENT TIME = 4.0E-6 SECONDS FOR LOCA BE AND EM DECKS
*   LOSS OF OFFSITE POWER = 4.0E-6 SECONDS FOR LOCA BE AND EM DECKS
*
*   TRIP 501: IS TIME LT ACCIDENT TIME ?
*   TRIP 502: IS TIME GE ACCIDENT TIME ?
*   TRIP 503: IS TIME GT 1.0E+06 SECONDS ? ALWAYS FALSE.
*
501   time 0   lt   null 0   4.0e+6   n   0.0
502   time 0   ge   null 0   4.0e+6   1

```

```

503   time    0   gt   null    0   1.0e+6   n
*
*****
*   REACTOR SCRAM SIGNALS AND TRIPS
*
*   TRIP 510: SCRAM ON RPS MG SET UNDERFREQUENCY LESS THAN 57 HZ AT 3.0
SEC
*           AFTER LOSS OF OFFSITE POWER.
*   TRIP 511: SCRAM ON HIGH DRYWELL PRESSURE GE TO 2.5 PSIG
*           (OCCURED AT 3.00 SEC-CONSERVATIVE ASSUMPTION)
*   TRIP 512: SCRAM ON RPV LEVEL LE 127 INCHES (LO LEVEL) ABOVE TOP OF
*           ENRICHED FUEL AT 351.5 INCHES.(LEVEL SCRAM AT 125.0-
CONSERVATIVE)
*   TRIP 513: SCRAM ON RPV PRESSURE ABOVE 1069.7 PSIA (1055 PSIG).
*   TRIP 514: SCRAM ON MSIV CLOSURE @ 10% CLOSED (90% MSIV OPENED)
*           WITH 1.0 SEC DELAY TO REACH 10% CLOSED (IE 100% CLOSED IN
10.0
*           SECONDS) FROM TRIPS 529 AND 531.
*   TRIP 614: DETERMINE IF & WHEN ANY SCRAM SIGNAL HAS OCCURRED AFTER
ACCIDENT
*           INITIATION; THEN
*   TRIP 515: INITIATES CONTROL ROD INSERTION WITH 1.8 SEC. DELAY.
*   TRIP 516: INITIATES TURBINE STOP VALVE (J549) CLOSURE 20.0 SEC
AFTER
*           REACTOR SCRAM (TRIP 614).
*
*   TRIP 616: IS TRIP 511 OR TRIP 516 TRUE ?
*
*   TRIP 517: IS TIME GE TIMEOF TRIP 616 PLUS 0.4 SEC ?
*           IF SO, RAMP TURBINE STOP VALVES CLOSED IN
*           0.1 SEC.
*
*   TRIP 518: INITIATES TURBINE BYPASS VALVE OPENING 0.1
*           SECONDS AFTER TRIP 517 (JNCTN 571)
*
510   time    0   ge   timeof   502   3.5           1
511   time    0           ge   null    0   3.00       1
512   cntrlvar    003   le   null    0   125.0       n
513   p      240010000   ge   null    0   1069.7      n
514   time      0           ge   timeof   531   1.0     1
*
610   512           or           513           n
611   610           or           514           n
612   611           or           511           n
613   612           and          502           n
515   time 0           ge   timeof   613   1.8     1
614   515           or           510           n   * scram trip *
*
*****
*   TURBINE STOP AND BYPASS VALVE
*
516   time 0           ge   timeof   614   20.0     1
616   511           or           516           1
517   time 0           ge   timeof   616   0.5     1
518   time 0           ge   timeof   517   0.1     1
*
*****
***
*   MAIN STEAM ISOLATION VALVE CLOSURE
*
*   TRIP 510: RPS MG SET UNDERFREQUENCY SIGNAL

```



```

*   TRIP 529: HI MAIN STEAMLINE FLOW (140 % RATED) IN J546-01.
*   TRIP 530: RPV LEVEL LE 80.0 INCHES (ACTUAL LO LO LEVEL SETPNT)
*   TRIP 630: PREVENTS CLOSURE ON LO LO LEVEL PRIOR TO ACCIDENT
*   TRIP 631: SELECTS TRIP 510 OR 630 AS VALID SIGNAL
*   TRIP 632: SELECTS TRIP 529 OR 631 AS VALID SIGNAL
*   TRIP 531: 1.8 SECOND DELAY FOR INSTRUMENT AND LOGIC CIRCUITS
*   TRIP 633: LATCH HI MAIN STEAMLINE FLOW SIGNAL FOR HPCI AND
*             RCIC ISOLATION
*
529   mflowj   546010000   ge   null   0   2500.56   n
530   cntrlvar   003   le   null   0   80.0   n
630           530   and   502           n
631           630   or   510           n   * use for
recirc lin
632           631   or   529           n   * use for
main steam
*
531   time           0   ge   timeof   632   1.8   1
633   529   and   529           1
*****
*   RECIRC PUMP MOTOR TRIP (This logic not used; pumps trip due to LOOP-
TRIP 5
*
*   TRIP 540: RPM TRIP ON HIGH RPV PRESSURE GE 1164.7 PSIA (1150 PSIG)
*   TRIP 541: 0.3 SECOND DELAY ADDED TO TRIP 540 FOR CIRCUITS
*   TRIP 542: 10.3 SECOND DELAY ADDED TO TRIP 630 (LO LO LEVEL)
*   TRIP 543: TRIP ON RECIRC LOOP MG-SET UNDERFREQUENCY 17.0 SECONDS
*             AFTER LOSS OF OFFSITE POWER.
*   TRIP 642: SELECTS TRIP 541 OR TRIP 542 AS VALID SIGNAL
*   TRIP 643: SELECTS TRIP 543 OR TRIP 642 AS VALID SIGNAL
*   TRIP 644: USE PUMP VELOCITY TABLE
*
540   p   240010000   ge   null   0   1164.7   1
541   time           0   ge   timeof   540   1.8   1
542   time           0   ge   timeof   630   11.8   1
543   time           0   ge   timeof   502   17.0   1
642           541   or   542           1
643           543   or   642           1
644           -643   or   -643           n
*
*****
****
*   RECIRC LOOP DISCHARGE VALVE CLOSURE
*   NOTE: POWER IS FROM AN UNINTERRUPTIBLE POWER SUPPLY
*   NOTE: ASSUME THE UPS FAILS;THE RECIRC LOOP DISCHARGE
*   VALVES FAIL TO CLOSE IN BOTH LOOPS
*
*   TRIP 646: SELECTS TRIP 511 ( HI DW PRESS) OR TRIP 630 (LO LO LEVEL)
*   TRIP 546: 2.00 SECOND DELAY ADDED TO TRIP 646 FOR CIRCUITS
*   TRIP 547: RPV PRESSURE LT OPEN PERMISSIVE ( 315 PSIA)
*   TRIP 647: TRIP 546 AND TRIP 547 MUST BE TRUE FOR THE RLDV TRIP
*
646           511   or   630           n
546   time           0   ge   timeof   646   2.00   1
547   p   240010000   le   null   0   315.0   1
647           546   and   547           1
*
*****
**
*   AUTOMATIC DEPRESSURIZATION SYSTEM

```

```

*
*      ADS ACTUATION CONDITIONS
*
*      TRIP 511: WAS HIGH DRYWELL PRESSURE (17.2 PSIA) EXCEEDED ?
*      TRIP 550: IS RPV LEVEL CURRENTLY BELOW LO LO LEVEL (80.0 INCHES) ?
*      TRIP 650: ARE TRIPS 511 AND 550 BOTH TRUE? THEN LO LO LEVEL AND
*                HI DRYWELL PRESSURE SIGNALS COEXISTED AT LAST TIME STEP.
*      TRIP 551: 122.0 SECOND DELAY (120 SEC TIMER, 2.0 CIRCUITS) REQUIRED
AFTER
*      TRIP 650 (TESTED AT LAST TIME STEP) IS TRUE PRIOR TO ADS.
*      TRIP 651: ARE BOTH TRIPS 551 AND 650 CURRENTLY TRUE ?
*      TRIP 694: IS AT LEAST ONE LO PRESSURE ECC PUMP RUNNING ?
*      TRIP 652: ARE TRIPS 651 AND 694 BOTH TRUE? THEN VALID ADS SIGNAL
EXISTS.
*      TRIP 552: IS MAIN STEAMLINE PRESSURE SUFFICIENTLY HIGH, 114.7 PSIA
*                TO OPEN PILOTS ON SRV'S?
*      TRIP 653: IF BOTH TRIP 552 AND 652 ARE TRUE, THEN OPEN ADS
AUTOMATICALLY.
*
*      TRIP 554: IS TIME GE TO MANUAL ADS ACTUATION TIME ?
*      TRIP 654: IF TRIPS 552 AND 554 ARE BOTH TRUE, THEN OPERATORS
*                MANUALLY OPEN ADS VALVES.
*
*      TRIP 655: IF TRIP 653 OR 654 IS TRUE, THEN OPEN ADS VALVES.
*                OTHERWISE, MAINTAIN OR TRIP ADS VALVES CLOSED.
*
550  cntrlvar  003   lt   null      0    80.0    n
650                511 and 550                n
551   time           0   ge   timeof  650   122.0    1
651                551 and 650                1
652                651 and 694                1
552   p  240010000   ge   null      0    114.7    n
553   p  240010000   le   null      0     64.7    n *   close ads valves
653                552 and 652                n *   criteria for auto
ads
*
554   time           0   ge   timeof  550   602.0    n
654                552 and 554                n *   criteria for
manual ads
*
655                653   or  654                n *   ramp ads open
(manual or
*
*****
**
**      SAFETY/RELIEF VALVE 1
*
*      S/RV1 OPENS AT 1080.0 PSID ABOVE DRYWELL AND ADS IS OFF
*      S/RV1 CLOSSES AT (0.97)*(1080 PSIG)= 1047.6 PSID ABOVE DRYWELL OR
WHEN ADS
*      (SEPARATE JUNCTION) OPENS.
*
560   p  544010000   ge   p 614010000  1080.0    n
561   p  544010000   le   p 614010000  1047.6    n
566   time           0   ge   timeof  560    0.4    n
660                566 and -655                n
661                561   or  655                n
*
*      SAFETY/RELIEF VALVES 2 AND 3
*      S/RV23 OPENS AT 1090.0 PSID ABOVE DRYWELL AND ADS IS OFF
*      S/RV23 CLOSSES AT (0.97)(1090 PSID)= 1057.3 PSID ABOVE DRYWELL OR

```

```

WHEN ADS
*      (SEPARATE JUNCTION) OPENS.
*
562    p      544010000      ge      p 614010000      1090.0      n
563    p      544010000      le      p 614010000      1057.3      n
567    time      0      ge      timeof 562      0.4      n
662            567      and      -655      n
663            563      or      655      n
*
*      SAFETY/RELIEF VALVE 4
*      S/RV4 OPENS AT 1100.0 PSID ABOVE DRYWELL AND ADS IS OFF
*      S/RV4 CLOSSES AT (0.97)(1100 PSID)= 1067.0 PSID ABOVE DRYWELL OR
WHEN ADS
*      OPENS.
*
564    p      544010000      ge      p 614010000      1100.0      n
565    p      544010000      le      p 614010000      1067.0      n
568    time      0      ge      timeof 564      0.4      n
664            568      and      -655      n
665            565      or      655      n
*
*      SAFETY VALVES 1 AND 2 (CURRENTLY DEACTIVATED)
*      SV12 OPENS AT 1240.0 PSID ABOVE DRYWELL
*      SV12 CLOSSES AT (.97)(1240 PSID) = 1202.8 PSID ABOVE DRYWELL
*
*566    P      544010000      GE      P 614010000      1240.0      N
*567    P      544010000      LE      P 614010000      1202.8      N
*
*****
*
*      HIGH PRESSURE COOLANT INJECTION (HPCI) SYSTEM
*
*      CRITERIA TO CONTROL HPCI INJECTION ON BISTABLE RPV LEVEL
*
*      TRIP 571: IS MAIN STEAM LINE PRESSURE GT 90 PSIA ?
*              (70 PSIG TECH SPEC + 15 PSIA ATM + 5 PSI UNCERTAINTY = 90
PSIA) I
*      TRIP 572: IS RPV LEVEL LT BISTABLE LEVEL (CNTRLVAR 676 ) ?
*      TRIP 671: ARE BOTH TRIP 571 AND 572 TRUE ?
*
*      CRITERIA TO INITIATE HPCI INJECTION ON HI DRYWELL PRESSURE FOR
FIRST TIME.
*      AFTER FIRST INITIATION, HI DRYWELL PRESSURE SEALS IN BUT IS
OVERRIDDEN
*      BY RPV LEVEL, MAIN STEAMLINE PRESSURE AND HI MAIN STEAMLINE FLOW
SIGNALS.
*
*      TRIP 511: IS DRYWELL PRESSURE GE 17.2 PSIA ?
*      TRIP 672: ARE BOTH TRIP 511 AND TRIP 571 TRUE ?
*      TRIP 673: HAS HPCI EVER BEEN INITIATED DURING THIS CASE ?
*      TRIP 674: HPCI READY TO INJECT FOR FIRST TIME ON HIGH DRYWELL
PRESSURE
*              SIGNAL
*
*      FINAL HPCI INJECTION SIGNALS AT EACH TIME STEP
*
*      TRIP 675: IS TRIP 671 OR TRIP 674 TRUE ?
*      TRIP 676: ARE TRIPS 675 AND -633 BOTH TRUE ? IF SO, THEN
HPCI STARTS UP OR CONTINUES TO INJECT.
*      TRIP 573: IF HPCI ECC INJECTION STARTS, THEN START HPCI

```

```

*          STEAM TURBINE FLOW.
*
571  p      544010000    gt      null    0    90.0    n
572  cntrlvar 003      lt      cntrlvar 676  0.0    n
671  cntrlvar 571      and      572                      n
*
672          511      and      571                      n
673          676      and      676                      l
674          672      and      -673                     n
*
675          671      or      674                      n
676          675      and      -633                     n * hpci pump
startup or on
*
573  mflowj 701000000  gt      null    0    0.0    n * hpci steam
turbine on
*
*****
*****
*
*   REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM (DEACTIVATED)
*
*   NOTE:  THE RCIC ACTUATION AND TERMINATION LOGIC IS VERY SIMILAR
TO
*          THE HPCI LOGIC EXCEPT RCIC DOES NOT ACTUATE ON HIGH
DRYWELL
*          PRESSURE.  THUS, MANY OF THE HPCI TRIP SIGNALS ARE USED TO
*          AVOID REDUNDANCY.  THESE TRIPS MEAN THE FOLLOWING FOR
RCIC:
*
*   CRITERIA TO CONTROL RCIC INJECTION ON BISTABLE RPV LEVEL
*
*   TRIP 571: IS MAIN STEAM LINE PRESSURE GT 90 PSIA ?
*   TRIP 572: IS RPV LEVEL LT BISTABLE LEVEL (CNTRLVAR 676 ) ?
*   TRIP 671: ARE BOTH TRIP 571 AND 572 TRUE ?
*
*   FINAL RCIC INJECTION SIGNALS AT EACH TIME STEP
*
*   TRIP 677: ARE TRIPS 671 AND -633 BOTH TRUE ? IF SO, THEN
*             RCIC STARTS UP OR CONTINUES TO INJECT.
*   TRIP 574: IF RCIC ECC INJECTION STARTS, THEN START RCIC
*             STEAM TURBINE FLOW.
*
*571  P      544010000    GT      NULL    0    90.0    N
*572  CNTRLVAR 003      LT      CNTRLVAR 676  0.0    N
*671  CNTRLVAR 571      AND      572                      N
**
**
*677          671      AND      -633                     N * RCIC PUMP
STARTUP OR ON
***
*574  MFLOWJ 711000000  GT      NULL    0    0.0    N * RCIC STEAM
TURBINE ON
*
*****
*****
*
*   LOW PRESSURE CORE SPRAY (LPCS) SYSTEMS
*
*   CRITERIA FOR LPCS PUMPS TO REACH RATED SPEED
*
*   TRIP 511: IS HIGH DRYWELL PRESSURE (17.2 PSIA) EXCEEDED ?

```

```

*   TRIP 530: IS RPV LEVEL LE LO LO LEVEL (80.0 INCHES WRT TOEF) ?
*   TRIP 630: PREVENTS L0 L0 LEVEL SIGNAL PRIOR TO ACCIDENT.
*   TRIP 547: IS RPV PRESSURE LE LO RPV PRESSURE (315.0 PSIA) ?
*   TRIP 680: VALID L0 L0 LEVEL WITHR ACCIDENT INITIATION SIGNAL VALID
*   TRIP 681: DOES A VALID LPCS INITIATION SIGNAL EXIST ?
*   TRIP 580: ADD 2.0 SEC DELAY ON EITHER LEVEL OR PRESSURE READINGS.
*   TRIP 581: DID THE LPCS INITIATION SIGNAL OCCUR PRIOR TO THE
EARLIEST
*           TIME ALLOWED FOR LPCS PUMP START UP ?
*   TRIP 582: IS THE CURRENT TIME GE TO THE EARLIEST TIME ALLOWED FOR
THE
*           LPCS PUMPS TO BE AT RATED SPEED ?
*   TRIP 682: IF BOTH TRIP 581 AND TRIP 582 ARE TRUE, THEN THE LPCS
PUMPS ARE
*           AT RATED SPEED.
*   TRIP 583: IF TRIP 581 IS FALSE, THEN IS THE CURRENT TIME GE TO THE
TIME
*   AND      :   THAT A VALID LPCS INITIATION SIGNAL OCCURRED PLUS A
5.4 SEC
*   TRIP 683:   DELAY (2.0 SEC CIRCUIT DELAY AND 5.0 SEC PUMP STARTUP)
?
*   TRIP 684: IF EITHER TRIP 682 OR 683 IS TRUE, THEN THE LPCS PUMPS
ARE AT
*           RATED SPEED.
*
*   CRITERIA FOR LPCS MOTOR OPERATED DISCHARGE VALVES TO OPEN
*
*   TRIP 584: IS TIME GE TIME OF TRIP 502 + 13.0 SECONDS, IE
*           IS POWER AVAILABLE ON THE EM BUSES?
*   TRIP 685: ARE BOTH TRIP 584 AND TRIP 681 TRUE?
*   TRIP 686: ARE BOTH TRIP 547 AND TRIP 685 ARE TRUE?
*   TRIP 586: IF TIME IS GE TO TIME OF TRIP 686 PLUS 11. SEC.
*           (2.0 CIRCUITS, 9.0 VALVE OPEN), THEN THE LPCS
*           INJECTION VALVE IS FULL OPEN.
*
*   CRITERIA FOR LPCS READY FOR INJECTION (SUBJECT TO LPCS SYSTEM
*           PRESSURE VS FLOW CHARACTERISTICS).
*
*   TRIP 687: IF BOTH TRIP 684 AND 586 ARE TRUE, THEN LPCS IS READY TO
INJECT
*
680           547   and   630           1
681           511   or   680           1
580   time           0   ge   timeof   681   2.0   1
581   timeof        580   le   timeof   502   23.0  1
582   time           0   ge   timeof   502   28.0  1
682           581   and   582           1
583   time           0   ge   timeof   580   5.0   1
683           583   and   -581          1
684           682   or   683           1
*
584   time           0   ge   timeof   502   13.0  1
685           584   and   681           1
686           547   and   685           1
586   time           0   ge   timeof   686   11.0  1
*
687           684   and   586           1   * lpcs starts
injecting
*
*****
*****

```

*
* LOW PRESSURE COOLANT INJECTION (LPCI) SYSTEMS
*
* CRITERIA FOR LPCI PUMPS TO REACH RATED SPEED.
* THE LPCI INITIATION SIGNALS ARE THE SAME AS THE LPCS INITIATION
SIGNALS,
* ALTHOUGH SEPARATE INSTRUMENTS AND LOGIC CIRCUITS ARE USED. THUS
TRIP
* 681 IS USED AND MEANS THE FOLLOWING FOR LPCI:
*
* TRIP 681: DOES A VALID LPCI INITIATION SIGNAL EXIST ?
* TRIP 588: DID THE LPCI INITIATION SIGNAL OCCUR PRIOR TO POWER
AVAILABLE
* ON THE EMERGENCY BUSES ?
* TRIP 589: IS THE CURRENT TIME GE TO THE EARLIEST TIME ALLOWED
FOR ALL LPCI PUMPS TO BE AT RATED SPEED ?
* TRIP 689: IF TRIPS 588 AND 589 ARE BOTH TRUE, THEN ALL LPCI
PUMPS ARE AT RATED SPEED AT THEIR EARLIEST TIME.
* TRIP 590: IF TRIP 588 IS FALSE, THEN IS THE CURRENT TIME GE TO THE
TIME
* AND : THAT A VALID LPCI INITIATION SIGNAL OCCURRED PLUS A
12.10 SEC
* TRIP 690: DELAY (2.10 SEC CIRCUIT, 10.0 SEC FOR SEQUENTIAL PUMP
START UP
*
* TRIP 691: IF EITHER TRIP 689 OR TRIP 690 IS TRUE, THEN THE LPCI
PUMPS
* ARE AT RATED SPEED.
*
* CRITERIA FOR LPCI MOTOR OPERATED INJECTION VALVES TO OPEN.
*
* TRIP 592: IS THE CURRENT TIME GE TO THE TIME NEEDED TO OPEN THE
INJECTION
* VALVES AFTER THE LOW RPV PRESSURE SIGNAL (TRIP 547)
OCCURRED
* IE TRIP 547 TIME PLUS 26.10 SEC DELAY (2.10 SEC
CIRCUITS, 24.0
* SECOND VALVE OPENING TIME) ?
* TRIP 692: IF TRIP 681 AND TRIP 592 ARE BOTH TRUE, THEN THE
INJECTION
* VALVES SHOULD BE OPEN.
*
* CRITERIA FOR LPCI READY FOR INJECTION (SUBJECT TO LPCI SYSTEM
PRESSURE VS FLOW CHARACTERISTICS)
*
* TRIP 693: IF TRIP 691 AND 692 ARE BOTH TRUE, THEN LPCI IS READY TO
INJECT.
* TRIP 694: IF TRIP 684 OR TRIP 691 IS TRUE, THEN AT LEAST ONE LOW
PRESSURE
* ECC PUMP IS AT RATED SPEED FOR THE ADS CRITERIA.
* TRIP 695: IF TRIP 687 OR TRIP 693 IS TRUE, THEN THE REWET/QUENCH
TRIP
* IS TRUE FOR AN EM ANALYSIS.
*
588 timeof 580 le timeof 502 13.00 1
589 time 0 ge timeof 502 23.0 1
689 588 and 589 1
590 time 0 ge timeof 580 10.00 1
690 590 and -588 1
691 689 or 690 1 * the lpci pumps
are star

```

*
593      time      0      ge      timeof      547      2.10      1
696      546      and      593      1      * open lpci
injection val
*
* The following trips are used for the ADS opening criteria *
*
592      time      0      ge      timeof      547      26.1      1
692      592      and      681      1
*
693      691      and      692      1
694      684      or      691      1      * one lp pump is
running
*
* The following trip activates the rewet-quench model *
*
695      687      or      693      1      * lpci/lpcs
inejecting
*
*****
*****
*          HYDRODYNAMIC COMPONENT DATA
*
*****
*****
*          LOWER PLENUM REGION          *
*****
*
0020000      loplnv02      snglv01
*
0020101      0.0      3.516      248.24      0.0      90.0
*
0020102      3.516      1.500e-4      1.827      00000
*
0020200 000      1099.6      515.32      1105.81      0.
*
*****

```