

South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

December 20, 2004 NOC-AE-04001827 10CFR50.90 STI 31817532 File No. G25

U. S. Nuclear Regulatory Commission Attention: Document Control Desk One White Flint North 11555 Rockville Pike Rockville, MD 20852

> South Texas Project Unit 1 Docket No. STN 50-498 Unit 1 Cycle 12 End of Life Moderator Temperature Coefficient Limit Report

As a condition for approval of the conditional elimination of the most negative end of life moderator temperature coefficient measurement technical specification change as stated in the referenced correspondence, STP committed to submit the following information for the first three uses of this methodology at STP:

- 1. A summary of the plant data used to confirm that the Benchmark Criteria of Table 3-2 of WCAP-13749-P-A, Safety Evaluation Supporting the Conditional Elimination of the Most Negative EOL Moderator Temperature Coefficient Measurement, have been met; and,
- 2. The Most Negative EOL Moderator Temperature Coefficient Limit Report (as found in Appendix D of WCAP-13749-P-A).

The information is attached. This transmittal is the third and final submittal of the three required submittals. If there are any questions regarding this information, please contact Mr. Duane Gore at (361) 972-8909.

D.L. Lagar D.A. Leazar

Manager, *V* Nuclear Fuel and Analysis

· Attachments:

- 1. Plant Data Used to Confirm Benchmark Requirements
- 2. Most Negative End of Life Moderator Temperature Coefficient Limit Report for South Texas Unit 1, Cycle 12

A001

NOC-AE-04001827 Page 2 of 2

cc: (paper copy)

Bruce S. Mallett Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 611 Ryan Plaza Drive, Suite 400 Arlington, Texas 76011-8064

U. S. Nuclear Regulatory Commission Attention: Document Control Desk One White Flint North 11555 Rockville Pike Rockville, MD 20852

Richard A. Ratliff Bureau of Radiation Control Texas Department of State Health Services 1100 West 49th Street Austin, TX 78756-3189

Jeffrey Cruz U. S. Nuclear Regulatory Commission P. O. Box 289, Mail Code: MN116 Wadsworth, TX 77483

C. M. Canady City of Austin Electric Utility Department 721 Barton Springs Road Austin, TX 78704 (electronic copy)

A. H. Gutterman, Esquire Morgan, Lewis & Bockius LLP

J. J. Nesrsta City Public Service

David H. Jaffe U. S. Nuclear Regulatory Commission

R. L. Balcom Texas Genco, LP

C. A. Johnson AEP Texas Central Company

Jon C. Wood Cox Smith Matthews

C. Kirksey City of Austin

R. K. Temple City Public Service Attachment 1

Ì

Plant Data Used to Confirm Benchmark Requirements

.

### Plant Data Used to Confirm Benchmark Requirements are Satisfied

This attachment presents a comparison of the South Texas Unit 1 Cycle 12 core characteristics with the requirements for use of the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement Methodology and presents plant data that support that the Benchmark Criteria presented in WCAP-13749-P-A are met.

The Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement Methodology is described in WCAP-13749-P-A. This report was approved by the NRC with two requirements:

- only PHOENIX/ANC calculation methods are used for the individual plant analyses relevant to determinations for the EOL MTC plant methodology, and
- the predictive correction is reexamined if changes in core fuel designs or continued MTC calculation/measurement data show significant effect on the predictive correction.

The PHOENIX/ANC calculation methods were used for the South Texas Unit 1, Cycle 12, core design and relevant analyses. Also, the Unit 1, Cycle 12, core design does not represent a major change in core fuel design. Therefore, the Predictive Correction of -3 pcm/°F remains valid for this cycle. The Unit 1, Cycle 12, core meets both of the above requirements.

A description of the data collection and calculations required to complete the Table 3 Worksheet of the Most Negative Moderator Temperature Coefficient Limit Report is presented in Attachment 2. Then the following data tables are provided in this attachment:

- Table 1 Benchmark Criteria for Application of the 300 ppm MTC Conditional Exemption Methodology (per WCAP-13749-P-A)
- Table 2 Flux Map Data: Assembly Powers and Core Tilt Criteria
- Table 3 Core Reactivity Balance Data
- Table 4 Low Power Physics Test Data (Beginning of Cycle, Hot Zero Power): Isothermal Temperature Coefficient (ITC)
- Table 5 Low Power Physics Test Data (Beginning of Cycle, Hot Zero Power): Individual Control Bank Worth

# Table 1 Benchmark Criteria for Application of the 300 ppm MTC Conditional <u>Exemption Methodology (per WCAP-13749-P-A)</u>

,

ţ

| Parameter                                        | Criteria                    |
|--------------------------------------------------|-----------------------------|
| Assembly Power (Measured Normal Reaction Rate)   | ± 0.1 or 10 %               |
| Measured Incore Quadrant Power Tilt (Low Power)  | ±4%                         |
| Measured Incore Quadrant Power Tilt (Full Power) | ±2%                         |
| Core Reactivity (Cb) Difference                  | ± 1000 pcm                  |
| BOL HZP ITC                                      | ±2 pcm/°F                   |
| Individual Control Bank Worth                    | $\pm 15$ % or $\pm 100$ pcm |
| Total Control Bank Worth                         | ± 10 %                      |

.

.

| Elux Man Measured to Prodicted Benchmark Criteria Benchmark C                                                                          | Criteria  |
|----------------------------------------------------------------------------------------------------------------------------------------|-----------|
| Elux Man Massured to Predicted                                                                                                         | Critoria  |
| Plux Map Measured to Fredicicu                                                                                                         |           |
| Number Error Requirement Satisfied Power Filt Requirement                                                                              | Satisfied |
| $112001 \frac{\% \text{ Diff}}{M \text{ P}} = 0.080 \text{ Yes} \frac{\text{Max} 1.00483}{\text{Min}}$                                 | Yes       |
| Min 0.99405                                                                                                                            |           |
| $112002 \qquad \qquad$ | Yes       |
| Min 0.99710                                                                                                                            | ·         |
| 112007 $\frac{76 \text{ Diff}}{14 \text{ D}}$ $\frac{5.2}{100028}$ Yes $\frac{100028}{100026}$                                         | Yes       |
| Min 0.99263                                                                                                                            |           |
| 112008 $\frac{100714}{100714}$ Yes $\frac{100714}{100714}$                                                                             | Yes       |
| Min 0.99262                                                                                                                            |           |
| 112009 % Diff 5.2 Yes Max 1.00878                                                                                                      | Yes       |
| Min 0.98994 Maps at < 90%                                                                                                              |           |
| 112010 Ves Max 1.00772 Reactor Power                                                                                                   | Yes       |
| M-P -0.047 Min 0.99071 Max Power                                                                                                       |           |
| $\begin{array}{c c c c c c c c c c c c c c c c c c c $                                                                                 | Yes       |
| Min 0.99319 Min Power                                                                                                                  |           |
| 112016 % Diff 4.1 % Diff within Ves Max 1.00457 Tilt $\geq 0.96$                                                                       | Ves       |
| M-P -0.040 ± 10% Min 0.99509                                                                                                           | 103       |
| 112017 % Diff 4.0 OP Ves Max 1.00155 OP                                                                                                | Ves       |
| M-P -0.035 Min 0.99679                                                                                                                 | 105       |
| 112018 % Diff 3.9 M-P within Max 1.00359                                                                                               | Vec       |
| $\begin{array}{c ccccccccccccccccccccccccccccccccccc$                                                                                  | 105       |
| Max 1.00425 Keactor Power Max Power                                                                                                    | Var       |
| $\begin{array}{c ccccccccccccccccccccccccccccccccccc$                                                                                  | 105       |
| % Diff 3.9 Max 1.00500 And                                                                                                             |           |
| Min 0.99611 Min Power                                                                                                                  | Yes       |
| % Diff 4.2 Max 1.00434                                                                                                                 |           |
| M-P -0.035 Yes Min 0.99585                                                                                                             | Yes       |
| % Diff 4.4 Max 1.00634                                                                                                                 |           |
| 112022 M-P -0.039 Yes Min 0.99530                                                                                                      | Yes       |
| % Diff 4.5 Max 1.00547                                                                                                                 |           |
| 112023 <u>M-P</u> -0.037 Yes <u>Min</u> 0.99574                                                                                        | Yes       |
| % Diff 4.7 Max 1.00507                                                                                                                 |           |
| 112024 Yes Min 0.99655                                                                                                                 | Yes       |
| % Diff 5.8 Max 1.00677                                                                                                                 |           |
| 112025 Yes Min 0.99451                                                                                                                 | Yes       |

.

# Table 2Page 1 of 2Flux Map Data:Assembly Powers and Core Tilt Criteria

| Table 2                                               |
|-------------------------------------------------------|
| Page 2 of 2                                           |
| Flux Map Data: Assembly Powers and Core Tilt Criteria |

|          |          | Assem        | bly Power     |                            | Measured Incore Quadrant Power Tilt |          |             |           |
|----------|----------|--------------|---------------|----------------------------|-------------------------------------|----------|-------------|-----------|
|          |          |              | Benchmark     | Benchmark Criteria         |                                     |          | Benchmark   | Criteria  |
| Flux Map | Measured | to Predicted |               | Criteria                   |                                     |          |             | Criteria  |
| Number   | E        | Error        | Requirement   | Satisfied                  | Pov                                 | wer Tilt | Requirement | Satisfied |
| 112026   | % Diff   | 6.7          | % Diff within | % Diff within<br>± 10% Yes | Max                                 | 1.00603  |             | Yes       |
| 112020   | M-P      | 0.046        | ± 10%         |                            | Min                                 | 0.99605  |             |           |
| 112027   | % Diff   | 6.5          | OP            | Vec                        | Max                                 | 1.00491  | See Note 1  | Voc       |
| 112027   | M-P      | 0.045        |               | 1 05                       | Min                                 | 0.99734  |             | 105       |
| 112028   | % Diff   | 6.8          | M-P within    | Vec                        | Max                                 | 1.00491  |             | Vec       |
| 112028   | M-P      | 0.047        | ± 0.1         | 105                        | Min                                 | 0.99667  |             | 1 65      |

Note 1: Maps at < 90% <u>Reactor Power</u>

Max Power Tilt  $\leq$  1.04 And Min Power Tilt  $\geq$  0.96

OR

Maps at > 90% <u>Reactor Power</u> Max Power Tilt  $\leq$  1.02 And Min Power Tilt  $\geq$  0.98

|          |       | Core Reactivity Difference |                         |           |  |  |
|----------|-------|----------------------------|-------------------------|-----------|--|--|
|          | Ļ     | (Critical boron)           |                         |           |  |  |
|          | ļ     | Reactivity                 | Benchmark Cr            | iteria    |  |  |
| Surveill | ance  | Deviation                  |                         |           |  |  |
| Date/T   | ime   | (pcm) Requirement          |                         | Satisfied |  |  |
| 8/15/03  | 12:38 | 116.7                      |                         | Yes       |  |  |
| 8/26/03  | 14:45 | 57.5                       | 1                       | Yes       |  |  |
| 9/23/03  | 15:43 | -102.6                     |                         | Yes       |  |  |
| 10/21/03 | 13:30 | -197.1                     |                         | Yes       |  |  |
| 11/18/03 | 14:52 | -246.8                     |                         | Yes       |  |  |
| 12/16/03 | 14:00 | -322.1                     | -                       | Yes       |  |  |
| 1/13/04  | 15:12 | -393.7                     |                         | Yes       |  |  |
| 2/11/04  | 15:44 | -337.5                     |                         | Yes       |  |  |
| 3/3/04   | 14:48 | -373.6                     | Reactivity              | Yes       |  |  |
| 4/2/04   | 9:09  | -401.32                    | $\pm 1000 \mathrm{ncm}$ | Yes       |  |  |
| 5/5/04   | 15:34 | -430.7                     |                         | Yes       |  |  |
| 6/2/04   | 9:56  | -381.7                     | -                       | Yes       |  |  |
| 6/29/04  | 16:30 | -389.7                     |                         | Yes       |  |  |
| 7/27/04  | 15:53 | -379.1                     | 1                       | Yes       |  |  |
| 8/25/04  | 10:14 | -314.1                     | 1                       | Yes       |  |  |
| 9/21/04  | 15:46 | -189.7                     | 1                       | Yes       |  |  |
| 10/19/04 | 14:40 | -122.3                     | 1                       | Yes       |  |  |
| 11/16/04 | 14:28 | -25.42                     | 1                       | Yes       |  |  |

Table 3Core Reactivity Balance Data

 $\overline{}$ 

\_\_\_\_\_ .\_...

-

# Table 4Low Power Physics Test Data(Beginning of Cycle, Hot Zero Power):Isothermal Temperature Coefficient (ITC)

|             | Measured  | Predicted | Error<br>(Measured – Predicted) | Benchmark Criteria            |           |
|-------------|-----------|-----------|---------------------------------|-------------------------------|-----------|
|             | (pcm/°F)* | (pcm/°F)* | (pcm/°F)*                       | Requirement                   | Satisfied |
| BOC HZP ITC | -2.70     | -2.32     | -0.38                           | ITC Error<br>within ±2 pcm/°F | Yes       |

\*Note: 1 pcm = 1 x  $10^{-5} \Delta K/K$ 

|                             |                    |                     |                   |         | Benchmark Cri          | teria     |
|-----------------------------|--------------------|---------------------|-------------------|---------|------------------------|-----------|
| Bank                        | Measured<br>(pcm)* | Predicted<br>(pcm)* | ∆ Error<br>(pcm)* | % Error | Requirement            | Satisfied |
| Shutdown Bank A             | 307.1              | 288.5               | 18.6              | 6.4     |                        | Yes       |
| Shutdown Bank B             | 898.8              | 912.6               | -13.8             | -1.5    | % Error                | Yes       |
| Shutdown Bank C             | 457.1              | 442.0               | 15.1              | 3.4     | within $\pm 15\%$      | Yes       |
| Shutdown Bank D             | 465.3              | 441.1               | 24.2              | 5.5     |                        | Yes       |
| Shutdown Bank E             | 448.1              | 469.2               | -21.1             | -4.5    | OR                     | Yes       |
| Control Bank A              | 646.9              | 676.2               | -29.3             | -4.3    |                        | Yes       |
| Control Bank B              | 788.9              | 749.1               | 39.8              | 5.3     | Δ Error                | Yes       |
| Control Bank C              | 700.6              | 710.9               | -10.3             | -1.5    | within $\pm 100$ pcm   | Yes       |
| Control Bank D              | 558.9              | 541.9               | 17                | 3.1     | 1                      | Yes       |
| Total Control<br>Bank Worth | 5271.7             | 5231.5              | 40.2              | 0.77    | % Error<br>within ±10% | Yes       |

Table 5Low Power Physics Test Data(Beginning of Cycle, Hot Zero Power):Individual Control Bank Worth

\*Note: 1 pcm = 1 x  $10^{-5} \Delta K/K$ 

## Attachment 2

\_

## Most Negative End of Life Moderator Temperature Coefficient Limit Report for South Texas Unit 1, Cycle 12

ı

.

#### Most Negative End of Life Moderator Temperature Coefficient Limit Report for South Texas Unit 1, Cycle 12

(Measured 300 ppm Burnup, as per WCAP-13749-P-A, Appendix D)

#### **PURPOSE:**

The purpose of this document is to present cycle-specific best estimate data for use in confirming the most negative end of life moderator temperature coefficient (MTC) limit in Technical Specification 3.1.1.3. This document also summarizes the methodology used for determining if a HFP 300 ppm MTC measurement is required.

#### PRECAUTIONS AND LIMITATIONS:

The EOL MTC elimination data presented in this document apply to South Texas Unit 1 Cycle 12 only and may not be used for other operating cycles.

The following reference is applicable to this document:

Fetterman, R. J., Slagle, W. H., Safety Evaluation Supporting the Conditional Exemption of the Most Negative EOL Moderator Temperature Coefficient Measurement, WCAP-13749-P-A, March, 1997.

#### **PROCEDURE:**

All core performance benchmark criteria listed in Table 1 must be met for the current operating cycle. These criteria are confirmed from startup physics test results and routine HFP boron concentration and flux map surveillance performed during the cycle.

If all core performance benchmark criteria are met, then the Revised Predicted MTC may be calculated per the algorithm given in Table 2. The required cycle specific data are provided in Table 2 and Figure 1. This methodology is also described in the above Reference. If all core performance benchmark criteria are met, and the Revised Predicted MTC is less negative than the 300 ppm limit specified in COLR Section 2.4.3, then a measurement is not required.

Note that Figure 1 is not entirely linear. However, the deviation is slight enough that linear interpolation between adjacent points from the data at the bottom of the Figure is acceptable.

# Table 1 Benchmark Criteria for Application of the 300 ppm MTC Conditional Exemption Methodology

| <u>Parameter</u>                                 | <u>Criteria</u>     |
|--------------------------------------------------|---------------------|
| Assembly Power (Measured Normal Reaction Rate)   | ± 0.1 or 10 %       |
| Measured Incore Quadrant Power Tilt (Low Power)  | ±4%                 |
| Measured Incore Quadrant Power Tilt (Full Power) | ±2%                 |
| Core Reactivity (Cb) Difference                  | ± 1000 pcm          |
| BOL HZP ITC                                      | ±2 pcm/°F           |
| Individual Control Bank Worth                    | ± 15 % or ± 100 pcm |
| Total Control Bank Worth                         | ± 10 %              |

-

#### Table 2

#### Algorithm for Determining the Revised Predicted Near-EOL 300 ppm MTC

The Revised Predicted MTC = Predicted MTC + AFD Correction  $- 3 \text{ pcm/}^{\circ}\text{F}$  where:

Predicted MTC is calculated from Figure 1 at the burnup corresponding to the measurement of 300 ppm at RTP conditions,

AFD Correction is the more negative value of:

{  $0 \text{ pcm/}^{\circ}F$ , (  $\Delta AFD * AFD$  Sensitivity ) }

 $\triangle$ AFD is the measured AFD minus the predicted AFD from an incore flux map taken at or near the burnup corresponding to 300 ppm.

AFD Sensitivity = 0.05 pcm / °F /  $\Delta$ AFD

è

Predictive Correction is  $-3 \text{ pcm/}^{\circ}\text{F}$ , as included in the equation for the Revised Predicted MTC.

•

|           |                                       |                                 | Table 3                          |              |                         |
|-----------|---------------------------------------|---------------------------------|----------------------------------|--------------|-------------------------|
|           | Worksheet                             | for Calculat                    | ting the Predicte                | d Near-EOL 3 | <u>00 ppm MTC</u>       |
| Unit:     | 1, Cycle 12                           | Date:                           | 11/22/2004                       | Time:        | 1012                    |
| Refere    | nce for Cycle-Spe                     | cific MTC I                     | Data:                            |              |                         |
| A4<br>Un  | 1009-00548UB Re<br>it 1 Nuclear Power | ev.A, The Nu<br>Plant Cycle     | clear Design and<br>12 Redesign. | Core Managen | nent of the South Texas |
| Part A    | . Predicted MTC                       |                                 |                                  |              |                         |
| <b>A.</b> | l Cycle Average                       | Burnup Cor                      | responding to                    |              |                         |
|           | the HFP ARO ppm.                      | equilibrium :                   | $xenon C_{\rm B} of 300$         | 17452        | .8_ MWD/MTU             |
| А.:       | 2 Predicted HFP<br>to burnup (A.1     | ARO MTC (                       | corresponding                    | -35.2        | 24 pcm/°F               |
| Part B    | . AFD Correction                      | l                               |                                  |              |                         |
| B.:       | Burnup of mos<br>conditions inco      | t recent HFP<br>ore flux map    | , equilibrium                    | 17238        | .0_ MWD/MTU             |
| В.2       | 2 Measured HFP                        | AFD at burn                     | nup (B.1)                        |              |                         |
|           | ID: <u>112028</u>                     | Date: _1                        | 1/16/04                          | -2.0         | 06_ % AFD               |
| В.:       | B Predicted HFP                       | AFD at burr                     | up (B.1)                         | -2.5         | 54_ % AFD               |
| B.4       | 4 MTC Sensitivi                       | MTC Sensitivity to AFD          |                                  |              | 05 pcm/°F/∆AFD          |
| В.        | 5 AFD Correctio                       | n. more neg                     | ative of                         |              |                         |
|           | { 0 pcm/°F, E                         | 8.4 *(B.2 – B                   |                                  | 0 pcm/°F     |                         |
| Part C    | . Revised Predict                     | ion                             |                                  |              |                         |
| С.        | l Revised Predic                      | tion (A.2 $+$ ]                 | 3.5 – 3)                         | -38.2        | 24 pcm/°F               |
| C.:       | 2 Surveillance L                      | Surveillance Limit (COLR 2.3.3) |                                  |              | 72 pcm/°F               |
|           | If C.1 is less n<br>HFP 300 ppm       | egative than<br>MTC measu       | C.2, then the rement is not      |              |                         |

----

•

required per Specification 4.1.1.3.

•



Figure 1 Predicted HFP FOP 300 ppm MTC vs. Cycle 12 Redesign Burnup

| Cycle Burnup | Moderator Temperature Coefficients |
|--------------|------------------------------------|
| (MWD/MTU)    | (pcm/°F)                           |
| 14000        | -33.65                             |
| 16000        | -34.60                             |
| 17000        | -35.05                             |
| 19000        | -35.91                             |
|              |                                    |

#### Table 4

#### Data Collection and Calculations Required to Complete the Table 3 Worksheet of the Most Negative Moderator Temperature Coefficient Limit Report

Data at the 300 ppm Boron Point

- RCS Boron at 300 ppm at 02:35 on 11/22/04.
- Burnup at 300 ppm: 17452.8 MWD/MTU (A.1)
- Predicted MTC: -35.24 pcm/°F (A.2)

Data from Last Flux Map:

- Flux Map Number: 112028 (B.2)
- Reactor Power 100% RTP Note: The monthly flux map was performed about a week before the unit reached the 300 ppm concentration value. Data from this flux map was used for the AFD Correction.
- Burnup 17238.0 MWD/MTU (B.1)
- Measured Axial Offset (MAO): -2.06% (B.2) Note: The Westinghouse BEACON computer code (similar to the Westinghouse INCORE code) determines Axial Offset (AO), not Axial Flux Difference (AFD). Therefore, the AO must be converted to AFD before use. The relationship between AO and AFD is

AFD = Axial Offset \* Fractional Power

Axial Flux Difference

Lower Predicted AO (LPAO): -2.35% at 16000 MWD/MTU Higher Predicted AO (HPAO): -2.73% at 18500 MWD/MTU Predicted AO (PAO) =

 $PAO = \frac{B/U_{@Measued AO} - B/U_{@LowerPredicted AO}}{B/U_{@HigherPredicted AO} - B/U_{@LowerPredicted AO}} \times (HPAO - LPAO) + LPAO$ 

PAO = (17238.0 - 16000)/(18500 - 16000) \* (-2.73% + 2.35%) - 2.35% = -2.54% (B.3)

$$\Delta AFD = (MAO-PAO) * (Reactor Power (%) / 100%)$$
  
= (-2.06% + 2.54%) \* (100% / 100%)  
= 0.48%

## Table 4 (cont.) Data Collection and Calculations Required to Complete the Table 3 Worksheet of the Most Negative Moderator Temperature Coefficient Limit Report

Determination of the Revised Predicted Moderator Temperature Coefficient (MTC)AFD Sensitivity: 0.05 pcm/°F/  $\Delta$ AFDAFD Correction: 0 pcm/°F (B.5)where: AFD Correction is the more negative of the following:0 pcm/°F or ( $\Delta$ AFD \* AFD Sensitivity)0 pcm/°F or (0.48 \* 0.05 pcm/°F/  $\Delta$ AFD)0 pcm/°F or 0.024 pcm/°F..0 pcm/°FRevised Predicted MTC= -35.24 pcm/°F + 0.0 pcm/°F - 3 pcm/°F= -38.24 pcm/°F (C.1)