

SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION

1. LICENSEE/LOCATION INSPECTED: PacifiCorp, Inc. Jim Bridger Power Plant, County Road 4-15 Point of Rocks, Wyoming		2. NRC/REGIONAL OFFICE USNRC Region IV 611 Ryan Plaza Drive, Suite 400 Arlington, Texas 76011-4005	
REPORT NUMBER(S) 2004-002			
3. DOCKET NUMBER(S) 030-33302	4. LICENSEE NUMBER(S) 49-27478-01	5. DATE(S) OF INSPECTION 12 / 16 / 2004	

LICENSEE:

The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:

- 1. Based on the inspection findings, no violations were identified.
- 2. Previous violation(s) closed.
- 3. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, NUREG-1600, to exercise discretion, were satisfied.

_____ Non-Cited Violation(s) was/were discussed involving the following requirement(s) and Corrective Action(s):

- 4. During this inspection certain of your activities, as described below and/or attached, were in violation of NRC requirements and are being cited. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11.

(Violations and Corrective Actions)

Licensee's Statement of Corrective Actions for Item 4, above.

I hereby state that, within 30 days, the actions described by me to the inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

Title	Printed Name	Signature	Date
LICENSEE'S REPRESENTATIVE			
NRC INSPECTOR	James L. Thompson	/RA/	12/16/2004

Docket File Information
**SAFETY INSPECTION REPORT
AND COMPLIANCE INSPECTION**

1. LICENSEE Pacificorp, Inc. REPORT NUMBER(S) 2004-002		2. NRC/REGIONAL OFFICE <p style="text-align: center;">USNRC Region IV</p>	
3. DOCKET NUMBER(S) 030-33302	4. LICENSE NUMBER(S) 49-27478-01	5. DATE(S) OF INSPECTION 12 / 16 / 2004	
6. INSPECTION PROCEDURES USED 87124	7. INSPECTION FOCUS AREAS all		

SUPPLEMENTAL INSPECTION INFORMATION

1. PROGRAM CODE(S) 03120	2. PRIORITY 5	3. LICENSEE CONTACT Dale Gillespie, Engineer	4. TELEPHONE NUMBER (307) 352-4281
-----------------------------	------------------	---	---------------------------------------

<input checked="" type="checkbox"/>	Main Office Inspection	Next Inspection Date: _____
<input type="checkbox"/>	Field Office _____	
<input type="checkbox"/>	Temporary Job Site _____	

PROGRAM SCOPE

This licensee possesses 22 specifically licensed fixed gauges containing cesium-137, 1 specifically licensed portable gauge containing nickel-63, 1 specifically licensed fixed gauge containing both cesium-137 and californium-252, and 1 generally licensed portable gauge containing americium-241 (SN 6078, Niton Corp.).

All gauges are located at the Jim Bridger Power Plant, 7 miles north of Point of Rocks, Wyoming. There is only one authorized gauge user, who is also the RSO, trained by Thermo Measure Tech in 40-hour radiation safety course.

Leak tests, inventories, and shutter checks are performed at six-month intervals for all gauges. The licensee is exempt from personnel monitoring.