

December 17, 2004

LICENSEE: Nuclear Management Company, LLC

FACILITY: Point Beach Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE HELD ON DECEMBER 16, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NUCLEAR MANAGEMENT COMPANY, LLC, CONCERNING DRAFT REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference on December 16, 2004, to discuss and clarify the staff's draft requests for additional information (D-RAIs) concerning the Point Beach Nuclear Plant, Units 1 and 2, license renewal application. The conference call was useful in clarifying the intent of the staff's D-RAIs.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the D-RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Michael J. Morgan, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosures: As stated

cc w/encls: See next page

December 17, 2004

LICENSEE: Nuclear Management Company, LLC
FACILITY: Point Beach Nuclear Plant, Units 1 and 2
SUBJECT: SUMMARY OF TELEPHONE CONFERENCE HELD ON DECEMBER 16, 2004, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NUCLEAR MANAGEMENT COMPANY, LLC, CONCERNING DRAFT REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference on December 16, 2004, to discuss and clarify the staff's draft requests for additional information (D-RAIs) concerning the Point Beach Nuclear Plant, Units 1 and 2, license renewal application. The conference call was useful in clarifying the intent of the staff's D-RAIs.

Enclosure 1 provides a listing of the meeting participants. Enclosure 2 contains a listing of the D-RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Michael J. Morgan, Project Manager
License Renewal Section A
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket Nos. 50-266 and 50-301

Enclosures: As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.:

DOCUMENT NAME: C:\FileNet\ML050060298.wpd

OFFICE	PM:RLEP	SC:RLEP
NAME	MMorgan	SLee
DATE	12/22/04	12/22/04

OFFICIAL RECORD COPY
Point Beach Nuclear Plant, Units 1 and 2

cc:

Jonathan Rogoff, Esq.
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Mr. Frederick D. Kuester
President and Chief Executive Officer
We Generation
231 West Michigan Street
Milwaukee, WI 53201

James Connolly
Manager, Regulatory Affairs
Point Beach Nuclear Plant
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241

Mr. Ken Duveneck
Town Chairman
Town of Two Creeks
13017 State Highway 42
Mishicot, WI 54228

Chairman
Public Service Commission
of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, WI 54241

Mr. Jeffrey Kitsembel
Electric Division
Public Service Commission of Wisconsin
P.O. Box 7854
Madison, WI 53707-7854

David Weaver
Nuclear Asset Manager
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, WI 53201

John Paul Cowan
Executive Vice President & Chief Nuclear
Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Douglas E. Cooper
Senior Vice President - Group Operations
Palisades Nuclear Plant
Nuclear Management Company, LLC
27780 Blue Star Memorial Highway
Covert, MI 49043

Fred Emerson
Nuclear Energy Institute
1776 I Street, NW., Suite 400
Washington, DC 20006-3708

Roger A. Newton
3623 Nagawicka Shores Drive
Hartland, WI 53029

James E. Knorr
License Renewal Project
Nuclear Management Company, LLC
6610 Nuclear Road
Point Beach Nuclear Plant
Two Rivers, WI 54241

DISTRIBUTION: Note to Licensee: Nuclear Management Co., LLC Re: Point Beach Nuclear Plant, Units 1 and 2, Dated: December 17, 2004

Adams accession no.:

HARD COPY

RLEP RF
Project Manager

E-MAIL:

RidsNrrDrip
RidsNrrDe
G. Bagchi
K. Manoly
W. Bateman
J. Calvo
R. Jenkins
P. Shemanski
J. Fair
RidsNrrDssa
RidsNrrDipm
D. Thatcher
R. Pettis
G. Galletti
C. Li
M. Itzkowitz (RidsOgcMailCenter)
R. Weisman
M. Mayfield
A. Murphy
S. Smith (srs3)
S. Duraiswamy
Y. L. (Renee) Li
RLEP Staff

P. Lougheed, RIII
J. Strasma, RIII
A. Stone, RIII
H. Chernoff
W. Ruland
C. Marco
L. Raghavan
T. Mensah
OPA

LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE
TO DISCUSS THE POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION

DECEMBER 16, 2004

Participants

Affiliations

J. Knorr	Nuclear Management Company, LLC (NMC)
J. Thorgersen	NMC
T. Mielke	NMC
D. Reddy	Nuclear Regulatory Commission (NRC)
M. Morgan	NRC
V. Rodriguez	NRC

DRAFT REQUESTS FOR ADDITIONAL INFORMATION (D-RAI)
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION
December 16, 2004

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Nuclear Management Company, LLC (NMC) held a telephone conference call on December 16, 2004, to discuss and clarify the staff's draft requests for additional information (D-RAIs) concerning the Point Beach Nuclear Plant, Units 1 and 2, license renewal application (LRA). The following D-RAI was discussed during the telephone conference call.

2.3.3.10 Essential Ventilation System

D-RAI 2.3.3.10-1

The Essential Ventilation System as described in the Point Beach Final Safety Analysis Report (PBNP FSAR) Sections 9.8 and 9.8.3 include the control room ventilation system, which is designed to provide heating, ventilation, air conditioning, and radiological habitability for the control and computer rooms within the control room envelope. The Essential Ventilation System license renewal drawings LR-M-144 sheet 2 and LR-M-214 sheets 1 and 4 highlight chiller components as in scope that are not included in LRA table 2.3.3-10, "Essential Ventilation System" and LRA Table 3.3.2-9, "Auxiliary Systems - Essential Ventilation System - Summary of Aging Management Evaluation." For example, while the tables list piping and fittings, pump casing, heat exchangers and coolers etc., they do not list the chiller and associated components shown on LR-M-214 sheet 4 at location C-9 for the control room chill water system. Degradation of these components could adversely impact the ability of the control room ventilation system to carry out its intended functions. Clarify whether these components and all other applicable components of the chill water system are within the scope of license renewal in accordance with 10CFR 54.4(a), and subject to aging management review in accordance with 10CFR 54.21(a)(1). If these components are within the scope of license renewal, update the LRA by providing the applicable information in the appropriate LRA tables. If these components are excluded from the scope of license renewal and not subject to an AMR, provide justification for the exclusion.

Discussion: The applicant indicated that the question is clear. This D-RAI will be sent as a formal RAI.